



CPV Valley Energy Center
50 Braintree Hill Office Park
Suite 300
Braintree, MA 02184

November 16, 2018

Mr. Christopher M. Hogan
Chief, Major Project Management Unit
New York State Department of Environmental Conservation
Division of Environmental Permits
625 Broadway, 4th Floor
Albany, New York 12233-1750
Federal Express Track # 7737 3755 7910, 7737 3755 8011

Re: CPV Valley, LLC
Title V and Title IV Air Permit Applications
Response to Notice of Incomplete Applications

Dear Mr. Hogan:

This letter responds to your letter dated October 25, 2018, indicating that the Title V and Title IV Air Permit Applications submitted by CPV Valley, LLC (“CPV Valley”) on August 29, 2018 (and received by the Department on August 30, 2018) requires additional information in order for the Department to consider the applications complete. CPV Valley respectfully disagrees that the applications are incomplete; rather, the information sought by your October 25 letter is in the nature of supplemental information to assist the Department in its review, and as a result, CPV Valley is entitled to the benefit of the application shield contained in Environmental Conservation Law § ECL 19-0311(5)(b) and guidance issued by the Environmental Protection Agency (“EPA”) implementing the Title V application shield.

Nonetheless, CPV Valley provides the following supplemental information in response to your letter:

Additional Technical Information

CPV Valley respectfully disagrees that any of the following information is explicitly required pursuant to 6 NYCRR § 201-6.2(d) to be included with the applications, and in fact, some of the information has already been provided to the Department, or made available upon request.

- 1) Plot Plan. A plot plan was submitted with the August 29, 2018 Title V application. An updated plot plan of the Facility based on the as-built plans identifying all permitted emission points is included herewith.
- 2) Process Flow Diagram. An updated process flow diagram based on the as-built plans is included herewith.

- 3) Stack Test and Performance Test Results. The Facility did not commence operation on August 19, 2018. The Facility commenced operation (First Fire) on January 17, 2018 on low sulfur diesel. The results of the Stack Tests on low sulfur diesel were previously submitted to the Department's Region 3 office per attached letter dated July 3rd, 2018. The results of the Performance Test on low sulfur diesel were previously submitted to the Department's Region 3 office per attached letter dated June 22nd, 2018. Copies of those documents are included herewith. The Facility commenced operation (First Fire) on natural gas on July 23, 2018, and Stack Tests were performed on September 25th-27th and October 10th-11th, 2018. Based on confirmation from Mr. Sweikert on November 07, 2018 with respect to the Department's request for supplemental information on Stack Test and Performance Test Results, copies of the results of the Stack Tests on natural gas are included herewith.
- 4) Continuous Emission Monitoring Plan. The Continuous Emissions Monitors ("CEMs") were certified on May 10, 2018 for Unit 1 and May 12, 2018 for Unit 2, and the CEM certifications were submitted to the Department and EPA per the attached letter dated June 22nd, 2018. Copies of the CEM certifications are included herewith, together with a CEM Plan.
- 5) Opacity Monitoring Plan. CPV Valley is not aware of any documented and verified opacity violations during startup of the Facility on low sulfur diesel. While CPV Valley is aware of complaints, it is not aware that any DEC personnel were certified to undertake opacity monitoring. Nonetheless, CPV Valley prepared an Opacity Monitoring Plan in February, 2018, and was advised by the Department's Region 3 personnel that it need not be submitted, but only be available at the Facility upon request. Consistent with that instruction, the Opacity log was inspected many times by DEC personnel when they visited the Facility. The Opacity Monitoring Plan has since been updated, and a copy is included herewith.

Revised Applications

The issues noted by Staff in the Title V application have been corrected, and revised applications including these corrections are included herewith.

Conclusion

CPV Valley, as noted above, respectfully disagrees that any of these items are required in order to have a complete application, but rather constitute supplemental information to assist the Department in its review of the applications. Moreover, CPV Valley respectfully disagrees with the statement in your letter that the application cannot be deemed complete until draft permits have been prepared and notice provided to the EPA. This statement is completely contradicted by the Department's past practice with respect to Title V and SPDES applications (especially renewal applications), which have been allowed to languish for years without action by the Department, yet the facilities continue to operate. While perhaps a Notice of Complete Application cannot be issued until that time, the applications should otherwise be complete without necessity of a formal notice.

We trust the enclosed information completely responds to your October 25, 2018 letter. Please feel free to contact me should you have any questions.

Very truly yours,



Donald G. Atwood


/rel

enclosures



cc: George Sweikert, RAPCE, Region 3 –
Federal Express Track # 7737 3755 7910, 7737 3755 8011
Kelly Turturro, Regional Director, Region 3
Khai Gibbs, Esq.
Mark Sanza, Esq.
Ruth Leistensnider, Esq.
Ben Stanley, DGC Ops

ATTACHMENT 1

Plot Plan



UTM NAD83 Zone18N

-  CPV Valley Property Boundary
-  Existing Emission Point

Title: CPV Valley Energy Center Site Plan


Date: November 2018




ATTACHMENT 2

Process Flow Diagram


Process Flow Diagram - EP001




Process Flow Diagram - EP002 & EP003




Process Flow Diagram - EP004



Process Flow Diagram - EP005



Process Flow Diagram - EP006



ATTACHMENT 3

Stack Test and Performance Test Results



CPV Valley Energy Center
3330 Route 6
Middletown, NY 10940

Tuesday, July 03, 2018

Regional Air Pollution Control Engineer
NYSDEC – Region 3
21 South Putt Corners Road
New Paltz, NY 12561
Certified Mail: 7017 0190 0000 0941 4359

Division of Air Resources
NYSDEC – Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258
Certified Mail: 7017 0190 0000 0941 4366

USEPA Region II
Air Compliance Branch
290 Broadway
New York, NY 10007-1866
Certified Mail: 7017 0190 0000 0941 4373

Re: CPV Valley Energy Center
NYSDEC State Facility Air Permit ID: 3-3356-00136/00001
Unit #1 and #2 Emissions Compliance Stack Test Report

Dear Sir / Madam:

CPV Valley Energy Center is submitting the Unit #1 and #2 emissions test report to validate compliance with the State Facility Air Permit requirements. Air Hygiene was contracted to perform stack compliance testing to determine the pollutant emissions from Unit #1 and #2 and to verify compliance with the emission limits listed in the State Facility Air Permit 3-3356-00136/00001. Air Hygiene adhere to all applicable testing requirements listed in the stack testing protocol and the State Facility Air Permit. Emissions testing was conducted on May 8th to 9th for Unit #1 and May 10th to 12th for Unit #2. Please see **Attachment A** for the Unit #1 and U#2 stack test report.

If there are any questions regarding this submittal, please contact Benjamin Stanley at (845) 649-8300.

Sincerely,

A handwritten signature in black ink, appearing to read "Benjamin Stanley", is written over a large, light-colored scribble or watermark.

Benjamin Stanley
DGC Operations, LLC on behalf of CPV Valley LLC
Plant Manager

CC: Donald Atwood
Chris Allgeier
Steve Barthelme
Jonathan Moore

Attachment A

Unit #1 and #2 Stack Test Report



CPV Valley Energy Center
 3330 Route 6
 Middletown, NY 10940

Friday, June 22, 2018

Regional Air Pollution Control Engineer
 NYSDEC – Region 3
 21 South Putt Corners Road
 New Paltz, NY 12561
 Certified Mail: 7017 0190 0000 0941 4441

Division of Air Resources
 NYSDEC – Bureau of Quality Assurance
 625 Broadway
 Albany, NY 12233-3258
 Certified Mail: 7017 0190 0000 0941 4465

USEPA Region II
 Air Compliance Branch
 290 Broadway
 New York, NY 10007-1866
 Certified Mail: 7017 0190 0000 0941 4472

USEPA -Clean Air Markets Division
 1200 Pennsylvania Avenue, NW
 Mail Code 6204J
 Washington, DC 20005
 Certified Mail: 7017 0190 0000 0941 4489

Dear Sir/Madam:

CPV – Valley Energy Center would like to submit the initial certification summary for Unit 1 & 2. The certification events were completed for Unit 1 on 05/10/2018 and Unit 2 on 05/12/2018. Where applicable, the USEPA Emissions Collection and Monitoring Plan System Software (ECMPS) was utilized to format the information.

The following table outlines the completion dates of the certification tests.

Unit No.	RATA Test	Linearity Test	7-Day Drift Test	Cycle Response Test
1	05/09/2018	05/10/2018	04/29/18 – 05/08/18	05/08/2018
2	05/12/2018	05/11/2018	04/24/18 – 05/03/18	05/08/2018

Attached to this is a complete summary of the certification events, Attachment 1 – Unit 1 and Attachment 2 – Unit 2. Each attachment includes a summary of the test events and a copy of the monitoring plan using the USEPA ECMPS software.

If there are any questions, or you require further information, please contact Ben Stanley at (845) 649-8300.

Thank you.

Regards,

Ben Stanley
 DGC Operations, LLC on behalf of CPV Valley LLC
 Plant Manager

CC: Donald Atwood
 Chris Allgeier
 Steve Barthelme
 Jonathan Moore

ATTACHMENT 1

Unit 1

40 CFR Part 75 Form
Monitoring Plan
RATA Test Summary
Linearity Test Summary
Cycle Response Test
7-day drift test



Certification Application

For more information, see instructions and refer to 40 CFR 75.63

This submission is for: • Initial Certification • Recertification

STEP 1
Identify the source by plant name, State, and ORIS Code from NADB

Plant Name	VALLEY ENERGY CENTER	State	NY	ORIS Code	56940
------------	----------------------	-------	----	-----------	-------

STEP 2
Identify unit short name/common stack description and boiler ID#/common stack ID#

Unit Short Name/Common Stack Description	Unit 1	Boiler/Common Stack ID#	1
--	--------	-------------------------	---

STEP 3
Mark the appropriate box and fill in if necessary

- Included is a copy of the monitoring plan)))))))
- No monitoring plan included

No. of pages	8
--------------	---

STEP 4
Provide the requested information for the monitoring systems and for the test data that are being submitted

Use page 2 to provide information for additional units/common stacks at this source or for units/common stacks with more than 10 systems

MONITORING SYSTEMS			TEST DATA		
System ID#	Parameter Monitored	Primary/Backup	Testing Date(s) (mm/dd/yy-mm/dd/yy)	Number of Tests (Total)	Number of Failed Tests
NOX	Nox	P	04/29/18 - 05/10/18	4	0
NOX	O2	P	04/29/18 - 05/10/18	4	0

STEP 5
Complete the boxes

Included are test results for systems listed in Step 4 Table(s))))))))

No. of pages	10
--------------	----

Included is DAHS verification test information)))))))

No. of pages	14
--------------	----

STEP 6
Read the certification, enter the name of the designated representative, and sign and date

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	BEN STANLEY - DEC OPERATIONS, LLC		
Signature		Date	6/22/2018



VIM
TECHNOLOGIES

June 22, 2018

CPV Valley Energy Center
3330 RT 6
Middletown, NY 10940

Attn: Duc Tran
Subject: DAHS Certification Statement for ORISPL 56940

Dear Duc,

VIM Technologies, Inc. certifies that the CEMLink6 automated Data Acquisition and Handling System (DAHS) component of each CEM System was tested and that proper computation of hourly averages for each formula submitted in the 40 CFR Part 75 monitoring plan was verified according to the requirements of 40 CFR Part 75 and EPA Policy Manual Question 13.22

VIM Technologies, Inc. certifies that the automated CEMLink6 DAHS component of each CEM System was tested and that proper computation of the missing data substitution procedures was verified according to 40 CFR Part 75 Subpart D and those routines permitted and defined in the EPA Policy Manual. VIM Technologies, Inc. has developed and confirmed over 65 test cases covering all possible data substitution scenarios permitted by 40 CFR Part 75.

Signed: 
Matt Caldwell

Date: 6/22/18

Title: President

CC: Rudi Muenster

Attachments: Formula Certification Report for 1 and 2

Formula Verification Report:

ORIS Code: 56940

Plant: Valley Energy Center

Report Date: 6/22/2018

Pollutant/Parameter: CO2 Mass Rate (tons/hr)

Formula: G-4 (Gas)

Source: 1

Date/Time	Hour	HTIP_Gas	GAS_FC	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 15:00:00	15	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 16:00:00	16	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 17:00:00	17	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 18:00:00	18	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 19:00:00	19	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 20:00:00	20	505.4	1040	30.0	30.0	0.0	1.00

Source: 2

Date/Time	Hour	HTIP_Gas	GAS_FC	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 15:00:00	15	505.4	1040	30.0	30.0	0.0	1.00
5/1/18 16:00:00	16	421.2	1040	25.0	25.0	0.0	1.00
5/1/18 17:00:00	17	421.2	1040	25.0	25.0	0.0	1.00
5/1/18 18:00:00	18	421.2	1040	25.0	25.0	0.0	1.00
5/1/18 19:00:00	19	421.2	1040	25.0	25.0	0.0	1.00
5/1/18 20:00:00	20	421.2	1040	25.0	25.0	0.0	1.00

CO2 Mass Rate = 1040 * Heat input * 1/385 * (44/2000)

*Simulated on Gas

Formula Verification Report:

ORIS Code: 56940

Plant: Valley Energy Center

Report Date: 6/22/2018

Pollutant/Parameter: CO2 Mass Rate (tons/hr)

Formula: G-4 (oil)

Source: 1

Date/Time	Hour	HTIP_Oil	OIL_FC	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	1195.1	1420	97.0	97.0	0.0	1.00
5/1/18 15:00:00	15	1253.8	1420	101.7	101.7	0.0	1.00
5/1/18 16:00:00	16	1253.8	1420	101.7	101.7	0.0	1.00
5/1/18 17:00:00	17	1253.8	1420	101.7	101.7	0.0	1.00
5/1/18 18:00:00	18	1253.8	1420	101.7	101.7	0.0	1.00
5/1/18 19:00:00	19	1253.8	1420	101.7	101.7	0.0	1.00
5/1/18 20:00:00	20	1253.8	1420	101.7	101.7	0.0	1.00

Source: 2

Date/Time	Hour	HTIP_Oil	OIL_FC	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	587.7	1420	47.7	47.7	0.0	0.90
5/1/18 16:00:00	16	1214.6	1420	98.6	98.6	0.0	1.00
5/1/18 17:00:00	17	1312.6	1420	106.5	106.5	0.0	1.00
5/1/18 18:00:00	18	1312.6	1420	106.5	106.5	0.0	1.00
5/1/18 19:00:00	19	1312.6	1420	106.5	106.5	0.0	1.00
5/1/18 20:00:00	20	1312.6	1420	106.5	106.5	0.0	1.00
5/1/18 21:00:00	21	1312.6	1420	106.5	106.5	0.0	1.00

CO2 Mass Rate = 1420 * Heat input * 1/385 * (44/2000)

Formula Verification Report:

Oris Code: 56940

Plant: Valley Energy Center

Report Date: 6/22/2018

Pollutant/Parameter: CO2 Mass Rate (tons/hr)

Formula: G-4A (combined)

Source: 1

Date/Time	Hour	CO2_Gas	GAS_ON	CO2_Oil	Oil_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	0.0	0.00	97.0	1.00	97.0	97.0	0.0	1.00
5/1/18 15:00:00	15	0.0	0.00	101.7	1.00	101.7	101.7	0.0	1.00
5/1/18 16:00:00	16	0.0	0.00	101.7	1.00	101.7	101.7	0.0	1.00
5/1/18 17:00:00	17	0.0	0.00	101.7	1.00	101.7	101.7	0.0	1.00
5/1/18 18:00:00	18	0.0	0.00	101.7	1.00	101.7	101.7	0.0	1.00
5/1/18 19:00:00	19	0.0	0.00	101.7	1.00	101.7	101.7	0.0	1.00
5/1/18 20:00:00	20	0.0	0.00	101.7	1.00	101.7	101.7	0.0	1.00

Source: 2

Date/Time	Hour	CO2_Gas	GAS_ON	CO2_Oil	Oil_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	0.0	0.00	47.7	0.90	47.7	47.7	0.0	0.90
5/1/18 16:00:00	16	0.0	0.00	98.6	1.00	98.6	98.6	0.0	1.00
5/1/18 17:00:00	17	0.0	0.00	106.5	1.00	106.5	106.5	0.0	1.00
5/1/18 18:00:00	18	0.0	0.00	106.5	1.00	106.5	106.5	0.0	1.00
5/1/18 19:00:00	19	0.0	0.00	106.5	1.00	106.5	106.5	0.0	1.00
5/1/18 20:00:00	20	0.0	0.00	106.5	1.00	106.5	106.5	0.0	1.00
5/1/18 21:00:00	21	0.0	0.00	106.5	1.00	106.5	106.5	0.0	1.00

CO2 mass = CO2 tons/hr (gas) * Gas Operating time + CO2 tons/hr (oil) * Oil Operating Time/Unit operating time

Formula Verification Report
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018

Pollutant/Parameter: Total Heat Input Rate (combined)

Formula: F-8

Source: 1

Date/Time	Hour	FD_GAS	GAS_ON	FD_OIL	OIL_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	8710	0.00	9190	1.00	9190.0	9190.0	0.0	1.00
5/1/18 15:00:00	15	8710	0.00	9190	1.00	9190.0	9190.0	0.0	1.00
5/1/18 16:00:00	16	8710	0.00	9190	1.00	9190.0	9190.0	0.0	1.00
5/1/18 17:00:00	17	8710	0.00	9190	1.00	9190.0	9190.0	0.0	1.00
5/1/18 18:00:00	18	8710	0.00	9190	1.00	9190.0	9190.0	0.0	1.00
5/1/18 19:00:00	19	8710	0.00	9190	1.00	9190.0	9190.0	0.0	1.00
5/1/18 20:00:00	20	8710	0.00	9190	1.00	9190.0	9190.0	0.0	1.00

Source: 2

Date/Time	Hour	FD_GAS	GAS_ON	FD_OIL	OIL_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	8710	0	9190	1	9190.0	9190.0	0.0	1.00
5/1/18 16:00:00	16	8710	0	9190	1	9190.0	9190.0	0.0	1.00
5/1/18 17:00:00	17	8710	0	9190	1	9190.0	9190.0	0.0	1.00
5/1/18 18:00:00	18	8710	0	9190	1	9190.0	9190.0	0.0	1.00
5/1/18 19:00:00	19	8710	0	9190	1	9190.0	9190.0	0.0	1.00
5/1/18 20:00:00	20	8710	0	9190	1	9190.0	9190.0	0.0	1.00
5/1/18 21:00:00	21	8710	0	9190	1	9190.0	9190.0	0.0	1.00

FD Total = FD (gas) * Gas Operating time + FD (oil) * Oil Operating Time/Unit operating time

Formula Verification Report
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018

Pollutant/Parameter: Total Heat Input Rate (combined)

Formula: D-15A

Source: 1

Date/Time	Hour	HI_GAS	GAS_ON	HI_OIL	OIL_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	0.00	0.00	1195.1	1.00	1195.1	1195.1	0.0	1.00
5/1/18 15:00:00	15	0.00	0.00	1253.8	1.00	1253.8	1253.8	0.0	1.00
5/1/18 16:00:00	16	0.00	0.00	1253.8	1.00	1253.8	1253.8	0.0	1.00
5/1/18 17:00:00	17	0.00	0.00	1253.8	1.00	1253.8	1253.8	0.0	1.00
5/1/18 18:00:00	18	0.00	0.00	1253.8	1.00	1253.8	1253.8	0.0	1.00
5/1/18 19:00:00	19	0.00	0.00	1253.8	1.00	1253.8	1253.8	0.0	1.00
5/1/18 20:00:00	20	0.00	0.00	1253.8	1.00	1253.8	1253.8	0.0	1.00

Source: 2

Date/Time	Hour	HI_Gas	GAS_ON	HI_OIL	OIL_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	0.0	0.00	587.7	0.90	587.7	587.7	0.0	0.90
5/1/18 16:00:00	16	0.0	0.00	1214.6	1.00	1214.6	1214.6	0.0	1.00
5/1/18 17:00:00	17	0.0	0.00	1312.6	1.00	1312.6	1312.6	0.0	1.00
5/1/18 18:00:00	18	0.0	0.00	1312.6	1.00	1312.6	1312.6	0.0	1.00
5/1/18 19:00:00	19	0.0	0.00	1312.6	1.00	1312.6	1312.6	0.0	1.00
5/1/18 20:00:00	20	0.0	0.00	1312.6	1.00	1312.6	1312.6	0.0	1.00
5/1/18 21:00:00	21	0.0	0.00	1312.6	1.00	1312.6	1312.6	0.0	1.00

Heat input = mmBtu/hr (gas) * Gas Operating time + mmBtu/hr (oil) * Oil Operating Time/Unit operating time

Formula Verification Report
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018
Pollutant/Parameter: Heat Input Rate (Oil)
Formula: F-19 (D-8)

Source: 1

Date/Time	Hour	Fuel Flow	GCV_OIL	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	61000	19591	1195.1	1195.1	0.0	1.00
5/1/18 15:00:00	15	64000	19591	1253.8	1253.8	0.0	1.00
5/1/18 16:00:00	16	64000	19591	1253.8	1253.8	0.0	1.00
5/1/18 17:00:00	17	64000	19591	1253.8	1253.8	0.0	1.00
5/1/18 18:00:00	18	64000	19591	1253.8	1253.8	0.0	1.00
5/1/18 19:00:00	19	64000	19591	1253.8	1253.8	0.0	1.00
5/1/18 20:00:00	20	64000	19591	1253.8	1253.8	0.0	1.00

Source: 2

Date/Time	Hour	Fuel Flow	GCV_Oil	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	30000	19591	587.7	587.7	0.0	0.90
5/1/18 16:00:00	16	62000	19591	1214.6	1214.6	0.0	1.00
5/1/18 17:00:00	17	67000	19591	1312.6	1312.6	0.0	1.00
5/1/18 18:00:00	18	67000	19591	1312.6	1312.6	0.0	1.00
5/1/18 19:00:00	19	67000	19591	1312.6	1312.6	0.0	1.00
5/1/18 20:00:00	20	67000	19591	1312.6	1312.6	0.0	1.00
5/1/18 21:00:00	21	67000	19591	1312.6	1312.6	0.0	1.00

Heat Input = Fuel Flow * GCV_Oil/10^6

Formula Verification Report
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018
Pollutant/Parameter: Heat Input Rate (Gas)
Formula: F-20 (D-6)

Source: 1

Date/Time	Hour	Fuel Flow	GCV_Gas	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	4860	104000	505.4	505.4	0.0	1.00
5/1/18 15:00:00	15	4860	104000	505.4	505.4	0.0	1.00
5/1/18 16:00:00	16	4860	104000	505.4	505.4	0.0	1.00
5/1/18 17:00:00	17	4860	104000	505.4	505.4	0.0	1.00
5/1/18 18:00:00	18	4860	104000	505.4	505.4	0.0	1.00
5/1/18 19:00:00	19	4860	104000	505.4	505.4	0.0	1.00
5/1/18 20:00:00	20	4860	104000	505.4	505.4	0.0	1.00

Source: 2

Date/Time	Hour	Fuel Flow	GCV_Gas	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	4860	104000	505.4	505.4	0.0	1.00
5/1/18 16:00:00	16	4860	104000	505.4	505.4	0.0	1.00
5/1/18 17:00:00	17	4050	104000	421.2	421.2	0.0	1.00
5/1/18 18:00:00	18	4050	104000	421.2	421.2	0.0	1.00
5/1/18 19:00:00	19	4050	104000	421.2	421.2	0.0	1.00
5/1/18 20:00:00	20	4050	104000	421.2	421.2	0.0	1.00
5/1/18 21:00:00	21	4050	104000	421.2	421.2	0.0	1.00

Heat Input = Fuel Flow * GCV_Gas/10^6

* Simulated on Gas

Formula Verification Report:**ORIS Code: 56940****Plant: Valley Energy Center****Report Date: 6/22/2018****Pollutant/Parameter: NOx Mass Rate (lb/hr)****Formula Code: F-24A****Source: 1**

Date/Time	Hour	NOx Rate	Adj. NOx Rate	Heat Input	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	0.163	0.163	1195.1	194.8	194.8	0.0	1.00
5/1/18 15:00:00	15	0.045	0.045	1253.8	56.4	56.4	0.0	1.00
5/1/18 16:00:00	16	0.022	0.022	1253.8	27.6	27.6	0.0	1.00
5/1/18 17:00:00	17	0.022	0.022	1253.8	27.6	27.6	0.0	1.00
5/1/18 18:00:00	18	0.022	0.022	1253.8	27.6	27.6	0.0	1.00
5/1/18 19:00:00	19	0.022	0.022	1253.8	27.6	27.6	0.0	1.00
5/1/18 20:00:00	20	0.022	0.022	1253.8	27.6	27.6	0.0	1.00

Source: 2

Date/Time	Hour	NOx Rate	Adj. NOx Rate	Heat Input	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	0.235	0.235	587.7	138.1	138.1	0.0	0.90
5/1/18 16:00:00	16	0.167	0.167	1214.6	202.8	202.8	0.0	1.00
5/1/18 17:00:00	17	0.043	0.043	1312.6	56.4	56.4	0.0	1.00
5/1/18 18:00:00	18	0.021	0.021	1312.6	27.6	27.6	0.0	1.00
5/1/18 19:00:00	19	0.022	0.022	1312.6	28.9	28.9	0.0	1.00
5/1/18 20:00:00	20	0.022	0.022	1312.6	28.9	28.9	0.0	1.00
5/1/18 21:00:00	21	0.022	0.022	1312.6	28.9	28.9	0.0	1.00

NOx mass = Adjusted NOx Rate * Heat input

Bias = 1.00

Formula Verification Report:

ORIS Code: 56940

Plant: Valley Energy Center

Report Date: 6/22/2018

Pollutant/Parameter: NOx Emissions Rate (lb/mmBtu) (gas)

Formula Code: F-5

Source: 1

Date/Time	Hour	NOx concentration	O2	F_fact	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	47.5	14.2	9190	0.163	0.163	0.0	1.00
5/1/18 15:00:00	15	13.4	14.0	9190	0.045	0.045	0.0	1.00
5/1/18 16:00:00	16	6.6	14.0	9190	0.022	0.022	0.0	1.00
5/1/18 17:00:00	17	6.5	14.0	9190	0.022	0.022	0.0	1.00
5/1/18 18:00:00	18	6.5	14.0	9190	0.022	0.022	0.0	1.00
5/1/18 19:00:00	19	6.5	14.0	9190	0.022	0.022	0.0	1.00
5/1/18 20:00:00	20	6.5	14.0	9190	0.022	0.022	0.0	1.00

Source: 2

Date/Time	Hour	NOx concentration	O2	F_fact	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	44.1	16.6	9190	0.235	0.235	0.0	0.90
5/1/18 16:00:00	16	48.1	14.3	9190	0.167	0.167	0.0	1.00
5/1/18 17:00:00	17	12.8	14.0	9190	0.043	0.043	0.0	1.00
5/1/18 18:00:00	18	6.2	14.0	9190	0.021	0.021	0.0	1.00
5/1/18 19:00:00	19	6.5	14.0	9190	0.022	0.022	0.0	1.00
5/1/18 20:00:00	20	6.5	14.0	9190	0.022	0.022	0.0	1.00
5/1/18 21:00:00	21	6.5	14.0	9190	0.022	0.022	0.0	1.00

$$\text{NOx Emissions Rate} = 1.194 \times 10^{-7} * \text{NOx} * 8710 * (20.9 / (20.9 - \text{O}_2))$$

Formula Verification Report:
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018
Pollutant/Parameter: SO2 Mass Rate (lb/hr) (oil)
Formula: D-2

Source: 1

Date/Time	Hour	Oil_Mass	%_Sulfur	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	61000.0	0.03480	42.5	42.5	0.0	1.00
5/1/18 15:00:00	15	64000.0	0.03480	44.5	44.5	0.0	1.00
5/1/18 16:00:00	16	64000.0	0.03480	44.5	44.5	0.0	1.00
5/1/18 17:00:00	17	64000.0	0.03480	44.5	44.5	0.0	1.00
5/1/18 18:00:00	18	64000.0	0.03480	44.5	44.5	0.0	1.00
5/1/18 19:00:00	19	64000.0	0.03480	44.5	44.5	0.0	1.00
5/1/18 20:00:00	20	64000.0	0.03480	44.5	44.5	0.0	1.00

Source: 2

Date/Time	Hour	Oil_Mass	%_Sulfur	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	30000.0	0.03480	20.9	20.9	0.0	0.90
5/1/18 16:00:00	16	62000.0	0.03480	43.2	43.2	0.0	1.00
5/1/18 17:00:00	17	67000.0	0.03480	46.6	46.6	0.0	1.00
5/1/18 18:00:00	18	67000.0	0.03480	46.6	46.6	0.0	1.00
5/1/18 19:00:00	19	67000.0	0.03480	46.6	46.6	0.0	1.00
5/1/18 20:00:00	20	67000.0	0.03480	46.6	46.6	0.0	1.00
5/1/18 21:00:00	21	67000.0	0.03480	46.6	46.6	0.0	1.00

SO2 mass = 2 * Oil Rate * % sulfur/100

Formula Verification Report:
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018
Pollutant/Parameter: SO2 Mass Rate (lb/hr) (gas)
Formula: D-5

Source: 1

Date/Time	Hour	Heat Input	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	505.4	0.30324	0.30324	0.0	1.00
5/1/18 15:00:00	15	505.4	0.30324	0.30324	0.0	1.00
5/1/18 16:00:00	16	505.4	0.30324	0.30324	0.0	1.00
5/1/18 17:00:00	17	505.4	0.30324	0.30324	0.0	1.00
5/1/18 18:00:00	18	505.4	0.30324	0.30324	0.0	1.00
5/1/18 19:00:00	19	505.4	0.30324	0.30324	0.0	1.00
5/1/18 20:00:00	20	505.4	0.30324	0.30324	0.0	1.00

Source: 2

Date/Time	Hour	Heat Input	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	505.4	0.30324	0.30324	0.0	1.00
5/1/18 16:00:00	16	505.4	0.30324	0.30324	0.0	1.00
5/1/18 17:00:00	17	421.2	0.25272	0.25272	0.0	1.00
5/1/18 18:00:00	18	421.2	0.25272	0.25272	0.0	1.00
5/1/18 19:00:00	19	421.2	0.25272	0.25272	0.0	1.00
5/1/18 20:00:00	20	421.2	0.25272	0.25272	0.0	1.00
5/1/18 21:00:00	21	421.2	0.25272	0.25272	0.0	1.00

SO2 mass = Heat Input * 0.0006

*Simulated on Gas

Formula Verification Report:
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018

Pollutant/Parameter: SO2 Mass Rate (lb/hr) (combined)
Formula: D-12

Source: 1

Date/Time	Hour	SO2_Gas	GAS_ON	SO2_Oil	Oil_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	0.00000	0.00	42.5	1.00	42.5000	42.5000	0.0	1.00
5/1/18 15:00:00	15	0.00000	0.00	44.5	1.00	44.5000	44.5000	0.0	1.00
5/1/18 16:00:00	16	0.00000	0.00	44.5	1.00	44.5440	44.5440	0.0	1.00
5/1/18 17:00:00	17	0.00000	0.00	44.5	1.00	44.5440	44.5440	0.0	1.00
5/1/18 18:00:00	18	0.00000	0.00	44.5	1.00	44.5440	44.5440	0.0	1.00
5/1/18 19:00:00	19	0.00000	0.00	44.5	1.00	44.5440	44.5440	0.0	1.00
5/1/18 20:00:00	20	0.00000	0.00	44.5	1.00	44.5440	44.5440	0.0	1.00

Source: 2

Date/Time	Hour	SO2_Gas	GAS_ON	SO2_Oil	Oil_ON	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	0.00000	0.0	20.9	0.90	20.9000	20.9000	0.0	0.90
5/1/18 16:00:00	16	0.00000	0.0	43.2	1.00	43.2000	43.2000	0.0	1.00
5/1/18 17:00:00	17	0.00000	0.0	46.6	1.00	46.6000	46.6000	0.0	1.00
5/1/18 18:00:00	18	0.00000	0.0	46.6	1.00	46.6000	46.6000	0.0	1.00
5/1/18 19:00:00	19	0.00000	0.0	46.6	1.00	46.6000	46.6000	0.0	1.00
5/1/18 20:00:00	20	0.00000	0.0	46.6	1.00	46.6000	46.6000	0.0	1.00
5/1/18 21:00:00	21	0.00000	0.0	46.6	1.00	46.6000	46.6000	0.0	1.00

SO2 mass = SO2 lb/hr (gas) * Gas Operating time + SO2 lb/hr (oil) * Oil Operating Time/Unit operating time

Formula Verification Report:
ORIS Code: 56940
Plant: Valley Energy Center

Report Date: 6/22/2018
Pollutant/Parameter: SO2 Mass Rate (lb/hr) (combined)
Formula: D-1H

Source: 1

Date/Time	Hour	Sulfur_NNG	GCV_NNG	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 14:00:00	14	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 15:00:00	15	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 16:00:00	16	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 17:00:00	17	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 18:00:00	18	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 19:00:00	19	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 20:00:00	20	0.00020	104000.00	0.000001	0.000001	0.0	1.00

Source: 2

Date/Time	Hour	Sulfur_NNG	GCV_NNG	Calculation	DAS System	ABS Difference	Unit Oper(Hr)
5/1/18 15:00:00	15	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 16:00:00	16	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 17:00:00	17	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 18:00:00	18	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 19:00:00	19	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 20:00:00	20	0.00020	104000.00	0.000001	0.000001	0.0	1.00
5/1/18 21:00:00	21	0.00020	104000.00	0.000001	0.000001	0.0	1.00

SO2 mass = (2.0 / 7000) * (10^6) * S_NNG/GCV_NNG)

* Simulated on gas



ECMPS Client Tool

Version 1.0 2018 Q2

Monitoring Plan Printout Report

June 22, 2018 04:36 PM

Facility Name: Valley Energy Center

Facility Details

Facility ID (ORISPL): 56940
 Monitoring Plan Location IDs: 1
 State: NY
 County: Orange County
 Latitude: 41.4130
 Longitude: -74.4350

Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
1	Q - Quarterly	2017 QTR 3	

Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Cross Area Exit	Cross Area Flow	Material Code	Shape Code	Begin Date	End Date
1		464	275	284		OTHER	ROUND	08/18/2017	

Unit Operation Information

Unit Identifier	Non-Load Based Ind	Commence Commercial Operation Date	Commence Operation Date	Boiler/Turbine Type			Max Heat Input		
				Code	Begin Date	End Date	Value (mmBtu)	Begin Date	End Date
1	0	01/25/2018	01/24/2018	CC	01/01/2018		2734.0	01/24/2018	

Unit Type Codes: CC - Combined cycle

Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
1	ARP	P2	01/25/2018	07/24/2018
	CSNOX	A	01/25/2018	07/24/2018
	CSOSG2	A	01/25/2018	07/24/2018
	CSSO2G1	A	01/25/2018	07/24/2018
	RGGI	A	01/25/2018	07/24/2018

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:36 PM

Unit Fuel

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
1	DSL	S				01/24/2018	
	NNG	P				01/24/2018	

Fuel Type Codes: NNG - Natural Gas
DSL - Diesel Oil

Fuel Indicator Codes: S - Secondary
P - Primary

Unit Controls

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
1	NOX	SCR	Y				

Control Equipment Descriptions: SCR - Selective Catalytic Reduction

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:36 PM

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
1	CO2	AD	SPTS		08/18/2017 00	
	HI	AD	SPTS		08/18/2017 00	
	NOX	NOXR			08/18/2017 00	
	NOXR	CEM	SPTS		08/18/2017 00	
	OP	EXP			08/18/2017 00	
	SO2	AD	SPTS		08/18/2017 00	

Parameter Codes:

- SO2 - SO2 Hourly Mass Rate (lb/hr)
- OP - Opacity
- NOXR - NOx Emission Rate (lb/mmBtu)
- NOX - NOx Hourly Mass Rate (lb/hr)
- HI - Heat Input Rate (mmBtu/hr)
- CO2 - CO2 Hourly Mass Rate (ton/hr)

Methodology Codes:

- NOXR - NOx Mass Calculated from NOx Emission Rate
- EXP - Exempt
- CEM - Continuous Emission Monitor
- AD - Appendix D

Substitute Data Codes:

- SPTS - Standard Part 75 for Missing Data

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:36 PM

Monitoring System / Analytical Components

Unit/Stack /Pipe Identifier	System					Component									
	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	BAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour	Hg Converter Indicator
1	GAS	GAS	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIES	CEMLINK6		08/18/2017 00		
						GAB	GFFM	ORF		FLUIDIC TECHNOLOGIES	FAB3110	FAB3110-1A	08/18/2017 00		
						GAS	GFFM	ORF		GTE	3044SS PADDLE	3033514	08/18/2017 00		
	NOX	NOX	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIES	CEMLINK6		08/18/2017 00		
						NOX	NOX	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						O2D	O2	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						PRB	PRB	EXT		UNIVERSAL	270SF	TBD	08/18/2017 00		
	OIL	OILM	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIES	CEMLINK6		08/18/2017 00		
						OIL	OFFM	TUR		FTI	FT-40C4U3-LEA-3	160405M51314	08/18/2017 00		

System Types Descriptions:

GAS - Gas Fuel Flow
 NOX - NOx Emission Rate
 OILM - Mass of Oil Fuel Flow

System Designations Descriptions:

P - Primary

Sample Acquisition Method (SAM):

TUR - Turbine
 ORF - Orifice
 EXT - Dry Extractive

Component Types Descriptions:

DAHS - Data Acquisition and Handling System
 GFFM - Gas Fuel Flowmeter
 NOX - NOx Concentration
 O2 - O2 Concentration
 PRB - Probe
 OFFM - Oil Fuel Flowmeter

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:36 PM

Monitoring System Fuel Flow

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
1	GAS	NNG	28000.0	HSCF	URV	08/18/2017 00	
	OIL	DSL	120000.0	LBHR	URV	08/18/2017 00	

System Fuel Codes Descriptions: NNG - Natural Gas
 DSL - Diesel Oil

Units of Measure Descriptions: LBHR - Pounds / Hour
 HSCF - Hundred Standard Cubic Feet / Hour

Source Codes Descriptions: URV - Upper Range Value

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dual Range Indicator	Begin Date/Hour	End Date/Hour
1	NOX	NOX	Auto Ranging	Y	08/18/2017 00	
	O2	O2D	High Range		08/18/2017 00	

Component Types Descriptions: NOX - NOx Concentration
 O2 - O2 Concentration

Emissions Formulas

Facility Name: Valley Energy Center

Monitoring Plan Printout Report

Facility ID (ORISPL): 56940

June 22, 2018 04:36 PM

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
1	NOXR	100	F-5	$NOx_lb/mmBtu = S\#(NOX-NOX) * (1.194 * 10^{-7}) * F\#(107) * (20.9 / (20.9 - S\#(O2D-NOX)))$	08/18/2017 00	
	HI	101	F-20	$HI_gas = (F\#(112) * GCV_gas) / 10^{**}6$	08/18/2017 00	
	SO2	102	D-5	$M_SO2_gas = F\#(111) * F\#(101)$	08/18/2017 00	
	CO2	103	G-4	$W_CO2_gas = (1040 * F\#(101) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	HI	104	D-8	$HI_oil = S\#(OIL-OIL)_oilrate * (GCV_oil / 10^{**}6)$	08/18/2017 00	
	SO2	105	D-2	$M_SO2_oil = 2.0 * S\#(OIL-OIL)_oilrate * (\%S_oil / 100)$	08/18/2017 00	
	CO2	106	G-4	$W_CO2_oil = (1420 * F\#(104) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	FD	107	F-8	$Fd = (X_oil * 9190) + (X_gas * 8710)$	08/18/2017 00	
	HI	108	D-15A	$HI_total = (F\#(101) * T_gas + F\#(104) * T_oil) / T_unit$	08/18/2017 00	
	CO2	109	G-4A	$CO2_total = (F\#(103) * T_gas + F\#(106) * T_oil) / T_unit$	08/18/2017 00	
	SO2	110	D-12	$SO2_total = (F\#(102) * T_gas + F\#(105) * T_oil) / T_unit$	08/18/2017 00	
	SO2R	111	D-1H	$ER_SO2_gas = (2.0 / 7000) * (10^{**}6) * S_NNG/GCV_NNG)$	08/18/2017 00	
	FGAS	112	N-GAS	$N_gas = S\#(GAS-GAS) + S\#(GAB-GAS)$	08/18/2017 00	
	NOX	113	F-24A	$NOx\ mass = F\#(NOX)*F\#(HT)*T_unit$	08/18/2017 00	

Parameter Codes Descriptions:
 NOXR - NOx Emission Rate (lb/mmBtu)
 HI - Heat Input Rate (mmBtu/hr)
 SO2 - SO2 Hourly Mass Rate (lb/hr)
 CO2 - CO2 Hourly Mass Rate (ton/hr)
 FD - F-Factor Dry-basis
 SO2R - SO2 Hourly Emission Rate (lb/mmBtu)
 FGAS - Gas Hourly Flow Rate (hscf)
 NOX - NOx Hourly Mass Rate (lb/hr)

Facility Name: Valley Energy Center

Monitoring Plan Printout Report

Facility ID (ORISPL): 56940

June 22, 2018 04:36 PM

Formula Codes Descriptions:

- N-GAS - FGAS (net gas flow rate)
- G-4A - CO2 (from CO2 rate for multiple fuels)
- G-4 - CO2 (from HI, Fc)
- F-8 - FD/FC/FW (from multiple fuels)
- F-5 - NOXR/SO2R (from NOX or SO2 dry, O2 dry, Fd)
- F-24A - NOX (from NOX rate, HI)
- F-20 - HI (same as D-6)
- D-8 - HI (from oil flow rate, GCV)
- D-5 - SO2 (from gas SO2 emission rate, HI)
- D-2 - SO2 (from OILM, oil sulfur content)
- D-1H - SO2R (from gas sulfur content, GCV)
- D-15A - HI (from HI rate for multiple fuels)
- D-12 - SO2 (from SO2 rate for multiple fuels)

Span Values

Unit/Stack /Pipe Identifier	Comp Type	Scale	Method	MPC/ MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)	Flow Span Value (SCFH)	Begin Date/Hour	End Date/Hour
1	NOX	H	ME	100.0	6.0	100.000	100.000	PPM	9.5				08/18/2017 00	
	NOX	L	PL		6.0	10.000	10.000	PPM	9.5				08/18/2017 00	
	O2	H				25.000	25.000	PCT					08/18/2017 00	

Component Types Descriptions:

- NOX - NOx Concentration
- O2 - O2 Concentration

Span Method Codes Descriptions:

- PL - Permit Limit for NOX MEC
- ME - Manufacturer's Estimate for NOX MPC

Units of Measure Descriptions:

- PPM - Parts per Million
- PCT - Percentage

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
1	380	MW	230	50	High	Mid	Yes	12/31/2017	12/31/2017 00	

Units of Measure Descriptions: MW - Megawatt

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:36 PM

Monitoring Defaults

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
1	NORX	1.1440	LBMMBTU	MD	NFS	A	DEF	08/18/2017 00	
	O2X	19.0000	PCT	DC	NFS	A	DEF	08/18/2017 00	

- Parameter Codes Descriptions:**
 - O2X - Maximum O2 Concentration (pct)
 - NORX - Maximum NOx Emission Rate (lb/mmBtu)
- Units of Measure Descriptions:**
 - PCT - Percentage
 - LBMMBTU - Pounds / mmBtu
- Purpose Codes Descriptions:**
 - MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default
 - DC - Diluent Cap
- Fuel Type Codes Descriptions:**
 - NFS - Non-Fuel Specific
- Operating Conditions Descriptions:**
 - A - Any Hour
- Source Codes Descriptions:**
 - DEF - Default Value from Part 75



ECMPS Client Tool

Version 1.0 2018 Q2

QA/Cert Test Detail Report

June 22, 2018 04:39 PM

Facility Name: Valley Energy Center

Facility Details

Facility ID (ORISPL): 56940
State: NY
County: Orange County

Unit/Stack/Pipe ID: 1

7-Day Calibration

Component ID: NOX **Component Type:** NOX **Test Completion:** 05/08/2018 12:35
Test Number: 1_NOxL_7Day **Reason for Test:** INITIAL **Reported Test Results:** PASSED
Span Scale Level: Low **Span Value:** 10.000 **EPA Calculated Result:** PASSED
Evaluation Status: No Errors **Submission Status:** Data loaded on EPA Host System
Submission Date/Time: 06/22/2018 4:24:00 PM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
04/29/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
04/29/2018 12	HIGH	8.170	81.7	8.300	1.30		1.30	
04/30/2018 17	ZERO	0.000	0	0.000	0.00		0.00	
04/30/2018 17	HIGH	8.170	81.7	8.200	0.30		0.30	
05/01/2018 16	ZERO	0.000	0	0.000	0.00		0.00	
05/01/2018 16	HIGH	8.170	81.7	8.100	0.70		0.70	
05/02/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/02/2018 12	HIGH	8.170	81.7	8.200	0.30		0.30	
05/03/2018 10	ZERO	0.000	0	0.000	0.00		0.00	
05/03/2018 10	HIGH	8.170	81.7	8.200	0.30		0.30	
05/07/2018 14	ZERO	0.000	0	0.100	1.00		1.00	
05/07/2018 14	HIGH	8.170	81.7	8.200	0.30		0.30	
05/08/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/08/2018 12	HIGH	8.170	81.7	8.000	1.70		1.70	

Additional Information:

No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

Facility Name: Valley Energy Center

QA/Cert Test Detail Report

Facility ID (ORISPL): 56940

June 22, 2018 04:39 PM

Unit/Stack/Pipe ID: 1

7-Day Calibration

Component ID: NOX	Component Type: NOX	Test Completion: 05/08/2018 12:41
Test Number: 1_NoXH_7Day	Reason for Test: INITIAL	Reported Test Results: PASSAPS
Span Scale Level: High	Span Value: 100.000	EPA Calculated Result: PASSED
Evaluation Status: No Errors		Submission Status: Data loaded on EPA Host System
		Submission Date/Time: 06/22/2018 4:24:00 PM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
04/29/2018 12	ZERO	0.000	0	0.100	0.10		0.10	
04/29/2018 12	HIGH	89.520	89.5	90.400	0.90		0.90	
04/30/2018 17	ZERO	0.000	0	0.100	0.10		0.10	
04/30/2018 17	HIGH	89.520	89.5	89.300	0.20		0.20	
05/01/2018 16	ZERO	0.000	0	0.000	0.00		0.00	
05/01/2018 16	HIGH	89.520	89.5	88.800	0.70		0.70	
05/02/2018 12	ZERO	0.000	0	0.100	0.10		0.10	
05/02/2018 12	HIGH	89.520	89.5	88.300	1.20		1.20	
05/03/2018 10	ZERO	0.000	0	0.000	0.00		0.00	
05/03/2018 10	HIGH	89.520	89.5	88.400	1.10		1.10	
05/07/2018 14	ZERO	0.000	0	0.100	0.10		0.10	
05/07/2018 14	HIGH	89.520	89.5	88.200	1.30		1.30	
05/08/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/08/2018 12	HIGH	89.520	89.5	88.100	1.40		1.40	

Additional Information:

No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A &3.1)

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:39 PM

Unit/Stack/Pipe ID: 1

7-Day Calibration

Component ID: O2D	Component Type: O2	Test Completion: 05/08/2018 12:44
Test Number: 1_O2_7Day	Reason for Test: INITIAL	Reported Test Results: PASSED
Span Scale Level: High	Span Value: 25.000	EPA Calculated Result: PASSED
Evaluation Status: No Errors	Submission Status: Data loaded on EPA Host System	Submission Date/Time: 06/22/2018 4:24:00 PM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
04/29/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
04/29/2018 12	HIGH	20.930	83.7	20.900	0.00		0.00	
04/30/2018 17	ZERO	0.000	0	0.000	0.00		0.00	
04/30/2018 17	HIGH	20.930	83.7	20.900	0.00		0.00	
05/01/2018 16	ZERO	0.000	0	0.000	0.00		0.00	
05/01/2018 16	HIGH	20.930	83.7	20.900	0.00		0.00	
05/02/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/02/2018 12	HIGH	20.930	83.7	20.900	0.00		0.00	
05/03/2018 10	ZERO	0.000	0	0.000	0.00		0.00	
05/03/2018 11	HIGH	20.930	83.7	20.900	0.00		0.00	
05/07/2018 14	ZERO	0.000	0	0.000	0.00		0.00	
05/07/2018 14	HIGH	20.930	83.7	20.900	0.00		0.00	
05/08/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/08/2018 12	HIGH	20.930	83.7	20.900	0.00		0.00	

Additional Information:

No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

Facility Name: Valley Energy Center

QA/Cert Test Detail Report

Facility ID (ORISPL): 56940

June 22, 2018 04:39 PM

Unit/Stack/Pipe ID: 1

Cycle Time Test

Component ID: NOX	Component Type: NOX	Test Completion: 05/08/2018 09:24
Test Number: 1_NoXH_Cycle_Cert	Reason for Test: INITIAL	Reported Test Results: PASSED
Span Scale Level: High	Span Value: 100.000	EPA Calculated Result: PASSED
Total Cycle Time: 3	Calculated Total Cycle Time: 3	

Evaluation Status: No Errors

Submission Status: Data loaded on EPA Host System

Submission Date/Time: 06/22/2018 4:24:00 PM

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2018/05/08	09:12	09:15	ZERO	0.000	43.900	0.200	3	3
2018/05/08	09:22	09:24	HIGH	89.520	42.800	87.600	2	2

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: 1

Cycle Time Test

Component ID: NOX	Component Type: NOX	Test Completion: 05/08/2018 10:50
Test Number: 1_NoXL_Cycle_Cert	Reason for Test: INITIAL	Reported Test Results: PASSED
Span Scale Level: Low	Span Value: 10.000	EPA Calculated Result: PASSED
Total Cycle Time: 2	Calculated Total Cycle Time: 2	

Evaluation Status: No Errors

Submission Status: Data loaded on EPA Host System

Submission Date/Time: 06/22/2018 4:24:00 PM

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2018/05/08	10:39	10:41	ZERO	0.000	4.200	0.000	2	2
2018/05/08	10:48	10:50	HIGH	8.170	4.200	8.100	2	2

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Facility Name: Valley Energy Center

QA/Cert Test Detail Report

June 22, 2018 04:39 PM

Facility ID (ORISPL): 56940

Unit/Stack/Pipe ID: 1

Cycle Time Test

Component ID: O2D	Component Type: O2	Test Completion: 05/08/2018 18:21
Test Number: 1_O2_Cycle_Cert	Reason for Test: INITIAL	Reported Test Results: PASSED
Span Scale Level: High	Span Value: 25.000	EPA Calculated Result: PASSED
Total Cycle Time: 3	Calculated Total Cycle Time: 3	

Evaluation Status: No Errors

Submission Status: Data loaded on EPA Host System

Submission Date/Time: 06/22/2018 4:24:00 PM

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2018/05/08	18:11	18:14	ZERO	0.000	13.700	0.000	3	3
2018/05/08	18:18	18:21	HIGH	20.930	13.900	20.900	3	3

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: 1

Linearity Check

Component ID: NOX	Component Type: NOX	Test Completion: 05/10/2018 10:24
Test Number: 1_NOXH_CERTLIN	Reason for Test: QA	Reported Test Results: PASSED
Span Scale Level: High	Span Value: 100.000	EPA Calculated Result: PASSED

Evaluation Status: No Errors

Submission Status: Data loaded on EPA Host System

Submission Date/Time: 06/22/2018 4:24:00 PM

Grace period Tested?

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
Low	CO,NO,BALN	G12018	EB0073000	03/19/2021
High	CO2,NO,NOX,BALN	B52017	CC329952	12/17/2025
Mid	NO,NOX,BALN	B22017	CC503502	11/01/2025

Summary Statistics:

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:39 PM

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	89.520	89.520	50.890	50.890	24.600	24.600
Mass CEM Value	88.400	88.300	51.433	51.433	25.067	25.067
Alt. Perf. Indicator						
Results	1.3	1.4	1.1	1.1	1.9	1.9

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
05/10/2018 09:51	LOW	25.000	24.600	24.6%
05/10/2018 10:16	LOW	25.100	24.600	24.6%
05/10/2018 10:04	LOW	25.100	24.600	24.6%
05/10/2018 10:00	HIGH	88.200	89.520	89.5%
05/10/2018 10:12	HIGH	88.200	89.520	89.5%
05/10/2018 10:24	HIGH	88.500	89.520	89.5%
05/10/2018 09:55	MID	51.400	50.890	50.9%
05/10/2018 10:20	MID	51.500	50.890	50.9%
05/10/2018 10:08	MID	51.400	50.890	50.9%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A & 3.2)

Unit/Stack/Pipe ID: 1

Linearity Check

Component ID: NOX	Component Type: NOX	Test Completion: 05/08/2018 10:29
Test Number: 1_Nox_L_CertLin	Reason for Test: INITIAL	Reported Test Results: PASSAPS
Span Scale Level: Low	Span Value: 10.000	EPA Calculated Result: PASSAPS
Evaluation Status: No Errors		Submission Status: Data loaded on EPA Host System
Grace period Tested?		Submission Date/Time: 06/22/2018 4:24:00 PM

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,CO2,NO,NOX,BALN	B52017	CC192317	09/26/2020

Facility Name: Valley Energy Center

QA/Cert Test Detail Report

Facility ID (ORISPL): 56940

June 22, 2018 04:39 PM

Low	CO,NO,BALN	G12017	EB0072315	07/04/2020
Mid	NO,BALN	G12017	EB0101725	12/03/2020

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	8.170	8.170	5.090	5.090	2.420	2.420
Mass CEM Value	8.000	8.000	5.367	5.367	2.500	2.500
Alt. Perf. Indicator			Y	Y		
Results	2.1	2.1	0.0	0.0	3.3	3.3

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
05/08/2018 10:09	MID	5.400	5.090	50.9%
05/08/2018 09:52	MID	5.300	5.090	50.9%
05/08/2018 10:24	MID	5.400	5.090	50.9%
05/08/2018 09:58	HIGH	8.000	8.170	81.7%
05/08/2018 10:29	HIGH	8.000	8.170	81.7%
05/08/2018 10:15	HIGH	8.000	8.170	81.7%
05/08/2018 10:02	LOW	2.500	2.420	24.2%
05/08/2018 09:48	LOW	2.500	2.420	24.2%
05/08/2018 10:19	LOW	2.500	2.420	24.2%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: 1

Linearity Check

Component ID:	O2D	Component Type:	O2	Test Completion:	05/10/2018 07:38
Test Number:	1_O2_CERTLIN	Reason for Test:	QA	Reported Test Results:	PASSED
Span Scale Level:	High	Span Value:	25.000	EPA Calculated Result:	PASSED
Evaluation Status:	No Errors			Submission Status:	Data loaded on EPA Host System
Grace period Tested?				Submission Date/Time:	06/22/2018 4:24:00 PM

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:39 PM

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,CO2,O2,BALN	B22017	EB0095428	09/17/2025
Low	CO2,O2,BALN	L12013	EB0049201	08/13/2021
Mid	O2,BALN	G12018	EB0060674	04/01/2026

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	20.930	20.930	13.820	13.820	6.360	6.360
Mass CEM Value	20.900	20.900	13.700	13.700	6.100	6.100
Alt. Perf. Indicator						
Results	0.1	0.1	0.9	0.9	4.1	4.1

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
05/10/2018 07:18	LOW	6.100	6.360	25.4%
05/10/2018 07:05	LOW	6.100	6.360	25.4%
05/10/2018 07:30	LOW	6.100	6.360	25.4%
05/10/2018 07:09	MID	13.700	13.820	55.3%
05/10/2018 07:21	MID	13.700	13.820	55.3%
05/10/2018 07:34	MID	13.700	13.820	55.3%
05/10/2018 07:38	HIGH	20.900	20.930	83.7%
05/10/2018 07:26	HIGH	20.900	20.930	83.7%
05/10/2018 07:13	HIGH	20.900	20.930	83.7%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: 1

Relative Accuracy Test

QA/Cert Test Detail Report

June 22, 2018 04:39 PM

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

System ID: NOX **System Parameter:** NOX
Test Number: 1_RATA_Cert **Reason for Test:** QA
of Op. Levels: 1 **Grace Period Test?**

Test Completion: 05/09/2018 17:49
Reported Test Results: PASSED
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Data loaded on EPA Host System
Submission Date: 06/22/2018 4:24:00 PM

Reported BAF: 1.000
EPA Calculated BAF: 1.000
RATA Frequency: 4QTRS

Air Emissions Testing Data

QI Name: Stockwell, Michael D
Exam Date: 01/06/2017
Provider Name: Source Evaluation Society
Provider Email: qstiprogram@gmail.com

AETB Name: Air Hygiene International Inc.
AETB Phone Number: 888-461-8778
AETB Email: info@airhygiene.com

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,NO,NOX,BALN	G12016	EB0026154	09/30/2019
Mid	CO,NO,NOX,BALN	G12017	EB0098858	09/18/2020
Low	CO,NO,NOX,BALN	G12018	EB0027723	01/25/2021
High	CO2,O2,BALN	G12017	EB0032327	01/07/2025
Mid	CO2,O2,BALN	G12018	EB0081248	03/12/2026
Low	ZERO			

Operating Level: High
Reference Method Used: 7E,3A: NOX RM 7E and CO2/O2 RM 3A

Summary Statistics:

	Reported	Recalculated		Reported	Recalculated
Mean of Monitoring System	0.01989	0.01989	Relative Accuracy	5.45	5.45
Mean of Reference Method Values	0.02044	0.02044	Bias Adjustment Factor	1.000	1.000
Mean of Difference	0.00056	0.00056	APS Indicator		
Standard Deviation of Difference	0.00073	0.00073	T-Value	2.306	2.306
Confidence Coefficient	0.00056	0.00056	Gross Unit Load or Velocity	178	178

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:39 PM

Run Data:

Run	Start Date	End Date	Run Status	Monitoring System Value	Reference Method Value	Gross Load or Velocity
1	05/09/2018 12:46	05/09/2018 13:07	RUNUSED	0.02000	0.02100	178
2	05/09/2018 13:27	05/09/2018 13:48	RUNUSED	0.02000	0.02100	177
3	05/09/2018 14:03	05/09/2018 14:24	RUNUSED	0.02000	0.02000	176
4	05/09/2018 14:38	05/09/2018 14:59	RUNUSED	0.02000	0.02200	177
5	05/09/2018 15:16	05/09/2018 15:37	RUNUSED	0.02000	0.02000	177
6	05/09/2018 15:48	05/09/2018 16:09	RUNUSED	0.02000	0.02000	179
7	05/09/2018 16:23	05/09/2018 16:44	RUNUSED	0.02000	0.02000	179
8	05/09/2018 16:55	05/09/2018 17:16	RUNUSED	0.02000	0.02000	179
9	05/09/2018 17:28	05/09/2018 17:49	RUNUSED	0.01900	0.02000	180

Additional Information:

No comment.

*Performance Spec: RA <= 10% or Mean Difference <= +/- 2.0fps:
Reduced Frequency Spec: RA <= 7.5% or Mean Difference +/- 1.5 fps (Appendix A &3.3.4)

ATTACHMENT 2

Unit 2

40 CFR Part 75 Form
Monitoring Plan
RATA Test Summary
Linearity Test Summary
Cycle Response Test
7-day drift test



Certification Application

For more information, see instructions and refer to 40 CFR 75.63

This submission is for: • Initial Certification • Recertification

STEP 1
Identify the source by plant name, State, and ORIS Code from NADB

Plant Name	VALLEY ENERGY CENTER	State	NY	ORIS Code	56940
------------	----------------------	-------	----	-----------	-------

STEP 2
Identify unit short name/common stack description and boiler ID#/common stack ID#

Unit Short Name/Common Stack Description	Unit 2	Boiler/Common Stack ID#	2
--	--------	-------------------------	---

STEP 3
Mark the appropriate box and fill in if necessary

- Included is a copy of the monitoring plan)))))))
- No monitoring plan included

No. of pages	8
--------------	---

STEP 4
Provide the requested information for the monitoring systems and for the test data that are being submitted

Use page 2 to provide information for additional units/common stacks at this source or for units/common stacks with more than 10 systems

MONITORING SYSTEMS			TEST DATA		
System ID#	Parameter Monitored	Primary/Backup	Testing Date(s) (mm/dd/yy-mm/dd/yy)	Number of Tests (Total)	Number of Failed Tests
NOX	Nox	P	04/24/18 - 05/12/18	4	0
NOX	O2	P	04/24/18 - 05/12/18	4	0

STEP 5
Complete the boxes

Included are test results for systems listed in Step 4 Table(s))))))))

No. of pages	10
--------------	----

Included is DAHS verification test information)))))))

No. of pages	14
--------------	----

STEP 6
Read the certification, enter the name of the designated representative, and sign and date

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	Ben STANLEY DGL OPERATIONS, LLC		
Signature		Date	6/22/2018



ECMPS Client Tool

Version 1.0 2018 Q2

Monitoring Plan Printout Report

June 22, 2018 04:38 PM

Facility Name: Valley Energy Center

Facility Details

Facility ID (ORISPL): 56940
 Monitoring Plan Location IDs: 2
 State: NY
 County: Orange County
 Latitude: 41.4130
 Longitude: -74.4350

Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
2	Q - Quarterly	2017 QTR 3	

Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Cross Area Exit	Cross Area Flow	Material Code	Shape Code	Begin Date	End Date
2		464	275	284		OTHER	ROUND	08/18/2017	

Unit Operation Information

Unit Identifier	Non-Load Based Ind	Commence Commercial Operation Date	Commence Operation Date	Boiler/Turbine Type			Max Heat Input		
				Code	Begin Date	End Date	Value (mmBtu)	Begin Date	End Date
2	0	01/24/2018	01/18/2018	CC	01/01/2018		2734.0	01/18/2018	

Unit Type Codes: CC - Combined cycle

Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
2	ARP	P2	01/24/2018	07/23/2018
	CSNOX	A	01/24/2018	07/23/2018
	CSOSG2	A	01/24/2018	07/23/2018
	CSSO2G1	A	01/24/2018	07/23/2018
	RGGI	A	01/24/2018	07/23/2018

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:38 PM

Unit Fuel

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
2	DSL	S				01/18/2018	
	NNG	P				01/18/2018	

Fuel Type Codes: NNG - Natural Gas
DSL - Diesel Oil

Fuel Indicator Codes: S - Secondary
P - Primary

Unit Controls

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
2	NOX	SCR	Y				

Control Equipment Descriptions: SCR - Selective Catalytic Reduction

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:38 PM

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
2	CO2	AD	SPTS		08/18/2017 00	
	HI	AD	SPTS		08/18/2017 00	
	NOX	NOXR			08/18/2017 00	
	NOXR	CEM	SPTS		08/18/2017 00	
	OP	EXP			08/18/2017 00	
	SO2	AD	SPTS		08/18/2017 00	

Parameter Codes:

- SO2 - SO2 Hourly Mass Rate (lb/hr)
- OP - Opacity
- NOXR - NOx Emission Rate (lb/mmBtu)
- NOX - NOx Hourly Mass Rate (lb/hr)
- HI - Heat Input Rate (mmBtu/hr)
- CO2 - CO2 Hourly Mass Rate (ton/hr)

Methodology Codes:

- NOXR - NOx Mass Calculated from NOx Emission Rate
- EXP - Exempt
- CEM - Continuous Emission Monitor
- AD - Appendix D

Substitute Data Codes:

- SPTS - Standard Part 75 for Missing Data

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:38 PM

Monitoring System / Analytical Components

Unit/Stack /Pipe Identifier	System					Component									
	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	BAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour	Hg Converter Indicator
2	GAS	GAS	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIES	CEMLINK6		08/18/2017 00		
						GAB	GFFM	ORF		FLUIDIC TECHNOLOGIES	FAB3110	FAB3110-1B	08/18/2017 00		
						GAS	GFFM	ORF		GTE	3044SS PADDLE	3033515	08/18/2017 00		
	NOX	NOX	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIES	CEMLINK6		08/18/2017 00		
						NOX	NOX	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						O2D	O2	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						PRB	PRB	EXT		UNIVERSAL	270SF	TBD	08/18/2017 00		
	OIL	OILM	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIES	CEMLINK6		08/18/2017 00		
OIL						OFFM	TUR		FTI	FT-40C4U3-LEA-3	160405M51315	08/18/2017 00			

System Types Descriptions:

GAS - Gas Fuel Flow
 NOX - NOx Emission Rate
 OILM - Mass of Oil Fuel Flow

System Designations Descriptions:

P - Primary

Sample Acquisition Method (SAM):

TUR - Turbine
 ORF - Orifice
 EXT - Dry Extractive

Component Types Descriptions:

DAHS - Data Acquisition and Handling System
 GFFM - Gas Fuel Flowmeter
 NOX - NOx Concentration
 O2 - O2 Concentration
 PRB - Probe
 OFFM - Oil Fuel Flowmeter

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:38 PM

Monitoring System Fuel Flow

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
2	GAS	NNG	28000.0	HSCF	URV	08/18/2017 00	
	OIL	DSL	120000.0	LBHR	URV	08/18/2017 00	

System Fuel Codes Descriptions: NNG - Natural Gas
DSL - Diesel Oil

Units of Measure Descriptions: LBHR - Pounds / Hour
HSCF - Hundred Standard Cubic Feet / Hour

Source Codes Descriptions: URV - Upper Range Value

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dual Range Indicator	Begin Date/Hour	End Date/Hour
2	NOX	NOX	Auto Ranging	Y	08/18/2017 00	
	O2	O2D	High Range		08/18/2017 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Emissions Formulas

Facility Name: Valley Energy Center

Monitoring Plan Printout Report

Facility ID (ORISPL): 56940

June 22, 2018 04:38 PM

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
2	NOXR	100	F-5	$NOx_lb/mmBtu = S\#(NOX-NOX) * (1.194 * 10^{-7}) * F\#(107) * (20.9 / (20.9 - S\#(O2D-NOX)))$	08/18/2017 00	
	HI	101	F-20	$HI_gas = (F\#(112) * GCV_gas) / 10^{**}6$	08/18/2017 00	
	SO2	102	D-5	$M_SO2_gas = F\#(111) * F\#(101)$	08/18/2017 00	
	CO2	103	G-4	$W_CO2_gas = (1040 * F\#(101) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	HI	104	D-8	$HI_oil = S\#(OIL-OIL)_oilrate * (GCV_oil) / 10^{**}6$	08/18/2017 00	
	SO2	105	D-2	$M_SO2_oil = 2.0 * S\#(OIL-OIL)_oilrate * (\%S_oil) / 100$	08/18/2017 00	
	CO2	106	G-4	$W_CO2_oil = (1420 * F\#(104) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	FD	107	F-8	$Fd = (X_oil * 9190) + (X_gas * 8710)$	08/18/2017 00	
	HI	108	D-15A	$HI_total = F\#(101) * T_gas + F\#(104) * T_oil) / T_unit$	08/18/2017 00	
	CO2	109	G-4A	$CO2_total = (F\#(103) * T_gas + F\#(106) * T_oil) / T_unit$	08/18/2017 00	
	SO2	110	D-12	$SO2_total = (F\#(102) * T_gas + F\#(105) * T_oil) / T_unit$	08/18/2017 00	
	SO2R	111	D-1H	$ER_SO2_gas = (2.0 / 7000) * (10^{**}6) * S_NNG/GCV_NNG$	08/18/2017 00	
	FGAS	112	N-GAS	$N_gas = S\#(GAS-GAS) + S\#(GAB-GAS)$	08/18/2017 00	
	NOX	113	F-24A	$NOx\ mass = F\#(NOX)*F\#(HT)*T_unit$	08/18/2017 00	

Parameter Codes Descriptions:
 NOXR - NOx Emission Rate (lb/mmBtu)
 HI - Heat Input Rate (mmBtu/hr)
 SO2 - SO2 Hourly Mass Rate (lb/hr)
 CO2 - CO2 Hourly Mass Rate (ton/hr)
 FD - F-Factor Dry-basis
 SO2R - SO2 Hourly Emission Rate (lb/mmBtu)
 FGAS - Gas Hourly Flow Rate (hscf)
 NOX - NOx Hourly Mass Rate (lb/hr)

Facility Name: Valley Energy Center

Monitoring Plan Printout Report

Facility ID (ORISPL): 56940

June 22, 2018 04:38 PM

Formula Codes Descriptions:

- N-GAS - FGAS (net gas flow rate)
- G-4A - CO2 (from CO2 rate for multiple fuels)
- G-4 - CO2 (from HI, Fc)
- F-8 - FD/FC/FW (from multiple fuels)
- F-5 - NOXR/SO2R (from NOX or SO2 dry, O2 dry, Fd)
- F-24A - NOX (from NOX rate, HI)
- F-20 - HI (same as D-6)
- D-8 - HI (from oil flow rate, GCV)
- D-5 - SO2 (from gas SO2 emission rate, HI)
- D-2 - SO2 (from OILM, oil sulfur content)
- D-1H - SO2R (from gas sulfur content, GCV)
- D-15A - HI (from HI rate for multiple fuels)
- D-12 - SO2 (from SO2 rate for multiple fuels)

Span Values

Unit/Stack /Pipe Identifier	Comp Type	Scale	Method	MPC/ MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)	Flow Span Value (SCFH)	Begin Date/Hour	End Date/Hour
2	NOX	H	ME	100.0	6.0	100.000	100.000	PPM	9.5				08/18/2017 00	
	NOX	L	PL		6.0	10.000	10.000	PPM	9.5				08/18/2017 00	
	O2	H				25.000	26.000	PCT					08/18/2017 00	

Component Types Descriptions:

- NOX - NOx Concentration
- O2 - O2 Concentration

Span Method Codes Descriptions:

- PL - Permit Limit for NOX MEC
- ME - Manufacturer's Estimate for NOX MPC

Units of Measure Descriptions:

- PPM - Parts per Million
- PCT - Percentage

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
2	380	MW	230	50	High	Mid	Yes	12/31/2017	12/31/2017 00	

Units of Measure Descriptions: MW - Megawatt

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

June 22, 2018 04:38 PM

Monitoring Defaults

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
2	NORX	1.1440	LBMMBTU	MD	NFS	A	DEF	08/18/2017 00	
	O2X	19.0000	PCT	DC	NFS	A	DEF	08/18/2017 00	

- Parameter Codes Descriptions:**
 - O2X - Maximum O2 Concentration (pct)
 - NORX - Maximum NOx Emission Rate (lb/mmBtu)
- Units of Measure Descriptions:**
 - PCT - Percentage
 - LBMMBTU - Pounds / mmBtu
- Purpose Codes Descriptions:**
 - MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default
 - DC - Diluent Cap
- Fuel Type Codes Descriptions:**
 - NFS - Non-Fuel Specific
- Operating Conditions Descriptions:**
 - A - Any Hour
- Source Codes Descriptions:**
 - DEF - Default Value from Part 75



Facility Name: Valley Energy Center

Facility Details

Facility ID (ORISPL): 56940
State: NY
County: Orange County

Unit/Stack/Pipe ID: 2

7-Day Calibration

Component ID: NOX **Component Type:** NOX **Test Completion:** 05/02/2018 12:12
Test Number: 2_NoxL_7Day **Reason for Test:** INITIAL **Reported Test Results:** PASSED
Span Scale Level: Low **Span Value:** 10.000 **EPA Calculated Result:** PASSED
Evaluation Status: No Errors **Submission Status:** Data loaded on EPA Host System
Submission Date/Time: 06/22/2018 4:26:00 PM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
04/24/2018 09	ZERO	0.000	0	0.000	0.00		0.00	
04/24/2018 09	HIGH	8.680	86.8	8.700	0.20		0.20	
04/25/2018 11	ZERO	0.000	0	0.000	0.00		0.00	
04/25/2018 11	HIGH	8.680	86.8	8.600	0.80		0.80	
04/28/2018 15	ZERO	0.000	0	0.000	0.00		0.00	
04/28/2018 15	HIGH	8.680	86.8	8.600	0.80		0.80	
04/29/2018 14	ZERO	0.000	0	0.000	0.00		0.00	
04/29/2018 15	HIGH	8.680	86.8	8.500	1.80		1.80	
04/30/2018 01	ZERO	0.000	0	0.000	0.00		0.00	
04/30/2018 01	HIGH	8.680	86.8	8.500	1.80		1.80	
05/01/2018 18	ZERO	0.000	0	0.000	0.00		0.00	
05/01/2018 18	HIGH	8.680	86.8	8.500	1.80		1.80	
05/02/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/02/2018 12	HIGH	8.680	86.8	8.500	1.80		1.80	

Additional Information:
No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:40 PM

Unit/Stack/Pipe ID: 2

7-Day Calibration

Component ID: NOX	Component Type: NOX	Test Completion: 05/02/2018 12:15
Test Number: 2_NoXH_7Day	Reason for Test: INITIAL	Reported Test Results: PASSED
Span Scale Level: High	Span Value: 100.000	EPA Calculated Result: PASSED
Evaluation Status: No Errors	Submission Status: Data loaded on EPA Host System	Submission Date/Time: 06/22/2018 4:26:00 PM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
04/24/2018 09	ZERO	0.000	0	0.100	0.10		0.10	
04/24/2018 09	HIGH	88.750	88.8	89.100	0.40		0.40	
04/25/2018 11	ZERO	0.000	0	0.000	0.00		0.00	
04/25/2018 11	HIGH	88.750	88.8	89.400	0.70		0.70	
04/28/2018 15	ZERO	0.000	0	0.000	0.00		0.00	
04/28/2018 15	HIGH	88.750	88.8	88.500	0.30		0.30	
04/29/2018 14	ZERO	0.000	0	0.000	0.00		0.00	
04/29/2018 15	HIGH	88.750	88.8	88.200	0.60		0.60	
04/30/2018 01	ZERO	0.000	0	0.000	0.00		0.00	
04/30/2018 01	HIGH	88.750	88.8	88.100	0.70		0.70	
05/01/2018 18	ZERO	0.000	0	0.000	0.00		0.00	
05/01/2018 18	HIGH	88.750	88.8	88.100	0.70		0.70	
05/02/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/02/2018 12	HIGH	88.750	88.8	87.900	0.90		0.90	

Additional Information:

No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

Facility Name: Valley Energy Center

QA/Cert Test Detail Report

Facility ID (ORISPL): 56940

June 22, 2018 04:40 PM

Unit/Stack/Pipe ID: 2

7-Day Calibration

Component ID: O2D	Component Type: O2	Test Completion: 05/03/2018 14:17
Test Number: 2_O2_7Day	Reason for Test: INITIAL	Reported Test Results: PASSED
Span Scale Level: High	Span Value: 25.000	EPA Calculated Result: PASSED
Evaluation Status: No Errors	Submission Status: Data loaded on EPA Host System	Submission Date/Time: 06/22/2018 4:26:00 PM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
04/25/2018 11	ZERO	0.000	0	0.000	0.00		0.00	
04/25/2018 11	HIGH	20.890	83.6	20.900	0.00		0.00	
04/28/2018 15	ZERO	0.000	0	0.000	0.00		0.00	
04/28/2018 15	HIGH	20.890	83.6	20.900	0.00		0.00	
04/29/2018 14	ZERO	0.000	0	0.000	0.00		0.00	
04/29/2018 15	HIGH	20.890	83.6	20.900	0.00		0.00	
04/30/2018 01	ZERO	0.000	0	0.000	0.00		0.00	
04/30/2018 01	HIGH	20.890	83.6	20.900	0.00		0.00	
05/01/2018 18	ZERO	0.000	0	0.000	0.00		0.00	
05/01/2018 18	HIGH	20.890	83.6	20.900	0.00		0.00	
05/02/2018 12	ZERO	0.000	0	0.000	0.00		0.00	
05/02/2018 12	HIGH	20.890	83.6	20.900	0.00		0.00	
05/03/2018 14	ZERO	0.000	0	0.000	0.00		0.00	
05/03/2018 14	HIGH	20.890	83.6	20.900	0.00		0.00	

Additional Information:

No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

Facility Name: Valley Energy Center**QA/Cert Test Detail Report**

Facility ID (ORISPL): 56940

June 22, 2018 04:40 PM

Unit/Stack/Pipe ID: 2

Cycle Time Test

Component ID: NOX **Component Type:** NOX **Test Completion:** 05/08/2018 15:17
Test Number: 2_NoXH_Cycle_Cert **Reason for Test:** INITIAL **Reported Test Results:** PASSED
Span Scale Level: High **Span Value:** 100.000 **EPA Calculated Result:** PASSED
Total Cycle Time: 3 **Calculated Total Cycle Time:** 3

Evaluation Status: No Errors **Submission Status:** Data loaded on EPA Host System
Submission Date/Time: 06/22/2018 4:26:00 PM

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2018/05/08	15:05	15:08	ZERO	0.000	6.200	0.000	3	3
2018/05/08	15:14	15:17	HIGH	88.750	6.300	87.100	3	3

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: 2

Cycle Time Test

Component ID: NOX **Component Type:** NOX **Test Completion:** 05/08/2018 14:18
Test Number: 2_NoXL_Cycle_Cert **Reason for Test:** INITIAL **Reported Test Results:** PASSED
Span Scale Level: Low **Span Value:** 10.000 **EPA Calculated Result:** PASSED
Total Cycle Time: 3 **Calculated Total Cycle Time:** 3

Evaluation Status: No Errors **Submission Status:** Data loaded on EPA Host System
Submission Date/Time: 06/22/2018 4:26:00 PM

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2018/05/08	14:04	14:06	ZERO	0.000	6.900	0.000	2	2
2018/05/08	14:15	14:18	HIGH	8.680	7.000	8.200	3	3

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Facility Name: Valley Energy Center**QA/Cert Test Detail Report**

Facility ID (ORISPL): 56940

June 22, 2018 04:40 PM

Unit/Stack/Pipe ID: 2

Cycle Time Test

Component ID: O2D **Component Type:** O2 **Test Completion:** 05/08/2018 15:40
Test Number: 2_O2_CYCLE_CERT **Reason for Test:** INITIAL **Reported Test Results:** PASSED
Span Scale Level: High **Span Value:** 25.000 **EPA Calculated Result:** PASSED
Total Cycle Time: 2 **Calculated Total Cycle Time:** 2

Evaluation Status: No Errors **Submission Status:** Data loaded on EPA Host System
Submission Date/Time: 06/22/2018 4:26:00 PM

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2018/05/08	15:29	15:31	ZERO	0.000	13.700	0.000	2	2
2018/05/08	15:39	15:40	HIGH	20.890	12.900	20.800	1	1

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: 2

Linearity Check

Component ID: NOX **Component Type:** NOX **Test Completion:** 05/11/2018 09:20
Test Number: 2_NOX_L_CERTLIN **Reason for Test:** INITIAL **Reported Test Results:** PASSED
Span Scale Level: Low **Span Value:** 10.000 **EPA Calculated Result:** PASSED

Evaluation Status: No Errors **Submission Status:** Data loaded on EPA Host System
Submission Date/Time: 06/22/2018 4:26:00 PM

Grace period Tested?

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,CO2,NO,BALN	B52017	CC280797	12/06/2020
Mid	CO,NO,BALN	G12017	EB0101725	10/03/2020
Low	CO,NO,BALN	G12017	EB0072315	07/04/2020

Summary Statistics:

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:40 PM

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	8.680	8.680	5.090	5.090	2.420	2.420
Mass CEM Value	8.500	8.500	5.300	5.300	2.333	2.333
Alt. Perf. Indicator						
Results	2.1	2.1	4.1	4.1	3.6	3.6

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
05/11/2018 09:16	MID	5.300	5.090	50.9%
05/11/2018 09:04	MID	5.300	5.090	50.9%
05/11/2018 08:52	MID	5.300	5.090	50.9%
05/11/2018 09:00	LOW	2.300	2.420	24.2%
05/11/2018 08:48	LOW	2.400	2.420	24.2%
05/11/2018 09:12	LOW	2.300	2.420	24.2%
05/11/2018 09:20	HIGH	8.500	8.680	86.8%
05/11/2018 08:56	HIGH	8.500	8.680	86.8%
05/11/2018 09:08	HIGH	8.500	8.680	86.8%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A & 3.2)

Unit/Stack/Pipe ID: 2

Linearity Check

Component ID: NOX	Component Type: NOX	Test Completion: 05/10/2018 17:20
Test Number: 2_NOXH_CERTLIN	Reason for Test: INITIAL	Reported Test Results: PASSED
Span Scale Level: High	Span Value: 100.000	EPA Calculated Result: PASSED
Evaluation Status: No Errors		Submission Status: Data loaded on EPA Host System
Grace period Tested?		Submission Date/Time: 06/22/2018 4:26:00 PM

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
Low	CO,NO,BALN	G12018	EB0073000	03/19/2021

Facility Name: Valley Energy Center

QA/Cert Test Detail Report

Facility ID (ORISPL): 56940

June 22, 2018 04:40 PM

High	CO2,NO,NOX,BALN	B52017	CC477949	09/25/2025
Mid	NO,NOX,BALN	B22017	CC503502	11/01/2025

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	88.750	88.750	50.890	50.890	24.600	24.600
Mass CEM Value	87.100	87.100	51.967	51.967	25.433	25.433
Alt. Perf. Indicator						
Results	1.9	1.9	2.1	2.1	3.4	3.4

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
05/10/2018 16:52	MID	52.000	50.890	50.9%
05/10/2018 17:04	MID	51.900	50.890	50.9%
05/10/2018 17:17	MID	52.000	50.890	50.9%
05/10/2018 17:13	LOW	25.400	24.600	24.6%
05/10/2018 17:00	LOW	25.500	24.600	24.6%
05/10/2018 16:48	LOW	25.400	24.600	24.6%
05/10/2018 16:56	HIGH	87.200	88.750	88.8%
05/10/2018 17:20	HIGH	86.900	88.750	88.8%
05/10/2018 17:08	HIGH	87.200	88.750	88.8%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: 2

Linearity Check

Component ID:	O2D	Component Type:	O2	Test Completion:	05/11/2018 10:56
Test Number:	2_O2_CERTLIN	Reason for Test:	INITIAL	Reported Test Results:	PASSED
Span Scale Level:	High	Span Value:	25.000	EPA Calculated Result:	PASSED
Evaluation Status:	No Errors			Submission Status:	Data loaded on EPA Host System
Grace period Tested?				Submission Date/Time:	06/22/2018 4:26:00 PM

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:40 PM

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,CO2,O2,BALN	B52017	EB0095371	09/19/2025
Low	CO2,O2,BALN	L12013	EB0049201	08/13/2021
Mid	O2,BALN	G12018	EB0060674	04/01/2026

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	20.890	20.890	13.820	13.820	6.360	6.360
Mass CEM Value	20.900	20.900	13.800	13.800	6.200	6.200
Alt. Perf. Indicator						
Results	0.0	0.0	0.1	0.1	2.5	2.5

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
05/11/2018 10:44	HIGH	20.900	20.890	83.6%
05/11/2018 10:32	HIGH	20.900	20.890	83.6%
05/11/2018 10:56	HIGH	20.900	20.890	83.6%
05/11/2018 10:27	MID	13.800	13.820	55.3%
05/11/2018 10:40	MID	13.800	13.820	55.3%
05/11/2018 10:52	MID	13.800	13.820	55.3%
05/11/2018 10:23	LOW	6.200	6.360	25.4%
05/11/2018 10:48	LOW	6.200	6.360	25.4%
05/11/2018 10:36	LOW	6.200	6.360	25.4%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A & 3.2)

Unit/Stack/Pipe ID: 2

Relative Accuracy Test

Facility Name: Valley Energy Center

QA/Cert Test Detail Report

June 22, 2018 04:40 PM

Facility ID (ORISPL): 56940

System ID: NOX **System Parameter:** NOX
Test Number: 2_RATA_Cert **Reason for Test:** QA
of Op. Levels: 1 **Grace Period Test?**

Test Completion: 05/12/2018 11:14
Reported Test Results: PASSED
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Data loaded on EPA Host System
Submission Date: 06/22/2018 4:26:00 PM

Reported BAF: 1.052
EPA Calculated BAF: 1.052
RATA Frequency: 4QTRS

Air Emissions Testing Data

QI Name: Stockwell, Michael D
Exam Date: 01/06/2017
Provider Name: Source Evaluation Society
Provider Email: qstiprogram@gmail.com

AETB Name: Air Hygiene International Inc.
AETB Phone Number: 888-461-8778
AETB Email: info@airhygiene.com

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,NO,NOX,BALN	G12016	EB0026154	09/30/2019
Mid	CO,NO,NOX,BALN	G12017	EB0098858	09/18/2020
Low	CO,NO,NOX,BALN	G12018	EB0027723	01/25/2021
High	CO2,O2,BALN	G12017	EB0032327	01/07/2025
Mid	CO2,O2,BALN	G12018	EB0081248	03/12/2026
Low	ZERO			

Operating Level: High
Reference Method Used: 7E,3A: NOX RM 7E and CO2/O2 RM 3A

Summary Statistics:

	Reported	Recalculated		Reported	Recalculated
Mean of Monitoring System	0.02133	0.02133	Relative Accuracy	7.01	7.01
Mean of Reference Method Values	0.02244	0.02244	Bias Adjustment Factor	1.052	1.052
Mean of Difference	0.00111	0.00111	APS Indicator		
Standard Deviation of Difference	0.00060	0.00060	T-Value	2.306	2.306
Confidence Coefficient	0.00046	0.00046	Gross Unit Load or Velocity	188	188

Facility Name: Valley Energy Center

Facility ID (ORISPL): 56940

QA/Cert Test Detail Report

June 22, 2018 04:40 PM

Run Data:

Run	Start Date	End Date	Run Status	Monitoring System Value	Reference Method Value	Gross Load or Velocity
1	05/11/2018 12:06	05/11/2018 12:27	RUNUSED	0.02100	0.02300	184
2	05/11/2018 12:41	05/11/2018 13:02	RUNUSED	0.02200	0.02200	185
3	05/11/2018 13:15	05/11/2018 13:36	RUNUSED	0.02200	0.02300	185
4	05/11/2018 13:48	05/11/2018 14:09	NOTUSED	0.02200	0.02300	185
5	05/11/2018 14:23	05/11/2018 14:44	RUNUSED	0.02100	0.02200	185
6	05/11/2018 15:00	05/11/2018 15:21	RUNUSED	0.02200	0.02300	185
7	05/12/2018 08:08	05/12/2018 08:29	RUNUSED	0.02100	0.02200	192
8	05/12/2018 08:59	05/12/2018 09:20	RUNUSED	0.02100	0.02300	193
9	05/12/2018 09:32	05/12/2018 09:53	RUNUSED	0.02100	0.02200	192
10	05/12/2018 10:53	05/12/2018 11:14	RUNUSED	0.02100	0.02200	192

Additional Information:

No comment.

*Performance Spec: RA <= 10% or Mean Difference <= +/- 2.0fps:
Reduced Frequency Spec: RA <= 7.5% or Mean Difference +/- 1.5 fps (Appendix A &3.3.4)

PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT OF THE RETURN ADDRESS. FOLD AT DOTTED LINE

CERTIFIED MAIL

PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT OF THE RETURN ADDRESS. FOLD AT DOTTED LINE

CERTIFIED MAIL



7017 0190 0000 0941 4441
7017 0190 0000 0941 4441

7017 0190 0000 0941 4465
7017 0190 0000 0941 4465

7017 0190 0000 0941 4472
7017 0190 0000 0941 4472

Regional Air Pollution Control
Engineer
NYSDEC - Region 3
21 South Putt Corners Road
New Paltz, NY 12561

Division of Air Resources
NYSDEC - Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

USEPA Region II
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

PS Form 3800

City, State, Zip: _____

Street and Apt: _____

Sent To: _____

Total Postage: \$ _____

Postage: \$ _____

Extra Services & Fees (check box, add fee as appropriate):

Return Receipt (hardcopy) \$ _____

Return Receipt (electronic) \$ _____

Certified Mail Restricted Delivery \$ _____

Adult Signature Required \$ _____

Adult Signature Restricted Delivery \$ _____

Certified Mail Fee: \$ _____

Postmark Here _____

PS Form 3800

City, State, Zip: _____

Street and Apt: _____

Sent To: _____

Total Postage: \$ _____

Postage: \$ _____

Extra Services & Fees (check box, add fee as appropriate):

Return Receipt (hardcopy) \$ _____

Return Receipt (electronic) \$ _____

Certified Mail Restricted Delivery \$ _____

Adult Signature Required \$ _____

Adult Signature Restricted Delivery \$ _____

Certified Mail Fee: \$ _____

Postmark Here _____

PS Form 3800

City, State, Zip: _____

Street and Apt: _____

Sent To: _____

Total Postage: \$ _____

Postage: \$ _____

Extra Services & Fees (check box, add fee as appropriate):

Return Receipt (hardcopy) \$ _____

Return Receipt (electronic) \$ _____

Certified Mail Restricted Delivery \$ _____

Adult Signature Required \$ _____

Adult Signature Restricted Delivery \$ _____

Certified Mail Fee: \$ _____

Postmark Here _____

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT


Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT OF THE RETURN ADDRESS. FOLD AT DOTTED LINE

CERTIFIED MAIL



7017 0190 0000 0941 4441
7017 0190 0000 0941 4441

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

OFFICIAL USE

For delivery information, visit our website at www.usps.com

CERTIFIED MAIL® RECEIPT

Domestic Mail Only

PS Form 3800

City, State, Zip: _____

Street and Apt: _____

Sent To: _____

Total Postage: \$ _____

Postage: \$ _____

Extra Services & Fees (check box, add fee as appropriate):

Return Receipt (hardcopy) \$ _____

Return Receipt (electronic) \$ _____

Certified Mail Restricted Delivery \$ _____

Adult Signature Required \$ _____


Adult Signature Restricted Delivery \$ _____

Certified Mail Fee: \$ _____

Postmark Here _____

USEPA - Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code 6204J
Washington, DC 20005

2. Article Number (Transfer from service label)
7017 0190 0000 0941 4465



9590 9402 2759 6351 7202 23

Division of Air Resources
NYSDEC - Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

SENDER: COMPLETE THIS SECTION

3. Service Type
- Priority Mail Express®
 - Registered Mail™
 - Registered Mail Restricted Delivery
 - Return Receipt for Merchandise
 - Certified Mail®
 - Certified Mail Restricted Delivery
 - Collect on Delivery
 - Collect on Delivery Restricted Delivery
 - Signature Confirmation™
 - Restricted Delivery
- all Restricted Delivery

D. Is delivery address different from item 1? Yes No
If YES, enter delivery address below:

A. Signature


X Agent Addressee

B. Received by (Printed Name) _____

C. Date of Delivery _____

COMPLETE THIS SECTION ON DELIVERY

2. Article Number (Transfer from service label)
7017 0190 0000 0941 4472



9590 9402 2759 6351 7202 30

USPA Region II
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

SENDER: COMPLETE THIS SECTION

3. Service Type
- Priority Mail Express®
 - Registered Mail™
 - Registered Mail Restricted Delivery
 - Return Receipt for Merchandise
 - Certified Mail®
 - Certified Mail Restricted Delivery
 - Collect on Delivery
 - Collect on Delivery Restricted Delivery
 - Signature Confirmation™
 - Restricted Delivery
- all Restricted Delivery

D. Is delivery address different from item 1? Yes No
If YES, enter delivery address below:

A. Signature _____

X Agent Addressee

B. Received by (Printed Name) _____

C. Date of Delivery _____

COMPLETE THIS SECTION ON DELIVERY

2. Article Number (Transfer from service label)
7017 0190 0000 0941 4489



9590 9402 2759 6351 7202 47

USPA - Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code 6204
Washington, DC 20005

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

SENDER: COMPLETE THIS SECTION

3. Service Type
- Priority Mail Express®
 - Registered Mail™
 - Registered Mail Restricted Delivery
 - Return Receipt for Merchandise
 - Certified Mail®
 - Certified Mail Restricted Delivery
 - Collect on Delivery
 - Collect on Delivery Restricted Delivery
 - Signature Confirmation™
 - Restricted Delivery
- all Restricted Delivery

D. Is delivery address different from item 1? Yes No
If YES, enter delivery address below:

A. Signature _____

X Agent Addressee

B. Received by (Printed Name) _____

C. Date of Delivery _____


COMPLETE THIS SECTION ON DELIVERY

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

Regional Air Pollution Control
 Engineer
 NYSDEC - Region 3
 21 South Putt Corners Road
 New Paltz, NY 12561

9590 9402 2759 6351 7202 16



Article Number (Transfer from service label)

7017 0190 0000 0941 4441

COMPLETE THIS SECTION ON DELIVERY

A. Signature Agent Addressee

B. Received by (Printed Name) _____

C. Date of Delivery _____

D. Is delivery address different from item 1? Yes No
If YES, enter delivery address below:

3. Service Type

Adult Signature Restricted Delivery

Adult Signature Restricted Delivery

Certified Mail®

Certified Mail Restricted Delivery

Return Receipt for Merchandise

Signature Confirmation

Restricted Delivery



CPV Valley Energy Center
3330 Route 6
Middletown, NY 10940

November 13th, 2018

Regional Air Pollution Control Engineer
NYSDEC – Region 3
21 South Putt Corners Road
New Paltz, NY 12561
FedEx Mail Tracking # 7737 0990 1539, #7737 0990
1594, #7737 0990 1469

Division of Air Resources
NYSDEC – Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258
FedEx Mail Tracking # 7737 1012 0238

USEPA Region II
Air Compliance Branch
290 Broadway
New York, NY 10007-1866
FedEx Mail Tracking # 7737 1007 4062

Re: CPV Valley Energy Center
NYSDEC State Facility Air Permit ID: 3-3356-00136/00001
Emissions Compliance Test Report

Dear Sir / Madam:

CPV Valley Energy Center is submitting the 2018 Emissions Compliance Test Report for Natural Gas operation in accordance with the State Facility Air Permit requirements. The Emissions Compliance Testing was performed at The Facility on Units No.1 and No.2 September 25-27, 2018 and October 10-11, 2018.

During the September testing, it was believed there was contamination in the first run of testing (unrelated to the unit operation) and as a result the Unit No.2 (Basel Load, 100% without duct burner) requirement for Particulate Matter (PM) test result was erroneously high. Unit No.2 retested and passed Base Load (100% without duct burner) for PM October 10-11, 2018.

Enclosed is the Emission Compliance Test report for Units No.1 and No.2 performed during September and October 2018.

Attachment A: Emissions Compliance Test Report Unit Nos. 1 & 2

If there are any questions regarding this submittal, please contact Donald Atwood at (781) 848-2202.

Sincerely,

A handwritten signature in blue ink, appearing to read 'DA', written over a blue horizontal line.

Donald Atwood
Competitive Power Ventures, Inc.
Asset Manager Representative

CC: Ben Stanley

Attachment A
Emissions Compliance Test Report
Unit Nos. 1 & 2



AIR HYGIENE, INC.

Testing Solutions for a Better World

EMISSION COMPLIANCE TEST
FOR THE
SIEMENS, SCC6-5000F,
UNIT #CTG-1 AND CTG-2
PREPARED FOR
CPV VALLEY, LLC
AT THE
CPV VALLEY ENERGY CENTER
MIDDLETOWN, NEW YORK

SEPTEMBER 25-27 AND OCTOBER 10-11, 2018



Corporate Headquarters

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012



AIR HYGIENE, INC.


(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices


Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

**EMISSION COMPLIANCE TEST
FOR THE
SIEMENS, SCC6-5000F,
UNIT #CTG-1 AND CTG-2
PREPARED FOR
CPV VALLEY, LLC
AT THE
CPV VALLEY ENERGY CENTER
MIDDLETOWN, NEW YORK
SEPTEMBER 25-27 AND OCTOBER 10-11, 2018**


Prepared and Reviewed by:



Logan Tsotsoros
AHU Support Staff



Thomas K. Graham, PE, QSTI
Director of Education

I, 

Patrick K. McGovern, Jr., QSTI
Sr. Regional Manager-Shreveport, LA
certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

Table of Contents

1.0	INTRODUCTION	1
1.1	TEST PURPOSE AND OBJECTIVES	1
1.2	SUMMARY OF TEST PROGRAM	1
1.2.1	Participating Organizations	1
1.2.2	Industry	1
1.2.3	Air Permit Requirements	1
1.2.4	Plant Location	1
1.2.5	Equipment Tested	2
1.2.6	Emission Points	2
1.2.7	Emission Parameters Measured	2
1.2.8	Dates of Emission Test	2
1.2.9	Federal Certifications	2
1.3	KEY PERSONNEL	2
2.0	SUMMARY OF TEST RESULTS	2
3.0	SOURCE OPERATION	5
3.1	PROCESS DESCRIPTION	5
3.2	SAMPLING LOCATION	5
4.0	SAMPLING AND ANALYTICAL PROCEDURES	5
4.1	TEST METHODS	5
4.2	INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS	6

APPENDICES

Appendix A	Test Results and Calculations
Appendix B	Emission Data Records
Appendix C	Calibration Gas Certifications
Appendix D	Quality Assurance and Quality Control Data
Appendix E	Fuel Analysis Records
Appendix F	Stratification Test Data
Appendix G	September 25-27 Failed PM Test Data

**Emissions Compliance Test
Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2
CPV Valley, LLC
CPV Valley Energy Center
Middletown, New York
September 25-27 and October 10-11, 2018**

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Emissions Compliance Test for nitrogen oxides (NO_x), carbon monoxide (CO), total hydrocarbons/volatile organic compounds (THC/VOC), sulfur dioxide (SO₂) [from fuel analysis], opacity / visual emissions (VE), ammonia (NH₃), particulate matter (PM), sulfuric acid mist (H₂SO₄), flow, moisture (H₂O), carbon dioxide (CO₂), and oxygen (O₂) from the exhaust of the Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2 for CPV Valley, LLC at the CPV Valley Energy Center in Middletown, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on September 25-27 and October 10-11, 2018.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to conduct an initial compliance emission test to document levels of selected pollutants at two test loads (base load without duct burners firing and base load with duct burners firing). The information will be used to confirm compliance with the operating permit issued by the New York State Department of Environmental Conservation (NYDEC). The specific objective was to determine the emission concentration of NO_x, CO, THC/VOC, SO₂ [from fuel], VE, NH₃, PM, H₂SO₄, flow, H₂O, CO₂, and O₂ from the exhaust of CPV Valley, LLC's Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

- 1.2.1 Participating Organizations
 - New York State Department of Environmental Conservation (NYDEC)
 - CPV Valley, LLC
 - Siemens Energy, Inc.
 - Air Hygiene
- 1.2.2 Industry
 - Electric Utility / Electric Services
- 1.2.3 Air Permit Requirements
 - Air Permit Number: 3-3356-00136/00001
- 1.2.4 Plant Location
 - CPV Valley Energy Center in Middletown, New York
 - GPS Coordinates [Latitude 41.14750, Longitude -80.85333]
 - Physical Address: 3330 U.S. Route 6, Middletown, New York 10940
 - Federal Registry System / Facility Registry Service (FRS) No. – 110043332471
 - Source Classification Code (SCC)
 - 20100201 (CTGs)
 - 10100601 (DBs)

- 1.2.5 Equipment Tested
 - Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2
- 1.2.6 Emission Points
 - Exhaust from the Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2
 - For all gases (NO_x, CO, VOCs, CO₂, and O₂), one sample point in the exhaust duct from the Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2, determined after conducting a stratification test (refer to Appendix F)
 - For all PM testing, 12 sampling points in the exhaust duct from the Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2
 - For all H₂SO₄ testing, one sampling point in the exhaust duct from the Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2
 - For all NH₃ testing, three sampling points in the exhaust duct from the Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2
- 1.2.7 Emission Parameters Measured
 - NO_x
 - CO
 - THC/VOC
 - VE (Opacity)
 - SO₂ [from fuel]
 - NH₃
 - PM
 - H₂SO₄
 - Flow
 - H₂O
 - CO₂
 - O₂
- 1.2.8 Dates of Emission Test
 - September 25-27 and October 10-11, 2018
- 1.2.9 Federal Certifications
 - Stack Testing Accreditation Council AETB Certificate No. 3796.02
 - International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

CPV Valley, LLC:	Ben Stanley (b.stanley@dgc-ops.com)	845-649-8300
Siemens Energy, Inc.:	Jordan Haywood (Jordan.haywood@siemens.com)	407-736-3045
Air Hygiene:	Pat McGovern (pmcgovern@airhygiene.com)	918-307-8865
Air Hygiene:	Michael Stockwell	918-307-8865
Air Hygiene:	Swanson Bierman	918-307-8865
Air Hygiene:	Andrew McMahan	918-307-8865
Air Hygiene:	Mike Plummer	918-307-8865
Air Hygiene:	James Reynolds	918-307-8865
Air Hygiene:	Alex Martinez	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on CPV Valley, LLC's Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2 located at the CPV Valley Energy Center on September 25-27 and October 10-11, 2018 are summarized in the following tables and relate only to the items tested.

**TABLE 2.1
SUMMARY OF SIEMENS, SCC6-5000F, UNIT #CTG-1 RESULTS**

Parameter	Base Load [9/24-25]	100% W/Db Load [9/24-25]	Permit Limits
Turbine Fuel Flow (SCFH)	2,092,202	2,121,629	--
Duct Burner Fuel Flow (lb/min)	0	268	--
Total Fuel Flow (SCFH)	2,092,202	2,500,805	--
Stack Flow (RM19) (SCFH)	51,771,034	52,506,949	--
Stack Moisture (% Method 4)	8.4	11.4	--
Power Output (megawatts)	206.5	210.2	--
NOx (ppmvd)	1.84	2.71	--
NOx (ppm@15%O ₂)	1.48	1.85	2.0
CO (ppmvd)	0.00	0.00	--
CO (ppm@15%O ₂)	0.00	0.00	2.0
VOC as CH ₄ (ppmvd)	0.40	0.07	--
VOC as CH ₄ (ppm@15%O ₂)	0.33	0.05	0.7 ¹ /1.8 ²
SO ₂ from Fuel Sulfur (grains/100scf)	0.039	0.039	--
SO ₂ from Fuel Sulfur (lb/MMBtu)	0.0001	0.0001	0.0022
Total PM (mg)	3.69	3.23	--
Total PM (g/dscf)	4.20E-05	3.69E-05	--
Total PM (gr/dscf)	6.48E-04	5.69E-04	--
Total PM (lb/hr)	4.42	3.96	--
Total PM (lb/MMBtu)	0.0023	0.0017	0.0073
H ₂ SO ₄ (mg)	0.01	0.01	--
H ₂ SO ₄ (g/dscf)	2.42E-07	2.75E-07	--
H ₂ SO ₄ (gr/dscf)	3.74E-06	4.25E-06	--
H ₂ SO ₄ (lb/MMBtu)	0.000013	0.000013	0.0007
NH ₃ (ppmvd)	5.03	4.56	--
NH ₃ (ppm@15%O ₂)	4.03	3.08	5.0
Opacity (%)	0	0	20
CO ₂ (%)	4.16	4.81	--
O ₂ (%)	13.57	12.26	--

Notes: ¹ - Base (no DB); ² - 100% with DB

**TABLE 2.2
SUMMARY OF SIEMENS, SCC6-5000F, UNIT #CTG-2 RESULTS**

Parameter	100% W/Db Load [9/24-25]	Base Load [9/24-25& 10/10-11]	Permit Limits
Turbine Fuel Flow (SCFH)	2,119,806	2,080,101	--
Duct Burner Fuel Flow (lb/min)	271	0	--
Total Fuel Flow (SCFH)	2,502,750	2,080,101	--
Stack Flow (RM19) (SCFH)	50,738,337	50,635,710	--
Stack Moisture (% Method 4)	10.8	9.0	--
Power Output (megawatts)	209.6	205.1	--
NOx (ppmvd)	2.48	2.01	--
NOx (ppm@15%O ₂)	1.64	1.59	2.0
CO (ppmvd)	0.31	0.27	--
CO (ppm@15%O ₂)	0.21	0.21	2.0
THC (ppmvd)	2.04	2.21	--
THC (ppm@15%O ₂)	1.35	1.75	--
CH ₄ (ppmvd)	--	2.00	--
C ₂ H ₆ (ppmvd)	--	0.10	--
VOC as CH ₄ (ppmvd)	2.04	0.32	--
VOC as CH ₄ (ppm@15%O ₂)	1.35	0.26	0.7 ¹ /1.8 ²
SO ₂ from Fuel Sulfur (grains/100scf)	0.039	0.039	--
SO ₂ from Fuel Sulfur (lb/MMBtu)	0.0001	0.0001	0.0022
Total PM (mg)	15.43	2.47	--
Total PM (g/dscf)	1.62E-04	2.85E-05	--
Total PM (gr/dscf)	2.50E-03	4.39E-04	--
Total PM (lb/hr)	17.46	2.88	--
Total PM (lb/MMBtu)	0.0072	0.0015	0.0073
H ₂ SO ₄ (mg)	0.01	0.01	--
H ₂ SO ₄ (g/dscf)	2.48E-07	2.92E-07	--
H ₂ SO ₄ (gr/dscf)	3.82E-06	4.50E-06	--
H ₂ SO ₄ (lb/MMBtu)	0.000011	0.000016	0.0007
NH ₃ (ppmvd)	4.39	5.23	--
NH ₃ (ppm@15%O ₂)	2.91	4.17	5.0
Opacity (%)	0	0	20
CO ₂ (%)	4.92	4.13	--
O ₂ (%)	11.95	13.45	--

Notes: ¹ - Base (no DB); ² - 100% with DB

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol. During the September 25-27 testing, CTG-2 failed Base load (100% without duct burner) for PM. Results from this test are located in Appendix G. The CTG-2 PM (100% without duct burner) was re-tested October 10-11.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

The CPV Valley Energy Center is located at 3330 U.S. Route 6 in Middletown, New York. CPV Valley Energy Center is an electric generation facility. The facility consists of two Siemens SCC6-5000F Combined Cycle Combustion Turbines (CTGs), designated as CTG-1 and CTG-2. Each CTG is rated for the turbine at 2,234 million British thermal units per hour (MMBtu/hr) based on higher heating value (HHV) on natural gas; and 2,145 MMBtu/hr (HHV) on ultra-low sulfur diesel (ULSD) fuel oil; and is rated at 500 MMBtu/hr on natural gas for the duct burner (DB). The CTGs are equipped with dry low NOx combustors, selective catalytic reduction (SCR), and catalytic oxidizers.

3.2 SAMPLING LOCATION

The stacks are vertical, circular, and measure 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 175 ft above grade level with an exit elevation of approximately 275 ft above grade level. The test ports are located approximately 91.25 ft (1,095 inches) downstream and approximately 100 ft (1,200 inches) upstream from the nearest disturbances. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test (Appendix F). During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time. For PM testing, an initial velocity traverse was performed across the stack from 12 total points. All PM sampling occurred from the same 12 points by leaving the probe at each for an equal amount of time in order to draw an isokinetic and representative sample. H₂SO₄ sampling occurred from a single test point.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the Siemens, SCC6-5000F, Unit #CTG-1 and CTG-2 at the CPV Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on September 25-27 and October 10-11, 2018.

**TABLE 4.1
SUMMARY OF SAMPLING METHODS**

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	S-Type Pitot Tube
Oxygen	EPA Method 3A	Paramagnetic Cell
Carbon Dioxide	EPA Method 3A	Nondispersive Infrared Analyzer

Pollutant or Parameter	Sampling Method	Analysis Method
Stack Moisture Content	EPA Method 4	Gravimetric Analysis
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Opacity	EPA Method 9	Visual Observation
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Volatile Organic Compounds	EPA Method 18/25A	Gas Chromatograph and Flame Ionization Detector
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor
Particulate Matter	EPA Method 201A	Front Half Filterables
Particulate Matter	EPA Method 202	Back Half Condensables
Sulfuric Acid Mist	CTM-013 (Method 8A)	Wet Chemistry Solubility
Ammonia Slip	CTM-027	Ion Specific Electrode
Sulfur Content Analysis	ASTM 5504	Fuel Gas Sample and Laboratory Analysis
Sulfur Dioxide	40 CFR 75, Appendix D	Calculation

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3A, 4, 7E, 9, 10, 18, 19, 25A; 40 CFR 51, Appendix M, Method 201A and 202; Conditional Test Method (CTM)-013 (Method 8A) and Conditional Test Method (CTM)-027.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample. Exhaust samples were routed to the wet based analyzers prior to gas conditioning.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in an air-conditioned, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NO_x calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds.

Figure 4.2 represents the sample system used for the PM tests. The sample system included a heated stainless steel probe sheath with a glass liner and stainless nozzle. The nozzle and probe assembly were inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train in an isokinetic fashion. Differential pressure was monitored with S-type Pitot tubes and oil filled manometers. Total sample volumes were measured with dry gas meters. The resulting Method 2 velocity heads were combined with Method 3A (molecular weight) and Method 4 (moisture content) data to determine the stack gas volumetric flow rates. These results were combined with pollutant concentrations (i.e. mg/scf, parts per million, etc.) to determine emission rates (i.e. pounds per hour). Per the requirements of Method 202, the back half of the test train included a condenser and dry impinger train configuration. Sample collection included a nitrogen purge and hexane rinse. Glassware that was used to collect and analyze Method 202 condensable particulate samples was cleaned prior to the test with soap and water, and rinsed using tap water, deionized water, acetone, and finally, hexane. After cleaning, Air Hygiene incorporated a glassware bake at 300°C for six hours rather than the alternative of collecting a field train proof blank. During testing the temperature of the CPM filter assembly was maintain as close as possible to 85° F in accordance with EPA Method 202.

Figure 4.3 represents the sample system used for the H₂SO₄ tests. The sample system included a heated stainless steel probe sheath with a glass liner. The probe assembly was inserted into a sample port of the stack to extract gas measurements from the emission stream through a filter and glass impinger train at a constant flow rate of approximately 10 liters per minute (LPM). Total sample volumes were measured with dry gas meters. The corresponding PM test run Method 2 velocity heads were combined with Method 3A (molecular weight) and Method 4 (moisture content) data to determine the stack gas volumetric flow rate. These results were combined with pollutant concentrations (i.e. parts per million, mg/scf, etc.) to determine emission rates (i.e. pounds per hour).

Figure 4.4 represents the sample system used for the NH₃ tests. A heated stainless steel probe with a glass liner and glass nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a glass impinger train. Differential pressures were monitored with oil filled manometers and total sample volumes were measured with dry gas meters.

The stack gas analysis for O₂ and CO₂ concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O₂ analyzer uses a paramagnetic cell detector and the CO₂ analyzer uses a continuous nondispersive infrared analyzer.


EPA Method 7E was used to determine concentrations of NO_x. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO₂ in nitrogen certified gas cylinder was used to verify at least a 90 percent NO₂ conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

THC emission concentrations were quantified in accordance with procedures set forth in EPA Method 25A. A continuous flame ionization (FID) analyzer was used for this purpose. VOC emission concentrations were quantified in conjunction with procedures outlined in EPA Method 18 for Tedlar bag sampling and analysis of methane and ethane content. However, when THC results were below VOC limits, no methane or ethane analysis occurred and no subtractions from the THC concentrations to determine VOC concentrations are included in the report.

**TABLE 4.2
ANALYTICAL INSTRUMENTATION**



Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NO _x	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO ₂ to NO. Chemiluminescence of reaction of NO with O ₃ . Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
CO ₂	SERVOMEX 1440	0-20%	0.1%	Nondispersive infrared
VOC	THERMO 51 series	User may select up to 10,000 ppm	0.1 ppm	GC Column and Flame Ionization Detector
O ₂	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.



EMISSIONS TESTING LAB
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
www.airhygiene.com
 (888) 461-8778

Figure 4.1


Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.



View of Probe End (from the bottom)



Figure 4.2
 METHOD 201a/202 ASSEMBLY
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
 www.airhygiene.com
 (888) 461-8778



AIR HYGIENE

Figure 4.3
 CTM-013 TESTING ASSEMBLY
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
 www.airhygiene.com
 (888) 461-8778

TEST NOTES:
 10 LPM SAMPLE FLOW
 Delta H @ 0.35 IS ABOUT 10 LPM ON STANDARD CONSOLE
 15 MIN AMBIENT AIR PURGE





Figure 4.4
 CTM-027 TESTING ASSEMBLY
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
 www.airhygiene.com
 (888) 461-8778

APPENDIX A
TEST RESULTS AND CALCULATIONS

**TABLE A.1:
EMISSIONS TESTING SCHEDULE**

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
CTG-1	Base	Stratification Test	1	09/24/18	16:03:46	16:55:46	DAHS
CTG-1	Base	NOx, CO, VOC, CO2, O2	1	09/25/18	15:52:48	16:52:18	DAHS
CTG-1	Base	NOx, CO, VOC, CO2, O2	2	09/25/18	17:13:46	18:13:16	DAHS
CTG-1	Base	NOx, CO, VOC, CO2, O2	3	09/25/18	18:51:46	19:51:16	DAHS
CTG-1	100% W/Db	NOx, CO, VOC, CO2, O2	1	09/25/18	9:20:46	10:20:16	DAHS
CTG-1	100% W/Db	NOx, CO, VOC, CO2, O2	2	09/25/18	10:44:46	11:44:16	DAHS
CTG-1	100% W/Db	NOx, CO, VOC, CO2, O2	3	09/25/18	12:10:46	13:10:16	DAHS
CTG-1	Base	PM	1-Base-PM-1	09/24/18	9:52:00	14:08:00	DAHS
CTG-1	Base	PM	1-Base-PM-2	09/24/18	15:02:00	19:13:00	DAHS
CTG-1	Base	PM	1-Base-PM-3	09/25/18	15:36:00	20:02:00	DAHS
CTG-1	100% W/Db	PM	1-100 w/DB-PM-1	09/24/18	23:32:00	3:48:00	DAHS
CTG-1	100% W/Db	PM	1-100 w/DB-PM-2	09/25/18	4:11:00	8:27:00	DAHS
CTG-1	100% W/Db	PM	1-100 w/DB-PM-3	09/25/18	9:20:00	13:40:00	DAHS
CTG-1	Base	H2SO4	1-Base-SO3-1	09/24/18	12:32:00	14:34:00	DAHS
CTG-1	Base	H2SO4	1-Base-SO3-2	09/25/18	20:28:00	22:28:00	DAHS
CTG-1	Base	H2SO4	1-Base-SO3-3	09/25/18	23:01:00	1:01:00	DAHS
CTG-1	100% W/Db	H2SO4	1-100 w/DB-SO3-1	09/25/18	0:32:00	2:32:00	DAHS
CTG-1	100% W/Db	H2SO4	1-100 w/DB-SO3-2	09/25/18	3:14:00	5:14:00	DAHS
CTG-1	100% W/Db	H2SO4	1-100 w/DB-SO3-3	09/25/18	6:31:00	8:31:00	DAHS
CTG-1	Base	NH3	1-Base-NH3-1	09/25/18	15:54:00	16:58:00	DAHS
CTG-1	Base	NH3	1-Base-NH3-2	09/25/18	17:13:00	18:13:00	DAHS
CTG-1	Base	NH3	1-Base-NH3-3	09/25/18	18:44:00	19:44:00	DAHS
CTG-1	100% W/Db	NH3	1-100 w/DB-NH3-1	09/25/18	9:21:00	10:24:00	DAHS
CTG-1	100% W/Db	NH3	1-100 w/DB-NH3-2	09/25/18	10:45:00	11:48:00	DAHS
CTG-1	100% W/Db	NH3	1-100 w/DB-NH3-3	09/25/18	12:10:00	13:14:00	DAHS

**TABLE A.2:
EMISSIONS TESTING SCHEDULE**

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
CTG-2	100% W/Db	Stratification Test	1	09/24/18	16:45:24	17:38:24	DAHS
CTG-2	100% W/Db	NOx, CO, VOC, CO2, O2	1	09/25/18	9:25:24	10:24:54	DAHS
CTG-2	100% W/Db	NOx, CO, VOC, CO2, O2	2	09/25/18	11:24:24	12:23:54	DAHS
CTG-2	100% W/Db	NOx, CO, VOC, CO2, O2	3	09/25/18	12:51:24	13:50:54	DAHS
CTG-2	Base	NOx, CO, VOC, CO2, O2	1	09/25/18	15:40:24	16:39:54	DAHS
CTG-2	Base	NOx, CO, VOC, CO2, O2	2	09/25/18	17:15:24	18:14:54	DAHS
CTG-2	Base	NOx, CO, VOC, CO2, O2	3	09/25/18	18:44:24	19:43:54	DAHS
CTG-2	100% W/Db	PM	2-100 w/DB-PM-1	09/24/18	23:36:00	3:53:00	DAHS
CTG-2	100% W/Db	PM	2-100 w/DB-PM-2	09/25/18	5:03:00	9:10:00	DAHS
CTG-2	100% W/Db	PM	2-100 w/DB-PM-3	09/25/18	10:20:00	14:39:00	DAHS
CTG-2	Base	PM	2-Base-PM-1	10/10/18	19:14:00	23:24:00	DAHS
CTG-2	Base	PM	2-Base-PM-2	10/10/18	23:30:00	3:57:00	DAHS
CTG-2	Base	PM	2-Base-PM-3	10/11/18	4:17:00	8:32:00	DAHS
CTG-2	100% W/Db	H2SO4	2-100 w/DB-SO3-1	09/25/18	12:31:00	14:31:00	DAHS
CTG-2	100% W/Db	H2SO4	2-100 w/DB-SO3-2	09/25/18	3:47:00	5:47:00	DAHS
CTG-2	100% W/Db	H2SO4	2-100 w/DB-SO3-3	09/25/18	6:29:00	8:29:00	DAHS
CTG-2	Base	H2SO4	2-Base-SO3-1	09/24/18	12:22:00	14:22:00	DAHS
CTG-2	Base	H2SO4	2-Base-SO3-2	09/25/18	20:29:00	22:29:00	DAHS
CTG-2	Base	H2SO4	2-Base-SO3-3	09/25/18	23:10:00	1:10:00	DAHS
CTG-2	100% W/Db	NH3	2-100 w/DB-NH3-1	09/25/18	9:25:00	10:26:00	DAHS
CTG-2	100% W/Db	NH3	2-100 w/DB-NH3-2	09/25/18	11:24:00	12:24:00	DAHS
CTG-2	100% W/Db	NH3	2-100 w/DB-NH3-3	09/25/18	12:57:00	13:57:00	DAHS
CTG-2	Base	NH3	2-Base-NH3-1	09/25/18	15:40:00	16:40:00	DAHS
CTG-2	Base	NH3	2-Base-NH3-2	09/25/18	17:15:00	18:15:00	DAHS
CTG-2	Base	NH3	2-Base-NH3-3	09/25/18	18:44:00	19:44:00	DAHS

TABLE A.3
SIEMENS, SCC6-5000F, UNIT #CTG-1 BASE LOAD[9/24-25] DATA SUMMARY

Parameter	Base Load, Run - 1	Base Load, Run - 2	Base Load, Run - 3	Average
Turbine Fuel Flow (SCFH)	2,095,143	2,091,745	2,089,719	2,092,202
Duct Burner Fuel Flow (lb/min)	0	0	0	0
Total Fuel Flow (SCFH)	2,095,143	2,091,745	2,089,719	2,092,202
Stack Flow (RM19) (SCFH)	51,977,206	51,486,411	51,849,484	51,771,034
Stack Moisture (% Method 4)	6.4	9.0	9.6	8.4
Power Output (megawatts)	206.9	206.4	206.1	206.5
NO _x (ppmvd)	2.11	1.75	1.65	1.84
NO _x (ppm@15%O ₂)	1.70	1.40	1.33	1.48
CO (ppmvd)	0.00	0.00	0.00	0.00
CO (ppm@15%O ₂)	0.00	0.00	0.00	0.00
VOC as CH ₄ (ppmvd)	0.54	0.19	0.49	0.40
VOC as CH ₄ (ppm@15%O ₂)	0.44	0.15	0.39	0.33
SO ₂ from Fuel Sulfur (grains/100scf)	0.039	0.039	0.039	0.039
SO ₂ from Fuel Sulfur (lb/MMBtu)	0.00011	0.00011	0.00011	0.00011
Total PM (mg)	6.08	2.09	2.89	3.69
Total PM (g/dscf)	6.84E-05	2.40E-05	3.35E-05	4.20E-05
Total PM (gr/dscf)	1.06E-03	3.71E-04	5.17E-04	6.48E-04
Total PM (lb/hr)	7.26	2.52	3.50	4.42
Total PM (lb/MMBtu)	0.0037	0.0013	0.0018	0.0023
H ₂ SO ₄ (mg)	0.01	0.01	0.01	0.01
H ₂ SO ₄ (g/dscf)	2.92E-07	2.18E-07	2.18E-07	2.42E-07
H ₂ SO ₄ (gr/dscf)	4.50E-06	3.36E-06	3.37E-06	3.74E-06
H ₂ SO ₄ (lb/MMBtu)	0.000015	0.000011	0.000012	0.000013
NH ₃ (ppmvd)	4.83	5.04	5.22	5.03
NH ₃ (ppm@15%O ₂)	3.91	4.02	4.16	4.03
Opacity (%)	0	0	0	0
CO ₂ (%)	4.14	4.17	4.16	4.16
O ₂ (%)	13.59	13.53	13.59	13.57

TABLE A.4
SIEMENS, SCC6-5000F, UNIT #CTG-1 100% W/DB LOAD[9/24-25] DATA SUMMARY

Parameter	100% W/Db Load, Run - 1	100% W/Db Load, Run - 2	100% W/Db Load, Run - 3	Average
Turbine Fuel Flow (SCFH)	2,128,585	2,122,302	2,114,001	2,121,629
Duct Burner Fuel Flow (lb/min)	268	268	268	268
Total Fuel Flow (SCFH)	2,507,761	2,501,478	2,493,177	2,500,805
Stack Flow (RM19) (SCFH)	51,790,579	53,428,357	52,301,913	52,506,949
Stack Moisture (% Method 4)	10.1	13.5	10.5	11.4
Power Output (megawatts)	211.1	210.3	209.3	210.2
NOx (ppmvd)	2.61	2.75	2.77	2.71
NOx (ppm@15%O ₂)	1.75	1.91	1.89	1.85
CO (ppmvd)	0.00	0.00	0.00	0.00
CO (ppm@15%O ₂)	0.00	0.00	0.00	0.00
VOC as CH ₄ (ppmvd)	0.08	0.00	0.14	0.07
VOC as CH ₄ (ppm@15%O ₂)	0.05	0.00	0.10	0.05
SO ₂ from Fuel Sulfur (grains/100scf)	0.039	0.039	0.039	0.039
SO ₂ from Fuel Sulfur (lb/MMBtu)	0.00011	0.00011	0.00011	0.00011
Total PM (mg)	5.04	1.98	2.66	3.23
Total PM (g/dscf)	5.83E-05	2.30E-05	2.93E-05	3.69E-05
Total PM (gr/dscf)	9.00E-04	3.55E-04	4.52E-04	5.69E-04
Total PM (lb/hr)	6.23	2.46	3.20	3.96
Total PM (lb/MMBtu)	0.0027	0.0011	0.0013	0.0017
H ₂ SO ₄ (mg)	0.01	0.01	0.01	0.01
H ₂ SO ₄ (g/dscf)	3.20E-07	2.70E-07	2.35E-07	2.75E-07
H ₂ SO ₄ (gr/dscf)	4.94E-06	4.16E-06	3.63E-06	4.25E-06
H ₂ SO ₄ (lb/MMBtu)	0.000015	0.000012	0.000011	0.000013
NH ₃ (ppmvd)	4.72	4.61	4.35	4.56
NH ₃ (ppm@15%O ₂)	3.13	3.16	2.95	3.08
Opacity (%)	0	0	0	0
CO ₂ (%)	4.80	4.82	4.82	4.81
O ₂ (%)	12.11	12.40	12.25	12.26

**TABLE A.5
SIEMENS, SCC6-5000F, UNIT #CTG-2 100% W/DB LOAD[9/24-25] DATA SUMMARY**

Parameter	100% W/Db Load, Run - 1	100% W/Db Load, Run - 2	100% W/Db Load, Run - 3	Average
Turbine Fuel Flow (SCFH)	2,129,501	2,119,978	2,109,939	2,119,806
Duct Burner Fuel Flow (lb/min)	271	271	271	271
Total Fuel Flow (SCFH)	2,512,210	2,502,922	2,493,119	2,502,750
Stack Flow (RM19) (SCFH)	50,847,815	50,755,979	50,611,217	50,738,337
Stack Moisture (% Method 4)	10.2	11.0	11.3	10.8
Power Output (megawatts)	210.7	209.5	208.6	209.6
NOx (ppmvd)	2.43	2.50	2.52	2.48
NOx (ppm@15%O ₂)	1.60	1.65	1.67	1.64
CO (ppmvd)	0.42	0.27	0.25	0.31
CO (ppm@15%O ₂)	0.28	0.18	0.16	0.21
THC (ppmvd)	1.81	2.54	1.77	2.04
THC (ppm@15%O ₂)	1.19	1.67	1.17	1.35
CH ₄ (ppmvd)	--	--	--	--
C ₂ H ₆ (ppmvd)	--	--	--	--
VOC as CH ₄ (ppmvd)	1.81	2.54	1.77	2.04
VOC as CH ₄ (ppm@15%O ₂)	1.19	1.67	1.17	1.35
SO ₂ from Fuel Sulfur (grains/100scf)	0.039	0.039	0.039	0.04
SO ₂ from Fuel Sulfur (lb/MMBtu)	0.00011	0.00011	0.00011	0.00011
Total PM (mg)	5.35	26.09	14.84	15.43
Total PM (g/dscf)	5.97E-05	2.83E-04	1.43E-04	1.62E-04
Total PM (gr/dscf)	9.21E-04	4.37E-03	2.21E-03	2.50E-03
Total PM (lb/hr)	5.99	31.06	15.34	17.46
Total PM (lb/MMBtu)	0.0027	0.0126	0.0064	0.0072
H ₂ SO ₄ (mg)	0.01	0.01	0.01	0.01
H ₂ SO ₄ (g/dscf)	1.93E-07	2.65E-07	2.85E-07	2.48E-07
H ₂ SO ₄ (gr/dscf)	2.97E-06	4.09E-06	4.40E-06	3.82E-06
H ₂ SO ₄ (lb/MMBtu)	0.000009	0.000012	0.000013	0.000011
NH ₃ (ppmvd)	1.52	5.97	5.68	4.39
NH ₃ (ppm@15%O ₂)	1.01	3.96	3.77	2.91
Opacity (%)	0	0	0	0
CO ₂ (%)	4.89	4.92	4.95	4.92
O ₂ (%)	11.93	11.95	11.96	11.95

TABLE A.6
SIEMENS, SCC6-5000F, UNIT #CTG-2 BASE LOAD[9/24-25&10/10-11] DATA SUMMARY

Parameter	Base Load, Run - 1	Base Load, Run - 2	Base Load, Run - 3	Average
Turbine Fuel Flow (SCFH)	2,095,738	2,052,599	2,091,966	2,080,101
Duct Burner Fuel Flow (lb/min)	0	0	0	0
Total Fuel Flow (SCFH)	2,095,738	2,052,599	2,091,966	2,080,101
Stack Flow (RM19) (SCFH)	51,012,770	49,960,821	50,933,540	50,635,710
Stack Moisture (% Method 4)	9.0	8.7	9.4	9.0
Power Output (megawatts)	204.1	205.6	205.5	205.1
NOx (ppmvd)	2.05	2.00	1.99	2.01
NOx (ppm@15%O ₂)	1.62	1.58	1.58	1.59
CO (ppmvd)	0.27	0.27	0.26	0.27
CO (ppm@15%O ₂)	0.22	0.22	0.21	0.21
THC (ppmvd)	2.41	1.46	2.76	2.21
THC (ppm@15%O ₂)	1.91	1.15	2.18	1.75
CH ₄ (ppmvd)	2.00	2.00	2.00	2.00
C ₂ H ₆ (ppmvd)	0.10	0.10	0.10	0.10
VOC as CH ₄ (ppmvd)	0.31	0.00	0.66	0.32
VOC as CH ₄ (ppm@15%O ₂)	0.24	0.00	0.52	0.26
SO ₂ from Fuel Sulfur (grains/100scf)	0.039	0.039	0.039	0.04
SO ₂ from Fuel Sulfur (lb/MMBtu)	0.00011	0.00011	0.00011	0.00011
Total PM (mg)	2.96	2.15	2.30	2.47
Total PM (g/dscf)	3.58E-05	2.32E-05	2.64E-05	2.85E-05
Total PM (gr/dscf)	5.52E-04	3.59E-04	4.08E-04	4.39E-04
Total PM (lb/hr)	3.57	2.44	2.63	2.88
Total PM (lb/MMBtu)	0.0019	0.0012	0.00141	0.0015
H ₂ SO ₄ (mg)	0.01	0.01	0.01	0.01
H ₂ SO ₄ (g/dscf)	2.91E-07	2.43E-07	3.42E-07	2.92E-07
H ₂ SO ₄ (gr/dscf)	4.49E-06	3.75E-06	5.27E-06	4.50E-06
H ₂ SO ₄ (lb/MMBtu)	0.000016	0.000013	0.000018	0.000016
NH ₃ (ppmvd)	4.93	5.28	5.49	5.23
NH ₃ (ppm@15%O ₂)	3.93	4.21	4.38	4.17
Opacity (%)	0	0	0	0
CO ₂ (%)	4.13	4.13	4.14	4.13
O ₂ (%)	13.44	13.44	13.45	13.45

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of NH ₃ (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH ₃ (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO ₂ (lb/lb-mole) =	44.01

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_o) \times \left(\frac{C_{M_A}}{C_M - C_o} \right)$$

2. Correction to % O₂, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

3. Correction to % O₂ and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_o - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_s = \left(\frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

40CFR60, App. A, RM 19, Table 19-1

Conversion Constant for NOx = 0.0000001194351

Conversion Constant for CO = 0.0000000726839

Conversion Constant for NH₃ = 0.0000001661345

Conversion Constant for THC = 0.0000001142175

Conversion Constant for VOC (methane) = 0.0000000415336

Conversion Constant for NH₃ = 0.0000000442074

Conversion Constant for HCHO = 0.0000000779534

Conversion Constant for CO₂ = 0.0000001142434

NOTE: units are lb/ppm*ft³

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_s \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O₂ based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O_2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp*hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp}$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{AVG} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO₂ to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NO_{Final} = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NO_xCorr = The NO_x concentration corrected for the converter efficiency.
NO_xFinal = The final NO_x concentration observed during the converter efficiency test in Section 16.2.2.
NO_xPeak = The highest NO_x concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Air} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{Final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H₂O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
%_C = Concentration of carbon from an ultimate analysis of fuel, weight percent.
%_{CO2d}, %_{CO2w} = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{aoi}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO₂ rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
E_{ij}, E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
E_{ih} = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
F_c = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft³ = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
%_H = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
%_{H2O} = Concentration of water from an ultimate analysis of fuel, weight percent.
H_t = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10⁻⁵ (kJ/J)/(%) [10⁶ Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = 2x10⁴ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p, L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
%_N = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
M% = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)¹
NCM = net Btu per SCF (constant based on compound)
%_O = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
%_{CO2d}, %_{CO2w} = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO₂ emissions, percent.
%_S = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_o = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
%_{Sr} = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
%S_p, %S_r = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
t_{0.95} = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2} = CO₂ Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

Nomenclature

- %CO = carbon monoxide concentration (%)
- %CO₂ = carbon dioxide concentration (%)
- %N₂ = nitrogen concentration (%)
- %O₂ = oxygen concentration (%)
- %O_{2,wet} = Oxygen content of gas stream, % by volume of wet gas. (Note: The oxygen percentage used in Method 201A, Equation 3 is on a wet gas basis. That means that since oxygen is typically measured on a dry gas basis, the measured percent O₂ must be multiplied by the quantity (1 - B_{ws}) to convert to the actual volume fraction. Therefore, %O_{2,wet} = (1 - B_{ws}) * %O_{2,dry})
- (%EA)_{avg} = average excess air (%)
- (F_o)_{avg} = average calculated fuel factor
- [(Δp)^{0.5}]_{avg} = Average of square roots of the velocity pressures measured during the preliminary traverse, inches W.C.
- μ = Gas viscosity, micropoise
- 12.0 = Constant calculated as 60 percent of 20.5 square inch cross-sectional area of combined cyclone head, square inches
- 17.03 = mg/milliequivalents for ammonium ion
- 22.4 = liters of ideal gas per lb-mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 24.04 = liters of ideal gas per lb-mol of substance at 20°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 5.02 x 10⁴ = constant derived from the molecular weight and correcting standard temperature and pressure (ref. Bay Area Air Quality Management District, Source Test Procedure ST-1B, Ammonia Integrated Sampling, Adopted January 20, 1982, Regulation 7-303)
- A = distance upstream (in.)
- A_D = stack diameters upstream (dia.)
- A_n = Area of nozzle, square feet
- A_s = area of stack (ft²)
- B = distance downstream (in.)
- B_D = stack diameters downstream (dia.)
- b_f = Average blockage factor calculated in Equation 26, dimensionless
- B_{wm} = meter moisture content (%)
- B_{ws} = stack moisture content (%)
- C = Cunningham correction factor for particle diameter, D_p, and calculated using the actual stack gas temperature, dimensionless
- C₁ = -150.3162 (micropoise)
- C₂ = 18.0614 (micropoise/K^{0.5}) = 13.4622 (micropoise/R^{0.5})
- C₃ = 1.19183 × 10⁶ (micropoise/K²) = 3.86153 × 10⁶ (micropoise/R²)
- C₄ = 0.591123 (micropoise)
- C₅ = 91.9723 (micropoise)
- C₆ = 4.91705 × 10⁻⁵ (micropoise/K²) = 1.51761 × 10⁻⁵ (micropoise/R²)
- C_a = Acetone blank concentration, mg/mg
- C_b = Concentration of NH₃ ion in the back half of train (breakthrough)
- C_f = Concentration of NH₃ ion in the front half of train (main catch)
- C_{fPM10} = Conc. of filterable PM₁₀, gr/dscf
- C_{fPM2.5} = Conc. of filterable PM_{2.5}, gr/dscf
- C_k = K Factor Constant, 849.8

Nomenclature

- C_n = nozzle diameter constant, 0.03575
- C_p' = Coefficient for the pitot used in the preliminary traverse, dimensionless
- C_p = Pitot coefficient for the combined cyclone pitot, dimensionless
- C_{cpm} = Concentration of the condensable PM in the stack gas, dry basis, corrected to standard conditions, milligrams/dry standard cubic foot.
- C_r = Re-estimated Cunningham correction factor for particle diameter equivalent to the actual cut size diameter and calculated using the actual stack gas temperature, dimensionless
- D_{50} = Particle cut diameter, micrometers
- $D_{50(N+1)}$ = D_{50} value for cyclone IV calculated during the N+1 iterative step, micrometers
- D_{50-1} = Re-calculated particle cut diameters based on re-estimated C_r , micrometers
- D_{50LL} = Cut diameter for cyclone I corresponding to the 2.25 micrometer cut diameter for cyclone IV, micrometer
- D_{50N} = D_{50} value for cyclone IV calculated during the Nth iterative step, micrometers
- D_{50T} = Cyclone I cut diameter corresponding to the middle of the overlap zone shown in Method 201A, Figure 10 of Section 17, micrometers
- D_e = equivalent stack diameter (in.)
- $\Delta H@$ = $\Delta H @ 0.75$ scfm (in. H₂O)
- ΔH_{avg} = average orifice pressure (in. H₂O)
- D_n = Inner diameter of sampling nozzle mounted on Cyclone I, inches
- D_{na} = actual nozzle diameter (in.)
- D_p = Physical particle size, micrometers
- Δp = velocity head (in. H₂O)
- Δp_1 = velocity head at first current traverse point (in. H₂O)
- $\Delta p'_1$ = velocity head at first preliminary traverse point (in. H₂O)
- Δp_{avg} = average pitot tube differential pressure (in. H₂O)
- Δp_n = velocity head at subsequent current traverse point (in. H₂O)
- Δp_{RM2} = method 2 velocity head (in. H₂O)
- D_s = diameter of stack (in.)
- F_d = fuel f-factor (dscf/MMBtu)
- f_{O_2} = stack gas fraction of O₂, by volume, dry basis
- I = Percent isokinetic sampling, dimensionless
- K_1 = standard volume correction, 17.65°R/in. Hg
- K_4 = isokinetic conversion constant, 0.0945min•in.Hg/sec•°R
- K_5 = water mass to std water vapor, 0.04715 ft³/g
- K_p = 85.49, ((ft/sec)/(pounds/mole -°R))
- L = length of stack (in.)
- L_{fw} = distance to far wall of stack (in.)
- L_{nw} = distance to near wall of stack (in.) [reference]
- $m_{\#x}$ = weight measurements (g)
- M_1 = Milligrams of PM collected on the filter, less than or equal to 2.5 micrometers
- M_2 = Milligrams of PM recovered from Container #2 (acetone blank corrected), greater than 10 micrometers
- M_3 = Milligrams of PM recovered from Container #3 (acetone blank corrected), less than or equal to 10 and greater than 2.5 micrometers
- M_4 = Milligrams of PM recovered from Container #4 (acetone blank corrected), less than or equal to 2.5 micrometers

Nomenclature

- m_a = Mass of residue of acetone after evaporation, mg
- m_c = Mass of the NH_4^+ added to sample to form ammonium sulfate, mg
- m_{cpm} = Mass of the total condensable PM, mg
- M_d = Molecular weight of dry gas, pounds/pound mole
- m_{fb} = Mass of total CPM in field train recovery blank, mg
- m_{fx} = final weight, avg of last two measurements (g)
- mg = Milligram
- mg/L = Milligram per liter
- m_i = Mass of inorganic CPM, mg
- m_{ib} = Mass of inorganic CPM in field train recovery blank, mg
- M_n = total particulates (mg)
- m_o = Mass of organic CPM, mg
- m_{ob} = Mass of organic CPM in field train blank, mg
- m_r = Mass of dried sample from inorganic fraction, mg
- m_{tx} = tare weight (g)
- MW = molecular weight (lb/lb-mole)
- M_w = Molecular weight of wet gas, pounds/pound mole
- N = Normality of ammonium hydroxide titrant
- N_a = null angle (deg.)
- N_{re} = Reynolds number, dimensionless
- N_{tp} = Number of iterative steps or total traverse points
- $P_b = P_{\text{bar}}$ = barometric pressure (in. Hg)
- P_{bar} = barometric pressure (in. Hg)
- ppmCO = carbon monoxide concentration (ppm)
- ppmv = Parts per million by volume
- ppmw = Parts per million by weight
- P_s = absolute stack pressure (in. Hg)
- P_{static} = static pressure (in. H_2O)
- P_{std} = standard pressure, 29.92 in. Hg
- Θ = total sampling time (min)
- Q_{aw} = average stack wet flow rate (ascf/min)
- Q_l = Sampling rate for cyclone I to achieve specified D_{50}
- Q_m = estimated orifice flow rate, 0.750 acfm, else V_m/Q from previous run
- Q_s = Sampling rate for cyclone I to achieve specified D_{50}
- $Q_{\text{s(std)}}$ = total cyclone flow rate at standard conditions (dscf/min)
- Q_{sd} = dry standard stack flow rate (dscfm)
- Q_{sST} = Dry gas sampling rate through the sampling assembly, dscfm
- Q_{sw} = wet standard stack flow rate (ascfm)
- R_{max} = Nozzle/stack velocity ratio parameter, dimensionless
- R_{min} = Nozzle/stack velocity ratio parameter, dimensionless
- t_1 = Sampling time at point 1, min
- t_m = average gas meter temperature ($^{\circ}\text{F}$)
- t_m = average meter temperature ($^{\circ}\text{F}$)
- T_m = Meter box and orifice gas temperature, $^{\circ}\text{R}$
- t_n = Sampling time at point n, min

Nomenclature

- t_r = Total projected run time, min
- T_s = Absolute stack gas temperature, °R
- T_{std} = standard temperature, 68°F, 528°R
- T_u = absolute temperature offset, 460°R
- V_a = Volume of acetone blank, ml
- V_{aw} = Volume of acetone used in sample recovery wash, ml
- V_b = Volume of aliquot taken for IC analysis, ml
- V_c = Quantity of water captured in impingers and silica gel, ml
- V_f = final impinger volume (ml)
- V_i = initial impinger volume (ml)
- V_{ic} = Volume of impinger contents sample, ml
- V_m = Dry gas meter volume sampled, acf
- $V_{m(std)}$ = standard meter volume (dscf)
- v_{max} = Maximum gas velocity calculated from Equations 18 or 19, ft/sec
- v_{max} = maximum nozzle velocity (ft/sec)
- V_{mf} = final dry gas meter reading (dcf)
- V_{mi} = initial dry gas meter reading (dcf)
- v_{min} = Minimum gas velocity calculated from Method 201A, Equations 16 or 17, ft/sec
- V_{ms} = Dry gas meter volume sampled, corrected to standard conditions, dscf
- v_n = Sample gas velocity in the nozzle, ft/sec
- v_{org} = organics wash volume (ml)
- V_p = Volume of water added during train purge
- v_s = average stack gas velocity (ft/sec)
- v_{sl} = local velocity (ft/sec)
- V_t = total impinger volume (ml) = $;(V_f - V_i)$
- V_t = Volume of NH₄OH titrant, ml
- $V_{w(std)}$ = volume of water vapor in gas sample at standard conditions (scf)
- v_x = blank volume (ml)
- W = width of stack (in.)
- $W_{2,3,4}$ = Weight of PM recovered from Containers #2, #3, and #4, mg
- W_a = Weight of blank residue in acetone used to recover samples, mg
- W_f = final impinger weight (g)
- W_i = initial impinger weight (g)
- W_t = total impinger weight (g) = $;(W_f - W_i)$
- w_x = blank weight of solids (g)
- Y = meter calibration factor (a.k.a gamma)
- Z = Ratio between estimated cyclone IV D_{50} values, dimensionless
- γ = Dry gas meter gamma value, dimensionless
- ΔH = Meter box orifice pressure drop, inches W.C.
- $\Delta H@$ = Pressure drop across orifice at flow rate of 0.75 scfm at standard conditions, inches W.C. (Note: Specific to each orifice and meter box.)
- Δp_1 = Velocity pressure measured at point 1, inches W.C.
- Δp_{avg} = Average velocity pressure, inches W.C.
- Δp_m = Observed velocity pressure using S-type pitot tube in preliminary traverse, inches W.C.
- Δp_{max} = Maximum velocity pressure, inches W.C.

Nomenclature

- Δp_{\min} = Minimum velocity pressure, inches W.C.
- Δp_n = Velocity pressure measured at point n during the test run, inches W.C.
- Δp_s = Velocity pressure calculated in Method 201a, Equation 25, inches W.C.
- Δp_{s1} = Velocity pressure adjusted for combined cyclone pitot tube, inches W.C.
- Δp_{s2} = Velocity pressure corrected for blockage, inches W.C.
- θ = Total run time, min
- ρ_a = Density of acetone, mg/ml (see label on bottle)
- Σ_n = total number of sampling points

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(\text{in.}) = L_{fv} - L_{mv}$$

$$D(\text{in.}) = 235.25 \text{ in.} - 7.25 \text{ in.} = 228.00 \text{ in.}$$

Stack Diameters Downstream

$$B_D(\text{dia.}) = \frac{B}{D}$$

$$B_D(\text{dia.}) = \frac{1095.00 \text{ in.}}{228.00 \text{ in.}} = 4.80 \text{ diameters}$$

Area of Stack (ft²)

$$A_s(\text{ft}^2) = \pi \times \left(\frac{D}{2 \times 12} \right)^2$$

$$A_s(\text{ft}^2) = 3.14 \times \left(\frac{228.00 \text{ in.}}{2 \times 12 \text{ in./ft}} \right)^2 = 283.53 \text{ ft}^2$$

Stack Diameters Upstream

$$A_D(\text{dia.}) = \frac{A}{D}$$

$$A_D(\text{dia.}) = \frac{1200.00 \text{ in.}}{228.00 \text{ in.}} = 5.26 \text{ diameters}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]

Carbon Monoxide Concentration (%)

$$\%CO = \frac{ppmCO}{10,000}$$

$$\%CO (\%) = \frac{0.00 \text{ ppm}}{10,000 \text{ ppm/\%}} = 0.0000 \%$$

Nitrogen Concentration (%)

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$$\%N_2 (\%) = 100 - 4.14 \% - 13.60 \% - 0.00 / 10,000 \% = 82.26 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb} / \text{lb} - \text{mole}) = \sum \left(\frac{MW_{comp}}{100} \times \%component \right)$$

$$M_d (\text{lb/lb-mol}) = \left(\frac{44 \text{ lb/lb-mol}}{100} \times 4.14 \% \right) +$$

$$\left(\frac{32 \text{ lb/lb-mol}}{100} \times 13.60 \% \right) + \left(\frac{28 \text{ lb/lb-mol}}{100} \times \left[\frac{0.00}{10,000} + 82.26 \right] \right) = \frac{29.21 \text{ lb}}{\text{lb-mol}}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_s (\text{lb} / \text{lb} - \text{mole}) = \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right] + \left[MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s (\text{lb/lb-mol}) = \left\{ \frac{29.21 \text{ lb}}{\text{lb-mol}} \times \left(1 - \frac{8.16 \%}{100} \right) \right\} + \left\{ \frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{8.16 \%}{100} \right\} = \frac{28.29 \text{ lb}}{\text{lb-mol}}$$

Average Calculated Fuel Factor (F_o)

$$F_{o(avg)} = \frac{[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - 13.60\% - (0.5 \times 0.0000\%)}{4.14\% + 0.0000\%} = 1.763$$

Average Excess Air (%)

$$\%EA_{avg} (\%) = \frac{100 \times [(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}{(0.264 \times (N_2)_{avg}) - [(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{ 13.60 \% - (0.5 \times 0.0000 \%) \}}{(0.264 \times 82.26 \%) - \{ 13.60 \% - (0.5 \times 0.0000 \%) \}} = 167.56 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]

Absolute Stack Pressure (in. Hg)

$$P_s (\text{in. Hg}) = P_b + \frac{P_{\text{static}}}{13.6}$$

$$P_s (\text{in. Hg}) = 29.97 \text{ in. Hg} + \frac{-0.87 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.91 \text{ in. Hg}$$

Average Stack Gas Velocity (ft/sec)

$$v_s (\text{ft / sec}) = K_p \times C_p \times (\sqrt{\Delta p})_{\text{avg}} \times \sqrt{\frac{(t_s)_{\text{avg}} + T_u}{P_s \times M_s}}$$

v_{sl} (ft/sec) =

$$\left(\frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\text{sec (}^\circ\text{R)(in. H}_2\text{O)}} \right)^{1/2} \times 0.72 \times 1.19 \text{ in. H}_2\text{O}^{1/2} \times \sqrt{\frac{217.08 + 460 \text{ }^\circ\text{R}}{29.91 \text{ in. Hg} \times 28.29 \text{ lb/lb-mol}}} = \frac{65.8 \text{ ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd} (\text{dscfh}) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sd} (\text{dscf/hr}) = \frac{3600 \text{ sec}}{\text{hr}} \times \left(1 - \frac{8.16 \%}{100}\right) \times \frac{65.88 \text{ ft}}{\text{sec}} \times 283.53 \text{ ft}^2 \times \frac{68.00 + 460 \text{ }^\circ\text{R}}{217.08 + 460 \text{ }^\circ\text{R}} \times \frac{29.91 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{48,135,876.34 \text{ dscf}}{\text{hr}}$$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw} (\text{acfm}) = 60 \times v_s \times A_s$$

$$Q_{aw} (\text{acf/min}) = \frac{60 \text{ sec}}{\text{min}} \times \frac{65.88 \text{ ft}}{\text{sec}} \times 283.53 \text{ ft}^2 = \frac{1,120,665.49 \text{ acf}}{\text{min}}$$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw} (\text{ascfh}) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sw} (\text{ascf/hr}) = \frac{60 \text{ min}}{\text{hr}} \times \frac{1,120,665.49 \text{ acf}}{\text{min}} \times \frac{68.00 + 460 \text{ }^\circ\text{R}}{217.08 + 460 \text{ }^\circ\text{R}} \times \frac{29.91 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{52,410,248.13 \text{ ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg(std)}(scf) = W_t \times K_s$$

$$V_{wsg(std)} = 167.50 \text{ g} \times 0.04715 \text{ ft}^3/\text{g} = 7.898 \text{ scf}$$

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6} \right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65 \text{ }^\circ\text{R}}{\text{in. Hg}} \times 0.96 \times 93.27 \text{ dcf} \times \left(29.97 \text{ in. Hg} + \frac{0.40 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O} / \text{in. Hg}} \right) = 88.94 \text{ dscf}$$

$$74.08 \text{ }^\circ\text{F} + 460 \text{ }^\circ\text{R}$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{7.90 \text{ dscf}}{7.90 \text{ dscf} + 88.94 \text{ dscf}} = 8.16 \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)}(\%) = 100 \times \frac{10^{6.691 - \frac{3144}{t_s(avg) + 390.86}}}{P_b + \frac{P_{static}}{13.6}} \leq 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{(6.691 - \frac{3144}{217.08 \text{ }^\circ\text{F} + 390.86})}}{29.97 \text{ in. Hg} + \frac{-0.87 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O} / \text{in. Hg}}} \leq 100 = 100.00 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Desired Orifice (in. H₂O) (first point)

$$\Delta H_d (\text{in. H}_2\text{O}) = K \times \Delta p$$

$$\Delta H_d (\text{in. H}_2\text{O}) = \quad \times \quad \text{in. H}_2\text{O} = \quad \text{in. H}_2\text{O}$$

Absolute Meter Pressure (in. Hg)

$$P_m (\text{in. Hg}) = P_b + \frac{\Delta H @}{13.6}$$

$$P_m (\text{in. Hg}) = 29.97 \text{ in. Hg} + \frac{1.84 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 30.11 \text{ in. Hg}$$

Recommended Nozzle Diameter (in.)

$$D_m (\text{in.}) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{ws}}{100}} \right) \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right)}{P_s \times \Delta p_{avg}} \right]}}$$

$$D_{ni} (\text{in.}) = \frac{0.03575 (\text{lb-mole} \cdot \text{R} \cdot \text{in. H}_2\text{O})^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acf} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times 0.75 \text{ acf} \times 30.11 \text{ in. Hg} \times \left(\frac{1 - \frac{0.00 \%}{100}}{1 - \frac{8.16 \%}{100}} \right) \times \left(\frac{74.08 \text{ }^\circ\text{F} + 460^\circ\text{R}}{217.08 \text{ }^\circ\text{F} + 460^\circ\text{R}} \right) \times \left(\frac{29.21 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{8.16 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{8.16 \%}{100} \right) \right) \times \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{8.16 \%}{100} \right) \times \left(\frac{29.91 \text{ in. Hg}}{1.19 \text{ in. H}_2\text{O}} \right) = 0.220 \text{ in.}$$

ΔP to ΔH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H (@) \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right)}{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right)} \right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{ws}}{100}} \right)^2 \times \left(\frac{t_m + T_u}{t_s + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times 0.72^2 \times 1.84 \text{ in. H}_2\text{O} \times 0.15^4 \times \left(\frac{1 - \frac{8.16 \%}{100}}{1 - \frac{0.00 \%}{100}} \right)^2 \times \left(\frac{74.08 \text{ }^\circ\text{F} + 460^\circ\text{R}}{217.08 \text{ }^\circ\text{F} + 460^\circ\text{R}} \right) \times \left(\frac{29.21 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{0.00 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.00 \%}{100} \right) \right) \times \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.00 \%}{100} \right) \times \left(\frac{29.91 \text{ in. Hg}}{30.11 \text{ in. Hg}} \right) = 0.29$$

Percent Isokinetic (%) (first point)

$$I (\%) = \frac{K_4 \times ((t_s)_{avg} + T_u) \times V_m (\text{std})}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12} \right)^2 \right) \times \left(1 - \frac{B_{ws}}{100} \right)}$$

$$I (\%) = \frac{0.0945 \text{ min} \cdot \text{in. Hg}}{\text{sec} \cdot \text{R}} \times (211.00 \text{ }^\circ\text{F} + 460^\circ\text{R}) \times 8.02 \text{ dscf} \times \frac{20.75 \text{ min} \times \frac{65.22 \text{ ft}}{\text{sec}} \times 29.91 \text{ in. Hg} \times 3.14 \times \left(\frac{0.15 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}} \right)^2 \times \left(1 - \frac{8.16 \%}{100} \right)}{100} = 109.58 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Cumulative Percent Isokinetic (%) (weighted average of all points)

Using Method 5, Eq 5-8 to determine intermediate isokinetics at each point, weighted averaging of the cumulative isokinetics is necessary since all points are not equal, and determined by using the dry standard meter volume collected at each point to weight the cumulative average. Intermediate isokinetics and dry standard meter volumes are found at each point. At each point the cumulative sum is found of each value and the quotient of the two used to determine the cumulative isokinetics for each residual point (n).

$$I(\%) = \sum_{1-n} \frac{I(\%) \times V_{m(std)} |_{1-n}}{V_{m(std)} |_{1-n}}$$

Pt	In (%)	x	Vm(std)n	=	I (%)n	Σ(I (%)n)	/	Σ(Vm(std)n)	=	I (%)
A-1	109.58	x	8.024	=	879.24	879.24	/	8.02	=	109.6
A-2	100.94	x	7.385	=	745.42	1624.65	/	15.41	=	105.4
A-3	101.96	x	7.443	=	758.92	2383.57	/	22.85	=	104.3
B-1	106.52	x	6.581	=	700.94	3084.51	/	29.43	=	104.8
B-2	105.20	x	6.495	=	683.28	3767.79	/	35.93	=	104.9
B-3	109.24	x	6.749	=	737.31	4505.10	/	42.68	=	105.6
C-1	101.63	x	7.663	=	778.81	5283.90	/	50.34	=	105.0
C-2	101.83	x	7.672	=	781.31	6065.22	/	58.01	=	104.6
C-3	99.19	x	7.473	=	741.28	6806.49	/	65.49	=	103.9
D-1	104.36	x	7.596	=	792.75	7599.24	/	73.08	=	104.0
D-2	100.50	x	7.840	=	787.84	8387.08	/	80.92	=	103.6
D-3	102.82	x	8.021	=	824.68	9211.76	/	88.94	=>	103.6

Last Pt

Percent Isokinetic (%) (intermediate equation, all points)

[equivalent to taking an average of point-by-point isokinetics without weighting the average (e.g. all points equal)]

$$I(\%) = \frac{K_4 \times ((t_s)_{avg} + T_u) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12} \right)^2 \right) \times \left(1 - \frac{B_{ws}}{100} \right)}$$

$$I(\%) = \frac{0.0945 \text{ min} \cdot \text{in. Hg}}{\text{sec} \cdot \text{°R}} \times (217.08 \text{ °F} + 460 \text{ °R}) \times 88.94 \text{ dscf}$$

$$243.00 \text{ min} \times \frac{65.88 \text{ ft}}{\text{sec}} \times 29.91 \text{ in. Hg} \times 3.14 \times \left(\frac{0.15 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}} \right)^2 \times \left(1 - \frac{8.16 \%}{100} \right) = 103.62 \%$$

Raw Data Percent Isokinetic (%)

[utilizes the raw data equation for isokinetics from Method 5]

$$I(\%) = \frac{100 \left((t_s)_{avg} + T_u \right) \left[K_4 V_{1c} + \frac{V_m Y}{(t_m)_{avg} + T_u} \left(P_{bar} + \frac{\Delta H}{13.6} \right) \right]}{60 \left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12} \right)^2 \right)}$$

$$100 \times (217.08 \text{ °F} + 460 \text{ °R}) \times \left[\frac{0.002669 \text{ ft}^3 \cdot \text{in. Hg}}{\text{ml} \cdot \text{°R}} \times 167.8 \text{ ml} + \frac{93.27 \text{ dcf} \times 0.962}{74.08 \text{ °F} + 460 \text{ °R}} \left(29.97 \text{ in Hg} + \frac{1.190}{13.6} \right) \right]$$

$$60 \times 243.00 \text{ min} \times \frac{65.88 \text{ ft}}{\text{sec}} \times 29.91 \text{ in. Hg} \times 3.14 \times \left(\frac{0.15 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}} \right)^2 = 103.75 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Gravimetric Analysis) [Values from Run 1 test]

Blank Concentration [Acetone Blank Weight of Solids] (mg/ml)

$$C_x (\text{mg/ml}) = \frac{1000 \text{ mg}}{\text{g}} \times \frac{0.0010 \text{ g}}{202.28 \text{ ml}} = \frac{0.0049 \text{ mg}}{\text{ml}}$$

$$C_x (\text{mg / ml}) = \frac{1000 \times W_x}{V_x} = \frac{0.0049 \text{ mg}}{\text{ml}}$$

Blank Adjustment [Acetone Blank Weight of Solids and Nozzle Wash PM>10] (mg)

$$W_x (\text{mg}) = V_x \times C_x$$

$$W_x (\text{mg}) = 70 \text{ ml} \times 0.0049 \text{ mg/ml} = 0.35 \text{ mg} < \text{Sample Gain}$$

Adjusted Sample Gain [Nozzle Wash PM>10] (mg)

$$m_{xadj} (\text{mg}) = m_x - W_x$$

$$m_{xadj} (\text{mg}) = 1.3 \text{ mg} - 0.35 \text{ mg} = 0.95 \text{ mg}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - Total PM₁₀/PM_{2.5} Mass]

Stack Total Concentration (g/dscf)

$$c_s (g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \quad c_s (g/dscf) = \frac{g}{1000 \text{ mg}} \times \frac{6.08 \text{ mg}}{88.94 \text{ dscf}} = \frac{6.84\text{E-}05 \text{ g}}{\text{dscf}}$$

Stack Total Concentration (gr/dscf)

$$c'_s (gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s (gr/dscf) = \frac{g}{1000 \text{ mg}} \times \frac{6.08 \text{ mg}}{88.94 \text{ dscf}} \times \frac{7000 \text{ gr}}{\text{lb}} \times \frac{\text{lb}}{453.592 \text{ g}} = \frac{1.06\text{E-}03 \text{ gr}}{\text{dscf}}$$

Total Emissions Rate (kg/hr)

$$E (kg/hr) = c_s \times Q_{sd} \times \frac{kg}{1000 \text{ g}}$$

$$E (kg/hr) = \frac{kg}{1000 \text{ g}} \times \frac{6.84\text{E-}05 \text{ g}}{\text{dscf}} \times \frac{48,135,876 \text{ dscf}}{\text{hr}} = \frac{3.29 \text{ kg}}{\text{hr}}$$

Total Emissions Rate (lb/hr)

$$E' (lb/hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{lb \times g}{453.592 \text{ g} \times 1000 \text{ mg}}$$

$$E' (lb/hr) = \frac{g}{1000 \text{ mg}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{6.08 \text{ mg}}{88.94 \text{ dscf}} \times \frac{48,135,876 \text{ dscf}}{\text{hr}} = \frac{7.26 \text{ lb}}{\text{hr}}$$

Total Emissions Rate (tpy)

$$E'' (ton/yr) = E' \times \frac{8760}{2000}$$

$$E'' (tpy) = \frac{\text{ton}}{2000 \text{ lb}} \times \frac{8,760 \text{ hr}}{\text{yr}} \times \frac{7.26 \text{ lb}}{\text{hr}} = \frac{31.79 \text{ ton}}{\text{yr}}$$

Total Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E''' (lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2} \right)$$

$$E''' (lb/MMBtu) = \frac{g}{1000 \text{ mg}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{6.08 \text{ mg}}{88.94 \text{ dscf}} \times \frac{8,633.27 \text{ dscf}}{\text{MMBtu}} \times \left(\frac{20.9}{20.9 - 13.6 \%} \right) = \frac{0.0037 \text{ lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Stack Gas Viscosity (μP) [based on preliminary data]

$$\mu(\mu\text{P}) = C_1 + C_2 \sqrt{T_s} + C_3 T_s^{-2} + C_4 (\%O_{2, wet}) - C_5 B_{ws} + C_6 B_{ws} T_s^2$$

$$\mu(\mu\text{P}) = -150.3162 \mu\text{P} + 13.4622 \sqrt{206 + 460} + 3.86153 \times 10^6 \left(\frac{206 + 460}{27.86} \right)^{-2} + 0.591123 \left(\frac{13.6}{100} \times (1 - \frac{12.00}{100}) \right) - 91.9723 \left(\frac{12.00}{100} \right) + 1.51761 \times 10^{-5} \left(\frac{12.00}{100} \right) \left(\frac{206 + 460}{27.86} \right)^2 = 202.65 \mu\text{P}$$

Cunningham Correction Factor

[based on preliminary data for a 2.25 micrometer diameter particle]

$$C = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}} \right] \left[\frac{T_s}{M_w} \right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{202.65 \mu\text{P}}{29.76 \text{ in Hg} \times 2.25 \mu\text{m}} \right) \left(\frac{206 + 460 \text{ }^\circ\text{R}}{27.86 \text{ lb / lb-mole}} \right)^{0.5} = 1.08$$

First calculation set using Cyclone I or Cyclone I and IV, assuming $N_{re} < 3,162$

Lower Limit Cut Diameter for Cyclone I (μm)

[assumes $N_{re} < 3,162$]

$$D_{50LL} (\mu\text{m}) = 9.507 C^{0.3007} \left[\frac{M_w P_s}{T_s} \right]^{0.1993}$$

$$D_{50LL} (\mu\text{m}) = 9.507 \times 1.08^{0.3007} \times \left(\frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ\text{R}} \right)^{0.1993} = 10.18 \mu\text{m}$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm)

[assumes $N_{re} < 3,162$]

$$D_{50T} (\mu\text{m}) = \left(\frac{11 + D_{50LL}}{2} \right)$$

$$D_{50T} (\mu\text{m}) = \frac{11 + 10.18 \mu\text{m}}{2} = 10.59 \mu\text{m}$$

Sampling Rate Using Both PM_{10} and $\text{PM}_{2.5}$ Cyclones (dscfm)

[assumes $N_{re} < 3,162$]

$$Q_s (\text{dscfm}) = Q_i (\text{dscfm}) = 0.07296 (\mu) \left[\frac{T_s}{M_w P_s} \right]^{0.2949} \left[\frac{1}{D_{50T}} \right]^{1.4102}$$

Q_s (dscfm) =

$$0.07296 \times 202.65 \mu\text{P} \times \left(\frac{206 + 460 \text{ }^\circ\text{R}}{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}} \right)^{0.2949} \times \left(\frac{1}{10.59 \mu\text{m}} \right)^{1.4102} = 0.50 \text{ dscfm}$$

Reynolds Number (dimensionless)

[verification of $N_{re} < 3,162$, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s} \right] \left[\frac{Q_s}{\mu} \right]$$

$$N_{re} = 8.64 \times 10^5 \times \frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ\text{R}} \times \frac{0.50 \text{ dscfm}}{202.65 \mu\text{P}} = 2638.90 < 3,162 \quad \text{Correct}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Second calculation set using Cyclone IV, assuming $N_{re} < 3,162$

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (μm)

[assumes $N_{re} < 3,162$]

$$D_{50} (\mu m) = 0.0024302 \left[\frac{\mu}{Q_s} \right]^{1.1791} \left[\frac{1}{C} \right]^{0.5} \left[\frac{T_s}{P_s M_w} \right]^{0.6790}$$

$$0.0024302 \times \left(\frac{202.65 \mu P}{0.50 \text{ dscfm}} \right)^{1.1791} \times \left(\frac{1}{1.08} \right)^{0.5} \times \left(\frac{206 + 460 \text{ }^\circ R}{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}} \right)^{0.6790} = 2.40 \mu m$$

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Less than 3,162 (dscfm)

$$Q_{IV} (\text{dscfm}) = 0.0060639 \left(\frac{\mu}{C^{0.4242}} \right) \left[\frac{P_s M_w}{T_s} \right]^{-0.5759} \left[\frac{1}{D_{50}} \right]^{-0.8481}$$

$$0.0060639 \times \left(\frac{202.65 \mu P}{1.08} \right)^{0.4242} \times \left(\frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ R} \right)^{-0.5759} \times \left(\frac{1}{2.40 \mu m} \right)^{0.8481} = 0.50 \text{ dscfm}$$

Reynolds Number (dimensionless)

[verification of $N_{re} < 3,162$, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s} \right] \left[\frac{Q_s}{\mu} \right]$$

Correct

$$N_{re} = 8.64 \times 10^5 \times \frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ R} \times \frac{0.50 \text{ dscfm}}{202.65 \mu P} = 2638.86 < 3,162$$

Third calculation set using Cyclone I or Cyclone I and IV, assuming $N_{re} \geq 3,162$

Lower Limit Cut Diameter for Cyclone I (μm)

[assumes $N_{re} \geq 3,162$]

$$D_{50LL} (\mu m) = 10.0959 C^{0.4400} \left[\frac{M_w P_s}{T_s} \right]^{0.0600}$$

$$D_{50LL} (\mu m) = 10.0959 \times 1.08^{0.4400} \times \left(\frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ R} \right)^{0.0600} = 10.60 \mu m$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm)

[assumes $N_{re} \geq 3,162$]

$$D_{50T} (\mu m) = \left(\frac{11 + D_{50LL}}{2} \right)$$

$$D_{50T} (\mu m) = \frac{11 + 10.60 \mu m}{2} = 10.80 \mu m$$

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (dscfm)

[assumes $N_{re} \geq 3,162$]

$$Q_s (\text{dscfm}) = Q_t (\text{dscfm}) = 0.07296 (\mu) \left[\frac{T_s}{M_w P_s} \right]^{0.2949} \left[\frac{1}{D_{50T}} \right]^{1.4102}$$

Q_s (dscfm) =

$$0.07296 \times 202.65 \mu P \times \left(\frac{206 + 460 \text{ }^\circ R}{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}} \right)^{0.2949} \times \left(\frac{1}{10.80 \mu m} \right)^{1.4102} = 0.48 \text{ dscfm}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Reynolds Number (dimensionless)

[verification of $N_{re} \geq 3,162$, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s} \right] \left[\frac{Q_s}{\mu} \right]$$

Wrong Assumption

$$N_{re} = 8.64 \times 10^5 \times \frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ\text{R}} \times \frac{0.48 \text{ dscfm}}{202.65 \text{ } \mu\text{P}} = 2565.96 < 3,162$$

Fourth calculation set using Cyclone IV, assuming $N_{re} \geq 3,162$

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (μm)

[assumes $N_{re} \geq 3,162$]

$$D_{50} (\mu\text{m}) = 0.019723 \left[\frac{\mu}{Q_s} \right]^{0.8058} \left[\frac{1}{C} \right]^{0.5} \left[\frac{T_s}{P_s M_w} \right]^{0.3058}$$

$D_{50} (\mu\text{m}) =$

$$0.019723 \times \left(\frac{202.65 \text{ } \mu\text{P}}{0.48 \text{ dscfm}} \right)^{0.8058} \times \left(\frac{1}{1.08} \right)^{0.5} \times \left(\frac{206 + 460 \text{ }^\circ\text{R}}{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}} \right)^{0.3058} = 2.30 \text{ } \mu\text{m}$$

Sampling Rate Using Only $\text{PM}_{2.5}$ Cyclone for N_{re} Greater than or Equal to 3,162 (dscfm)

$Q_{IV} (\text{dscfm}) =$

$$Q_{IV} (\text{dscfm}) = 0.007657 \left(\frac{\mu}{C^{0.6205}} \right) \left[\frac{P_s M_w}{T_s} \right]^{-0.3795} \left[\frac{1}{D_{50}} \right]^{1.241}$$

$$0.007657 \times \left(\frac{202.65 \text{ } \mu\text{P}}{1.08^{0.6205}} \right) \times \left(\frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ\text{R}} \right)^{-0.3795} \times \left(\frac{1}{2.30 \text{ } \mu\text{m}} \right)^{1.241} = 0.48 \text{ dscfm}$$

Reynolds Number (dimensionless)

[verification of $N_{re} \geq 3,162$, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s} \right] \left[\frac{Q_s}{\mu} \right]$$

Wrong Assumption

$$N_{re} = 8.64 \times 10^5 \times \frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ\text{R}} \times \frac{0.50 \text{ dscfm}}{202.65 \text{ } \mu\text{P}} = 2638.90 < 3,162$$

Meter Box Orifice Pressure Drop (in H_2O)

$$\Delta H (\text{in } \text{H}_2\text{O}) = \left[\frac{Q_s (1 - B_{vis}) P_s}{T_s} \right]^2 \left[\frac{1.083 T_m M_d \Delta H_{@}}{P_{bar}} \right]$$

$$\Delta H (\text{in } \text{H}_2\text{O}) = \left(\frac{0.50 \text{ dscfm} \times (1 - 12.00 / 100) \times 29.76 \text{ in Hg}}{206 + 460 \text{ }^\circ\text{R}} \right)^2 \times \left(\frac{1.083 \times (85.00 + 460 \text{ }^\circ\text{R}) \times 29.21 \text{ lb / lb-mole} \times 1.838 \text{ in } \text{H}_2\text{O}}{29.82 \text{ in Hg}} \right) = 0.406 \text{ in } \text{H}_2\text{O}$$

50 °F above stack temperature	$T_{s+50} =$	256	$\Delta H_{+50} =$	0.351	in H_2O
50 °F below stack temperature	$T_{s+50} =$	156	$\Delta H_{+50} =$	0.475	in H_2O

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Adjusted Velocity Pressure (in H₂O) [point A-1]

$$\Delta p_s (\text{inH}_2\text{O}) = \Delta p_m \left[\frac{C_p}{C'_p} \right]^2$$

$$\Delta p_s (\text{in H}_2\text{O}) = 1.40 \text{ in H}_2\text{O} \times \left(\frac{0.72}{0.72} \right)^2 = 1.40 \text{ in H}_2\text{O}$$

Average Probe Blockage Factor

$$b_f = \frac{22.0}{A}$$

$$b_f = \frac{22.0}{40828.14 \text{ in}^2} = 5.39\text{E-}04$$

Velocity Pressure Adjusted for Blockage Factor (in H₂O) [point A-1]

$$\Delta p_{s,2} (\text{inH}_2\text{O}) = \Delta p_{s,1} \left[\frac{1}{(1 - b_f)} \right]^2$$

$$\Delta p_s (\text{in H}_2\text{O}) = 1.80 \text{ in H}_2\text{O} \times \left(\frac{1}{(1 - 5.39\text{E-}04)} \right)^2 = 1.80 \text{ in H}_2\text{O}$$

Velocity of Stack Gas Adjusted for Blockage Factor (ft/sec)

$$v_s = K_p C_p \left(\sqrt{(\Delta p)} \right)_{avg} \left[\sqrt{\frac{T_s}{P_s M_w}} \right]$$

v_s (ft/sec) =

$$\frac{85.49 \text{ ft/sec}}{\text{lb/mole} \cdot ^\circ\text{R}} \times 0.72 \times 1.15 \times \left(\frac{206 + 460 \text{ }^\circ\text{R}}{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}} \right)^{0.5} = 63.53 \frac{\text{ft}}{\text{sec}}$$

Calculated Nozzle Diameter for Acceptable Sampling Rate (in)

$$D(\text{in}) = \left[\frac{3.056 Q_s}{v_s} \right]^{0.5}$$

$$D(\text{in}) = \left(\frac{3.056 \times 0.50 \text{ dscfm}}{63.53 \text{ ft/sec}} \right)^{0.5} = 0.155 \text{ in}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Velocity of Gas in Nozzle 3 (diam. = 0.151 in), (ft/sec)

$$v_n \text{ (ft/sec)} = \frac{0.50 \text{ dscfm}}{60 \text{ min / sec}} \times \frac{1.24E-04 \text{ ft}^2}{1} = 66.64 \frac{\text{ft}}{\text{sec}} \quad v_n = \left(\frac{Q_s}{60 \frac{\text{min}}{\text{sec}} A_n} \right)$$

Minimum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless)

Nozzle 3 (diam. = 0.151 in)

$$R_{\min} = \left[0.2457 + \left(0.3072 - \frac{0.2603 (\mu)(Q_s)^{0.5}}{v_n^{1.5}} \right)^{0.5} \right]$$

$$R_{\min} = 0.2457 + \left(0.3072 - \frac{0.2603 \times 202.65 \mu\text{P} \times (0.50 \text{ dscfm})^{0.5}}{64.91 \text{ in}^{1.5}} \right)^{0.5} = 0.73$$

Maximum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless)

Nozzle 3 (diam. = 0.151 in)

$$R_{\max} = \left[0.4457 + \left(0.5690 + \frac{0.2603 (\mu)(Q_s)^{0.5}}{v_n^{1.5}} \right)^{0.5} \right]$$

$$R_{\max} = 0.4457 + \left(0.5690 + \frac{0.2603 \times 202.65 \mu\text{P} \times (0.50 \text{ dscfm})^{0.5}}{64.91 \text{ in}^{1.5}} \right)^{0.5} = 1.25$$

Minimum Gas Velocity for R_{\min} Less than 0.5 (ft/sec)

Nozzle 3 (diam. = 0.151 in)

$$v_{\min} \text{ (ft / sec)} = v_n (0.5) \quad v_{\min} \text{ (ft/sec)} = 0.5 \times \frac{\text{ft}}{\text{sec}} = \frac{\text{ft}}{\text{sec}}$$

Minimum Gas Velocity for R_{\min} Greater than or Equal to 0.5 (ft/sec)

Nozzle 3 (diam. = 0.151 in)

$$v_{\min} \text{ (ft / sec)} = v_n R_{\min} \quad v_{\min} \text{ (ft/sec)} = 64.91 \frac{\text{ft}}{\text{sec}} \times 0.73 = 47.49 \frac{\text{ft}}{\text{sec}}$$

Maximum Gas Velocity for R_{\max} Less than 1.5 (ft/sec)

Nozzle 3 (diam. = 0.151 in)

$$v_{\max} \text{ (ft / sec)} = v_n R_{\max} \quad v_{\max} \text{ (ft/sec)} = 64.91 \frac{\text{ft}}{\text{sec}} \times 1.25 = 80.87 \frac{\text{ft}}{\text{sec}}$$

Maximum Gas Velocity for R_{\max} Greater than or Equal to 1.5 (ft/sec)

Nozzle 3 (diam. = 0.151 in)

$$v_{\max} \text{ (ft / sec)} = v_n (1.5) \quad v_{\max} \text{ (ft/sec)} = 1.5 \times \frac{\text{ft}}{\text{sec}} = \frac{\text{ft}}{\text{sec}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Minimum Velocity Pressure (in H₂O)

$$\Delta p_{\min} (\text{in H}_2\text{O}) = 1.3686 \times 10^{-4} \left[\frac{P_s M_w}{T_s} \right] \left[\frac{v_{\min}}{C_p} \right]^2$$

$$1.3686 \times 10^{-4} \times \left(\frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ\text{R}} \right) \times \left(\frac{47.49 \text{ ft/sec}}{0.72} \right)^2 = 0.73 \text{ in H}_2\text{O}$$

Maximum Velocity Pressure (in H₂O)

$$\Delta p_{\max} (\text{in H}_2\text{O}) = 1.3686 \times 10^{-4} \left[\frac{P_s M_w}{T_s} \right] \left[\frac{v_{\max}}{C_p} \right]^2$$

$$1.3686 \times 10^{-4} \times \left(\frac{29.76 \text{ in Hg} \times 27.86 \text{ lb / lb-mole}}{206 + 460 \text{ }^\circ\text{R}} \right) \times \left(\frac{80.87 \text{ ft/sec}}{0.72} \right)^2 = 2.13 \text{ in H}_2\text{O}$$

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Adjusted Velocity Pressure (in H₂O) [point A-1]

$$\Delta p_s (\text{in H}_2\text{O}) = \Delta p_m \left[\frac{C_p}{C_p^*} \right]^2$$

$$1.40 \text{ in H}_2\text{O} \times \left(\frac{0.72}{0.72} \right)^2 = 1.40 \text{ in H}_2\text{O}$$

Average Probe Blockage Factor

$$b_f = \frac{22.0}{40828.14 \text{ in}^2} = 5.39\text{E-}04$$

Velocity Pressure Adjusted for Blockage Factor (in H₂O) [point A-1]

$$\Delta p_{s,2} (\text{in H}_2\text{O}) = \Delta p_{s,1} \left[\frac{1}{(1 - b_f)} \right]^2$$

$$1.80 \text{ in H}_2\text{O} \times \left(\frac{1}{(1 - 5.39\text{E-}04)} \right)^2 = 1.80 \text{ in H}_2\text{O}$$

Sampling Dwell Time at Each Point (minutes) [point A-1]

$$t_n (\text{min}) = \left[\frac{C_p \sqrt{\Delta p_n}}{C_p^* (\sqrt{\Delta p_n})_{\text{avg}}} \right] \left[\frac{t_r}{N_p} \right]$$

$$t_n (\text{min}) = \left(\frac{0.72}{0.72} \times \left(\frac{1.80}{1.30} \right)^{0.5} \right) \times \left(\frac{240.00 \text{ min}}{12.00} \right) = 20.65 \text{ minutes}$$

Dry Gas Volume Sampled at Standard Conditions (dscf) [point A-1]

$$v_{ms} (\text{dscf}) = \left(\frac{528}{29.92} \right) \left(0.962 \times 8.35 \text{ dscf} \right) \times \left[\frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right]$$

$$\left(\frac{29.97 \text{ in Hg} + 0.40 \text{ in H}_2\text{O} / 13.6}{70.00 + 460 \text{ }^\circ\text{R}} \right) = 8.02 \text{ dscf}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sample Flow Rate at Standard Conditions (dscfm)

$$Q_{sST} (dscfm) = \frac{v_{ms}}{\Theta}$$

$$Q_{sST} (dscfm) = \frac{88.94 \text{ dscf}}{243.00 \text{ min}} = \frac{0.37 \text{ dscf}}{\text{min}}$$

Sampling Rate (dscfm) [e.g. cyclone flow rate]

$$Q_s (dscfm) = \frac{29.92}{528} Q_{sST} \left[\frac{1}{(1 - B_{vis})} \right] \left[\frac{T_s}{P_s} \right]$$

$$Q_s (dscfm) = \frac{29.92 \text{ in Hg}}{528 \text{ }^\circ\text{R}} \times \frac{0.37 \text{ dscf}}{\text{min}} \times \frac{1}{(1 - 8.16 / 100)} \times \frac{217 + 460 \text{ }^\circ\text{R}}{29.91 \text{ in Hg}} = 0.51 \text{ dscfm}$$

Reynolds Number (dimensionless)

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s} \right] \left[\frac{Q_s}{\mu} \right]$$

$$N_{re} = 8.64 \times 10^5 \times \frac{29.91 \text{ in Hg} \times 28.29 \text{ lb / lb-mole}}{217 + 460 \text{ }^\circ\text{R}} \times \frac{0.51 \text{ dscfm}}{208.85 \text{ } \mu\text{P}} = 2643.03$$

Actual Particle Cut Diameter for Cyclone I (μm)

$$D_{50} (\mu\text{m}) = 0.15625 \left[\frac{T_s}{M_w P_s} \right]^{0.2091} \left[\frac{\mu}{Q_s} \right]^{0.7091}$$

$$D_{50} (\mu\text{m}) = 0.15625 \times \left(\frac{217 + 460 \text{ }^\circ\text{R}}{29.91 \text{ in Hg} \times 28.29 \text{ lb / lb-mole}} \right)^{0.2091} \times \left(\frac{208.85 \text{ } \mu\text{P}}{0.51 \text{ dscfm}} \right)^{0.7091} = 10.60 \text{ } \mu\text{m}$$

Actual Particle Cut Diameter for Cyclone IV is determined by:

Cunningham Correction Factor (dimensionless)

[for a 2.5 micrometer diameter particle (estimated size)]

$$C = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}} \right] \left[\frac{T_s}{M_w} \right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{208.85 \text{ } \mu\text{P}}{29.91 \text{ in Hg} \times 2.5 \text{ } \mu\text{m}} \right) \left(\frac{217 + 460 \text{ }^\circ\text{R}}{28.29 \text{ lb / lb-mole}} \right)^{0.5} = 1.08$$

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (μm)

$D_{50} (\mu\text{m}) =$

$$D_{50} (\mu\text{m}) = 0.0024302 \left[\frac{\mu}{Q_s} \right]^{1.1791} \left[\frac{1}{C} \right]^{0.5} \left[\frac{T_s}{P_s M_w} \right]^{0.6790}$$

$$0.0024302 \times \left(\frac{208.85 \text{ } \mu\text{P}}{0.51 \text{ dscfm}} \right)^{1.1791} \times \left(\frac{1}{1.08} \right)^{0.5} \times \left(\frac{217 + 460 \text{ }^\circ\text{R}}{29.91 \text{ in Hg} \times 28.29 \text{ lb / lb-mole}} \right)^{0.6790} = 2.41 \text{ } \mu\text{m}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (μm)

$$D_{50} (\mu\text{m}) = 0.019723 \left(\frac{\mu\text{P}}{\text{dscfm}} \right)^{0.8058} \left(\frac{1}{\text{in Hg} \times \frac{+460 \text{ }^\circ\text{R}}{\text{lb / lb-mole}}} \right)^{0.5} \left[\frac{\mu}{Q_s} \right]^{0.8058} \left[\frac{1}{C} \right]^{0.5} \left[\frac{T_s}{P_s M_w} \right]^{0.3058}$$

Re-estimated Cunningham Correction Factor (dimensionless)

$$C_r = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}} \right] \left[\frac{T_s}{M_w} \right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{208.85 \mu\text{P}}{29.91 \text{ in Hg} \times 2.41 \mu\text{m}} \right) \left(\frac{217 + 460 \text{ }^\circ\text{R}}{28.29 \text{ lb / lb-mole}} \right)^{0.5} = 1.08$$

Re-calculated Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (μm)

$$D_{50-1} (\mu\text{m}) = 0.0024302 \left(\frac{208.85 \mu\text{P}}{0.51 \text{ dscfm}} \right)^{1.1791} \left(\frac{1}{1.08} \right)^{0.5} \left[\frac{\mu}{Q_s} \right]^{1.1791} \left[\frac{1}{C} \right]^{0.5} \left[\frac{T_s}{P_s M_w} \right]^{0.6790}$$

$$D_{50-1} (\mu\text{m}) = 0.0024302 \left(\frac{208.85 \mu\text{P}}{0.51 \text{ dscfm}} \right)^{1.1791} \left(\frac{1}{1.08} \right)^{0.5} \left(\frac{217 + 460 \text{ }^\circ\text{R}}{29.91 \text{ in Hg} \times 28.29 \text{ lb / lb-mole}} \right)^{0.6790} = 2.41 \mu\text{m}$$

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (μm)

$$D_{50-1} (\mu\text{m}) = 0.019723 \left(\frac{\mu\text{P}}{\text{dscfm}} \right)^{0.8058} \left(\frac{1}{\text{in Hg} \times \frac{+460 \text{ }^\circ\text{R}}{\text{lb / lb-mole}}} \right)^{0.5} \left[\frac{\mu}{Q_s} \right]^{0.8058} \left[\frac{1}{C} \right]^{0.5} \left[\frac{T_s}{P_s M_w} \right]^{0.3058}$$

Ratio (Z) Between D_{50} and D_{50-1} Values (dimensionless)

$$Z = \frac{D_{50-1}}{D_{50}} \quad Z = \frac{2.41 \mu\text{m}}{2.41 \mu\text{m}} = 1.00 \quad 0.99 \leq \left[Z = \left(\frac{D_{50}}{D_{50-1}} \right) \right] \leq 1.01$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - H₂SO₄ (IC)]

Stack H₂SO₄ Mass (mg)

$$M_n(mg) = \frac{M_n(lab)}{V_s(lab)} \times V_{sample} \times \frac{L}{1000ml} \quad M_n(mg) = \frac{L}{1000 ml} \times 0.10 \frac{mg}{L} \times 107.00 ml = 0.01 mg$$

Stack H₂SO₄ Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \quad c_s(g/dscf) = \frac{g}{1000 mg} \times \frac{0.01 mg}{37.73 dscf} = \frac{2.90E-07 g}{dscf}$$

Stack H₂SO₄ Concentration (gr/dscf)

$$c'_s(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s(g/dscf) = \frac{g}{1000 mg} \times \frac{0.01 mg}{37.73 dscf} \times \frac{7000 gr}{lb} \times \frac{lb}{453.592 g} = \frac{4.50E-06 gr}{dscf}$$

Stack H₂SO₄ Concentration (g/L)

$$c''_s(g/L) = c_s \times \frac{dscf}{28.31685 dsL}$$

$$c'_s(g/dscf) = 2.92E-07 \frac{g}{dscf} \times \frac{dscf}{28.31685 dsL} = \frac{1.00E-08 g}{L}$$

Stack H₂SO₄ Concentration (ppmvd)

$$c'''_s(ppmvd) = \frac{M_n}{V_{m(std)}} \times Ideal\ Gas\ Constant \times \frac{10^6 parts}{million\ parts} \times \frac{1}{Mol\ Wt}$$

$$c'''_s(ppmvd) = 1.03E-08 \frac{g}{L} \times \frac{24.04 L\ gas}{lb-mol} \times \frac{10^6 parts}{MM\ parts} \times \frac{lb-mol}{98.0790 lb} = 0.0025 ppmvd$$

H₂SO₄ Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2} \right)$$

$$E'''(lb/MMBtu) = \frac{g}{1000 mg} \times \frac{lb}{453.592 g} \times \frac{0.01 mg}{37.73 dscf} \times \frac{8,633.27 dscf}{MMBtu} \times \left(\frac{20.9}{20.9 - 13.4 \%} \right) = \frac{0.000015 lb}{MMBtu}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (FFACTOR)

RM 19, (02-27-14),
2.0 Summary of Method,
2.1 Emission Rates. Oxygen (O₂) or carbon dioxide (CO₂) concentrations and appropriate F factors (ratios of combustion gas volumes to heat inputs) are used to calculate pollutant emission rates from pollutant concentrations.

RM 19, (02-27-14),
12.2 Emission Rates of PM, SO₂, and NOx. Select from the following sections the applicable procedure to compute the PM, SO₂, or NOx emission rate (E) in lb/MMBtu. The pollutant concentration must be in lb/scf and the F factor must be in scf/MMBtu. If the pollutant concentration (C) is not in the appropriate units, use Table 19-1 in Section 17.0 to make the proper conversion. An F factor is the ratio of the gas volume of the products of combustion to the heat content of the fuel. The dry F factor (F_d) includes all components of combustion less water, the wet F factor (F_w) includes all components of combustion, and the carbon F factor (F_c) includes only carbon dioxide.

Mark's Std Hdbk, 10th ed.,pg 4-26
High Heat Value Dry (HHV_{dry}), calc for Methane (single component for the fuel gas)

$$HHV_{dry} (Btu / SCF) = \left[\left(\frac{M_{\%}}{100} \right) \times GCM \right] \quad HHV_{dry} = \frac{97.80 \%}{100.00} \times \frac{994.85 \text{ Btu}}{SCF} = \frac{972.91 \text{ Btu}}{SCF}$$

Mark's Std Hdbk, 10th ed., pg 4-26
Low Heat Value Dry (LHV_{dry}), calc for Methane (single component for the fuel gas)

$$LHV_{dry} (Btu / SCF) = \left[\left(\frac{M_{\%}}{100} \right) \times NCM \right] \quad LHV_{dry} = \frac{97.80 \%}{100.00} \times \frac{895.75 \text{ Btu}}{SCF} = \frac{876.00 \text{ Btu}}{SCF}$$

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
High Heat Value Wet (HHV_{wet}), calc for entire sample (all components of the fuel gas)

$$HHV_{wet} (Btu / SCF) = \frac{HHV_{dry}}{W / D. factor} \quad HHV_{wet} = \frac{1,005.86 \text{ Btu/SCF}}{1.0236} = 982.67 \text{ Btu/SCF}$$

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
Low Heat Value Wet (LHV_{wet}), calc for entire sample (all components of the fuel gas)

$$LHV_{wet} (Btu / SCF) = \frac{LHV_{dry}}{W / D. factor} \quad LHV_{wet} = \frac{906.15 \text{ Btu/SCF}}{1.0236} = 885.26 \text{ Btu/SCF}$$

Lbs Component per Lb-Mol of Gas (CM), calc for Methane (single component for the fuel gas)

$$CM (lb / lb - mol) = \left[\left(\frac{M_{\%}}{100} \right) \times MW \right] \quad CM = \frac{97.80 \%}{100.00} \times \frac{16.04 \text{ lb}}{\text{lb-mol}} = 15.69 \text{ lb/lb-mol}$$

ASTM D 3588

Fuel Molecular Weight (MW_{Fuel})

$$MW_{Fuel} (lb / lb \cdot mol) = \sum (CM) \quad MW_{Fuel} = 15.69 \text{ lb/lb-mol} + 0.55 \text{ lb/lb-mol} + \text{etc.} = 16.357 \text{ lb/lb-mol}$$

Btu per Lb of Gas Gross (GCV)

$$GCV (Btu / lb) = \left[\frac{HHV_{dry} \times G}{MW_{Fuel}} \right] \quad GCV = \frac{1,005.86 \text{ Btu/SCF} \times 385.23 \text{ ft}^3/\text{lbmol}}{16.357 \text{ lb/lb-mol}} = 23,689.40 \text{ Btu/lb}$$

ASTM D 3588 (SG)

Specific Gravity

$$SG = \left[\frac{MW_{Fuel}}{MW_{AIR}} \right] \quad SG = \frac{16.36 \text{ lb/lb-mol}}{28.96 \text{ lb/lb-mol}} = 0.5648$$

Btu per Lb of Gas Net (NCV)

$$NCV (Btu / lb) = \left[\frac{LHV_{dry} \times G}{MW_{Fuel}} \right] \quad NCV = \frac{906.15 \text{ Btu/SCF} \times 385.23 \text{ ft}^3/\text{lbmol}}{16.357 \text{ lb/lb-mol}} = 21,341.06 \text{ Btu/lb}$$

Weight Percent of Component (C%), methane

$$C_{\%} (\%) = \left[\left(\frac{CM}{MW_{Fuel}} \right) \times 100 \right]$$

$$C_{\%} = \frac{15.69 \text{ lb/lb-mol}}{16.36 \text{ lb/lb-mol}} \times 100 = 95.92 \%$$

Weight Percent of Volatile Organic Compounds (VOC%)

$$VOC_{\%} (\%) = \left[\sum_{C_2H_6}^{C_8H_{18}} M_{\%} \right] \quad VOC_{\%} = 0.12 \% + 0.00 \% + 0.00 \% + \text{etc.} = 0.12 \%$$

RM 19, (02-27-14), 12.3.2 Determined **F Factors**. If the fuel burned is not listed in Table 19-2 or if the owner or operator chooses to determine an F factor rather than use the values in Table 19-2, use the procedure below: 12.3.2.1 Equations. Use the eq

RM 19, (02-27-14),

12.1 Nomenclature

K (scf/lb)/%

H	3.64
C	1.53
S	0.57
N ₂	0.14
O ₂	0.46

$$F_d = \frac{K(K_{hd} \%H + K_c \%C + K_s \%S + K_n \%N - K_o \%O)}{GCV} \quad \text{Eq. 19-13}$$

$$F_d = \frac{10^6 \text{ Btu}}{\text{MMBtu}} \times \left[\frac{3.64 \text{ SCF}}{\text{lb} \cdot \%} \times 24.80 \% + \frac{1.53 \text{ SCF}}{\text{lb} \cdot \%} \times 74.62 \% + \frac{0.57 \text{ SCF}}{\text{lb} \cdot \%} \times 0.00 \% + \frac{0.14 \text{ SCF}}{\text{lb} \cdot \%} \times 0.51 \% - \frac{0.46 \text{ SCF}}{\text{lb} \cdot \%} \times 0.07 \% \right] \times \frac{\text{lb}}{23,689.40 \text{ Btu}} = \frac{8,632.22 \text{ SCF}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (INFORMATION)**Specific Humidity (RH_{sp})**

Note: RH_{sp} (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} (lb/lb) = \left[\left(\frac{gr}{lb} \right) \times \frac{lb}{7000 gr} \right]$$

$$RH_{sp} = \frac{68.12 \text{ gr}}{lb} \times \frac{1 \text{ lb}}{7000 \text{ gr}} = 0.009731 \frac{\text{lb H}_2\text{O}}{\text{lb Air}}$$

EXAMPLE CALCULATIONS (CALIBRATION)**Analyzer Calibration Error**

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100 \quad \text{Eq. 7E-1}$$

$$ACE = \frac{4.83 \text{ ppm} - 4.92 \text{ ppm}}{8.90 \text{ ppm}} \times 100 = -1.01 \%$$

Calibration Error and Estimated Point, RM 25A, THC/VOC Analyzer

RM 25A, (02-27-14), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC/VOC analyzer mid gas, if applicable)

$$E_p = \frac{C_{Dir(H)} - C_{Dir(Z)}}{C_{V(H)} - C_{V(Z)}} \times C_{Dir(M)} + C_{Dir(Z)} \quad \text{Eq. of a line}$$

Eq. of a line
y=mx+b

$$E_p = \frac{8.28 \text{ ppm} - 0.00 \text{ ppm}}{8.29 \text{ ppm} - 0.00 \text{ ppm}} \times 5.11 \text{ ppm} + 0.00 = 5.10 \text{ ppm}$$

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100 \quad \text{Eq. 7E-1}$$

$$ACE_{voc} = \frac{4.85 \text{ ppm} - 5.10 \text{ ppm}}{5.11 \text{ ppm}} \times 100 = -4.97 \%$$

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)**System Bias**

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS} \right) \times 100 \quad \text{Eq. 7E-2}$$

$$SB = \frac{4.85 \text{ ppm} - 4.83 \text{ ppm}}{8.90 \text{ ppm}} \times 100 = 0.22 \%$$

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{final} - SB_i| \quad \text{Eq. 7E-4}$$

$$D = |0.94 \% - 0.22 \%| = 0.72 \%$$

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |C_s - C_{dir}| is ≤ 0.5 ppmv or if |C_s - C_v| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Air} = |C_S - C_{Dir}| \quad \text{Eq. Section 13.2 and 13.3}$$

$$SB / D_{Air} = |4.85 \text{ ppm} - 4.83 \text{ ppm}| = 0.02 \text{ ppm}$$

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate C_{avg}, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of C_{avg} for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_o) \times \left(\frac{C_M}{C_M - C_o} \right) \quad \text{Eq. 7E-5b}$$

$$C_{Gas} = \left[2.08 \text{ ppm} - (-0.01 \text{ ppm}) \right] \left(\frac{4.92 \text{ ppm}}{4.88 \text{ ppm} - (-0.01 \text{ ppm})} \right) = 2.11 \text{ ppm}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Stack Exhaust Flow (Q_s) - RM19

$$Q_s = \left(\frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

Note: Equation presented in EPA Emission Measurement Center (EMC), Frequently Asked Questions (FAQ) for Method 19

$$Q_s = \frac{8,632.22 \text{ SCF}}{\text{MMBtu}} \times \frac{2,095,143.00 \text{ SCF}}{\text{hr}} \times \frac{1,005.86 \text{ Btu}}{\text{SCF}} \times \frac{\text{MMBtu}}{10^6 \text{ Btu}} \times \left(\frac{20.90\%}{20.9\% - 13.6\%} \right) = 51,977,205.83 \text{ SCFH}$$

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_W}{1 - B_{WS}} \quad \text{Eq. 7E-10} \quad C_D = \frac{1.97 \text{ ppmvw}}{1 - 0.06} = 2.11 \text{ ppmvc} \quad \text{or inversely,} \quad C_W = 2.11 \text{ ppmvd} \times \left(1 - 0.06 \right) = 1.97 \text{ ppmvw}$$

Diluent-Corrected Pollutant Concentration, O₂ Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O₂ Concentration. Calculate the O₂ corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(T arg et)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right) \quad \text{Eq. 20-4} \quad C_{adj} = 2.11 \text{ ppm} \times \left(\frac{20.9\% - 15.00\%}{20.9\% - 13.59\%} \right) = 1.70 \text{ ppm@15\%O}_2$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B
EMISSION DATA RECORDS

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
without Duct Burners Firing
Unit Operations Data**

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	206.87	2095143.28	0.00	89.11
Time	CT MEGAWATT SELECT MW 11HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 11HAD00EU001 XQ27	HRSG1 DB NG FLOW1 KPPH 11HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 11MBP10CF910 XQ07	
Note: System time offset					
one hour from run time		209.31358	2115002	9.58677	90.00289
2018/09/25 16:52:00:000		206.99046	2092509.8	0.0034248	89.15962
2018/09/25 16:53:00:000		206.99046	2093407.2	0.0034248	89.13533
2018/09/25 16:54:00:000		206.99046	2097966.5	0.0034248	89.13533
2018/09/25 16:55:00:000		206.65663	2097102	0.0034248	89.08363
2018/09/25 16:56:00:000		207.15526	2096651.5	0.0034248	89.08363
2018/09/25 16:57:00:000		207.15526	2096047.1	0.0034248	89.10239
2018/09/25 16:58:00:000		206.94987	2096424.8	0.0034248	89.10239
2018/09/25 16:59:00:000		206.94987	2096772.5	0.0034248	89.10239
2018/09/25 17:00:00:000		206.94987	2094151.4	0.0034248	89.1956
2018/09/25 17:01:00:000		206.94987	2097167.5	0.0034248	89.072205
2018/09/25 17:02:00:000		206.94987	2092217.2	0.0034248	89.21742
2018/09/25 17:03:00:000		206.94987	2095334.4	0.0034248	89.14716
2018/09/25 17:04:00:000		206.94987	2096876.1	0.0034248	89.14716
2018/09/25 17:05:00:000		206.94987	2097472.5	0.0034248	89.14716
2018/09/25 17:06:00:000		206.94987	2096614.5	0.0034248	89.14716
2018/09/25 17:07:00:000		206.94987	2096155.2	0.0034248	89.14716
2018/09/25 17:08:00:000		206.94987	2095696.1	0.0034248	89.14716
2018/09/25 17:09:00:000		206.94987	2095636	0.0034248	89.08043
2018/09/25 17:10:00:000		206.94987	2094032.4	0.0034248	89.08043
2018/09/25 17:11:00:000		206.94987	2094226.5	0.0034248	89.08043
2018/09/25 17:12:00:000		206.94987	2097049.6	0.0034248	89.15825
2018/09/25 17:13:00:000		206.94987	2096774.2	0.0034248	89.15825
2018/09/25 17:14:00:000		206.94987	2094190.4	0.0034248	89.15825
2018/09/25 17:15:00:000		206.94987	2094475.4	0.0034248	89.07872
2018/09/25 17:16:00:000		206.94987	2094886.4	0.0034248	89.07872
2018/09/25 17:17:00:000		206.75887	2094500.2	0.0034248	89.07872
2018/09/25 17:18:00:000		206.75887	2093104.8	0.0034248	89.07872
2018/09/25 17:19:00:000		206.75887	2093337.5	0.0034248	89.18068
2018/09/25 17:20:00:000		206.88487	2092853.1	0.0034248	88.94061
2018/09/25 17:21:00:000		206.88487	2097154.5	0.0034248	89.0938
2018/09/25 17:22:00:000		206.88487	2099829.2	0.0034248	89.12959
2018/09/25 17:23:00:000		206.88487	2093591.4	0.0034248	89.12959
2018/09/25 17:24:00:000		206.88487	2095542.2	0.0034248	89.06823
2018/09/25 17:25:00:000		206.88487	2095484	0.0034248	89.19249
2018/09/25 17:26:00:000		206.62627	2094707.4	0.0034248	89.00996
2018/09/25 17:27:00:000		206.62627	2094246.5	0.0034248	89.15744
2018/09/25 17:28:00:000		206.87631	2094093.4	0.0034248	89.15744
2018/09/25 17:29:00:000		206.87631	2093450.2	0.0034248	89.09917
2018/09/25 17:30:00:000		206.87631	2097591.5	0.0034248	89.154434
2018/09/25 17:31:00:000		206.87631	2097909	0.0034248	89.154434
2018/09/25 17:32:00:000		206.87631	2095809.4	0.0034248	89.154434
2018/09/25 17:33:00:000		206.87631	2096137.8	0.0034248	89.154434
2018/09/25 17:34:00:000		206.87631	2091909.4	0.0034248	89.10352
2018/09/25 17:35:00:000		206.26053	2091428.1	0.0034248	88.936356
2018/09/25 17:36:00:000		206.8802	2094122.2	0.0034248	89.00545
2018/09/25 17:37:00:000		206.8802	2093325.4	0.0034248	89.16067
2018/09/25 17:38:00:000		206.5308	2092300.4	0.0034248	89.16067
2018/09/25 17:39:00:000		207.01653	2092746.1	0.0034248	89.125916
2018/09/25 17:40:00:000		207.01653	2097315.5	0.0034248	89.125916
2018/09/25 17:41:00:000		207.01653	2096189.6	0.0034248	89.125916
2018/09/25 17:42:00:000		206.7468	2098122.2	0.0034248	89.125916
2018/09/25 17:43:00:000		206.7468	2093744.5	0.0034248	89.125916
2018/09/25 17:44:00:000		206.7468	2094777.4	0.0034248	89.09584
2018/09/25 17:45:00:000		206.7468	2096146.1	0.0034248	89.09584
2018/09/25 17:46:00:000		206.7468	2095318.5	0.0034248	89.09584
2018/09/25 17:47:00:000		206.7468	2095149.4	0.0034248	89.008415
2018/09/25 17:48:00:000		206.7468	2095221.9	0.0034248	89.12211
2018/09/25 17:49:00:000		206.7468	2095183.2	0.0034248	89.12211
2018/09/25 17:50:00:000		206.7468	2093189	0.0034248	89.0507
2018/09/25 17:51:00:000		206.65353	2093228.4	0.0034248	89.0507

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	206.42	2091745.53	0.00	89.00
Time	CT MEGAWATT SELECT MW 11HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 11HAD00EU001 XQ27	HRSG1 DB NG FLOW1 KPPH 11HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 11MBP10CF910 XQ07	
Note: System time offset					
one hour from run time		209.31358	2115002	9.58677	90.00289
2018/09/25 18:13:00:000		206.64647	2099081.2	0.0034248	89.04799
2018/09/25 18:14:00:000		206.64647	2094539	0.0034248	89.04799
2018/09/25 18:15:00:000		206.64647	2094997.1	0.0034248	89.04799
2018/09/25 18:16:00:000		206.64647	2094302.8	0.0034248	89.04799
2018/09/25 18:17:00:000		206.64647	2094282.8	0.0034248	89.04799
2018/09/25 18:18:00:000		206.58878	2090318.4	0.0034248	89.04799
2018/09/25 18:19:00:000		206.58878	2092167	0.0034248	88.96357
2018/09/25 18:20:00:000		206.58878	2091505.9	0.0034248	89.02887
2018/09/25 18:21:00:000		206.58878	2092198.2	0.0034248	89.02887
2018/09/25 18:22:00:000		206.58878	2092189.2	0.0034248	89.02887
2018/09/25 18:23:00:000		206.58878	2093576.4	0.0034248	89.02887
2018/09/25 18:24:00:000		206.58878	2094983.2	0.0034248	89.02887
2018/09/25 18:25:00:000		206.45906	2093198.9	0.0034248	89.02887
2018/09/25 18:26:00:000		206.45906	2091887.5	0.0034248	89.02887
2018/09/25 18:27:00:000		206.45906	2090737.2	0.0034248	88.97801
2018/09/25 18:28:00:000		206.61256	2091603.9	0.0034248	88.97801
2018/09/25 18:29:00:000		206.61256	2091672.9	0.0034248	89.07643
2018/09/25 18:30:00:000		206.61256	2091440.2	0.0034248	89.07643
2018/09/25 18:31:00:000		206.22247	2091084.4	0.0034248	89.0008
2018/09/25 18:32:00:000		206.55214	2091603.4	0.0034248	89.0008
2018/09/25 18:33:00:000		206.55214	2091855.6	0.0034248	89.0008
2018/09/25 18:34:00:000		206.55214	2095436	0.0034248	89.03546
2018/09/25 18:35:00:000		206.55214	2093949.6	0.0034248	89.004074
2018/09/25 18:36:00:000		206.41148	2092255.5	0.0034248	89.004074
2018/09/25 18:37:00:000		206.41148	2091066.6	0.0020549	89.004074
2018/09/25 18:38:00:000		206.41148	2091230.2	0.0020549	89.004074
2018/09/25 18:39:00:000		206.41148	2093310.5	0.0020549	89.004074
2018/09/25 18:40:00:000		206.41148	2092486.4	0.0020549	89.228745
2018/09/25 18:41:00:000		206.41148	2093448	0.0020549	89.02167
2018/09/25 18:42:00:000		206.41148	2092775	0.0020549	89.02167
2018/09/25 18:43:00:000		206.57852	2075268.5	0.0020549	88.90518
2018/09/25 18:44:00:000		206.43597	2073803.5	0.0020549	88.63934
2018/09/25 18:45:00:000		206.6159	2096943.5	0.0020549	89.24779
2018/09/25 18:46:00:000		206.6159	2080692.2	0.0020549	88.86258
2018/09/25 18:47:00:000		205.85535	2099319.2	0.0020549	89.22862
2018/09/25 18:48:00:000		205.7944	2086660.5	0.0020549	88.70805
2018/09/25 18:49:00:000		205.7944	2084174.8	0.0020549	88.86585
2018/09/25 18:50:00:000		206.63008	2099535	0.0020549	88.89804
2018/09/25 18:51:00:000		205.84076	2083590.9	0.0020549	88.89804
2018/09/25 18:52:00:000		206.42455	2102724.2	0.0020549	89.10206
2018/09/25 18:53:00:000		206.42455	2092766	0.0020549	88.96239
2018/09/25 18:54:00:000		206.42455	2083329.9	0.0020549	88.96239
2018/09/25 18:55:00:000		206.42455	2098301.8	0.0020549	89.09124
2018/09/25 18:56:00:000		206.42455	2101161.8	0.0020549	89.09124
2018/09/25 18:57:00:000		206.42455	2083091	0.0020549	88.91807
2018/09/25 18:58:00:000		206.42455	2089365	0.0020549	88.9963
2018/09/25 18:59:00:000		206.42455	2090626	0.0020549	89.129105
2018/09/25 19:00:00:000		206.42455	2095282.2	0.0020549	89.03006
2018/09/25 19:01:00:000		206.42455	2099796.8	0.0020549	89.03006
2018/09/25 19:02:00:000		206.42455	2084763.2	0.0020549	88.932434
2018/09/25 19:03:00:000		206.21455	2083993.1	0.0020549	88.932434
2018/09/25 19:04:00:000		206.21455	2092370.2	0.0020549	88.985275
2018/09/25 19:05:00:000		206.01367	2092254.1	0.0020549	88.985275
2018/09/25 19:06:00:000		206.01367	2092981.6	0.0020549	89.03348
2018/09/25 19:07:00:000		206.41437	2091353.9	0.0020549	88.8981
2018/09/25 19:08:00:000		206.41437	2093146.6	0.0020549	88.928246
2018/09/25 19:09:00:000		206.01884	2092370.8	0.0020549	88.928246
2018/09/25 19:10:00:000		206.43898	2095733.4	0.0020549	89.04379
2018/09/25 19:11:00:000		206.43898	2091357.4	0.0020549	88.968445
2018/09/25 19:12:00:000		206.43898	2092791.8	0.0020549	89.04931

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	206.13	2089719.89	0.00	88.89
Time	CT MEGAWATT SELECT MW 11HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 11HAD00EU001 XQ27	HRSG1 DB NG FLOW1 KPPH 11HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 11MBP10CF910 XQ07	
Note: System time offset					
one hour from run time		209.31358	2115002	9.58677	90.00289
2018/09/25 19:51:00:000		206.56883	2116054.8	0.0034248	89.16432
2018/09/25 19:52:00:000		205.9256	2068775.8	0.0034248	88.81766
2018/09/25 19:53:00:000		205.82968	2073306.9	0.0034248	88.8491
2018/09/25 19:54:00:000		207.25995	2091374.8	0.0034248	88.87486
2018/09/25 19:55:00:000		206.66446	2119962.8	0.0034248	88.87486
2018/09/25 19:56:00:000		205.99844	2077905.2	0.0034248	88.80574
2018/09/25 19:57:00:000		206.85045	2096751.8	0.0034248	89.06781
2018/09/25 19:58:00:000		206.16284	2080167	0.0034248	89.0939
2018/09/25 19:59:00:000		206.21808	2085168	0.0034248	88.792435
2018/09/25 20:00:00:000		206.21808	2094434.4	0.0034248	89.0389
2018/09/25 20:01:00:000		206.56924	2088555.6	0.0034248	89.0389
2018/09/25 20:02:00:000		206.28168	2085515.9	0.0034248	88.94696
2018/09/25 20:03:00:000		206.28168	2102217.8	0.0034248	89.107285
2018/09/25 20:04:00:000		206.28168	2084002	0.0034248	88.90076
2018/09/25 20:05:00:000		206.60124	2084337.8	0.0034248	88.96069
2018/09/25 20:06:00:000		206.60124	2105807.5	0.0034248	88.96069
2018/09/25 20:07:00:000		206.22162	2086970.2	0.0034248	88.82686
2018/09/25 20:08:00:000		206.22162	2085613.5	0.0034248	88.953
2018/09/25 20:09:00:000		206.22162	2088950.4	0.0034248	88.953
2018/09/25 20:10:00:000		206.22162	2092689.9	0.0034248	88.953
2018/09/25 20:11:00:000		206.22162	2094461	0.0034248	88.88961
2018/09/25 20:12:00:000		206.22162	2090973.9	0.0034248	88.88961
2018/09/25 20:13:00:000		206.22162	2091851.4	0.0034248	88.88961
2018/09/25 20:14:00:000		206.22162	2092508	0.0034248	88.88961
2018/09/25 20:15:00:000		206.22162	2092375.2	0.0034248	88.88961
2018/09/25 20:16:00:000		206.22162	2092007	0.0034248	88.88961
2018/09/25 20:17:00:000		205.9125	2088731.5	0.0034248	88.77124
2018/09/25 20:18:00:000		205.9125	2087706	0.0034248	88.84733
2018/09/25 20:19:00:000		205.9125	2086710.5	0.0034248	88.84733
2018/09/25 20:20:00:000		205.9125	2091696.9	0.0034248	88.8079
2018/09/25 20:21:00:000		205.9125	2087657.4	0.0034248	88.8079
2018/09/25 20:22:00:000		205.9125	2088221.1	0.0034248	88.92718
2018/09/25 20:23:00:000		205.9125	2088720.2	0.0034248	88.842316
2018/09/25 20:24:00:000		205.9125	2088217.6	0.0034248	88.74787
2018/09/25 20:25:00:000		205.9125	2085386.4	0.0034248	88.81616
2018/09/25 20:26:00:000		205.9125	2086311	0.0034248	88.81616
2018/09/25 20:27:00:000		205.9125	2087745.8	0.0034248	88.81616
2018/09/25 20:28:00:000		205.9125	2088240	0.0034248	88.81616
2018/09/25 20:29:00:000		205.9125	2088358.2	0.0034248	88.81616
2018/09/25 20:30:00:000		205.9125	2088962.5	0.0034248	88.94191
2018/09/25 20:31:00:000		205.9125	2089456.2	0.0034248	88.7471
2018/09/25 20:32:00:000		205.9125	2090222.5	0.0034248	88.86646
2018/09/25 20:33:00:000		206.20337	2089456.2	0.0034248	88.86646
2018/09/25 20:34:00:000		206.20337	2089701.5	0.0034248	88.94419
2018/09/25 20:35:00:000		206.20337	2092924	0.0034248	88.94419
2018/09/25 20:36:00:000		206.20337	2093724.8	0.0034248	88.94419
2018/09/25 20:37:00:000		206.20337	2089452.1	0.0034248	88.94419
2018/09/25 20:38:00:000		206.20337	2092892.4	0.0034248	88.94419
2018/09/25 20:39:00:000		206.20337	2089455.1	0.0034248	88.94419
2018/09/25 20:40:00:000		206.20337	2089094.5	0.0034248	88.94419
2018/09/25 20:41:00:000		206.20337	2089793.1	0.0034248	88.94419
2018/09/25 20:42:00:000		206.20337	2083521.6	0.0034248	88.87656
2018/09/25 20:43:00:000		206.20337	2085093.4	0.0034248	88.87656
2018/09/25 20:44:00:000		205.6989	2092485.1	0.0034248	88.77988
2018/09/25 20:45:00:000		205.6989	2088269.5	0.0034248	88.77988
2018/09/25 20:46:00:000		205.6989	2090368.8	0.0034248	88.86218
2018/09/25 20:47:00:000		205.6989	2081449.6	0.0034248	88.73709
2018/09/25 20:48:00:000		205.82227	2087796.6	0.0034248	88.85785
2018/09/25 20:49:00:000		205.82227	2089952.9	0.0034248	88.80904
2018/09/25 20:50:00:000		205.82227	2092679.5	0.0034248	88.78766

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
with Duct Burners Firing
Unit Operations Data**

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	211.11	2128585.04	16.10	90.64
Time	CT MEGAWATT SELECT MW 11HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 11HAD00EU001 XQ27	HRSG1 DB NG FLOW1 KPPH 11HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 11MBP10CF910 XQ07	
one hour from run time		209.31358	2115002	9.58677	90.00289
2018/09/25 10:20:00:000		211.48035	2116300	16.117199	90.57444
2018/09/25 10:21:00:000		211.48035	2132331.2	16.09117	90.82739
2018/09/25 10:22:00:000		211.48035	2139236.5	16.09117	90.659004
2018/09/25 10:23:00:000		211.23233	2122908	16.09117	90.69632
2018/09/25 10:24:00:000		211.61517	2140348	16.09117	90.69632
2018/09/25 10:25:00:000		211.61517	2124879.2	16.111032	90.631996
2018/09/25 10:26:00:000		211.34164	2120075	16.111032	90.76417
2018/09/25 10:27:00:000		211.34164	2143322.8	16.111032	90.92467
2018/09/25 10:28:00:000		211.34164	2122605.5	16.111032	90.75724
2018/09/25 10:29:00:000		211.34164	2129441.5	16.111032	90.75724
2018/09/25 10:30:00:000		211.67445	2150751.8	16.111032	90.92613
2018/09/25 10:31:00:000		211.21979	2123427.8	16.111032	90.69119
2018/09/25 10:32:00:000		211.21979	2124796.5	16.102129	90.6312
2018/09/25 10:33:00:000		211.21979	2135802	16.102129	90.71254
2018/09/25 10:34:00:000		211.21979	2122920	16.102129	90.71254
2018/09/25 10:35:00:000		211.21979	2125975	16.102129	90.81316
2018/09/25 10:36:00:000		211.21979	2142698.8	16.102129	90.81316
2018/09/25 10:37:00:000		211.21979	2125467.2	16.102129	90.59698
2018/09/25 10:38:00:000		211.21979	2120096.8	16.102129	90.670456
2018/09/25 10:39:00:000		211.21979	2142163.8	16.102129	90.670456
2018/09/25 10:40:00:000		211.21979	2127503.5	16.102129	90.45266
2018/09/25 10:41:00:000		211.20375	2121072.2	16.102129	90.45266
2018/09/25 10:42:00:000		211.20375	2137666.2	16.102129	90.648026
2018/09/25 10:43:00:000		211.20375	2131402	16.102129	90.648026
2018/09/25 10:44:00:000		211.05135	2119903.5	16.102129	90.648026
2018/09/25 10:45:00:000		211.05135	2125672.2	16.102129	90.648026
2018/09/25 10:46:00:000		211.05135	2138397.8	16.102129	90.648026
2018/09/25 10:47:00:000		211.05135	2127592.2	16.102129	90.648026
2018/09/25 10:48:00:000		210.76817	2120087.5	16.102129	90.648026
2018/09/25 10:49:00:000		211.04117	2125884.8	16.102129	90.82149
2018/09/25 10:50:00:000		211.04117	2133908.2	16.102129	90.73563
2018/09/25 10:51:00:000		211.37761	2135211.2	16.087059	90.62367
2018/09/25 10:52:00:000		211.37761	2130496.5	16.087059	90.62367
2018/09/25 10:53:00:000		210.71857	2131022.5	16.087059	90.51688
2018/09/25 10:54:00:000		211.08418	2133932.5	16.087059	90.51688
2018/09/25 10:55:00:000		211.08418	2126612.5	16.087059	90.56998
2018/09/25 10:56:00:000		211.08418	2127805.8	16.104183	90.6356
2018/09/25 10:57:00:000		210.66232	2123234.2	16.104183	90.64386
2018/09/25 10:58:00:000		210.66232	2126248	16.104183	90.64386
2018/09/25 10:59:00:000		211.00533	2129352.5	16.104183	90.64386
2018/09/25 11:00:00:000		211.00533	2124210.5	16.104183	90.813065
2018/09/25 11:01:00:000		211.00533	2126705	16.104183	90.664474
2018/09/25 11:02:00:000		211.00533	2126785.2	16.104183	90.5453
2018/09/25 11:03:00:000		211.00533	2131659.8	16.104183	90.5453
2018/09/25 11:04:00:000		211.00533	2125475.5	16.104183	90.5453
2018/09/25 11:05:00:000		211.00533	2131051	16.104183	90.5453
2018/09/25 11:06:00:000		210.60077	2125163	16.104183	90.68649
2018/09/25 11:07:00:000		211.00725	2123977.5	16.104183	90.68649
2018/09/25 11:08:00:000		211.00725	2126057.5	16.104183	90.68649
2018/09/25 11:09:00:000		211.00725	2124345.2	16.104183	90.68649
2018/09/25 11:10:00:000		211.09702	2127602.2	16.104183	90.54216
2018/09/25 11:11:00:000		211.09702	2131676.5	16.104183	90.54216
2018/09/25 11:12:00:000		210.89598	2123775.2	16.104183	90.42555
2018/09/25 11:13:00:000		210.89598	2130829	16.104183	90.57951
2018/09/25 11:14:00:000		210.89598	2130943	16.104183	90.57951
2018/09/25 11:15:00:000		211.12488	2129908	16.104183	90.503235
2018/09/25 11:16:00:000		211.12488	2129468.8	16.104183	90.503235
2018/09/25 11:17:00:000		210.86754	2124269.2	16.104183	90.503235
2018/09/25 11:18:00:000		210.66824	2119036.8	16.104183	90.503235
2018/09/25 11:19:00:000		210.66824	2123610.2	16.086374	90.581635

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	210.34	2122302.42	16.11	90.36
Time	CT MEGAWATT SELECT MW 11HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 11HAD00EU001 XQ27	HRSG1 DB NG FLOW1 KPPH 11HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 11MBP10CF910 XQ07	
one hour from run time		209.31358	2115002	9.58677	90.00289
2018/09/25 11:44:00:000		210.52037	2120418	16.10487	90.531006
2018/09/25 11:45:00:000		210.52037	2127214.8	16.10487	90.531006
2018/09/25 11:46:00:000		210.52037	2126690.5	16.10487	90.531006
2018/09/25 11:47:00:000		210.52037	2125035.5	16.10487	90.531006
2018/09/25 11:48:00:000		210.74509	2125670	16.10487	90.49521
2018/09/25 11:49:00:000		210.74509	2124724.8	16.10487	90.49521
2018/09/25 11:50:00:000		210.74509	2124490	16.10487	90.49521
2018/09/25 11:51:00:000		210.41583	2122780.2	16.10487	90.37451
2018/09/25 11:52:00:000		210.41583	2119236.2	16.10487	90.37451
2018/09/25 11:53:00:000		210.5239	2119803	16.10487	90.37451
2018/09/25 11:54:00:000		210.5239	2124700	16.10487	90.37451
2018/09/25 11:55:00:000		210.5239	2120789	16.10487	90.37451
2018/09/25 11:56:00:000		210.5239	2125804.8	16.10487	90.49695
2018/09/25 11:57:00:000		210.5239	2121981.2	16.10487	90.339714
2018/09/25 11:58:00:000		210.5239	2122448.5	16.10487	90.403694
2018/09/25 11:59:00:000		210.5239	2121992.2	16.10487	90.403694
2018/09/25 12:00:00:000		210.5239	2124186.2	16.10487	90.403694
2018/09/25 12:01:00:000		210.5239	2125309.5	16.10487	90.403694
2018/09/25 12:02:00:000		210.5239	2124789.2	16.10487	90.403694
2018/09/25 12:03:00:000		210.5239	2124952.8	16.10487	90.403694
2018/09/25 12:04:00:000		210.46133	2125066.2	16.10487	90.403694
2018/09/25 12:05:00:000		210.46133	2125542	16.10487	90.403694
2018/09/25 12:06:00:000		210.46133	2123810.5	16.10487	90.30316
2018/09/25 12:07:00:000		210.46133	2124242.2	16.10487	90.37359
2018/09/25 12:08:00:000		210.17078	2124709	16.10487	90.37359
2018/09/25 12:09:00:000		210.25044	2121489.2	16.10487	90.37359
2018/09/25 12:10:00:000		210.25044	2123445	16.10487	90.290344
2018/09/25 12:11:00:000		210.45561	2124078	16.10487	90.290344
2018/09/25 12:12:00:000		210.45561	2125115.5	16.117884	90.414764
2018/09/25 12:13:00:000		210.45561	2121459.5	16.117884	90.30348
2018/09/25 12:14:00:000		210.34253	2116806.2	16.117884	90.30348
2018/09/25 12:15:00:000		210.34253	2120096	16.117884	90.4102
2018/09/25 12:16:00:000		210.34253	2117794	16.097334	90.4102
2018/09/25 12:17:00:000		210.34253	2119002.2	16.097334	90.37479
2018/09/25 12:18:00:000		210.34253	2124024.2	16.097334	90.22237
2018/09/25 12:19:00:000		210.34253	2125842.5	16.097334	90.288414
2018/09/25 12:20:00:000		210.34253	2123173.8	16.097334	90.288414
2018/09/25 12:21:00:000		210.09712	2118778.2	16.097334	90.288414
2018/09/25 12:22:00:000		210.09712	2124820.5	16.097334	90.288414
2018/09/25 12:23:00:000		210.09712	2120403.2	16.097334	90.212166
2018/09/25 12:24:00:000		210.09712	2120038.8	16.111032	90.212166
2018/09/25 12:25:00:000		210.09712	2121054.8	16.111032	90.3448
2018/09/25 12:26:00:000		210.09712	2120821.5	16.111032	90.3448
2018/09/25 12:27:00:000		210.09712	2120247	16.111032	90.450775
2018/09/25 12:28:00:000		210.09712	2119518.5	16.111032	90.450775
2018/09/25 12:29:00:000		210.64842	2118431.5	16.111032	90.450775
2018/09/25 12:30:00:000		210.32823	2123664.2	16.111032	90.450775
2018/09/25 12:31:00:000		210.32823	2119287.2	16.111032	90.35276
2018/09/25 12:32:00:000		210.25775	2123081.8	16.100075	90.15761
2018/09/25 12:33:00:000		210.25775	2122206	16.100075	90.23875
2018/09/25 12:34:00:000		210.25775	2120855	16.100075	90.34223
2018/09/25 12:35:00:000		210.02289	2121021.8	16.100075	90.20767
2018/09/25 12:36:00:000		210.02289	2121781.8	16.100075	90.342606
2018/09/25 12:37:00:000		210.02289	2123969.8	16.100075	90.28888
2018/09/25 12:38:00:000		210.02289	2118681.8	16.100075	90.28888
2018/09/25 12:39:00:000		210.13275	2121207	16.112404	90.281784
2018/09/25 12:40:00:000		210.13275	2117412.2	16.112404	90.15707
2018/09/25 12:41:00:000		210.04501	2121432.5	16.112404	90.286964
2018/09/25 12:42:00:000		210.04501	2121805.8	16.112404	90.22057
2018/09/25 12:43:00:000		210.04501	2118912	16.112404	90.22057

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	209.27	2114001.84	16.10	90.00
Time	CT MEGAWATT SELECT MW 11HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 11HAD00EU001 XQ27	HRSG1 DB NG FLOW1 KPPH 11HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 11MBP10CF910 XQ07	
one hour from run time		209.31358	2115002	9.58677	90.00289
2018/09/25 13:10:00:000		210.22772	2120308.5	16.108294	90.24419
2018/09/25 13:11:00:000		209.71103	2117708.8	16.108294	90.24419
2018/09/25 13:12:00:000		209.71103	2118607	16.108294	90.08908
2018/09/25 13:13:00:000		209.71103	2119009.5	16.102129	90.08908
2018/09/25 13:14:00:000		209.71103	2120395.2	16.102129	90.14778
2018/09/25 13:15:00:000		209.71103	2115919.8	16.102129	90.14778
2018/09/25 13:16:00:000		209.71103	2113974.5	16.102129	90.14778
2018/09/25 13:17:00:000		209.71103	2114394.8	16.102129	90.14778
2018/09/25 13:18:00:000		209.71103	2117719.2	16.102129	90.14778
2018/09/25 13:19:00:000		209.71103	2117234.2	16.102129	90.14778
2018/09/25 13:20:00:000		209.71103	2117004	16.102129	90.14778
2018/09/25 13:21:00:000		209.71103	2117936	16.102129	90.14778
2018/09/25 13:22:00:000		209.71103	2116195.5	16.102129	90.14778
2018/09/25 13:23:00:000		209.71103	2113952.2	16.102129	90.14778
2018/09/25 13:24:00:000		209.71103	2119100.8	16.102129	90.28032
2018/09/25 13:25:00:000		209.71103	2120193.2	16.102129	90.20247
2018/09/25 13:26:00:000		209.49774	2116773.8	16.102129	90.20247
2018/09/25 13:27:00:000		209.49774	2116484	16.102129	90.12979
2018/09/25 13:28:00:000		209.49774	2111807.5	16.102129	90.12979
2018/09/25 13:29:00:000		209.49774	2117844	16.102129	90.12979
2018/09/25 13:30:00:000		209.49774	2114737	16.102129	90.12979
2018/09/25 13:31:00:000		209.49774	2114531.5	16.102129	90.12979
2018/09/25 13:32:00:000		209.49774	2114812.5	16.098019	90.05994
2018/09/25 13:33:00:000		209.49774	2115912.5	16.098019	90.05994
2018/09/25 13:34:00:000		209.29831	2114198.5	16.098019	90.05994
2018/09/25 13:35:00:000		209.29831	2114719.8	16.098019	90.05994
2018/09/25 13:36:00:000		209.29831	2107062.5	16.098019	90.05994
2018/09/25 13:37:00:000		209.29831	2111946.5	16.098019	89.97656
2018/09/25 13:38:00:000		209.29831	2116451.5	16.098019	89.907135
2018/09/25 13:39:00:000		209.29831	2123952.8	16.098019	89.98874
2018/09/25 13:40:00:000		209.29831	2109316.5	16.098019	89.92592
2018/09/25 13:41:00:000		209.29831	2104508	16.098019	89.92592
2018/09/25 13:42:00:000		209.29831	2108646.2	16.098019	89.92592
2018/09/25 13:43:00:000		209.29831	2120345	16.098019	90.01801
2018/09/25 13:44:00:000		209.05458	2118048.8	16.098019	89.93681
2018/09/25 13:45:00:000		209.05458	2104046	16.098019	89.833115
2018/09/25 13:46:00:000		209.05458	2107801.5	16.098019	90.0179
2018/09/25 13:47:00:000		209.05458	2113493.8	16.098019	90.0179
2018/09/25 13:48:00:000		209.05458	2113356.5	16.098019	89.94121
2018/09/25 13:49:00:000		209.05458	2110914.5	16.098019	89.94121
2018/09/25 13:50:00:000		209.05458	2111504.2	16.098019	89.94121
2018/09/25 13:51:00:000		209.05458	2116488.5	16.098019	89.94121
2018/09/25 13:52:00:000		209.05458	2113376.8	16.098019	89.94121
2018/09/25 13:53:00:000		208.63916	2113555	16.098019	89.79225
2018/09/25 13:54:00:000		208.63916	2114255	16.098019	89.79225
2018/09/25 13:55:00:000		208.99493	2113951	16.098019	89.72542
2018/09/25 13:56:00:000		208.99493	2115173.5	16.098019	89.77428
2018/09/25 13:57:00:000		208.99493	2114126	16.098019	89.77428
2018/09/25 13:58:00:000		208.99493	2113314.2	16.098019	89.8209
2018/09/25 13:59:00:000		208.99493	2109122	16.098019	89.8209
2018/09/25 14:00:00:000		208.99493	2114408.5	16.098019	89.830246
2018/09/25 14:01:00:000		208.8409	2112427.2	16.098019	89.830246
2018/09/25 14:02:00:000		208.8409	2110720	16.098019	89.92894
2018/09/25 14:03:00:000		208.53719	2109238	16.098019	89.92894
2018/09/25 14:04:00:000		208.64731	2107288.8	16.098019	89.83522
2018/09/25 14:05:00:000		208.64731	2111991	16.098019	89.83522
2018/09/25 14:06:00:000		208.64731	2109375.5	16.098019	89.83522
2018/09/25 14:07:00:000		208.64731	2109820.5	16.098019	89.69255
2018/09/25 14:08:00:000		208.86307	2108894.8	16.098019	89.80907
2018/09/25 14:09:00:000		208.86307	2109715.2	16.098019	89.80907

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
without Duct Burners Firing
NO_x, CO, VOC, CO₂, and O₂ Data**

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-1
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,095,143	SCFH
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,095,143	SCFH

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	96	%
Ambient Temperature	58	°F
Specific Humidity	0.009731	lb H ₂ O / lb air

Unit Data

Unit Load	206.9	megawatts
Meas. Stack Moisture	6.4	%
Stack Exhaust Flow (M19)	51,977,206	SCFH

Base Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO ₂ (%)
09/25/18 15:52:46	101940	13.58	2.25	-0.35	0.57	4.12
09/25/18 15:53:46	102000	13.57	2.23	-0.37	0.55	4.12
09/25/18 15:54:46	102060	13.58	2.23	-0.37	0.58	4.13
09/25/18 15:55:46	102120	13.58	2.16	-0.39	0.62	4.13
09/25/18 15:56:46	102180	13.59	2.16	-0.37	0.63	4.13
09/25/18 15:57:46	102240	13.58	2.13	-0.37	0.66	4.12
09/25/18 15:58:46	102300	13.60	2.13	-0.38	0.65	4.12
09/25/18 15:59:46	102360	13.59	2.10	-0.37	0.68	4.11
09/25/18 16:00:46	102420	13.59	2.08	-0.34	0.68	4.12
09/25/18 16:01:46	102480	13.58	2.03	-0.34	0.65	4.11
09/25/18 16:02:46	102540	13.60	2.05	-0.37	0.63	4.12
09/25/18 16:03:46	102600	13.58	2.07	-0.38	0.63	4.12
09/25/18 16:04:46	102660	13.58	2.06	-0.37	0.61	4.12
09/25/18 16:05:46	102720	13.58	2.04	-0.37	0.58	4.12
09/25/18 16:06:46	102780	13.57	2.02	-0.38	0.56	4.12
09/25/18 16:07:46	102840	13.57	2.00	-0.36	0.54	4.12
09/25/18 16:08:46	102900	13.55	1.99	-0.39	0.52	4.12
09/25/18 16:09:46	102960	13.54	1.98	-0.39	0.52	4.12
09/25/18 16:10:46	103020	13.53	1.99	-0.36	0.51	4.12
09/25/18 16:11:46	103080	13.52	2.02	-0.37	0.50	4.12
09/25/18 16:12:46	103140	13.48	2.01	-0.39	0.50	4.11
09/25/18 16:13:46	103200	13.41	2.03	-0.40	0.48	4.12
09/25/18 16:14:46	103260	13.40	2.04	-0.39	0.46	4.12
09/25/18 16:15:46	103320	13.39	2.04	-0.37	0.47	4.13
09/25/18 16:16:46	103380	13.41	2.06	-0.35	0.48	4.12
09/25/18 16:17:46	103440	13.46	2.04	-0.33	0.45	4.12
09/25/18 16:18:46	103500	13.56	2.05	-0.39	0.44	4.12
09/25/18 16:19:46	103560	13.44	2.10	-0.38	0.43	4.12
09/25/18 16:20:46	103620	13.44	2.07	-0.38	0.42	4.11
09/25/18 16:21:46	103680	13.42	2.06	-0.41	0.43	4.10
09/25/18 16:22:46	103740	13.43	2.06	-0.37	0.44	4.10
09/25/18 16:23:46	103800	13.45	2.08	-0.39	0.44	4.11
09/25/18 16:24:46	103860	13.45	2.07	-0.40	0.43	4.12
09/25/18 16:25:46	103920	13.42	2.04	-0.40	0.43	4.13
09/25/18 16:26:46	103980	13.41	2.04	-0.38	0.42	4.12
09/25/18 16:27:46	104040	13.69	2.08	-0.44	0.43	4.12
09/25/18 16:28:46	104100	13.97	2.07	-0.41	0.43	4.12
09/25/18 16:29:46	104160	13.65	2.07	-0.42	0.43	4.11
09/25/18 16:30:46	104220	13.50	2.12	-0.41	0.42	4.11
09/25/18 16:31:46	104280	13.48	2.09	-0.42	0.43	4.11
09/25/18 16:32:46	104340	13.49	2.07	-0.39	0.44	4.11
09/25/18 16:33:46	104400	13.49	2.08	-0.39	0.46	4.11
09/25/18 16:34:46	104460	13.48	2.12	-0.36	0.45	4.11
09/25/18 16:35:46	104520	13.44	2.11	-0.40	0.44	4.12
09/25/18 16:36:46	104580	13.44	2.11	-0.40	0.47	4.12
09/25/18 16:37:46	104640	13.44	2.12	-0.38	0.49	4.12
09/25/18 16:38:46	104700	13.43	2.16	-0.39	0.47	4.11
09/25/18 16:39:46	104760	13.44	2.14	-0.40	0.46	4.12
09/25/18 16:40:46	104820	13.47	2.15	-0.43	0.45	4.11
09/25/18 16:41:46	104880	13.47	2.13	-0.42	0.46	4.11
09/25/18 16:42:46	104940	13.41	2.09	-0.44	0.46	4.10
09/25/18 16:43:46	105000	13.41	2.12	-0.43	0.47	4.11
09/25/18 16:44:46	105060	13.42	2.13	-0.43	0.46	4.10
09/25/18 16:45:46	105120	13.45	2.08	-0.43	0.48	4.11
09/25/18 16:46:46	105180	13.50	2.09	-0.44	0.50	4.10
09/25/18 16:47:46	105240	13.52	2.07	-0.44	0.50	4.11
09/25/18 16:48:46	105300	13.54	2.09	-0.42	0.50	4.11
09/25/18 16:49:46	105360	13.52	2.10	-0.43	0.52	4.12
09/25/18 16:50:46	105420	13.46	2.10	-0.42	0.53	4.11
09/25/18 16:51:46	105480	13.55	2.09	-0.42	0.54	4.11

RAW AVERAGE **13.51** **2.08** **-0.39** **0.51** **4.12**

	Serial Number: INST-O2-0017 INST-NX-0043 INST-CO-0018 INST-TH-0009 INST-C2-0018				
	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO ₂ (%)
Initial Zero	0.03	0.00	0.06	0.01	0.08
Final Zero	0.03	-0.02	-0.07	0.01	0.08
Avg. Zero	0.03	-0.01	-0.01	0.01	0.08
Initial UpScale	12.00	4.85	5.09	3.07	8.79
Final UpScale	11.98	4.91	4.97	3.13	8.75
Avg. UpScale	11.99	4.88	5.03	3.10	8.77
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92

EMISSIONS DATA	O ₂	NOx	CO	VOC	CO ₂
Corrected Raw Average (ppm/% dry basis)	13.59	2.11	0.00	0.54	4.14
Concentration (ppm@ 15%O ₂)	N/A	1.70	0.00	0.44	N/A

Non-Bias Adjusted Averages Include:

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-1
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,091,745	SCFH
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,091,745	SCFH

Weather Data

Barometric Pressure	30.22	in. Hg
Relative Humidity	93	%
Ambient Temperature	60	° F
Specific Humidity	0.010153	lb H ₂ O / lb air

Unit Data

Unit Load	206.4	megawatts
Meas. Stack Moisture	9.0	%
Stack Exhaust Flow (M19)	51,486,411	SCFH

Base Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO ₂ (%)
09/25/18 17:13:46	106800	13.44	2.13	-0.45	0.14	4.16
09/25/18 17:14:46	106860	13.88	2.11	-0.45	0.15	4.15
09/25/18 17:15:46	106920	13.65	2.12	-0.45	0.15	4.15
09/25/18 17:16:46	106980	13.69	2.15	-0.45	0.14	4.16
09/25/18 17:17:46	107040	13.89	2.15	-0.45	0.16	4.17
09/25/18 17:18:46	107100	13.41	2.12	-0.44	0.15	4.16
09/25/18 17:19:46	107160	13.42	2.13	-0.45	0.16	4.17
09/25/18 17:20:46	107220	13.42	2.14	-0.45	0.17	4.16
09/25/18 17:21:46	107280	13.44	2.12	-0.45	0.17	4.16
09/25/18 17:22:46	107340	13.41	2.11	-0.45	0.18	4.16
09/25/18 17:23:46	107400	13.40	2.12	-0.45	0.18	4.16
09/25/18 17:24:46	107460	13.42	2.11	-0.46	0.18	4.16
09/25/18 17:25:46	107520	13.42	2.10	-0.45	0.17	4.16
09/25/18 17:26:46	107580	13.41	2.08	-0.45	0.15	4.17
09/25/18 17:27:46	107640	13.40	2.13	-0.45	0.14	4.18
09/25/18 17:28:46	107700	13.39	1.99	-0.45	0.14	4.18
09/25/18 17:29:46	107760	13.38	1.93	-0.45	0.16	4.17
09/25/18 17:30:46	107820	13.39	2.14	-0.45	0.14	4.17
09/25/18 17:31:46	107880	13.39	2.12	-0.46	0.15	4.16
09/25/18 17:32:46	107940	13.38	2.09	-0.45	0.18	4.17
09/25/18 17:33:46	108000	13.38	2.10	-0.45	0.18	4.17
09/25/18 17:34:46	108060	13.38	1.65	-0.46	0.19	4.17
09/25/18 17:35:46	108120	13.39	2.11	-0.45	0.18	4.17
09/25/18 17:36:46	108180	13.38	1.80	-0.46	0.19	4.17
09/25/18 17:37:46	108240	13.38	1.38	-0.45	0.21	4.16
09/25/18 17:38:46	108300	13.38	1.63	-0.45	0.21	4.15
09/25/18 17:39:46	108360	13.37	1.49	-0.46	0.18	4.15
09/25/18 17:40:46	108420	13.37	1.71	-0.46	0.17	4.15
09/25/18 17:41:46	108480	13.36	2.12	-0.45	0.17	4.16
09/25/18 17:42:46	108540	13.36	1.68	-0.46	0.16	4.16
09/25/18 17:43:46	108600	13.36	1.90	-0.45	0.17	4.16
09/25/18 17:44:46	108660	13.36	1.34	-0.45	0.17	4.16
09/25/18 17:45:46	108720	13.36	1.47	-0.45	0.18	4.16
09/25/18 17:46:46	108780	13.37	1.11	-0.42	0.19	4.16
09/25/18 17:47:46	108840	13.36	1.48	-0.46	0.18	4.17
09/25/18 17:48:46	108900	13.36	1.33	-0.46	0.19	4.16
09/25/18 17:49:46	108960	13.36	1.39	-0.46	0.18	4.17
09/25/18 17:50:46	109020	13.36	1.49	-0.46	0.17	4.16
09/25/18 17:51:46	109080	13.36	1.84	-0.46	0.17	4.17
09/25/18 17:52:46	109140	13.35	0.97	-0.46	0.20	4.17
09/25/18 17:53:46	109200	13.37	0.99	-0.46	0.20	4.16
09/25/18 17:54:46	109260	13.38	1.08	-0.45	0.18	4.15
09/25/18 17:55:46	109320	13.37	1.47	-0.46	0.17	4.16
09/25/18 17:56:46	109380	13.37	1.79	-0.46	0.17	4.16
09/25/18 17:57:46	109440	13.36	1.38	-0.45	0.16	4.16
09/25/18 17:58:46	109500	13.36	1.27	-0.46	0.15	4.16
09/25/18 17:59:46	109560	13.36	1.63	-0.45	0.16	4.17
09/25/18 18:00:46	109620	13.36	1.10	-0.46	0.16	4.17
09/25/18 18:01:46	109680	13.36	1.60	-0.46	0.19	4.16
09/25/18 18:02:46	109740	13.36	1.03	-0.46	0.19	4.15
09/25/18 18:03:46	109800	13.36	1.39	-0.46	0.20	4.15
09/25/18 18:04:46	109860	13.35	1.21	-0.46	0.17	4.17
09/25/18 18:05:46	109920	13.36	1.71	-0.45	0.16	4.17
09/25/18 18:06:46	109980	13.36	1.50	-0.46	0.18	4.16
09/25/18 18:07:46	110040	13.36	1.21	-0.45	0.19	4.16
09/25/18 18:08:46	110100	13.36	1.14	-0.46	0.19	4.16
09/25/18 18:09:46	110160	13.36	0.72	-0.46	0.20	4.15
09/25/18 18:10:46	110220	13.36	1.80	-0.46	0.19	4.16
09/25/18 18:11:46	110280	13.36	1.47	-0.46	0.17	4.16
09/25/18 18:12:46	110340	13.37	1.27	-0.46	0.15	4.16

RAW AVERAGE

13.40 1.68 -0.45 0.17 4.16

Serial Number: INST-O2-0017 INST-NX-0043 INST-CO-0018 INST-TH-0009 INST-C2-0018

Bias

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO ₂ (%)
Initial Zero	0.03	-0.02	-0.07	0.01	0.08
Final Zero	0.02	0.05	-0.14	0.08	0.06
Avg. Zero	0.02	0.02	-0.11	0.05	0.07
Initial UpScale	11.98	4.91	4.97	3.13	8.75
Final UpScale	11.91	4.45	5.05	3.24	8.89
Avg. UpScale	11.94	4.68	5.01	3.19	8.82

Upscale Cal Gas

12.05 4.92 5.13 3.22 8.92

EMISSIONS DATA	O ₂	NOx	CO	VOC	CO ₂
Corrected Raw Average (ppm/% dry basis)	13.53	1.75	0.00	0.19	4.17
Concentration (ppm@ 15%O ₂)	N/A	1.40	0.00	0.15	N/A

Non-Bias Adjusted Averages Include:

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-1
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,089,719	SCFH
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,089,719	SCFH

Weather Data

Barometric Pressure	29.98	in. Hg
Relative Humidity	99	%
Ambient Temperature	59	° F
Specific Humidity	0.010519	lb H ₂ O / lb air

Unit Data

Unit Load	206.1	megawatts
Meas. Stack Moisture	9.6	%
Stack Exhaust Flow (M19)	51,849,484	SCFH

Base Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO ₂ (%)
09/25/18 18:51:46	112680	13.34	2.14	-0.45	0.22	4.16
09/25/18 18:52:46	112740	13.36	2.08	-0.45	0.26	4.15
09/25/18 18:53:46	112800	13.36	2.05	-0.46	0.28	4.16
09/25/18 18:54:46	112860	13.36	2.03	-0.45	0.30	4.16
09/25/18 18:55:46	112920	13.37	2.00	-0.46	0.30	4.15
09/25/18 18:56:46	112980	13.39	2.00	-0.46	0.32	4.15
09/25/18 18:57:46	113040	13.37	1.98	-0.46	0.32	4.15
09/25/18 18:58:46	113100	13.38	1.96	-0.46	0.33	4.15
09/25/18 18:59:46	113160	13.37	1.99	-0.46	0.34	4.15
09/25/18 19:00:46	113220	13.37	1.96	-0.46	0.35	4.16
09/25/18 19:01:46	113280	13.37	1.98	-0.46	0.37	4.15
09/25/18 19:02:46	113340	13.37	1.96	-0.46	0.41	4.15
09/25/18 19:03:46	113400	13.36	1.94	-0.46	0.40	4.16
09/25/18 19:04:46	113460	13.38	1.92	-0.46	0.40	4.15
09/25/18 19:05:46	113520	13.38	1.94	-0.45	0.41	4.14
09/25/18 19:06:46	113580	13.36	1.93	-0.46	0.43	4.15
09/25/18 19:07:46	113640	13.38	1.90	-0.46	0.46	4.15
09/25/18 19:08:46	113700	13.38	1.88	-0.45	0.46	4.15
09/25/18 19:09:46	113760	13.37	1.92	-0.46	0.45	4.15
09/25/18 19:10:46	113820	13.38	1.92	-0.46	0.46	4.15
09/25/18 19:11:46	113880	13.38	1.89	-0.46	0.47	4.15
09/25/18 19:12:46	113940	13.39	1.79	-0.46	0.49	4.14
09/25/18 19:13:46	114000	13.39	1.74	-0.46	0.48	4.15
09/25/18 19:14:46	114060	13.39	1.94	-0.46	0.47	4.15
09/25/18 19:15:46	114120	13.39	1.84	-0.45	0.47	4.16
09/25/18 19:16:46	114180	13.40	1.60	-0.46	0.45	4.15
09/25/18 19:17:46	114240	13.40	1.52	-0.46	0.47	4.15
09/25/18 19:18:46	114300	13.40	1.72	-0.45	0.52	4.15
09/25/18 19:19:46	114360	13.41	1.17	-0.46	0.52	4.15
09/25/18 19:20:46	114420	13.42	1.67	-0.45	0.50	4.15
09/25/18 19:21:46	114480	13.42	1.58	-0.46	0.50	4.16
09/25/18 19:22:46	114540	13.43	1.61	-0.45	0.48	4.16
09/25/18 19:23:46	114600	13.42	1.60	-0.46	0.49	4.15
09/25/18 19:24:46	114660	13.43	1.55	-0.46	0.47	4.15
09/25/18 19:25:46	114720	13.43	1.36	-0.46	0.45	4.14
09/25/18 19:26:46	114780	13.43	1.63	-0.46	0.44	4.14
09/25/18 19:27:46	114840	13.42	1.12	-0.45	0.45	4.15
09/25/18 19:28:46	114900	13.41	1.55	-0.46	0.47	4.15
09/25/18 19:29:46	114960	13.41	0.93	-0.46	0.46	4.15
09/25/18 19:30:46	115020	13.39	1.36	-0.45	0.47	4.15
09/25/18 19:31:46	115080	13.39	1.01	-0.45	0.48	4.15
09/25/18 19:32:46	115140	13.40	1.10	-0.46	0.48	4.14
09/25/18 19:33:46	115200	13.39	1.19	-0.46	0.49	4.15
09/25/18 19:34:46	115260	13.40	1.29	-0.45	0.48	4.15
09/25/18 19:35:46	115320	13.39	0.42	-0.46	0.47	4.16
09/25/18 19:36:46	115380	13.39	0.98	-0.46	0.47	4.16
09/25/18 19:37:46	115440	13.40	1.22	-0.46	0.44	4.16
09/25/18 19:38:46	115500	13.40	1.17	-0.46	0.45	4.15
09/25/18 19:39:46	115560	13.40	1.21	-0.46	0.47	4.15
09/25/18 19:40:46	115620	13.40	0.88	-0.46	0.50	4.15
09/25/18 19:41:46	115680	13.39	0.86	-0.46	0.51	4.16
09/25/18 19:42:46	115740	13.40	1.20	-0.45	0.50	4.17
09/25/18 19:43:46	115800	13.40	1.36	-0.46	0.47	4.16
09/25/18 19:44:46	115860	13.40	1.34	-0.46	0.47	4.16
09/25/18 19:45:46	115920	13.41	1.24	-0.45	0.48	4.15
09/25/18 19:46:46	115980	13.40	0.72	-0.46	0.49	4.14
09/25/18 19:47:46	116040	13.40	0.87	-0.46	0.48	4.15
09/25/18 19:48:46	116100	13.40	0.97	-0.46	0.47	4.15
09/25/18 19:49:46	116160	13.40	1.22	-0.46	0.46	4.15
09/25/18 19:50:46	116220	13.40	1.42	-0.46	0.44	4.16

RAW AVERAGE

13.39 1.54 -0.46 0.44 4.15

Bias	Serial Number:	O ₂	NOx	CO	VOC	CO ₂
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
	INST-O2-0017	0.02	0.05	-0.14	0.08	0.06
	INST-NX-0043	0.02	-0.02	-0.03	0.05	0.05
	INST-CO-0018	0.02	0.02	-0.08	0.07	0.06
	INST-TH-0009					
	INST-C2-0018					
	Initial UpScale	11.91	4.45	5.05	3.24	8.89
	Final UpScale	11.85	4.68	5.16	3.04	8.80
	Avg. UpScale	11.88	4.57	5.11	3.14	8.85
	Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92

EMISSIONS DATA	O ₂	NOx	CO	VOC	CO ₂
Corrected Raw Average (ppm/% dry basis)	13.59	1.65	0.00	0.49	4.16
Concentration (ppm@ 15%O ₂)	N/A	1.33	0.00	0.39	N/A

Non-Bias Adjusted Averages Include:

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
with Duct Burners Firing
NO_x, CO, VOC, CO₂, and O₂ Data**

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-1
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,128,585	SCFH
Duct Burner Fuel Flow	268	lb/min
Total Fuel Flow	2,507,761	SCFH

Weather Data

Barometric Pressure	30.39	in. Hg
Relative Humidity	95	%
Ambient Temperature	53	° F
Specific Humidity	0.007979	lb H ₂ O / lb air

Unit Data

Unit Load	211.1	megawatts
Meas. Stack Moisture	10.1	%
Stack Exhaust Flow (M19)	51,790,579	SCFH

100% W/Db Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmw)	CO ₂ (%)
09/25/18 09:20:46	78420	12.07	2.39	-0.30	0.00	4.78
09/25/18 09:21:46	78480	12.06	2.41	-0.30	0.00	4.78
09/25/18 09:22:46	78540	12.07	2.47	-0.31	0.00	4.78
09/25/18 09:23:46	78600	12.07	2.38	-0.30	0.00	4.79
09/25/18 09:24:46	78660	12.06	2.43	-0.30	0.00	4.79
09/25/18 09:25:46	78720	12.08	2.48	-0.30	0.00	4.79
09/25/18 09:26:46	78780	12.08	2.38	-0.31	0.00	4.78
09/25/18 09:27:46	78840	12.06	2.41	-0.31	0.00	4.78
09/25/18 09:28:46	78900	12.07	2.45	-0.31	0.01	4.78
09/25/18 09:29:46	78960	12.07	2.48	-0.31	0.01	4.77
09/25/18 09:30:46	79020	12.05	2.42	-0.31	0.00	4.77
09/25/18 09:31:46	79080	12.07	2.43	-0.30	0.00	4.77
09/25/18 09:32:46	79140	12.07	2.44	-0.31	0.01	4.78
09/25/18 09:33:46	79200	12.07	2.56	-0.29	0.01	4.78
09/25/18 09:34:46	79260	12.08	2.51	-0.31	0.01	4.78
09/25/18 09:35:46	79320	12.07	2.41	-0.30	0.01	4.78
09/25/18 09:36:46	79380	12.08	2.47	-0.30	0.30	4.79
09/25/18 09:37:46	79440	12.08	2.48	-0.29	0.17	4.78
09/25/18 09:38:46	79500	12.06	2.59	-0.30	0.19	4.78
09/25/18 09:39:46	79560	12.06	2.64	-0.29	0.17	4.78
09/25/18 09:40:46	79620	12.08	2.58	-0.29	0.12	4.78
09/25/18 09:41:46	79680	12.07	2.50	-0.29	0.09	4.77
09/25/18 09:42:46	79740	12.07	2.58	-0.30	0.10	4.78
09/25/18 09:43:46	79800	12.07	2.64	-0.30	0.09	4.77
09/25/18 09:44:46	79860	12.06	2.56	-0.30	0.08	4.78
09/25/18 09:45:46	79920	12.06	2.62	-0.31	0.09	4.79
09/25/18 09:46:46	79980	12.06	2.58	-0.28	0.10	4.79
09/25/18 09:47:46	80040	12.06	2.59	-0.30	0.11	4.79
09/25/18 09:48:46	80100	12.06	2.54	-0.30	0.12	4.80
09/25/18 09:49:46	80160	12.06	2.65	-0.29	0.13	4.79
09/25/18 09:50:46	80220	12.06	2.72	-0.30	0.12	4.79
09/25/18 09:51:46	80280	12.05	2.70	-0.29	0.12	4.78
09/25/18 09:52:46	80340	12.06	2.71	-0.31	0.13	4.78
09/25/18 09:53:46	80400	12.06	2.63	-0.31	0.13	4.78
09/25/18 09:54:46	80460	12.06	2.65	-0.30	0.12	4.78
09/25/18 09:55:46	80520	12.06	2.68	-0.30	0.12	4.78
09/25/18 09:56:46	80580	12.06	2.68	-0.30	0.12	4.78
09/25/18 09:57:46	80640	12.07	2.64	-0.31	0.12	4.78
09/25/18 09:58:46	80700	12.08	2.56	-0.30	0.11	4.78
09/25/18 09:59:46	80760	13.06	2.63	-0.30	0.11	4.78
09/25/18 10:00:46	80820	12.61	2.66	-0.32	0.10	4.79
09/25/18 10:01:46	80880	12.19	2.72	-0.31	0.10	4.79
09/25/18 10:02:46	80940	12.16	2.62	-0.31	0.10	4.78
09/25/18 10:03:46	81000	12.51	2.61	-0.31	0.09	4.78
09/25/18 10:04:46	81060	12.34	2.60	-0.31	0.08	4.78
09/25/18 10:05:46	81120	12.49	2.64	-0.31	0.09	4.77
09/25/18 10:06:46	81180	12.24	2.60	-0.32	0.08	4.78
09/25/18 10:07:46	81240	12.24	2.55	-0.30	0.06	4.78
09/25/18 10:08:46	81300	12.28	2.63	-0.32	0.05	4.78
09/25/18 10:09:46	81360	12.30	2.75	-0.33	0.04	4.79
09/25/18 10:10:46	81420	12.37	2.71	-0.31	0.03	4.79
09/25/18 10:11:46	81480	12.11	2.68	-0.32	0.02	4.79
09/25/18 10:12:46	81540	12.12	2.64	-0.30	0.02	4.79
09/25/18 10:13:46	81600	12.21	2.61	-0.31	0.02	4.78
09/25/18 10:14:46	81660	12.16	2.66	-0.31	0.02	4.78
09/25/18 10:15:46	81720	12.14	2.76	-0.31	0.02	4.77
09/25/18 10:16:46	81780	12.12	2.64	-0.31	0.03	4.77
09/25/18 10:17:46	81840	12.11	2.75	-0.30	0.03	4.78
09/25/18 10:18:46	81900	12.13	2.67	-0.31	0.02	4.78
09/25/18 10:19:46	81960	12.11	2.65	-0.32	0.03	4.78
RAW AVERAGE		12.14	2.58	-0.30	0.07	4.78

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmw)	CO ₂ (%)
Serial Number: INST-O2-0017		INST-NX-0043	INST-CO-0018	INST-TH-0009	INST-C2-0018
Initial Zero	0.00	-0.02	0.05	0.00	0.07
Final Zero	0.05	-0.05	-0.01	0.00	0.08
Avg. Zero	0.02	-0.03	0.02	0.00	0.07
Initial UpScale	11.85	4.90	5.15	3.13	8.86
Final UpScale	11.86	4.89	5.11	3.07	8.79
Avg. UpScale	12.08	4.89	5.13	3.10	8.82
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92

EMISSIONS DATA	O ₂	NOx	CO	VOC	CO ₂
Corrected Raw Average (ppm/% dry basis)	12.11	2.61	0.00	0.08	4.80
Concentration (ppm@15%O ₂)	N/A	1.75	0.00	0.05	N/A

Non-Bias Adjusted Averages Include:

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-1
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,122,302	SCFH
Duct Burner Fuel Flow	268	lb/min
Total Fuel Flow	2,501,478	SCFH

Weather Data

Barometric Pressure	30.36	in. Hg
Relative Humidity	94	%
Ambient Temperature	55	° F
Specific Humidity	0.008509	lb H ₂ O / lb air

Unit Data

Unit Load	210.3	megawatts
Meas. Stack Moisture	13.5	%
Stack Exhaust Flow (M19)	53,428.357	SCFH

100% W/Db Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)	VOC (ppmw)	CO ₂ (%)
09/25/18 10:44:46	83460	12.40	2.70	-0.28	0.00	4.79
09/25/18 10:45:46	83520	12.38	2.80	-0.29	0.00	4.80
09/25/18 10:46:46	83580	12.37	2.79	-0.30	0.00	4.79
09/25/18 10:47:46	83640	12.37	2.76	-0.30	0.00	4.78
09/25/18 10:48:46	83700	12.39	2.77	-0.31	0.00	4.79
09/25/18 10:49:46	83760	12.41	2.66	-0.30	0.00	4.79
09/25/18 10:50:46	83820	12.40	2.73	-0.31	0.00	4.79
09/25/18 10:51:46	83880	12.42	2.67	-0.30	0.00	4.79
09/25/18 10:52:46	83940	12.41	2.71	-0.31	0.00	4.79
09/25/18 10:53:46	84000	12.41	2.68	-0.30	0.00	4.79
09/25/18 10:54:46	84060	12.41	2.65	-0.30	0.00	4.78
09/25/18 10:55:46	84120	12.43	2.71	-0.31	0.00	4.78
09/25/18 10:56:46	84180	12.42	2.56	-0.32	0.00	4.78
09/25/18 10:57:46	84240	12.46	2.59	-0.32	0.00	4.79
09/25/18 10:58:46	84300	12.21	2.66	-0.30	0.00	4.79
09/25/18 10:59:46	84360	12.21	2.68	-0.31	0.00	4.79
09/25/18 11:00:46	84420	12.21	2.75	-0.31	0.00	4.79
09/25/18 11:01:46	84480	12.69	2.76	-0.30	0.00	4.79
09/25/18 11:02:46	84540	12.38	2.66	-0.30	0.00	4.78
09/25/18 11:03:46	84600	12.26	2.70	-0.30	0.00	4.79
09/25/18 11:04:46	84660	12.32	2.70	-0.31	0.00	4.78
09/25/18 11:05:46	84720	12.24	2.72	-0.30	0.00	4.78
09/25/18 11:06:46	84780	12.24	2.67	-0.29	0.00	4.78
09/25/18 11:07:46	84840	12.24	2.69	-0.30	0.00	4.78
09/25/18 11:08:46	84900	12.23	2.75	-0.31	0.00	4.79
09/25/18 11:09:46	84960	12.23	2.69	-0.29	0.00	4.79
09/25/18 11:10:46	85020	12.23	2.68	-0.32	0.00	4.80
09/25/18 11:11:46	85080	12.23	2.73	-0.32	0.00	4.80
09/25/18 11:12:46	85140	12.23	2.80	-0.30	0.00	4.80
09/25/18 11:13:46	85200	12.23	2.61	-0.32	0.00	4.79
09/25/18 11:14:46	85260	12.24	2.73	-0.35	0.00	4.79
09/25/18 11:15:46	85320	12.23	2.72	-0.30	0.00	4.78
09/25/18 11:16:46	85380	12.23	2.72	-0.30	0.00	4.78
09/25/18 11:17:46	85440	12.23	2.71	-0.29	0.00	4.78
09/25/18 11:18:46	85500	12.23	2.72	-0.30	0.00	4.77
09/25/18 11:19:46	85560	12.22	2.70	-0.30	0.00	4.79
09/25/18 11:20:46	85620	12.22	2.72	-0.31	0.00	4.79
09/25/18 11:21:46	85680	12.22	2.77	-0.29	0.00	4.79
09/25/18 11:22:46	85740	12.22	2.70	-0.31	0.00	4.79
09/25/18 11:23:46	85800	12.22	2.79	-0.30	0.00	4.79
09/25/18 11:24:46	85860	12.22	2.65	-0.30	0.00	4.79
09/25/18 11:25:46	85920	12.22	2.70	-0.31	0.00	4.78
09/25/18 11:26:46	85980	12.23	2.72	-0.30	0.04	4.78
09/25/18 11:27:46	86040	12.22	2.66	-0.32	0.00	4.78
09/25/18 11:28:46	86100	12.23	2.76	-0.30	0.00	4.79
09/25/18 11:29:46	86160	12.22	2.79	-0.31	0.00	4.78
09/25/18 11:30:46	86220	12.21	2.81	-0.30	0.00	4.79
09/25/18 11:31:46	86280	12.21	2.74	-0.31	0.00	4.79
09/25/18 11:32:46	86340	12.22	2.71	-0.30	0.00	4.79
09/25/18 11:33:46	86400	12.22	2.71	-0.31	0.00	4.79
09/25/18 11:34:46	86460	12.21	2.74	-0.31	0.00	4.79
09/25/18 11:35:46	86520	12.21	2.69	-0.31	0.00	4.80
09/25/18 11:36:46	86580	12.22	2.65	-0.31	0.00	4.79
09/25/18 11:37:46	86640	12.22	2.62	-0.32	0.00	4.79
09/25/18 11:38:46	86700	12.22	2.69	-0.30	0.00	4.78
09/25/18 11:39:46	86760	12.22	2.70	-0.30	0.00	4.78
09/25/18 11:40:46	86820	12.22	2.78	-0.30	0.00	4.78
09/25/18 11:41:46	86880	12.23	2.72	-0.31	0.00	4.78
09/25/18 11:42:46	86940	12.21	2.72	-0.30	0.00	4.78
09/25/18 11:43:46	87000	12.22	2.70	-0.30	0.00	4.78
RAW AVERAGE		12.28	2.71	-0.31	0.00	4.79

	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)	VOC (ppmw)	CO ₂ (%)
Serial Number:	INST-O2-0017	INST-NX-0043	INST-CO-0018	INST-TH-0009	INST-C2-0018
Initial Zero	0.05	-0.05	-0.01	0.00	0.08
Final Zero	0.03	-0.06	0.09	0.00	0.08
Avg. Zero	0.04	-0.06	0.04	0.00	0.08
Bias					
Initial UpScale	11.86	4.89	5.11	3.07	8.79
Final UpScale	12.00	4.90	5.12	3.12	8.79
Avg. UpScale	11.93	4.90	5.11	3.10	8.79
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92

EMISSIONS DATA	O ₂	NO _x	CO	VOC	CO ₂
Corrected Raw Average (ppm/% dry basis)	12.40	2.75	0.00	0.00	4.82
Concentration (ppm@ 15%O ₂)	N/A	1.91	0.00	0.00	N/A

Non-Bias Adjusted Averages Include:

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-1
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,114,001	SCFH
Duct Burner Fuel Flow	268	lb/min
Total Fuel Flow	2,493,177	SCFH

Weather Data

Barometric Pressure	30.32	in. Hg
Relative Humidity	96	%
Ambient Temperature	58	° F
Specific Humidity	0.009718	lb H ₂ O / lb air

Unit Data

Unit Load	209.3	megawatts
Meas. Stack Moisture	10.5	%
Stack Exhaust Flow (M19)	52,301,913	SCFH

100% W/Db Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)	VOC (ppmw)	CO ₂ (%)
09/25/18 12:10:46	88620	12.20	2.61	-0.29	0.14	4.79
09/25/18 12:11:46	88680	12.20	2.79	-0.29	0.14	4.79
09/25/18 12:12:46	88740	12.21	2.76	-0.29	0.14	4.79
09/25/18 12:13:46	88800	12.21	2.70	-0.29	0.13	4.79
09/25/18 12:14:46	88860	12.21	2.63	-0.29	0.12	4.78
09/25/18 12:15:46	88920	12.21	2.61	-0.29	0.13	4.78
09/25/18 12:16:46	88980	12.20	2.69	-0.30	0.14	4.78
09/25/18 12:17:46	89040	12.20	2.71	-0.29	0.14	4.78
09/25/18 12:18:46	89100	12.21	2.70	-0.30	0.14	4.77
09/25/18 12:19:46	89160	12.21	2.69	-0.29	0.14	4.78
09/25/18 12:20:46	89220	12.19	2.77	-0.29	0.15	4.77
09/25/18 12:21:46	89280	12.21	2.76	-0.29	0.15	4.78
09/25/18 12:22:46	89340	12.21	2.73	-0.27	0.15	4.79
09/25/18 12:23:46	89400	12.20	2.73	-0.28	0.15	4.79
09/25/18 12:24:46	89460	12.21	2.70	-0.27	0.16	4.79
09/25/18 12:25:46	89520	12.21	2.79	-0.27	0.17	4.78
09/25/18 12:26:46	89580	12.20	2.70	-0.25	0.16	4.79
09/25/18 12:27:46	89640	12.19	2.66	-0.26	0.15	4.78
09/25/18 12:28:46	89700	12.20	2.67	-0.26	0.14	4.77
09/25/18 12:29:46	89760	12.20	2.66	-0.25	0.14	4.78
09/25/18 12:30:46	89820	12.20	2.71	-0.26	0.13	4.78
09/25/18 12:31:46	89880	12.20	2.69	-0.25	0.11	4.78
09/25/18 12:32:46	89940	12.20	2.64	-0.25	0.10	4.78
09/25/18 12:33:46	90000	12.20	2.65	-0.25	0.08	4.78
09/25/18 12:34:46	90060	12.19	2.69	-0.26	0.08	4.79
09/25/18 12:35:46	90120	12.20	2.69	-0.26	0.07	4.79
09/25/18 12:36:46	90180	12.20	2.75	-0.27	0.06	4.79
09/25/18 12:37:46	90240	12.20	2.75	-0.25	0.05	4.79
09/25/18 12:38:46	90300	12.19	2.75	-0.27	0.06	4.79
09/25/18 12:39:46	90360	12.20	2.78	-0.27	0.11	4.78
09/25/18 12:40:46	90420	12.21	2.72	-0.27	0.29	4.79
09/25/18 12:41:46	90480	12.20	2.74	-0.27	0.23	4.78
09/25/18 12:42:46	90540	12.20	2.73	-0.27	0.23	4.79
09/25/18 12:43:46	90600	12.19	2.75	-0.26	0.18	4.79
09/25/18 12:44:46	90660	12.19	2.73	-0.26	0.17	4.78
09/25/18 12:45:46	90720	12.20	2.73	-0.27	0.16	4.78
09/25/18 12:46:46	90780	12.20	2.69	-0.26	0.15	4.79
09/25/18 12:47:46	90840	12.19	2.77	-0.26	0.13	4.79
09/25/18 12:48:46	90900	12.19	2.81	-0.26	0.13	4.79
09/25/18 12:49:46	90960	12.20	2.79	-0.22	0.12	4.79
09/25/18 12:50:46	91020	12.19	2.79	-0.24	0.12	4.79
09/25/18 12:51:46	91080	12.19	2.86	-0.27	0.10	4.78
09/25/18 12:52:46	91140	12.18	2.81	-0.26	0.10	4.78
09/25/18 12:53:46	91200	12.19	2.80	-0.23	0.10	4.78
09/25/18 12:54:46	91260	12.20	2.77	-0.22	0.10	4.78
09/25/18 12:55:46	91320	12.19	2.73	-0.24	0.10	4.79
09/25/18 12:56:46	91380	12.20	2.87	-0.25	0.11	4.79
09/25/18 12:57:46	91440	12.20	2.88	-0.25	0.12	4.78
09/25/18 12:58:46	91500	12.20	2.80	-0.26	0.13	4.79
09/25/18 12:59:46	91560	12.20	2.75	-0.26	0.12	4.79
09/25/18 13:00:46	91620	12.20	2.77	-0.25	0.11	4.80
09/25/18 13:01:46	91680	12.20	2.80	-0.25	0.10	4.79
09/25/18 13:02:46	91740	12.19	2.73	-0.25	0.10	4.78
09/25/18 13:03:46	91800	12.19	2.64	-0.25	0.10	4.77
09/25/18 13:04:46	91860	12.19	2.71	-0.25	0.09	4.78
09/25/18 13:05:46	91920	12.19	2.72	-0.26	0.08	4.78
09/25/18 13:06:46	91980	12.20	2.78	-0.25	0.15	4.78
09/25/18 13:07:46	92040	12.20	2.69	-0.25	0.12	4.78
09/25/18 13:08:46	92100	12.19	2.68	-0.25	0.11	4.78
09/25/18 13:09:46	92160	12.19	2.70	-0.25	0.10	4.79

RAW AVERAGE **12.20** **2.73** **-0.26** **0.13** **4.78**

Bias	Serial Number: INST-O2-0017 INST-NX-0043 INST-CO-0018 INST-TH-0009 INST-C2-0018				
	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)	VOC (ppmw)	CO ₂ (%)
	Initial Zero	0.03	-0.06	0.09	0.00
Final Zero	0.03	0.00	0.06	0.01	0.08
Avg. Zero	0.03	-0.03	0.07	0.00	0.08
Initial UpScale	12.00	4.90	5.12	3.12	8.79
Final UpScale	12.00	4.85	5.09	3.07	8.79
Avg. UpScale	12.00	4.88	5.10	3.10	8.79
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92

EMISSIONS DATA					
Corrected Raw Average (ppm% dry basis)	O ₂	NO _x	CO	VOC	CO ₂
Concentration (ppm@ 15%O ₂)	N/A	1.89	0.00	0.10	N/A

Non-Bias Adjusted Averages Include:

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
without Duct Burners Firing
Opacity Data**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name **CPV Valley LLC**
 Facility Name **CPV Valley Energy Center**
 Street Address **3330 US Route 6**
 City **Middletown** State **NY** Zip **10940**

Process Unit # Operating Mode
CTG-1 **Base Load**
 Control Equipment Operating Mode
Base Load

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start **Clear** End **clear**
 Emission Color Water Droplet Plume
 Start **clear** End **clear** Start **none** End **none**

Describe Plume Background
 Start **cloudy** End **cloudy**
 Background Color Sky Conditions
 Start **White/gray** End **white/gray** Start **Broken** End **Broken**
 Wind Speed Wind Direction
 Start **10 mph** End **12 mph** Start **ESE** End **E**
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start **60°F** End **61°F** **72%**

Source Layout Sketch
 Draw North Arrow
 TN MN
 FEET
 FEET
 Side View
 Stack with Plume
 Sun
 Wind
 Emissions Point
 Observer
 140°
 Sun Location Line
 Latitude **41.4161** Longitude **-74.4362** Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) **sie-18-middletown.ny-start#1** Page **1** of **2**
 Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time	Comments						
9/24/18		11:15am	12:15pm	Min.	Sec.	0	15	30	45	
1		0	0	0	0					
2		0	0	0	0					
3		0	0	0	0					
4		0	0	0	0					
5		0	0	0	0					
6		0	0	0	0					
7		0	0	0	0					
8		0	0	0	0					
9		0	0	0	0					
10		0	0	0	0					
11		0	0	0	0					
12		0	0	0	0					
13		0	0	0	0					
14		0	0	0	0					
15		0	0	0	0					
16		0	0	0	0					
17		0	0	0	0					
18		0	0	0	0					
19		0	0	0	0					
20		0	0	0	0					
21		0	0	0	0					
22		0	0	0	0					
23		0	0	0	0					
24		0	0	0	0					
25		0	0	0	0					
26		0	0	0	0					
27		0	0	0	0					
28		0	0	0	0					
29		0	0	0	0					
30		0	0	0	0					

Observer's Name (Print) **Axel Garrido-Martinez**
 Observer's Signature *[Signature]* Date **09/24/18**
 Organization **Air Hygiene International, Inc.**
 Certified By **Compliance Assurance Associates, Inc.** Date **07/06/18**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940


Process: Unit # Operating Mode
 CTG-1 Base Load
 Control Equipment: Operating Mode
 Base Load

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: Clear End: clear
 Emission Color: Water Droplet Plume
 Start: clear End: clear Start: none End: none

Describe Plume Background
 Start: cloudy End: cloudy
 Background Color: Start white/gray End white/gray Sky Conditions: Start Broken End Broken
 Wind Speed: Start 10 mph End 12 mph Wind Direction: Start ESE End E
 Ambient Temp: Start 60°F End 61°F Wet Bulb Temp. RH Percent: 72%

Source Layout Sketch
 Draw North Arrow

 Latitude: 41.4161 Longitude: -74.4362 Declination: _____

Additional Information


VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): **sle-18-middletown.ny-start#1** Page **2** of **2**

Continued on Form Number (AHI Project Code)

Observation Date: **9/24/18** Time Zone: Start Time: **11:15 am** End Time: **12:15 pm**

Min.	Sec.	Time				Comments
		0	15	30	45	
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11	0	0	0	0		
12	0	0	0	0		
13	0	0	0	0		
14	0	0	0	0		
15	0	0	0	0		
16	0	0	0	0		
17	0	0	0	0		
18	0	0	0	0		
19	0	0	0	0		
20	0	0	0	0		
21	0	0	0	0		
22	0	0	0	0		
23	0	0	0	0		
24	0	0	0	0		
25	0	0	0	0		
26	0	0	0	0		
27	0	0	0	0		
28	0	0	0	0		
29	0	0	0	0		
30	0	0	0	0		

Observer's Name (Print): **Axel Garrido-Martinez**
 Observer's Signature:  Date: **09/24/18**
 Organization: **Air Hygiene International, Inc.**
 Certified By: **Compliance Assurance Associates, Inc.** Date: **07/06/18**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940

Process: Unit # CTG-1 Operating Mode Base Load
 Control Equipment: Operating Mode Base Load

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start clear End clear
 Emission Color Water Droplet Plume
 Start clear End clear Start none End none

Describe Plume Background
 Start Cloudy End Cloudy
 Background Color Sky Conditions
 Start White/gray End White/gray Start Broken End Broken
 Wind Speed Wind Direction
 Start 11mph End 11mph Start ENE End E
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 61°F End 62°F 72%

Source Layout Sketch
 Draw North Arrow

 Latitude: 41.4068 Longitude: -74.4305 Declination:
 TN MN
 FEET
 FEET
 Side View
 Slack with Plume
 Sun
 Wind

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 2
 sle-18-middletown.ny-start#1

Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time	Comments					
		12:30pm	1:30pm						
				0	15	30	45		
1				0	0	0	0		
2				0	0	0	0		
3				0	0	0	0		
4				0	0	0	0		
5				0	0	0	0		
6				0	0	0	0		
7				0	0	0	0		
8				0	0	0	0		
9				0	0	0	0		
10				0	0	0	0		
11				0	0	0	0		
12				0	0	0	0		
13				0	0	0	0		
14				0	0	0	0		
15				0	0	0	0		
16				0	0	0	0		
17				0	0	0	0		
18				0	0	0	0		
19				0	0	0	0		
20				0	0	0	0		
21				0	0	0	0		
22				0	0	0	0		
23				0	0	0	0		
24				0	0	0	0		
25				0	0	0	0		
26				0	0	0	0		
27				0	0	0	0		
28				0	0	0	0		
29				0	0	0	0		
30				0	0	0	0		

Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: [Signature]
 Date: 09/24/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc.
 Date: 07/06/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940


Process: Unit # Operating Mode
 CTG-1 Base Load
 Control Equipment: Operating Mode
 Base Load

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: clear End: clear
 Emission Color: Water Droplet Plume
 Start: clear End: clear Start: none End: none

Describe Plume Background
 Start: Cloudy End: Cloudy
 Background Color: Sky Conditions
 Start: white/gray End: white/gray Start: Broken End: Broken
 Wind Speed: Wind Direction
 Start: 11 mph End: 11 mph Start: ENE End: E
 Ambient Temp: Wet Bulb Temp. RH Percent
 Start: 61°F End: 62°F 72%


Source Layout Sketch
 Draw North Arrow

 Latitude: 41.4068 Longitude: -74.4305 Declination:
 TN MN

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 2
 sie-18-middletown.ny-start#1
 Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time	Comments					
09/24/18		12:30pm	1:30pm						
Min.	Sec.	0	15	30	45				
1		0	0	0	0				
2		0	0	0	0				
3		0	0	0	0				
4		0	0	0	0				
5		0	0	0	0				
6		0	0	0	0				
7		0	0	0	0				
8		0	0	0	0				
9		0	0	0	0				
10		0	0	0	0				
11		0	0	0	0				
12		0	0	0	0				
13		0	0	0	0				
14		0	0	0	0				
15		0	0	0	0				
16		0	0	0	0				
17		0	0	0	0				
18		0	0	0	0				
19		0	0	0	0				
20		0	0	0	0				
21		0	0	0	0				
22		0	0	0	0				
23		0	0	0	0				
24		0	0	0	0				
25		0	0	0	0				
26		0	0	0	0				
27		0	0	0	0				
28		0	0	0	0				
29		0	0	0	0				
30		0	0	0	0				

Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: 
 Date: 09/24/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc.
 Date: 07/06/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) **slc-18-middletown.ny-start#1** Page **1** of **2**

Company Name **CPV Valley LLC**
 Facility Name **CPV Valley Energy Center**
 Street Address **3330 US Route 6**
 City **Middletown** State **NY** Zip **10840**

Continued on Form Number (AHI Project Code)
 Observation Date **9/24/18** Time Zone
 Start Time **1:45 PM** End Time **2:45 PM**

Process Unit # Operating Mode
CTG-1 Base Load
 Control Equipment Operating Mode
Base Load


Min.	Sec.				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Point
 Height of Emis. Pt. Height of Emis. Pt. Rel. to Observer
 Start End Start End
 Distance to Emis. Pt. Direction to Emis. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start **clear** End **clear**
 Emission Color Water Droplet Plume
 Start **clear** End **clear** Start **none** End **none**

Describe Plume Background
 Start **cloudy** End **cloudy**
 Background Color Sky Conditions
 Start **white/gray** End **white/gray** Start **Broken** End **Broken**
 Wind Speed Wind Direction
 Start **11 mph** End **10 mph** Start **E** End **E**
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start **61°F** End **61°F** **74%**



Observer's Name (Print) **Axel Garrido-Martin**
 Observer's Signature _____ Date **9/24/18**
 Organization **Air Hygiene International, Inc.**
 Certified By **Compliance Assurance Associates, Inc.** Date **7/06/18**

Additional Information

Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 2
 sie-18-middletown.ny-start#1

Company Name **CPV Valley LLC**
 Facility Name **CPV Valley Energy Center**
 Street Address **3330 US Route 6**
 City **Middletown** State **NY** Zip **10940**

Continued on Form Number (AHI Project Code)

Process **CTG-1** Unit # **CTG-1** Operating Mode **Base Load**
 Control Equipment **CTG-1** Operating Mode **Base Load**

Observation Date **9/24/18** Time Zone _____ Start Time **1:45pm** End Time **2:45pm**


Describe Emissions Point
 Height of Emiss. Pt. _____ Height of Emiss. Pt. Rel. to Observer _____
 Start _____ End _____ Start _____ End _____
 Distance to Emiss. Pt. _____ Direction to Emiss. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____

Mi.	Sec.				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Vertical Angle to Obs. Pt. _____ Direction to Obs. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____
 Distance and Direction to Observation Point from Emission Point
 Start _____ End _____

Describe Emissions
 Start **clear** End **clear**
 Emission Color **clear** Water Droplet Plume **none**
 Start **clear** End **clear** Start **none** End **none**

Describe Plume Background
 Start **cloudy** End **cloudy**
 Background Color **white/gray** Sky Conditions **Broken**
 Start **white/gray** End **white/gray** Start **Broken** End **Broken**
 Wind Speed **11 mph** Wind Direction **E**
 Start **11 mph** End **10 mph** Start **E** End **E**
 Ambient Temp. **61°F** Wet Bulb Temp. **74%**
 Start **61°F** End **61°F**



Observer's Name (Print) **Axel Garrido-Martinez**

Observer's Signature _____ Date **09/24/18**

Additional Information

Organization **Air Hygiene International, Inc.**

Certified By **Compliance Assurance Associates, Inc.** Date **07/06/18**

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
with Duct Burners Firing
Opacity Data**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940

Process: Unit # Operating Mode
 CTG-1 100% w/ DB
 Control Equipment: Operating Mode
 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: clear End: clear
 Emission Color: Water Droplet Plume
 Start: clear End: clear Start: detached End: detached

Describe Plume Background
 Start: gray clouds End: gray clouds
 Background Color: Sky Conditions
 Start: gray End: gray Start: overcast End: overcast
 Wind Speed: Wind Direction
 Start: 3mph End: 3mph Start: NNE End: NE
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start: 58°F End: 58°F 97%

Source Layout Sketch
 Draw North Arrow
 TN MN
 FEET
 FEET
 Side View
 Stack with Plume
 Sun
 Wind
 Emissions Point
 Observer
 140°
 Sun Location Line
 Latitude: 41.4069 Longitude: -74.4305 Declination:

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 2
 sie-18-middletown.ny-start#1

Continued on Form Number (AHI Project Code)

Observation Date: 9/25/18 Time Zone: Start Time: 3:30pm End Time: 4:30pm

Min.	Sec.	Time				Comments
		0	15	30	45	
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7	0	0	0	0	0	
8	0	0	0	0	0	
9	0	0	0	0	0	
10	0	0	0	0	0	
11	0	0	0	0	0	
12	0	0	0	0	0	
13	0	0	0	0	0	
14	0	0	0	0	0	
15	0	0	0	0	0	
16	0	0	0	0	0	
17	0	0	0	0	0	
18	0	0	0	0	0	
19	0	0	0	0	0	
20	0	0	0	0	0	
21	0	0	0	0	0	
22	0	0	0	0	0	
23	0	0	0	0	0	
24	0	0	0	0	0	
25	0	0	0	0	0	
26	0	0	0	0	0	
27	0	0	0	0	0	
28	0	0	0	0	0	
29	0	0	0	0	0	
30	0	0	0	0	0	

Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: [Signature] Date: 9/25/18

Organization: Air Hygiene International, Inc.

Certified By: Compliance Assurance Associates, Inc. Date: 7/6/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name **CPV Valley LLC**
 Facility Name **CPV Valley Energy Center**
 Street Address **3330 US Route 6**
 City State Zip
Middletown **NY** **10940**

Process Unit # Operating Mode
 CTG-1 100% w/ DB
 Control Equipment Operating Mode
 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start **clear** End **clear**
 Emission Color Water Droplet Plume
 Start **clear** End **clear** Start **detached** End **detached**

Describe Plume Background
 Start **gray clouds** End **gray clouds**
 Background Color Sky Conditions
 Start **gray** End **gray** Start **overcast** End **overcast**
 Wind Speed Wind Direction
 Start **3mph** End **3mph** Start **NNE** End **NE**
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start **58°F** End **58°F** **97%**

Source Layout Sketch Draw North Arrow

Latitude Longitude Declination
41.4069 **-74.4305**

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page **2** of **2**
sie-18-middletown.ny-start#1

Continued on Form Number (AHI Project Code)

Observation Date Time Zone Start Time End Time
9/25/18 **3:30pm** **4:30pm**

	Min. Sec.		0	15	30	45	Comments
1	0	0	0	0	0	0	
2	0	0	0	0	0	0	
3	0	0	0	0	0	0	
4	0	0	0	0	0	0	
5	0	0	0	0	0	0	
6	0	0	0	0	0	0	
7	0	0	0	0	0	0	
8	0	0	0	0	0	0	
9	0	0	0	0	0	0	
10	0	0	0	0	0	0	
11	0	0	0	0	0	0	
12	0	0	0	0	0	0	
13	0	0	0	0	0	0	
14	0	0	0	0	0	0	
15	0	0	0	0	0	0	
16	0	0	0	0	0	0	
17	0	0	0	0	0	0	
18	0	0	0	0	0	0	
19	0	0	0	0	0	0	
20	0	0	0	0	0	0	
21	0	0	0	0	0	0	
22	0	0	0	0	0	0	
23	0	0	0	0	0	0	
24	0	0	0	0	0	0	
25	0	0	0	0	0	0	
26	0	0	0	0	0	0	
27	0	0	0	0	0	0	
28	0	0	0	0	0	0	
29	0	0	0	0	0	0	
30	0	0	0	0	0	0	

Observer's Name (Print) **Axel Garrido-Martinez**
 Observer's Signature Date **9/25/18**
 Organization **Air Hygiene International, Inc.**
 Certified By **Compliance Assurance Associates, Inc.** Date **7/6/18**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940


Process: Unit # Operating Mode
 CTG-1 100% w/ DB
 Control Equipment: Operating Mode
 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: clear End: clear
 Emission Color Water Droplet Plume
 Start: clear End: clear Start: detached End: detached

Describe Plume Background
 Start: gray clouds End: gray clouds
 Background Color Sky Conditions
 Start: gray End: gray Start: overcast End: overcast
 Wind Speed Wind Direction
 Start: 4 mph End: 4 mph Start: NNE End: N
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start: 56°F End: 56°F 100%

Source Layout Sketch
 Draw North Arrow
 TN MN
 FEET
 Feet
 Side View
 Stack with Plume
 Sun
 Wind
 Latitude: 41.4069 Longitude: -74.4305 Declination


Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): sie-18-middletown.ny-start#1 Page 1 of 2

Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time	Comments					
9/25/18		1:00pm	2:00pm						
				0	15	30	45		
1				0	0	0	0		
2				0	0	0	0		
3				0	0	0	0		
4				0	0	0	0		
5				0	0	0	0		
6				0	0	0	0		
7				0	0	0	0		
8				0	0	0	0		
9				0	0	0	0		
10				0	0	0	0		
11				0	0	0	0		
12				0	0	0	0		
13				0	0	0	0		
14				0	0	0	0		
15				0	0	0	0		
16				0	0	0	0		
17				0	0	0	0		
18				0	0	0	0		
19				0	0	0	0		
20				0	0	0	0		
21				0	0	0	0		
22				0	0	0	0		
23				0	0	0	0		
24				0	0	0	0		
25				0	0	0	0		
26				0	0	0	0		
27				0	0	0	0		
28				0	0	0	0		
29				0	0	0	0		
30				0	0	0	0		

Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: [Signature]
 Date: 9/25/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc.
 Date: 7/6/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name **CPV Valley LLC**
 Facility Name **CPV Valley Energy Center**
 Street Address **3330 US Route 6**
 City **Middletown** State **NY** Zip **10940**


Process Unit # Operating Mode
 CTG-1 100% w/ DB
 Control Equipment Operating Mode
 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start clear End clear
 Emission Color Water Droplet Plume
 Start clear End clear Start detached End detached

Describe Plume Background
 Start gray clouds End gray clouds
 Background Color Sky Conditions
 Start gray End gray Start overcast End overcast
 Wind Speed Wind Direction
 Start 4 mph End 4 mph Start NNE End N
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 56°F End 56°F 100%



Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) **sie-18-middletown.ny-start#1** Page **2** of **2**

Continued on Form Number (AHI Project Code)

Observation Date **9/25/18** Time Zone _____ Start Time **1:00pm** End Time **2:00pm**

Mn.	Sec.	Time				Comments
		0	15	30	45	
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7	0	0	0	0	0	
8	0	0	0	0	0	
9	0	0	0	0	0	
10	0	0	0	0	0	
11	0	0	0	0	0	
12	0	0	0	0	0	
13	0	0	0	0	0	
14	0	0	0	0	0	
15	0	0	0	0	0	
16	0	0	0	0	0	
17	0	0	0	0	0	
18	0	0	0	0	0	
19	0	0	0	0	0	
20	0	0	0	0	0	
21	0	0	0	0	0	
22	0	0	0	0	0	
23	0	0	0	0	0	
24	0	0	0	0	0	
25	0	0	0	0	0	
26	0	0	0	0	0	
27	0	0	0	0	0	
28	0	0	0	0	0	
29	0	0	0	0	0	
30	0	0	0	0	0	

Observer's Name (Print) **Axel Garrido-Martinez** Date **9/25/18**
 Observer's Signature _____ Date _____
 Organization **Air Hygiene International, Inc.**
 Certified By **Compliance Assurance Associates, Inc.** Date **7/6/18**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940

Process: Unit # Operating Mode
 CTG-1 100% w/ DB
 Control Equipment: Operating Mode
 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: ~~white~~ clear End: clear
 Emission Color: Water Droplet Plume
 Start: ~~white~~ clear End: ~~white~~ clear Start: detached End: detached

Describe Plume Background
 Start: gray clouds End: gray clouds
 Background Color: Start: gray End: gray Sky Conditions: Start: overcast End: overcast
 Wind Speed: Start: 4 mph End: 9 mph Wind Direction: Start: NNE End: NE
 Ambient Temp.: Start: 51°F End: 51°F Wet Bulb Temp.: RH Percent: 95%

Source Layout Sketch
 Draw North Arrow
 TN MN
 FEET
 FEET
 Side View
 Stack with Plume
 Sun
 Wind
 Latitude: 41.4069 Longitude: -74.4305 Declination:
 Emissions Point
 Observer
 140°
 Sun Location

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 2
 sie-18-middletown.ny-start#1
 Continued on Form Number (AHI Project Code)

Observation Date: 9/25/18 Time Zone: Start Time: 8:30am End Time: 9:30am

Min.	Sec.	0	15	30	45	Comments
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7	0	0	0	0	0	
8	0	0	0	0	0	
9	0	0	0	0	0	
10	0	0	0	0	0	
11	0	0	0	0	0	
12	0	0	0	0	0	
13	0	0	0	0	0	
14	0	0	0	0	0	
15	0	0	0	0	0	
16	0	0	0	0	0	
17	0	0	0	0	0	
18	0	0	0	0	0	
19	0	0	0	0	0	
20	0	0	0	0	0	
21	0	0	0	0	0	
22	0	0	0	0	0	
23	0	0	0	0	0	
24	0	0	0	0	0	
25	0	0	0	0	0	
26	0	0	0	0	0	
27	0	0	0	0	0	
28	0	0	0	0	0	
29	0	0	0	0	0	
30	0	0	0	0	0	

Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: [Signature] Date: 9/25/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc. Date: 7/06/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name CPV Valley LLC
 Facility Name CPV Valley Energy Center
 Street Address 3330 US Route 6
 City State Zip
 Middletown NY 10940

Process Unit # Operating Mode
 CTG-1 100% w/ DB
 Control Equipment Operating Mode
 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start clear End clear
 Emission Color Water Droplet Plume
 Start clear End clear Start detached End detached

Describe Plume Background
 Start gray clouds End gray clouds
 Background Color Sky Conditions
 Start gray End gray Start overcast End overcast
 Wind Speed Wind Direction
 Start 4mph End 9mph Start NNE End NE
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 51°F End 51°F 95%

Source Layout Sketch
 Draw North Arrow

 Latitude 41.4069 Longitude -74.4305 Declination
 TN MN
 FEET
 FEET
 Side View
 Stack with Plume
 Sun
 Wind

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 2
 sie-18-middletown.ny-start#1
 Continued on Form Number (AHI Project Code)

Observation Date Time Zone Start Time End Time
 9/25/18 8:30am 9:30am

Min.	Sec.				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print) Axel Garrido-Martinez
 Observer's Signature Date 09/25/18
 Organization Air Hygiene International, Inc.
 Certified By Compliance Assurance Associates, Inc. Date 07/06/18

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
without Duct Burners Firing
PM Data**

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	Average	Units	Limits
Run Start Time	09:52	15:02	15:36		hh:mm	
Run Stop Time	14:08	19:13	20:02		hh:mm	
Test Date	09/24/18	09/24/18	09/25/18		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.962	0.962	0.962			
Pitot Tube Coefficient	0.7240	0.7240	0.7240			
Average Nozzle Diameter	0.151	0.152	0.152		in	
Stack Test Data	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	Average	Units	Limits
Initial Meter Volume	190.320	283.810	654.310		ft ³	
Final Meter Volume	283.590	375.140	744.530		ft ³	
Total Meter Volume	93.270	91.330	90.220	91.607	ft ³	
Total Sampling Time	243.00	241.50	246.75	243.75	min	
Average Meter Temperature	74.08	73.92	75.42	74.47	°F	
Average Stack Temperature	217.08	217.75	205.00	213.28	°F	
Barometric Pressure	29.97	29.96	30.08	30.00	in Hg	
Stack Static Pressure	-0.87	-0.87	-0.87	-0.87	in H ₂ O	
Absolute Stack Pressure	29.91	29.90	30.02	29.94	in Hg	
Average Orifice Pressure Drop	0.40	0.40	0.40	0.40	in H ₂ O	
Absolute Meter Pressure	30.11	30.10	30.22	30.14	in Hg	
Avg Square Root Pitot Pressure	1.19	1.18	1.16	1.18	√(in H ₂ O)	
Moisture Content Data	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	Average	Units	Limits
Impinger Water Weight Gain	154.20	162.00	154.90	157.03	g	
Silica Gel Weight Gain	13.30	17.40	19.80	16.83	g	
Total Water Volume Collected	167.80	179.72	175.02	174.18	ml	
Standard Water Vapor Volume	7.90	8.46	8.24	8.20	scf	
Standard Meter Volume	88.9	87.1	86.1	87.4	dscf	
Standard Metric Meter Volume	2.5	2.5	2.4	2.5	dscm	
Calculated Stack Moisture	8.16	8.85	8.73	8.58	%	
Saturated Stack Moisture	100.00	100.00	86.54	95.51	%	
Reported Stack Moisture Content	8.16	8.85	8.73	8.58	%	
Gas Analysis Data	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	Average	Units	Limits
Carbon Dioxide Content	4.1	4.1	4.1	4.1	%	
Oxygen Content	13.6	13.6	13.6	13.6	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.3	82.4	82.3	82.3	%	
Stack Dry Molecular Weight	29.21	29.20	29.20	29.20	lb/lb-mole	
Stack Wet Molecular Weight	28.29	28.21	28.22	28.24	lb/lb-mole	
Calculated Fuel Factor	1.763	1.793	1.780	1.779		
Fuel F-Factor	8633.27	8633.27	8632.22	8632.92	dscf/MMBtu	
Percent Excess Air	167.6	165.4	167.3	166.8	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	Average	Units	Limits
Average Stack Gas Velocity	65.88	65.64	63.84	65.12	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,120,665	1,116,601	1,086,097	1,107,788	acfm	
Wet Standard Stack Flow Rate	52,410	52,151	51,907	52,156	wkscfh	
Dry Standard Stack Flow Rate	48,135,876	47,534,391	47,375,970	47,682,079	dscfh	
Percent of Isokinetic Rate	103.6	103.0	100.1	102.2	%	
Emission Rate Data	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	Average	Units	Limits
Total PM ₁₀ /PM _{2.5} Mass	6.08	2.09	2.89	3.69	mg	--
Total PM ₁₀ /PM _{2.5} Concentration	6.84E-05	2.40E-05	3.35E-05	4.20E-05	g/dscf	--
	1.06E-03	3.71E-04	5.17E-04	6.48E-04	gr/dscf	--
Total PM ₁₀ /PM _{2.5} Emission Rate	3.29	1.14	1.59	2.01	kg/hr	--
	7.26	2.52	3.50	4.42	lb/hr	--
	31.79	11.02	15.33	19.38	tpy	--
	0.0037	0.0013	0.0018	0.0023	lb/MMBtu	0.0073
Filterable PM ₁₀ Mass	1.20	0.32	0.20	0.57	mg	--
Filterable PM ₁₀ Concentration	1.35E-05	3.71E-06	2.36E-06	6.52E-06	g/dscf	--
	2.08E-04	5.73E-05	3.64E-05	1.01E-04	gr/dscf	--
Filterable PM ₁₀ Emission Rate	0.65	0.18	0.11	0.31	kg/hr	--
	1.43	0.39	0.25	0.69	lb/hr	--
	6.26	1.70	1.08	3.02	tpy	--
	0.0007	0.0002	0.0001	0.0004	lb/MMBtu	--
Filterable PM _{2.5} Mass	1.28	0.97	1.48	1.24	mg	--
Filterable PM _{2.5} Concentration	1.44E-05	1.11E-05	1.72E-05	1.43E-05	g/dscf	--
	2.23E-04	1.71E-04	2.66E-04	2.20E-04	gr/dscf	--
Filterable PM _{2.5} Emission Rate	0.69	0.53	0.82	0.68	kg/hr	--
	1.53	1.16	1.80	1.50	lb/hr	--
	6.71	5.10	7.87	6.56	tpy	--
	0.0008	0.0006	0.0009	0.0008	lb/MMBtu	--
Condensable PM _{2.5} Mass	3.60	0.80	1.20	1.87	mg	--
Condensable PM _{2.5} Concentration	4.05E-05	9.19E-06	1.39E-05	2.12E-05	g/dscf	--
	6.25E-04	1.42E-04	2.15E-04	3.27E-04	gr/dscf	--
Condensable PM _{2.5} Emission Rate	1.95	0.44	0.66	1.02	kg/hr	--
	4.30	0.96	1.46	2.24	lb/hr	--
	18.81	4.22	6.37	9.80	tpy	--
	0.0022	0.0005	0.0008	0.0012	lb/MMBtu	--
RM 201A Quality Control	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	Average	Units	Limits
Cyclone Flow Rate	0.51	0.51	0.48	0.50	ft ³ /min	
Stack Viscosity	208.85	208.34	205.47	207.55	μP	
Cunningham Correction Factor	1.08	1.09	1.08	1.08		
Recalculated D50-1 for CIV	2.41	2.43	2.52	2.45		
Recalculated Cunninham	1.08	1.08	1.08	1.08		
Lower Limit Cut Diameter, CI (NRE<3162), D50LL	2.41	2.42	2.51	2.45		
Reynolds Number	2643.03	2622.56	2571.92	2,612.50		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Dp	0	0	1	0	points	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		CG /MP	
Date for Preliminary Run	(mm/dd/yy)	09/24/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		CTG-1	
Base Run Number		1-Base-PM	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/24/18	09/24/18	09/25/18	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8633.27	8633.27	8632.22	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0028	samp-cp-0028	samp-cp-0028	
Meter Calibration Factor	(Y)	0.962	0.962	0.962	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.838	1.838	1.838	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	4187/10	4187/10	4187/10	
Pitot Tube Coefficient	(C _p)	0.7240	0.7240	0.7240	
Nozzle Number	from ACS	3	3	3	must match cyc nozz tab (e.g. 3, 4, etc.)
Nozzle Diameter	(D _n)	0.151	0.152	0.152	in
Probe Number	from ACS	samp-hp-0151	samp-hp-0151	samp-hp-0151	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-hp-0011	samp-hp-0011	samp-hp-0011	
Impinger Case Number	from ACS	samp-cp-0017	samp-cp-0017	samp-cp-0017	


Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830


METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	CPV Valley Energy Center	Date	09/24/18
Sampling Location	CTG-1 Stack	Stack Type	Circular
Operator	CG /MP	Ports Available	4
Project #	sie-18-middletown.ny-start#1	Ports Used	4
Stack Size	Large (>24 inch diameter)	Port ID (inches)	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	235.25	in
Distance to Near Wall of Stack	(L_{nw})	7.25	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft ²



Distance from Port to Disturbances			
Distance Upstream	(A)	1200.00	in
Diameters Upstream	(A_D)	5.26	diameters
Distance Downstream	(B)	1095.00	in
Diameters Downstream	(B_D)	4.80	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		24	16
Traverse Pts Required		24	16

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

² 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

- Method 1 Trav
- 12 Point PM Trav
- Velocity

Number of Traverse Points Used			
4	Ports by	3	Across
12	Pts Used	12	Required

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
	Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.044	10	17 2/8
2	0.146	33 2/8	40 4/8
3	0.296	67 4/8	74 6/8
4			
5			
6			
7			
8			
9			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	CPV Valley Energy Center			
Sampling Location	CTG-1 Stack			
Operator	CG /MP			
Project #	sie-18-middletown.ny-start#1			
Pitot Leak Check	x	PreTest	x	PostTest

Stack Dimensions			
Area of Stack	(A _s)	283.53	ft²
Diameter of Stack	(D)	228.00	in

Pressures			
Barometric Pressure	(P _b)	29.82	in Hg
Static Pressure	(P _{static})	-0.87	in H ₂ O
Absolute Stack Pressure	(P _s)	29.76	in Hg

Stack Gas Composition			
Composition Data:	Estimated Composition		
Carbon Dioxide Concentration	(%CO ₂)	4.16	%vd
Oxygen Concentration	(%O ₂)	13.55	%vd
Carbon Monoxide Concentration	(ppmCO)	0.00	ppmv
Nitrogen Concentration	(%N ₂)	82.29	%vd
Stack Moisture Content	(B _{ws})	12.00	%
Stack Dry Molecular Weight	(M _d)	29.21	lb/lb-mole
Stack Wet Molecular Weight	(M _w)	27.86	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v _s)	63.53	ft/sec
Avg Stack Dry Std Flow Rate	(Q _{sd})	44,986,694	dscf/hr
Avg Stack Dry Std Flow Rate	(Q _{sd})	749,778	dscf/min
Avg Stack Wet Flow Rate	(Q _{aw})	1,080,765	acf/min
Avg Stack Wet Std Flow Rate	(Q _{sw})	51,121,243	ascf/hr

40 CFR 60, Method 2G, Section 8.11.1 (but applies to all Method 2 type static pressure measurements):
 If a Type S probe is used for this measurement, position the probe at or between any traverse point(s) and rotate the probe until a null differential pressure reading is obtained. Disconnect the tubing from one of the pressure ports; read and record the ΔP. For pressure devices with one-directional scales, if a deflection in the positive direction is noted with the negative side disconnected, then the static pressure is positive. Likewise, if a deflection in the positive direction is noted with the positive side disconnected, then the static pressure is negative.

Stack Cross Section Schematic			

Preliminary Run Date	09/24/18		
Stack Type	Circular		
Ports Available	4		
Thermocouple ID	samp-hp-0151		
Pitot Coefficient	0.8200	Pitot Identification	A8162

Velocity Traverse Data					
1-Base-PM-V1					
Run Number					
Run Time	08:19	Start	08:35	End	
Traverse Point	Velocity Head (Δp)	Null Angle (N _a)	Zero Deg Pressure (0° _a)	Stack Temp (t _s)	Local Velocity (v _{s(l)})
	in H ₂ O	deg	in H ₂ O	°F	ft/sec
A-1	1.40	0	0.00	204	74.23
A-2	1.40	0	0.00	206	74.34
A-3	1.20	0	0.00	207	68.88
B-1	1.10	0	0.00	205	65.85
B-2	1.10	0	0.00	205	65.85
B-3	1.00	0	0.00	206	62.83
C-1	1.40	0	0.00	208	74.45
C-2	1.40	0	0.00	207	74.40
C-3	1.50	0	0.00	205	76.89
D-1	1.40	0	0.00	205	74.29
D-2	1.40	0	0.00	207	74.40
D-3	1.50	0	0.00	208	77.07
Average	1.32	0		206	
	1.15	= Square roots of Δp			
Standard deviation of null angles =					0.0

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	1-Base-PM-4	1-Base-PM-5	1-Base-PM-6	
Carbon Dioxide Content	4.2	4.1	4.1	4.1				%
Oxygen Content	13.6	13.6	13.6	13.6				%
Stack Moisture Content	12.0	8.2	8.9	8.7				%
Nitrogen plus CO Content	82.3	82.3	82.4	82.3				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H₂O)	Min.	1.28	Max.	1.93
---	------	------	------	------

Stack and Equipment Information	Prelim	1-Base-PM-1	1-Base-PM-2	1-Base-PM-3	1-Base-PM-4	1-Base-PM-5	1-Base-PM-6	
Barometric Pressure	29.82	29.97	29.96	30.08				in Hg
Stack Static Pressure	-0.87	-0.87	-0.87	-0.87				in H ₂ O
Absolute Stack Pressure	29.76	29.91	29.90	30.02				in Hg
Average Stack Temp	206	217	218	205				0.00
Average Stack Temp	666	677	678	665				°R
Average Meter Temp	85	74	74	75				0.00
Orifice Meter Coefficient	1.838	1.838	1.838	1.838				in H ₂ O
Pitot Coefficient	0.724	0.724	0.724	0.724				
Stack Dry Molecular Weight	29.21	29.21	29.20	29.20				lb/lb mole
Stack Wet Molecular Weight	27.86	28.29	28.21	28.22				lb/lb mole
Stack Viscosity	202.65	208.85	208.34	205.47				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.08							
Cunningham Correction Factor, for a 2.5 µm particle		1.08	1.08	1.08				
Prelim Cut Dia., Cyclone I, D _{50LL} , N _{re} <3162	10.18	2.41	2.42	2.51				µm
Middle Zone Dia., Cyclone I, D _{50T} , N _{re} <3162	10.59							µm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic), N _{re} <3162	0.50							dscfm
Reynolds Number, Cyc I & IV, N _{re} <3162	2638.90	2643.03	2622.56	2571.92				
Dia. of 50% Prob. (D ₅₀) Cyc IV (N _{re} <3162)	2.40	2.41	2.43	2.52				µm
Sampling Rate, Cyc IV, N _{re} <3,162	0.50							dscfm
Reynolds Number, Cyc IV, N _{re} <3162	2638.86	2643.03	2622.56	2571.92				
Prelim Cut Dia., Cyclone I, D _{50LL} ≥3162	10.60							µm
Middle Zone Dia., Cyclone I, D _{50T} ≥3162	10.80							µm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic)≥3162	0.48							dscfm
Reynolds Number, Cyc I & IV, N _{re} ≥3162	2565.96							
Dia. of 50% Prob. (D ₅₀) CIV (N _{re} ≥3162)	2.30							µm
Sampling Rate, Cyc IV, N _{re} ≥3,162	4.84							dscfm
Reynolds Number ≥ 3162	25659.77							
Cyclone Flow Rate	0.50	0.51	0.51	0.48				ft ³ /min
Recalculated D ₅₀₋₁ for C _{IV}		2.41	2.43	2.52				
Recalculated Cunningham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		103.57	103.00	100.13				%
No. Sampling Pts. Outside Δp		0	0	1				
Sample Nozzle Diameter		0.151	0.152	0.152				in

Orifice Head and Nozzle Selection Calculation

Nozzle No.	1	2	3	4	5	6	7	8	9	10	11
Nozzle diameter, D _n , in.	0.125	0.138	0.153	0.172	0.188	0.200	0.216	0.234	0.253	0.274	0.296
Nozzle velocity, v _n , ft/sec	97.25	79.79	64.91	51.36	42.99	37.99	32.57	27.75	23.74	20.24	17.34
R _{min}	0.76	0.75	0.73	0.70	0.66	0.63	0.57	0.50	0.50	0.50	0.50
v _{min} , ft/sec	74.28	59.90	47.49	35.94	28.56	23.96	18.66	13.88	11.87	10.12	8.67
R _{max}	1.23	1.23	1.25	1.26	1.28	1.30	1.32	1.35	1.39	1.43	1.49
v _{max} , ft/sec	119.16	98.45	80.87	64.94	55.16	49.34	43.08	37.55	32.98	29.03	25.79
Δp _{min} , in. H ₂ O @ t _s -50°F	1.94	1.26	0.79	0.45	0.29	0.20	0.12	0.07	0.05	0.04	0.03
Δp _{min} , in. H ₂ O @ t _s	1.79	1.17	0.73	0.42	0.27	0.19	0.11	0.06	0.05	0.03	0.02
Δp _{max} , in. H ₂ O @ t _s	4.61	3.15	2.13	1.37	0.99	0.79	0.60	0.46	0.35	0.27	0.22
Δp _{min} , in. H ₂ O @ t _s +50°F	4.29	2.93	1.98	1.27	0.92	0.74	0.56	0.43	0.33	0.25	0.20
ΔH, in. H ₂ O @ t _s +50°F						0.351					
ΔH, in. H ₂ O @ t _s						0.406					
ΔH, in. H ₂ O @ t _s -50°F						0.475					

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18		
Sampling Location	CTG-1 Stack	Operator	CG /MP		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	1-Base-PM-1		Date	09/24/18	Run Start Time	09:52	Run Stop Time	14:08
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:16	4.1	13.6	0.0	82.3	29.21	1.763	167.6	YES

Gas Analysis Data								
Run Number	1-Base-PM-2		Date	09/24/18	Run Start Time	15:02	Run Stop Time	19:13
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:11	4.1	13.6	0.0	82.4	29.20	1.793	165.4	YES

Gas Analysis Data								
Run Number	1-Base-PM-3		Date	09/25/18	Run Start Time	15:36	Run Stop Time	20:02
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:26	4.1	13.6	0.0	82.3	29.20	1.780	167.3	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18
Sampling Location	CTG-1 Stack	Operator	CG /MP
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/24/18	500	499.9	-0.1	Pass
Test Day 1	09/24/18	500	499.9	-0.1	Pass

Moisture Content Data								
Run Number	1-Base-PM-1		Date	09/24/18	Start Time	09:52	Stop Time	14:08
Meter Box Number	samp-cp-0028		Meter Cal Factor			(Y)	0.962	
Total Meter Volume	(V _m)	93.270	dcf	Barometric Pressure	(P _b)	29.97	in Hg	
Average Stack Temp	(t _s) _{avg}	217	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	74	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.40	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	Dry		Dry	DI Water	Sil Gel			
Final Value	(V _f),(W _f)	490.60	547.90	807.70	896.30			
Initial Value	(V _i),(W _i)	351.60	546.40	794.00	883.00			
Net Value	(V _n),(W _n)	139.0	1.5	13.7	13.3			
Results								
Total Weight	(W _t)	167.50	g	Water Vol Weighed	(V _{wsg(std)})	7.898	scf	
Std Meter Volume	(V _{m(std)})	88.939	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.00	%	
Calc Moisture Content	(B _{ws(calc)})	8.16	%	Final Moisture Content	(B _{ws})	8.16	%	

Moisture Content Data								
Run Number	1-Base-PM-2		Date	09/24/18	Start Time	15:02	Stop Time	19:13
Meter Box Number	samp-cp-0028		Meter Cal Factor			(Y)	0.962	
Total Meter Volume	(V _m)	91.330	dcf	Barometric Pressure	(P _b)	29.96	in Hg	
Average Stack Temp	(t _s) _{avg}	218	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	74	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.40	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	Dry		Dry	DI Water	Sil Gel			
Final Value	(V _f),(W _f)	510.70	619.60	743.70	962.40			
Initial Value	(V _i),(W _i)	363.30	617.90	730.80	945.00			
Net Value	(V _n),(W _n)	147.4	1.7	12.9	17.4			
Results								
Total Weight	(W _t)	179.40	g	Water Vol Weighed	(V _{wsg(std)})	8.459	scf	
Std Meter Volume	(V _{m(std)})	87.087	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.00	%	
Calc Moisture Content	(B _{ws(calc)})	8.85	%	Final Moisture Content	(B _{ws})	8.85	%	

Moisture Content Data								
Run Number	1-Base-PM-3		Date	09/25/18	Start Time	15:36	Stop Time	20:02
Meter Box Number	samp-cp-0028		Meter Cal Factor			(Y)	0.962	
Total Meter Volume	(V _m)	90.220	dcf	Barometric Pressure	(P _b)	30.08	in Hg	
Average Stack Temp	(t _s) _{avg}	205	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	75	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.40	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	Dry		Dry	DI Water	Sil Gel			
Final Value	(V _f),(W _f)	507.60	619.90	764.70	891.60			
Initial Value	(V _i),(W _i)	365.60	620.50	751.20	871.80			
Net Value	(V _n),(W _n)	142.0	-0.6	13.5	19.8			
Results								
Total Weight	(W _t)	174.70	g	Water Vol Weighed	(V _{wsg(std)})	8.237	scf	
Std Meter Volume	(V _{m(std)})	86.131	dscf	Sat. Moisture Content	(B _{ws(svp)})	86.54	%	
Calc Moisture Content	(B _{ws(calc)})	8.73	%	Final Moisture Content	(B _{ws})	8.73	%	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	CG
Run Number	1-Base-PM-1

Filter #	000013
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.7240	4187/10	
Average Stack Temp (t _s)	217.1		°F
Average Meter Temp (t _m)	74.1		
Orifice Meter Coefficient (ΔH@)	1.838		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.19		in H ₂ O
Stack Moisture Content (B _{ws})	8.16		%
Stack Dry Molecular Weight (M _d)	29.21		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	0.29		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	5.0	in H ₂ O for	15.0	sec
	Pre (-)	5.0	in H ₂ O for	15.0	sec
	Post (+)	5.0	in H ₂ O for	15.0	sec
	Post (-)	5.0	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	samp-cp-0028		
Meter Cal Factor (Y)	0.962		
Nozzle Number	3		
Average Nozzle Diameter (D _{na})	0.1513		in
Suggested Nozzle Diameter (D _m)	0.2201		in
Probe Number	samp-hp-0151		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-hp-0011		
Impinger Case Number	samp-cp-0017		

Nozzle Measurements					ID: 3
Pre	0.153	0.151	0.150	PASS	
Post	0.153	0.151	0.150	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	09:52	End	14:08

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	351.6	546.4	794.0	883.0				
Post	490.6	547.9	807.7	896.3				

Pressures			
Barometric Pressure (P _b)	29.97		in Hg
Stack Static Pressure (P _{static})	-0.87		in H ₂ O
Absolute Stack Pressure (P _s)	29.91		in Hg
Absolute Meter Pressure (P _m)	30.11		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0028	samp-cp-0028	samp-cp-0028			samp-hp-0151	samp-hp-0151	samp-hp-0151	samp-cp-0017	1006	8664	samp-cp-0028				samp-cp-0028					
Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m,Std})	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	190.320	1.40	0.406	0.40	211	254	252	52	65	70	70	70	2.5	1.18	65.22	8.024	109.6	93.963	
A-2	20.8	00:20:45	198.670	1.40	0.406	0.40	212	259	260	52	65	70	71	71	2.5	1.18	65.27	15.409	105.4	90.225	
A-3	41.5	00:41:30	206.370	1.40	0.406	0.40	215	259	259	64	65	71	73	73	2.5	1.18	65.41	22.852	104.3	89.206	
B-1	62.3	01:02:15	214.160	1.30	0.406	0.40	217	263	262	52	65	71	74	74	2.5	1.14	63.13	29.433	104.8	88.847	
B-2	80.5	01:20:30	221.060	1.30	0.406	0.40	218	264	261	60	66	70	74	74	2.5	1.14	63.17	35.928	104.9	88.409	
B-3	98.8	01:38:45	227.870	1.30	0.406	0.40	217	261	252	62	68	71	75	75	2.5	1.14	63.13	42.677	105.6	88.636	
C-1	117.0	01:57:00	234.960	1.50	0.406	0.40	218	250	252	64	68	68	77	77	2.5	1.22	67.86	50.340	105.0	88.803	
C-2	137.8	02:17:45	243.040	1.50	0.406	0.40	219	248	250	64	68	69	77	77	2.5	1.22	67.91	58.012	104.6	88.940	
C-3	158.5	02:38:30	251.130	1.50	0.406	0.40	219	260	252	65	68	71	77	77	2.5	1.22	67.91	65.485	103.9	88.775	
D-1	179.3	02:59:15	259.010	1.40	0.406	0.40	219	255	255	62	67	68	73	73	2.5	1.18	65.61	73.082	104.0	88.794	
D-2	200.0	03:20:00	266.960	1.50	0.406	0.40	220	251	251	59	66	70	74	74	2.5	1.22	67.96	80.921	103.6	88.776	
D-3	221.5	03:41:30	275.180	1.50	0.406	0.40	220	250	251	60	67	69	74	74	2.5	1.22	67.96	88.942	103.6	88.942	
Last Pt	243.0	04:03:00	283.590																		
Final Val	243.0	04:03:00	283.590												Max Vac	2.5	Final Values	88.942	103.6		
Average Values				1.42		0.40	217	256	255	60	67	70	74	74		1.19	65.88				

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	CG
Run Number	1-Base-PM-2

Filter #	000017
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.7240	4187/10	
Average Stack Temp (t _s)	217.8		°F
Average Meter Temp (t _m)	73.9		
Orifice Meter Coefficient (ΔH ₀)	1.838		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.18		in H ₂ O
Stack Moisture Content (B _{ws})	8.85		%
Stack Dry Molecular Weight (M _d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.37		acfm
ΔP to ΔH Isokinetic Factor (K)	0.29		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	20.0	in Hg
PASS	Post	0.000	ft ³ /min@	20.0	in Hg
Pitot	Pre (+)	5.0	in H ₂ O for	15.0	sec
	Pre (-)	5.0	in H ₂ O for	15.0	sec
	Post (+)	5.0	in H ₂ O for	15.0	sec
	Post (-)	5.0	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	samp-cp-0028		
Meter Cal Factor (Y)	0.962		
Nozzle Number	3		
Average Nozzle Diameter (D _{na})	0.1517	in	
Suggested Nozzle Diameter (D _m)	0.1539	in	
Probe Number	samp-hp-0151		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-hp-0011		
Impinger Case Number	samp-cp-0017		

Nozzle Measurements					ID: 3
Pre	0.151	0.153	0.151	PASS	
Post	0.151	0.153	0.151	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	15:02	End 19:13

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	363.3	617.9	730.8	945.0				
Post	510.7	619.6	743.7	962.4				

Pressures			
Barometric Pressure (P _b)	29.96		in Hg
Stack Static Pressure (P _{static})	-0.87		in H ₂ O
Absolute Stack Pressure (P _s)	29.90		in Hg
Absolute Meter Pressure (P _m)	30.10		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0028	samp-cp-0028	samp-cp-0028			samp-hp-0151	samp-hp-0151	samp-hp-0151	samp-cp-0017	1037	3130	samp-cp-0028	samp-cp-0028							
Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp) (in H ₂ O)	Desired Orifice ΔH (ΔH ₀) (in H ₂ O)	Actual Orifice ΔH (ΔH _a) (in H ₂ O)	Stack Temp (t _s) (°F)	Probe Temp (248±25°F) (°F)	Filter Temp (248±25°F) (°F)	Impinger Exit Temp (≤68°F) (°F)	Cond. Temp (≤85°F) (°F)	CPM Filter Temp (76.5±8.5°F) (°F)	Meter Inlet Temp (t _{mi}) (°F)	Meter Outlet Temp (t _{mo}) (°F)	Pump Vacuum (in Hg)	Square Root ΔP (ΔP ^{1/2}) (in H ₂ O)	Local Stack Velocity (V _s) (ft/sec)	Cumul. Meter Volume (V _{m,Std}) (dscf)	Cumul. Percent IsoKinetic (I) (%)	Est-Run Meter Volume (V _{m,Std}) (dscf)
A-1	0.0	00:00:00	283.810	1.50	0.406	0.40	223	262	255	68	70	75	74	74	2.5	1.22	68.22	7.408	98.8	86.217
A-2	20.8	00:20:45	291.580	1.50	0.406	0.40	222	257	259	60	69	68	74	74	2.5	1.22	68.17	15.064	100.4	87.660
A-3	41.5	00:41:30	299.610	1.50	0.406	0.40	220	260	261	62	69	70	74	74	2.5	1.22	68.07	22.729	101.0	88.178
B-1	62.3	01:02:15	307.650	1.40	0.406	0.40	218	262	257	60	62	71	73	73	2.5	1.18	65.67	29.320	101.4	87.959
B-2	80.5	01:20:30	314.550	1.40	0.406	0.40	218	260	255	60	64	74	74	74	2.5	1.18	65.67	36.127	102.4	88.351
B-3	98.8	01:38:45	321.690	1.40	0.406	0.40	218	260	254	61	68	72	72	72	2.5	1.18	65.67	42.682	102.4	88.101
C-1	117.0	01:57:00	328.540	1.40	0.406	0.40	216	256	250	66	68	71	71	71	2.5	1.18	65.57	50.228	102.6	88.059
C-2	137.8	02:17:45	336.410	1.40	0.406	0.40	217	260	255	65	67	70	72	72	2.5	1.18	65.62	57.530	102.3	87.656
C-3	158.5	02:38:30	344.040	1.40	0.406	0.40	216	257	250	62	69	72	74	74	2.5	1.18	65.57	65.224	102.7	87.875
D-1	179.3	02:59:15	352.110	1.30	0.406	0.40	216	259	257	62	68	70	76	76	2.5	1.14	63.19	72.822	103.3	87.933
D-2	200.0	03:20:00	360.110	1.30	0.406	0.40	215	259	254	61	68	70	76	76	2.5	1.14	63.14	79.965	103.1	87.482
D-3	220.8	03:40:45	367.630	1.30	0.406	0.40	214	255	255	61	68	71	77	77	2.5	1.14	63.09	87.085	103.0	87.085
Last Pt	241.5	04:01:30	375.140																	
Final Val	241.5	04:01:30	375.140												Max Vac 2.5	Final Values	87.085	103.0		
Average Values				1.40		0.40	218	259	255	62	68	71	74	74		1.18	65.64			

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/07/18
Operator	CG / MP
Run Number	1-Base-PM-3

Filter #	000010
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.7240	4187/10	
Average Stack Temp (t _s)	205.0		°F
Average Meter Temp (t _m)	75.4		
Orifice Meter Coefficient (ΔH@)	1.838		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.16		in H ₂ O
Stack Moisture Content (B _{ws})	8.73		%
Stack Dry Molecular Weight (M _d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.36		acfm
ΔP to ΔH Isokinetic Factor (K)	0.30		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	5.0	in H ₂ O for	30.0	sec
	Pre (-)	5.0	in H ₂ O for	30.0	sec
	Post (+)	5.0	in H ₂ O for	30.0	sec
	Post (-)	5.0	in H ₂ O for	30.0	sec

Sampling Equipment			
Meter Box Number	samp-cp-0028		
Meter Cal Factor (Y)	0.962		
Nozzle Number	3		
Average Nozzle Diameter (D _{na})	0.1517		in
Suggested Nozzle Diameter (D _m)	0.1526		in
Probe Number	samp-hp-0151		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-hp-0011		
Impinger Case Number	samp-cp-0017		

Nozzle Measurements					ID: 3
Pre	0.152	0.151	0.152	PASS	
Post	0.152	0.151	0.152	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	15:36	End	20:02

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	365.6	620.5	751.2	871.8				
Post	507.6	619.9	764.7	891.6				

Pressures			
Barometric Pressure (P _b)	30.08		in Hg
Stack Static Pressure (P _{static})	-0.87		in H ₂ O
Absolute Stack Pressure (P _s)	30.02		in Hg
Absolute Meter Pressure (P _m)	30.22		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0028	samp-cp-0028	samp-cp-0028			samp-hp-0151	samp-hp-0151	samp-hp-0151	samp-cp-0017	1006	8664	samp-cp-0028				samp-cp-0028					
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	654.310	1.40	0.406	0.40	205	257	262	61	62	74	70	70	2.0	1.18	64.89	7.040	95.6	83.721	
A-2	20.8	00:20:45	661.610	1.40	0.406	0.40	206	258	261	61	62	73	70	70	2.0	1.18	64.94	13.801	93.8	82.058	
A-3	41.5	00:41:30	668.620	1.40	0.406	0.40	206	259	258	61	63	72	72	72	2.0	1.18	64.94	21.689	98.7	85.973	
B-1	62.3	01:02:15	676.830	1.40	0.406	0.40	205	257	261	62	63	74	73	73	2.0	1.18	64.89	28.671	100.9	87.883	
B-2	80.5	01:20:30	684.110	1.50	0.406	0.40	206	254	262	60	63	72	76	76	2.0	1.22	67.21	35.375	100.0	87.727	
B-3	99.5	01:39:30	691.140	1.50	0.406	0.40	207	259	259	60	62	74	77	77	2.0	1.22	67.26	42.124	99.5	87.713	
C-1	118.5	01:58:30	698.230	1.30	0.406	0.40	204	261	264	54	59	72	77	77	2.0	1.14	62.48	49.110	99.3	87.023	
C-2	139.3	02:19:15	705.570	1.20	0.406	0.40	205	259	259	52	59	73	78	78	2.5	1.10	60.07	55.856	99.9	86.682	
C-3	159.0	02:39:00	712.670	1.20	0.406	0.40	204	257	261	53	61	71	78	78	3.0	1.10	60.03	62.516	100.2	86.299	
D-1	178.8	02:58:45	719.680	1.10	0.406	0.40	204	258	260	53	61	72	78	78	3.0	1.05	57.47	69.290	100.5	85.701	
D-2	199.5	03:19:30	726.810	1.40	0.406	0.40	204	256	258	54	62	69	78	78	3.0	1.18	64.84	77.518	100.4	85.870	
D-3	222.8	03:42:45	735.470	1.50	0.406	0.40	204	255	257	55	62	70	78	78	3.0	1.22	67.11	86.126	100.1	86.126	
Last Pt	246.8	04:06:45	744.530																		
Final Val	246.8	04:06:45	744.530												Max Vac	3.0	Final Values	86.126	100.1		
Average Values				1.36		0.40	205	258	260	57	62	72	75	75		1.16	63.84				

Notes:

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
with Duct Burners Firing
PM Data**

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	Average	Units	Limits
Run Start Time	23:32	04:11	09:20		hh:mm	
Run Stop Time	03:48	08:27	13:40		hh:mm	
Test Date	09/24/18	09/25/18	09/25/18		mm/dd/yy	
Load	Base w/DB	Base w/DB	Base w/DB		% or w/DB	--
Meter Calibration Factor	0.962	0.962	0.962			
Pitot Tube Coefficient	0.7240	0.7240	0.7240			
Average Nozzle Diameter	0.151	0.152	0.152		in	
Stack Test Data	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	Average	Units	Limits
Initial Meter Volume	375.620	467.130	559.420		ft ³	
Final Meter Volume	466.630	557.450	652.730		ft ³	
Total Meter Volume	91.010	90.320	93.310	91.547	ft ³	
Total Sampling Time	243.75	246.75	246.75	245.75	min	
Average Meter Temperature	74.67	70.75	71.58	72.33	°F	
Average Stack Temperature	192.58	192.17	190.50	191.75	°F	
Barometric Pressure	29.84	29.77	30.39	30.00	in Hg	
Stack Static Pressure	-1.10	-1.10	-1.10	-1.10	in H ₂ O	
Absolute Stack Pressure	29.76	29.69	30.31	29.92	in Hg	
Average Orifice Pressure Drop	0.42	0.42	0.42	0.42	in H ₂ O	
Absolute Meter Pressure	29.98	29.91	30.53	30.14	in Hg	
Avg Square Root Pitot Pressure	1.20	1.16	1.19	1.18	√(in H ₂ O)	
Moisture Content Data	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	Average	Units	Limits
Impinger Water Weight Gain	182.10	106.50	153.00	147.20	g	
Silica Gel Weight Gain	19.70	18.00	18.00	18.57	g	
Total Water Volume Collected	202.16	124.72	171.31	166.07	ml	
Standard Water Vapor Volume	9.51	5.87	8.06	7.82	scf	
Standard Meter Volume	86.3	86.1	90.7	87.7	dscf	
Standard Metric Meter Volume	2.4	2.4	2.6	2.5	dscm	
Calculated Stack Moisture	9.93	6.38	8.17	8.16	%	
Saturated Stack Moisture	67.40	66.97	63.30	65.89	%	
Reported Stack Moisture Content	9.93	6.38	8.17	8.16	%	
Gas Analysis Data	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	Average	Units	Limits
Carbon Dioxide Content	4.9	4.9	4.7	4.8	%	
Oxygen Content	12.4	12.3	12.0	12.2	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.7	82.9	83.3	83.0	%	
Stack Dry Molecular Weight	29.28	29.27	29.23	29.26	lb/lb-mole	
Stack Wet Molecular Weight	28.16	28.55	28.32	28.34	lb/lb-mole	
Calculated Fuel Factor	1.742	1.775	1.889	1.802		
Fuel F-Factor	8633.27	8632.22	8632.22	8632.57	dscf/MMBtu	
Percent Excess Air	131.4	128.2	120.6	126.7	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	Average	Units	Limits
Average Stack Gas Velocity	65.52	63.07	64.30	64.30	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,114,523	1,072,962	1,093,824	1,093,770	acfm	
Wet Standard Stack Flow Rate	53,814	51,719	53,963	53,165	wkscfh	
Dry Standard Stack Flow Rate	48,471,185	48,417,320	49,555,590	48,814,698	dscfh	
Percent of Isokinetic Rate	99.5	97.8	99.8	99.0	%	
Emission Rate Data	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	Average	Units	Limits
Total PM ₁₀ /PM _{2.5} Mass	5.04	1.98	2.66	3.23	mg	--
Total PM ₁₀ /PM _{2.5} Concentration	5.83E-05	2.30E-05	2.93E-05	3.69E-05	g/dscf	--
	9.00E-04	3.55E-04	4.52E-04	5.69E-04	gr/dscf	--
Total PM ₁₀ /PM _{2.5} Emission Rate	2.83	1.11	1.45	1.80	kg/hr	--
	6.23	2.46	3.20	3.96	lb/hr	--
	27.30	10.77	14.03	17.37	tpy	--
	0.0027	0.0011	0.0013	0.0017	lb/MMBtu	0.0073
Filterable PM ₁₀ Mass	0.22	0.18	0.15	0.19	mg	--
Filterable PM ₁₀ Concentration	2.53E-06	2.13E-06	1.70E-06	2.12E-06	g/dscf	--
	3.90E-05	3.29E-05	2.62E-05	3.27E-05	gr/dscf	--
Filterable PM ₁₀ Emission Rate	0.12	0.10	0.08	0.10	kg/hr	--
	0.27	0.23	0.19	0.23	lb/hr	--
	1.18	1.00	0.81	1.00	tpy	--
	0.0001	0.0001	0.0001	0.0001	lb/MMBtu	--
Filterable PM _{2.5} Mass	1.32	1.41	1.10	1.28	mg	--
Filterable PM _{2.5} Concentration	1.53E-05	1.64E-05	1.22E-05	1.46E-05	g/dscf	--
	2.35E-04	2.53E-04	1.88E-04	2.26E-04	gr/dscf	--
Filterable PM _{2.5} Emission Rate	0.74	0.79	0.60	0.71	kg/hr	--
	1.63	1.75	1.33	1.57	lb/hr	--
	7.14	7.67	5.82	6.88	tpy	--
	0.0007	0.0008	0.0005	0.0007	lb/MMBtu	--
Condensable PM _{2.5} Mass	3.50	0.39	1.40	1.76	mg	--
Condensable PM _{2.5} Concentration	4.05E-05	4.48E-06	1.54E-05	2.02E-05	g/dscf	--
	6.26E-04	6.91E-05	2.38E-04	3.11E-04	gr/dscf	--
Condensable PM _{2.5} Emission Rate	1.97	0.22	0.77	0.98	kg/hr	--
	4.33	0.48	1.69	2.17	lb/hr	--
	18.98	2.09	7.39	9.49	tpy	--
	0.0019	0.0002	0.0007	0.0009	lb/MMBtu	--
RM 201A Quality Control	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	Average	Units	Limits
Cyclone Flow Rate	0.49	0.46	0.49	0.48	ft ³ /min	
Stack Viscosity	200.77	203.90	201.70	202.12	μP	
Cunningham Correction Factor	1.08	1.07	1.08	1.08		
Recalculated D50-1 for CIV	2.39	2.57	2.37	2.44		
Recalculated Cunninham	1.08	1.07	1.08	1.08		
Lower Limit Cut Diameter, CI (NRE<3162), D50LL	2.39	2.57	2.37	2.44		
Reynolds Number	2699.68	2554.88	2749.68	2,668.08		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Dp	0	0	0	0	points	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		MP / CG	
Date for Preliminary Run	(mm/dd/yy)	09/24/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		CTG-1	
Base Run Number		1-100 w/DB-PM	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/24/18	09/25/18	09/25/18	
Load		Base w/DB	Base w/DB	Base w/DB	% or w/DB
Fuel F-Factor		8633.27	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	SAMP-CP-0028	SAMP-CP-0028	SAMP-CP-0028	
Meter Calibration Factor	(Y)	0.962	0.962	0.962	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.838	1.838	1.838	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	4187/10	4187/10	4187/10	
Pitot Tube Coefficient	(C _p)	0.7240	0.7240	0.7240	
Nozzle Number	from ACS	3	3	3	must match cyc nozz tab (e.g. 3, 4, etc.)
Nozzle Diameter	(D _n)	0.151	0.152	0.152	in
Probe Number	from ACS	samp-hp-0151	samp-hp-0151	samp-hp-0151	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-hp-0011	samp-hp-0011	samp-hp-0011	
Impinger Case Number	from ACS	samp-cp-0017	samp-cp-0017	samp-cp-0017	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	1-100 w/DB-PM-4	1-100 w/DB-PM-5	1-100 w/DB-PM-6	
Carbon Dioxide Content	4.9	4.9	4.9	4.7				%
Oxygen Content	12.4	12.4	12.3	12.0				%
Stack Moisture Content	10.0	9.9	6.4	8.2				%
Nitrogen plus CO Content	82.7	82.7	82.9	83.3				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H₂O)	Min.	1.00	Max.	1.70
---	------	------	------	------

Stack and Equipment Information	Prelim	1-100 w/DB-PM-1	1-100 w/DB-PM-2	1-100 w/DB-PM-3	1-100 w/DB-PM-4	1-100 w/DB-PM-5	1-100 w/DB-PM-6	
Barometric Pressure	29.83	29.84	29.77	30.39				in Hg
Stack Static Pressure	-1.10	-1.10	-1.10	-1.10				in H ₂ O
Absolute Stack Pressure	29.75	29.76	29.69	30.31				in Hg
Average Stack Temp	191	193	192	191				0.00
Average Stack Temp	651	653	652	651				°R
Average Meter Temp	85	75	71	72				0.00
Orifice Meter Coefficient	1.838	1.838	1.838	1.838				in H ₂ O
Pitot Coefficient	0.724	0.724	0.724	0.724				
Stack Dry Molecular Weight	29.28	29.28	29.27	29.23				lb/lb mole
Stack Wet Molecular Weight	28.15	28.16	28.55	28.32				lb/lb mole
Stack Viscosity	200.26	200.77	203.90	201.70				μP
Cunningham Correction Factor, for a 2.25 μm particle	1.08							
Cunningham Correction Factor, for a 2.5 μm particle		1.07	1.08	1.07				
Prelim Cut Dia., Cyclone I, D _{50LL} , N _{re} <3162	10.24	2.39	2.57	2.37				μm
Middle Zone Dia., Cyclone I, D _{50T} , N _{re} <3162	10.62							μm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic), N _{re} <3162	0.48							dscfm
Reynolds Number, Cyc I & IV, N _{re} <3162	2690.55	2699.68	2554.88	2749.68				
Dia. of 50% Prob. (D ₅₀) Cyc IV (N _{re} <3162)	2.39	2.39	2.56	2.37				μm
Sampling Rate, Cyc IV, N _{re} <3,162	0.48							dscfm
Reynolds Number, Cyc IV, N _{re} <3162	2690.51	2699.68	2554.88	2749.68				
Prelim Cut Dia., Cyclone I, D _{50LL} ≥3162	10.61							μm
Middle Zone Dia., Cyclone I, D _{50T} ≥3162	10.81							μm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic)≥3162	0.47							dscfm
Reynolds Number, Cyc I & IV, N _{re} ≥3162	2624.92							
Dia. of 50% Prob. (D ₅₀) CIV (N _{re} ≥3162)	2.30							μm
Sampling Rate, Cyc IV, N _{re} ≥3,162	4.73							dscfm
Reynolds Number ≥ 3162	26249.36							
Cyclone Flow Rate	0.48	0.49	0.46	0.49				ft ³ /min
Recalculated D ₅₀₋₁ for C _{IV}		2.39	2.57	2.37				
Recalculated Cunningham		1.08	1.07	1.08				
Z		1.00	1.00	1.00				
Isokinetics		99.45	97.79	99.76				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.151	0.152	0.152				in

Orifice Head and Nozzle Selection Calculation

	1	2	3	4	5	6	7	8	9	10	11
Nozzle No.											
Nozzle diameter, D _n , in.	0.125	0.138	0.156	0.172	0.188	0.200	0.216	0.234	0.253	0.274	0.296
Nozzle velocity, v _n , ft/sec	94.78	77.77	60.86	50.06	41.90	37.02	31.74	27.05	23.14	19.73	16.90
R _{min}	0.76	0.75	0.73	0.70	0.66	0.63	0.57	0.50	0.50	0.50	0.50
v _{min} , ft/sec	72.34	58.32	44.19	34.95	27.74	23.25	18.05	13.52	11.57	9.86	8.45
R _{max}	1.23	1.23	1.25	1.27	1.28	1.30	1.32	1.36	1.39	1.44	1.49
v _{max} , ft/sec	116.17	95.99	76.01	63.33	53.80	48.14	42.04	36.65	32.20	28.35	25.19
Δp _{min} , in. H ₂ O @ t _s -50°F	1.90	1.24	0.71	0.44	0.28	0.20	0.12	0.07	0.05	0.04	0.03
Δp _{min} , in. H ₂ O @ t _s	1.76	1.14	0.66	0.41	0.26	0.18	0.11	0.06	0.04	0.03	0.02
Δp _{max} , in. H ₂ O @ t _s	4.53	3.10	1.94	1.35	0.97	0.78	0.59	0.45	0.35	0.27	0.21
Δp _{min} , in. H ₂ O @ t _s +50°F	4.21	2.87	1.80	1.25	0.90	0.72	0.55	0.42	0.32	0.25	0.20
ΔH, in. H ₂ O @ t _s +50°F						0.365					
ΔH, in. H ₂ O @ t _s						0.423					
ΔH, in. H ₂ O @ t _s -50°F						0.497					

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18		
Sampling Location	CTG-1 Stack	Operator	MP / CG		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	1-100 w/DB-PM-1		Date	09/24/18	Run Start Time	23:32	Run Stop Time	03:48
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:16	4.9	12.4	0.0	82.7	29.28	1.742	131.4	YES

Gas Analysis Data								
Run Number	1-100 w/DB-PM-2		Date	09/25/18	Run Start Time	04:11	Run Stop Time	08:27
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:16	4.9	12.3	0.0	82.9	29.27	1.775	128.2	YES

Gas Analysis Data								
Run Number	1-100 w/DB-PM-3		Date	09/25/18	Run Start Time	09:20	Run Stop Time	13:40
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:20	4.7	12.0	0.0	83.3	29.23	1.889	120.6	NO

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18
Sampling Location	CTG-1 Stack	Operator	MP / CG
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/24/18	500	499.9	-0.1	Pass
Test Day 1	09/24/18	500	499.9	-0.1	Pass

Moisture Content Data									
Run Number	1-100 w/DB-PM-1		Date	09/24/18	Start Time	23:32	Stop Time	03:48	
Meter Box Number	SAMP-CP-0028				Meter Cal Factor	(Y)	0.962		
Total Meter Volume	(V _m)	91.010	dcf		Barometric Pressure	(P _b)	29.84	in Hg	
Average Stack Temp	(t _s) _{avg}	193	°F		Stack Static Pressure	(P _{static})	-1.10	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	75	°F		Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	516.70	550.70	706.10	872.10				
Initial Value	(V _i),(W _i)	350.70	547.50	693.20	852.40				
Net Value	(V _n),(W _n)	166.0	3.2	12.9	19.7				
Results									
Total Weight	(W _t)	201.80	g		Water Vol Weighed	(V _{wsg(std)})	9.515	scf	
Std Meter Volume	(V _{m(std)})	86.318	dscf		Sat. Moisture Content	(B _{ws(svp)})	67.40	%	
Calc Moisture Content	(B _{ws(calc)})	9.93	%		Final Moisture Content	(B _{ws})	9.93	%	

Moisture Content Data									
Run Number	1-100 w/DB-PM-2		Date	09/25/18	Start Time	04:11	Stop Time	08:27	
Meter Box Number	SAMP-CP-0028				Meter Cal Factor	(Y)	0.962		
Total Meter Volume	(V _m)	90.320	dcf		Barometric Pressure	(P _b)	29.77	in Hg	
Average Stack Temp	(t _s) _{avg}	192	°F		Stack Static Pressure	(P _{static})	-1.10	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	71	°F		Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	462.90	620.30	751.20	871.80				
Initial Value	(V _i),(W _i)	364.40	620.60	742.90	853.80				
Net Value	(V _n),(W _n)	98.5	-0.3	8.3	18.0				
Results									
Total Weight	(W _t)	124.50	g		Water Vol Weighed	(V _{wsg(std)})	5.870	scf	
Std Meter Volume	(V _{m(std)})	86.094	dscf		Sat. Moisture Content	(B _{ws(svp)})	66.97	%	
Calc Moisture Content	(B _{ws(calc)})	6.38	%		Final Moisture Content	(B _{ws})	6.38	%	

Moisture Content Data									
Run Number	1-100 w/DB-PM-3		Date	09/25/18	Start Time	09:20	Stop Time	13:40	
Meter Box Number	SAMP-CP-0028				Meter Cal Factor	(Y)	0.962		
Total Meter Volume	(V _m)	93.310	dcf		Barometric Pressure	(P _b)	30.39	in Hg	
Average Stack Temp	(t _s) _{avg}	191	°F		Stack Static Pressure	(P _{static})	-1.10	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	72	°F		Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	493.70	550.40	763.30	889.70				
Initial Value	(V _i),(W _i)	351.30	549.50	753.60	871.70				
Net Value	(V _n),(W _n)	142.4	0.9	9.7	18.0				
Results									
Total Weight	(W _t)	171.00	g		Water Vol Weighed	(V _{wsg(std)})	8.063	scf	
Std Meter Volume	(V _{m(std)})	90.652	dscf		Sat. Moisture Content	(B _{ws(svp)})	63.30	%	
Calc Moisture Content	(B _{ws(calc)})	8.17	%		Final Moisture Content	(B _{ws})	8.17	%	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	MP / CG
Run Number	1-100 w/DB-PM-1

Filter #	000010
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7240	4187/10	
Average Stack Temp (t_s)	192.6		°F
Average Meter Temp (t_m)	74.7		
Orifice Meter Coefficient (ΔH_{or})	1.838		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.20		in H ₂ O
Stack Moisture Content (B_{ws})	9.93		%
Stack Dry Molecular Weight (M_d)	29.28		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	0.29		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	15.0	in H ₂ O for	30.0 sec
		Pre (-)	15.0	in H ₂ O for	30.0 sec
		Post (+)	15.0	in H ₂ O for	30.0 sec
		Post (-)	15.0	in H ₂ O for	30.0 sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0028		
Meter Cal Factor (Y)	0.962		
Nozzle Number	3		
Average Nozzle Diameter (D_{na})	0.1513		in
Suggested Nozzle Diameter (D_m)	0.2170		in
Probe Number	samp-hp-0151		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-hp-0011		
Impinger Case Number	samp-cp-0017		

Nozzle Measurements					ID: 3
Pre	0.151	0.152	0.151	PASS	
Post	0.151	0.152	0.151	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	23:32	End	03:48

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	350.7	547.5	693.2	852.4				
Post	516.7	550.7	706.1	872.1				

Pressures			
Barometric Pressure (P_b)	29.84		in Hg
Stack Static Pressure (P_{static})	-1.10		in H ₂ O
Absolute Stack Pressure (P_s)	29.76		in Hg
Absolute Meter Pressure (P_m)	29.98		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0028	SAMP-CP-0028	SAMP-CP-0028			samp-hp-0151	samp-hp-0151	samp-hp-0011	samp-cp-0017	1006	8664	SAMP-CP-0028	SAMP-CP-0028							
Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp) (in H ₂ O)	Desired Orifice ΔH (ΔH _d) (in H ₂ O)	Actual Orifice ΔH (ΔH _a) (in H ₂ O)	Stack Temp (t _s) (°F)	Probe Temp (248±25°F) (°F)	Filter Temp (248±25°F) (°F)	Impinger Exit Temp (≤68°F) (°F)	Cond. Temp (≤85°F) (°F)	CPM Filter Temp (76.5±8.5°F) (°F)	Meter Inlet Temp (t _{mi}) (°F)	Meter Outlet Temp (t _{mo}) (°F)	Pump Vacuum (in Hg)	Square Root ΔP (ΔP ^{1/2}) (in H ₂ O)	Local Stack Velocity (V _s) (ft/sec)	Cumul. Meter Volume (V _m) _{std} (dscf)	Cumul. Percent IsoKinetic (I) (%)	Est-Run Meter Volume (V _m) _{std} (dscf)
A-1	0.0	00:00:00	375.620	1.50	0.423	0.42	193	242	258	49	56	70	74	74	2.5	1.22	66.92	7.236	96.0	85.003
A-2	20.8	00:20:45	383.240	1.40	0.423	0.42	192	246	256	46	56	70	74	74	2.5	1.18	64.60	13.998	96.2	83.728
A-3	40.8	00:40:45	390.360	1.50	0.423	0.42	191	253	255	47	61	70	76	76	2.5	1.22	66.82	21.491	97.3	85.176
B-1	61.5	01:01:30	398.280	1.20	0.423	0.42	192	245	260	47	63	71	76	76	2.5	1.10	59.81	27.441	98.5	84.402
B-2	79.3	01:19:15	404.570	1.30	0.423	0.42	193	236	245	47	64	72	76	76	2.5	1.14	62.30	33.932	99.5	84.612
B-3	97.8	01:37:45	411.430	1.30	0.423	0.42	194	255	258	48	65	71	76	76	2.5	1.14	62.35	40.573	100.6	85.073
C-1	116.3	01:56:15	418.450	1.50	0.423	0.42	193	242	249	50	66	72	75	75	2.5	1.22	66.92	48.535	100.9	85.883
C-2	137.8	02:17:45	426.850	1.40	0.423	0.42	193	236	255	47	65	71	74	74	2.5	1.18	64.65	55.885	100.9	85.943
C-3	158.5	02:38:30	434.590	1.40	0.423	0.42	193	225	254	47	65	70	74	74	2.5	1.18	64.65	63.264	100.9	86.028
D-1	179.3	02:59:15	442.360	1.70	0.423	0.42	193	223	257	47	64	70	74	74	2.5	1.30	71.24	71.165	99.9	86.086
D-2	201.5	03:21:30	450.680	1.60	0.423	0.42	192	224	256	47	64	69	74	74	2.5	1.26	69.06	78.828	99.5	86.163
D-3	223.0	03:43:00	458.750	1.50	0.423	0.42	192	229	252	47	64	70	73	73	2.5	1.22	66.87	86.325	99.5	86.325
Last Pt	243.8	04:03:45	466.630																	
Final Val	243.8	04:03:45	466.630												Max Vac	2.5	Final Values	86.325	99.5	
Average Values				1.44		0.42	193	238	255	47	63	71	75	75		1.20	65.52			

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP / CG
Run Number	1-100 w/DB-PM-2

Filter #	05301
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7240	4187/10	
Average Stack Temp (t_s)	192.2		°F
Average Meter Temp (t_m)	70.8		
Orifice Meter Coefficient ($\Delta H @$)	1.838		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.16		in H ₂ O
Stack Moisture Content (B_{ws})	6.38		%
Stack Dry Molecular Weight (M_d)	29.27		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.35		acfm
ΔP to ΔH Isokinetic Factor (K)	0.31		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	15.0	in H ₂ O for	30.0 sec
		Pre (-)	15.0	in H ₂ O for	30.0 sec
		Post (+)	15.0	in H ₂ O for	30.0 sec
		Post (-)	15.0	in H ₂ O for	30.0 sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0028		
Meter Cal Factor (Y)	0.962		
Nozzle Number	3		
Average Nozzle Diameter (D_{na})	0.1517		in
Suggested Nozzle Diameter (D_m)	0.1513		in
Probe Number	samp-hp-0151		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-hp-0011		
Impinger Case Number	samp-cp-0017		

Nozzle Measurements					ID: 3
Pre	0.152	0.152	0.151	PASS	
Post	0.152	0.152	0.151	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	04:11	End 08:27

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	364.4	620.6	742.9	853.8				
Post	462.9	620.3	751.2	871.8				

Pressures			
Barometric Pressure (P_b)	29.77		in Hg
Stack Static Pressure (P_{static})	-1.10		in H ₂ O
Absolute Stack Pressure (P_s)	29.69		in Hg
Absolute Meter Pressure (P_m)	29.91		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0028	SAMP-CP-0028	SAMP-CP-0028			samp-hp-0151	samp-hp-0151	samp-hp-0011	samp-cp-0017	1006	8664	SAMP-CP-0028	SAMP-CP-0028							
Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m,Std})
A-1	0.0	00:00:00	467.130	1.40	0.423	0.42	190	225	256	48	52	70	71	71	1.0	1.18	64.13	7.317	96.9	87.013
A-2	20.8	00:20:45	474.810	1.30	0.423	0.42	191	231	251	46	50	68	70	70	1.0	1.14	61.85	14.047	96.4	85.056
A-3	40.8	00:40:45	481.860	1.40	0.423	0.42	191	228	261	45	51	69	71	71	1.5	1.18	64.18	21.335	96.5	85.602
B-1	61.5	01:01:30	489.510	1.30	0.423	0.42	191	226	253	45	51	69	71	71	1.5	1.14	61.85	27.223	96.1	84.762
B-2	79.3	01:19:15	495.690	1.30	0.423	0.42	192	225	256	45	51	71	70	70	2.0	1.14	61.90	33.466	96.9	85.132
B-3	97.0	01:37:00	502.230	1.400	0.423	0.42	193	226	256	47	52	72	70	70	2.0	1.18	64.28	40.196	97.4	85.873
C-1	115.5	01:55:30	509.280	1.400	0.423	0.42	193	226	255	47	52	72	71	71	2.0	1.18	64.28	47.942	97.7	86.348
C-2	137.0	02:17:00	517.410	1.400	0.423	0.42	193	238	250	47	54	71	71	71	2.0	1.18	64.28	55.402	97.4	86.249
C-3	158.5	02:38:30	525.240	1.40	0.423	0.42	193	246	261	48	54	68	71	71	2.0	1.18	64.28	62.995	97.4	86.356
D-1	180.0	03:00:00	533.210	1.30	0.423	0.42	193	244	262	49	56	70	71	71	2.0	1.14	61.94	70.722	97.6	86.283
D-2	202.3	03:22:15	541.320	1.30	0.423	0.42	193	261	253	49	56	71	71	71	2.0	1.14	61.94	78.487	97.8	86.266
D-3	224.5	03:44:30	549.470	1.30	0.423	0.42	193	263	257	49	57	72	71	71	2.0	1.14	61.94	86.090	97.8	86.090
Last Pt	246.8	04:06:45	557.450																	
Final Val	246.8	04:06:45	557.450												Max Vac 2.0		Final Values	86.090	97.8	
Average Values				1.35		0.42	192	237	256	47	53	70	71	71		1.16	63.07			

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP / CG
Run Number	1-100 w/DB-PM-3

Filter #	05323
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.7240	4187/10	
Average Stack Temp (t _s)	190.5		°F
Average Meter Temp (t _m)	71.6		
Orifice Meter Coefficient (ΔH@)	1.838		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.19		in H ₂ O
Stack Moisture Content (B _{ws})	8.17		%
Stack Dry Molecular Weight (M _d)	29.23		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.35		acfm
ΔP to ΔH Isokinetic Factor (K)	0.31		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	5.0	in H ₂ O for	30.0	sec
	Pre (-)	5.0	in H ₂ O for	30.0	sec
	Post (+)	5.0	in H ₂ O for	30.0	sec
	Post (-)	5.0	in H ₂ O for	30.0	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0028		
Meter Cal Factor (Y)	0.962		
Nozzle Number	3		
Average Nozzle Diameter (D _{na})	0.1523		in
Suggested Nozzle Diameter (D _m)	0.1494		in
Probe Number	samp-hp-0151		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-hp-0011		
Impinger Case Number	samp-cp-0017		

Nozzle Measurements				ID: 3
Pre	0.152	0.152	0.153	PASS
Post	0.152	0.152	0.153	PASS

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0031

Run Time		
Start	09:20	End 13:40

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	351.3	549.5	753.6	871.7				
Post	493.7	550.4	763.3	889.7				

Pressures		
Barometric Pressure (P _b)	30.39	in Hg
Stack Static Pressure (P _{static})	-1.10	in H ₂ O
Absolute Stack Pressure (P _s)	30.31	in Hg
Absolute Meter Pressure (P _m)	30.53	in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0028	SAMP-CP-0028	SAMP-CP-0028			samp-hp-0151	samp-hp-0151	samp-hp-0011	samp-cp-0017	1037	3130	SAMP-CP-0028	SAMP-CP-0028								
Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}	
A-1	0.0	00:00:00	559.420	1.30	0.423	0.42	191	261	262	51	59	74	71	71	2.0	1.14	61.46	7.479	102.4	88.939	
A-2	20.8	00:20:45	567.110	1.30	0.423	0.42	191	258	251	53	59	74	71	71	2.0	1.14	61.46	15.143	103.7	90.037	
A-3	41.5	00:41:30	574.990	1.30	0.423	0.42	190	262	260	54	59	73	71	71	2.0	1.14	61.42	22.476	102.6	89.093	
B-1	62.3	01:02:15	582.530	1.40	0.423	0.42	191	248	251	54	63	72	70	70	2.0	1.18	63.78	29.171	102.7	89.973	
B-2	80.0	01:20:00	589.400	1.40	0.423	0.42	191	248	253	55	62	71	70	70	2.0	1.18	63.78	34.842	100.3	87.951	
B-3	97.8	01:37:45	595.220	1.40	0.423	0.42	190	248	255	54	65	72	71	71	2.0	1.18	63.73	41.105	99.7	87.815	
C-1	115.5	01:55:30	601.660	1.50	0.423	0.42	189	249	257	54	68	71	72	72	2.0	1.22	65.92	48.900	99.1	88.074	
C-2	137.0	02:17:00	609.690	1.50	0.423	0.42	190	250	252	54	65	72	72	72	2.0	1.22	65.97	56.880	98.9	88.549	
C-3	158.5	02:38:30	617.910	1.50	0.423	0.42	190	251	252	54	65	73	72	72	2.0	1.22	65.97	64.976	99.0	89.071	
D-1	180.0	03:00:00	626.250	1.50	0.423	0.42	191	258	262	58	65	72	73	73	2.0	1.22	66.02	73.570	99.4	89.757	
D-2	202.3	03:22:15	635.120	1.50	0.423	0.42	191	254	261	59	63	71	73	73	2.0	1.22	66.02	82.174	99.7	90.318	
D-3	224.5	03:44:30	644.000	1.50	0.423	0.42	191	252	261	59	63	72	73	73	2.0	1.22	66.02	90.633	99.8	90.633	
Last Pt	246.8	04:06:45	652.730																		
Final Val	246.8	04:06:45	652.730												Max Vac	2.0	Final Values	90.633	99.8		
Average Values				1.43		0.42	191	253	256	55	63	72	72	72		1.19	64.30				

Notes:

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
without Duct Burners Firing
Sulfuric Acid Mist Data**

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	1-Base-SO3-1	1-Base-SO3-2	1-Base-SO3-3	Average	Units	Limits
Run Start Time	12:32	20:28	23:01		hh:mm	
Run Stop Time	14:34	22:28	01:01		hh:mm	
Test Date	09/24/18	09/25/18	09/25/18		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	1.009	1.009	1.009			
Stack Test Data	1-Base-SO3-1	1-Base-SO3-2	1-Base-SO3-3	Average	Units	Limits
Initial Meter Volume	220.520	728.050	775.610		ft ³	
Final Meter Volume	258.320	769.610	816.580		ft ³	
Total Meter Volume	37.800	41.560	40.970	40.110	ft ³	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	75.17	76.63	69.92	73.90	°F	
Average Stack Temperature	217.08	217.75	205.00	213.28	°F	
Barometric Pressure	29.97	29.96	29.94	29.96	in Hg	
Stack Static Pressure	-0.87	-0.87	-0.87	-0.87	in H ₂ O	
Absolute Stack Pressure	29.91	29.90	29.88	29.89	in Hg	
Average Orifice Pressure Drop	0.43	0.43	0.43	0.43	in H ₂ O	
Absolute Meter Pressure	30.11	30.10	30.08	30.09	in Hg	
Moisture Content Data	1-Base-SO3-1	1-Base-SO3-2	1-Base-SO3-3	Average	Units	Limits
Impinger Water Weight Gain	58.80	165.50	82.00	102.10	g	
Silica Gel Weight Gain	18.60	7.10	8.70	11.47	g	
Total Water Volume Collected	77.54	172.91	90.86	113.77	ml	
Standard Water Vapor Volume	3.65	8.14	4.28	5.35	scf	
Standard Meter Volume	37.7	41.4	41.3	40.1	dscf	
Standard Metric Meter Volume	1.1	1.2	1.2	1.1	dscm	
Calculated Stack Moisture	8.82	16.44	9.39	11.55	%	
Saturated Stack Moisture	100.00	100.00	86.95	95.65	%	
Reported Stack Moisture Content	8.82	16.44	9.39	11.55	%	
Gas Analysis Data	1-Base-SO3-1	1-Base-SO3-2	1-Base-SO3-3	Average	Units	Limits
Carbon Dioxide Content	4.1	4.2	4.2	4.2	%	
Oxygen Content	13.4	13.4	13.4	13.4	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.5	82.5	82.4	82.5	%	
Stack Dry Molecular Weight	29.19	29.20	29.21	29.20	lb/lb-mole	
Stack Wet Molecular Weight	28.20	27.36	28.16	27.91	lb/lb-mole	
Calculated Fuel Factor	1.829	1.817	1.786	1.811		
Fuel F-Factor	8633.27	8632.22	8632.22	8632.57	dscf/MMBtu	
Percent Excess Air	159.9	158.7	160.4	159.7	%	
Volumetric Flow Rate Data	1-Base-SO3-1	1-Base-SO3-2	1-Base-SO3-3	Average	Units	Limits
Stack Cross-Sectional Area	285.40	285.40	285.40	285.40	ft ²	

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Sulfuric Acid Mist IC Analysis	1-Base-SO3-1	1-Base-SO3-2	1-Base-SO3-3	Average	Units	Limits
H ₂ SO ₄ (IC) Sample Volume - Front Half Rinse	107.0	85.0	90.0	94.00	ml	--
H ₂ SO ₄ (IC) Sample - Mass Per Volume	0.103	0.106	0.100	0.10	mg/L	--
H ₂ SO ₄ (IC) Mass	0.01	0.01	0.01	0.01	mg	--
H ₂ SO ₄ (IC) Concentration	2.92E-07	2.18E-07	2.18E-07	2.42E-07	g/dscf	--
	4.50E-06	3.36E-06	3.37E-06	3.74E-06	gr/dscf	--
	1.03E-08	7.68E-09	7.70E-09	8.56E-09	g/L	--
	0.0025	0.0019	0.0019	0.0021	ppmvd	--
H ₂ SO ₄ (IC) Emission Rate	0.000015	0.000011	0.000012	0.000013	lb/MMBtu	0.0007

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		CG/MP	
Date for Preliminary Run	(mm/dd/yy)	09/24/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	8a, 2.4.1.3	10.6	scf
Run Duration	10 L/min	120	minutes
Unit Number		CTG-1	
Base Run Number		1-Base-SO3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/24/18	09/25/18	09/25/18	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8633.27	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0024	samp-cp-0024	samp-cp-0024	
Meter Calibration Factor	(Y)	1.009	1.009	1.009	
Orifice Meter Coefficient	(ΔH_{or})	1.869	1.869	1.869	in H ₂ O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	1	1	1	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-bh-0005	samp-bh-0005	samp-bh-0005	
Impinger Case Number	from ACS	samp-bc-0025	3028	samp-bc-0025	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18		
Sampling Location	CTG-1 Stack	Operator	CG/MP		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	1-Base-SO3-1		Date	09/24/18	Run Start Time	12:32	Run Stop Time	14:34
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:02	4.1	13.4	0.0	82.5	29.19	1.829	159.9	YES

Gas Analysis Data								
Run Number	1-Base-SO3-2		Date	09/25/18	Run Start Time	20:28	Run Stop Time	22:28
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.2	13.4	0.0	82.5	29.20	1.817	158.7	YES

Gas Analysis Data								
Run Number	1-Base-SO3-3		Date	09/25/18	Run Start Time	23:01	Run Stop Time	01:01
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
	4.2	13.4	0.0	82.4	29.21	1.786	160.4	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18
Sampling Location	CTG-1 Stack	Operator	CG/MP
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/24/18	500	499.9	-0.1	Pass
Test Day 1	09/24/18	500	499.9	-0.1	Pass
Test Day 2	09/25/18	500	499.9	-0.1	Pass

Moisture Content Data								
Run Number	1-Base-SO3-1		Date	09/24/18	Start Time	12:32	Stop Time	14:34
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009	
Total Meter Volume	(V _m)	37.800	dcf	Barometric Pressure	(P _b)	29.97	in Hg	
Average Stack Temp	(t _s) _{avg}	217	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	75	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	720.90	674.20	605.40	878.60			
Initial Value	(V _i),(W _i)	681.10	658.40	602.20	860.00			
Net Value	(V _n),(W _n)	39.8	15.8	3.2	18.6			
Results								
Total Weight	(W _t)	77.40	g	Water Vol Weighed	(V _{wsg(std)})	3.649	scf	
Std Meter Volume	(V _{m(std)})	37.732	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.00	%	
Calc Moisture Content	(B _{ws(calc)})	8.82	%	Final Moisture Content	(B _{ws})	8.82	%	

Moisture Content Data								
Run Number	1-Base-SO3-2		Date	09/25/18	Start Time	20:28	Stop Time	22:28
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009	
Total Meter Volume	(V _m)	41.560	dcf	Barometric Pressure	(P _b)	29.96	in Hg	
Average Stack Temp	(t _s) _{avg}	218	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	77	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	785.30	763.20	606.20	894.50			
Initial Value	(V _i),(W _i)	714.80	668.20	606.20	887.40			
Net Value	(V _n),(W _n)	70.5	95.0	0.0	7.1			
Results								
Total Weight	(W _t)	172.60	g	Water Vol Weighed	(V _{wsg(std)})	8.138	scf	
Std Meter Volume	(V _{m(std)})	41.359	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.00	%	
Calc Moisture Content	(B _{ws(calc)})	16.44	%	Final Moisture Content	(B _{ws})	16.44	%	

Moisture Content Data								
Run Number	1-Base-SO3-3		Date	09/25/18	Start Time	23:01	Stop Time	01:01
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009	
Total Meter Volume	(V _m)	40.970	dcf	Barometric Pressure	(P _b)	29.94	in Hg	
Average Stack Temp	(t _s) _{avg}	205	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	70	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	740.50	686.80	597.10	889.90			
Initial Value	(V _i),(W _i)	665.40	680.80	596.20	881.20			
Net Value	(V _n),(W _n)	75.1	6.0	0.9	8.7			
Results								
Total Weight	(W _t)	90.70	g	Water Vol Weighed	(V _{wsg(std)})	4.277	scf	
Std Meter Volume	(V _{m(std)})	41.260	dscf	Sat. Moisture Content	(B _{ws(svp)})	86.95	%	
Calc Moisture Content	(B _{ws(calc)})	9.39	%	Final Moisture Content	(B _{ws})	9.39	%	

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	CG
Run Number	1-Base-SO3-1

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	217.1	°F	
Average Meter Temp (t _m)	75.2		
Orifice Meter Coefficient (ΔH@)	1.869	in H ₂ O	
Square Root ΔP (ΔP ^{1/2} _{avg})		in H ₂ O	
Stack Moisture Content (B _{ws})	8.82	%	
Stack Dry Molecular Weight (M _d)	29.19	lb/lb-mole	
Estimated Orifice Flow Rate (Q _m)	0.75	acfm	
ΔP to ΔH IsoKinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	NA	in H ₂ O for	NA	sec
	Pre (-)	NA	in H ₂ O for	NA	sec
	Post (+)	NA	in H ₂ O for	NA	sec
	Post (-)	NA	in H ₂ O for	NA	sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D _{na})	--	in	
Suggested Nozzle Diameter (D _m)		in	
Probe Number	1	in	
Probe Length	108	in	
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0005		
Impinger Case Number	samp-bc-0025		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	12:32	End	14:34

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	681.1	658.4	602.2	860.0				
Post	720.9	674.2	605.4	878.6				

Pressures			
Barometric Pressure (P _b)	29.97	in Hg	
Stack Static Pressure (P _{static})	-0.87	in H ₂ O	
Absolute Stack Pressure (P _s)	29.91	in Hg	
Absolute Meter Pressure (P _m)	30.11	in Hg	

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024	samp-cp-0024	samp-cp-0024		1	1	samp-bh-0005	samp-bc-0025	1013		samp-cp-0024	samp-cp-0024							
Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m,Std})
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	220.520	--	--	0.43	211	378	530	64	168	74	74	5.0	--	--	1.000	--	24.009
A-1	5.0	00:05:00	221.520	--	--	0.43	212	368	534	64	173	74	74	5.0	--	--	2.601	--	31.212
A-1	10.0	00:10:00	223.120	--	--	0.43	215	369	528	64	173	74	74	5.0	--	--	4.202	--	33.613
A-1	15.0	00:15:00	224.720	--	--	0.43	217	370	541	64	172	74	74	5.0	--	--	5.802	--	34.813
A-1	20.0	00:20:00	226.320	--	--	0.43	218	370	540	65	172	74	74	5.0	--	--	7.403	--	35.534
A-1	25.0	00:25:00	227.920	--	--	0.43	217	371	535	65	171	74	74	5.0	--	--	9.003	--	36.014
A-1	30.0	00:30:00	229.520	--	--	0.43	218	374	541	65	177	74	74	5.0	--	--	10.604	--	36.357
A-1	35.0	00:35:00	231.120	--	--	0.43	219	372	545	64	176	74	74	5.0	--	--	12.205	--	36.614
A-1	40.0	00:40:00	232.720	--	--	0.43	219	374	540	65	175	74	74	5.0	--	--	13.805	--	36.814
A-1	45.0	00:45:00	234.320	--	--	0.43	219	379	542	64	176	75	75	5.0	--	--	15.403	--	36.967
A-1	50.0	00:50:00	235.920	--	--	0.43	220	379	548	64	180	75	75	5.0	--	--	17.001	--	37.092
A-1	55.0	00:55:00	237.520	--	--	0.43	220	374	546	64	179	75	75	5.0	--	--	18.598	--	37.196
A-1	60.0	01:00:00	239.120	--	--	0.43	211	380	542	65	181	75	75	5.0	--	--	20.196	--	37.285
A-1	65.0	01:05:00	240.720	--	--	0.43	212	379	544	66	180	75	75	5.0	--	--	21.793	--	37.360
A-1	70.0	01:10:00	242.320	--	--	0.43	215	375	540	66	179	75	75	5.0	--	--	23.391	--	37.426
A-1	75.0	01:15:00	243.920	--	--	0.43	217	375	541	66	180	75	75	5.0	--	--	24.989	--	37.483
A-1	80.0	01:20:00	245.520	--	--	0.43	218	372	535	67	178	76	76	5.0	--	--	26.583	--	37.529
A-1	85.0	01:25:00	247.120	--	--	0.43	217	371	541	67	180	76	76	5.0	--	--	28.178	--	37.571
A-1	90.0	01:30:00	248.720	--	--	0.43	218	375	545	68	181	76	76	5.0	--	--	29.773	--	37.607
A-1	95.0	01:35:00	250.320	--	--	0.43	219	380	540	68	181	77	77	5.0	--	--	31.364	--	37.637
A-1	100.0	01:40:00	251.920	--	--	0.43	219	377	545	67	179	77	77	5.0	--	--	32.956	--	37.664
A-1	105.0	01:45:00	253.520	--	--	0.43	219	375	541	67	175	77	77	5.0	--	--	34.548	--	37.688
A-1	110.0	01:50:00	255.120	--	--	0.43	220	374	539	67	175	77	77	5.0	--	--	36.139	--	37.711
A-1	115.0	01:55:00	256.720	--	--	0.43	220	370	540	67	175	77	77	5.0	--	--	37.731	--	37.731
Last Pt	120.0	02:00:00	258.320	--	--														
Final Val	120.0	02:00:00	258.320											Max Vac	5.0	Final Values	37.731		
Average Values						0.43	217	374	540	66	177	75	75						
												75							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP
Run Number	1-Base-SO3-2

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)			
Average Stack Temp (t_s)	217.8	°F	
Average Meter Temp (t_m)	76.6		
Orifice Meter Coefficient ($\Delta H @$)	1.869	in H ₂ O	
Square Root ΔP ($\Delta P^{1/2}_{avg}$)		in H ₂ O	
Stack Moisture Content (B_{ws})	16.44	%	
Stack Dry Molecular Weight (M_d)	29.20	lb/lb-mole	
Estimated Orifice Flow Rate (Q_m)	0.31	acfm	
ΔP to ΔH Isokinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot Pre (+)	NA	in H ₂ O for	NA	sec
	Pitot Pre (-)	NA	in H ₂ O for	NA	sec
	Pitot Post (+)	NA	in H ₂ O for	NA	sec
	Pitot Post (-)	NA	in H ₂ O for	NA	sec

Sampling Equipment		
Meter Box Number	samp-cp-0024	
Meter Cal Factor (Y)	1.009	
Nozzle Number		
Average Nozzle Diameter (D_{na})	--	in
Suggested Nozzle Diameter (D_m)		in
Probe Number	1	in
Probe Length	108	in
Liner Material	glass	
Sample Case / Oven Number	samp-bh-0005	
Impinger Case Number	3028	

Pressures			
Barometric Pressure (P_b)	29.96	in Hg	
Stack Static Pressure (P_{static})	-0.87	in H ₂ O	
Absolute Stack Pressure (P_s)	29.90	in Hg	
Absolute Meter Pressure (P_m)	30.10	in Hg	

Nozzle Measurements				
Pre	--	--	--	PASS
Post	--	--	--	PASS

Barometer ID		
SAMP-WE-0041		
Scale ID		
SAMP-SC-0031		

Run Time			
Start	20:28	End	22:28

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	714.8	668.2	606.2	887.4				
Post	785.3	763.2	606.2	894.5				

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024	samp-cp-0024	samp-cp-0024	1		1		samp-bh-0005		3028		3028		samp-cp-0024		samp-cp-0024	Sump	Square Root ΔP ($\Delta P^{1/2}$)	Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)
				Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (t_p)	Filter Temp (t_f)	Impinger Exit Temp (t_e)	Cond. Temp (t_c)	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Root ΔP ($\Delta P^{1/2}$)	Local Stack Velocity (v_s)							
A-1	0.0	00:00:00	728.050	--	--	0.43	223	377	523	63	170	--	77	77	1.5	--	--	--	1.710	--	41.051	
A-2	5.0	00:05:00	729.770	--	--	0.43	222	376	524	59	171	--	78	78	1.5	--	--	--	3.408	--	40.894	
A-3	10.0	00:10:00	731.480	--	--	0.43	220	377	522	60	171	--	77	77	1.5	--	--	--	5.118	--	40.947	
A-4	15.0	00:15:00	733.200	--	--	0.43	218	375	522	60	171	--	77	77	1.5	--	--	--	6.839	--	41.033	
A-5	20.0	00:20:00	734.930	--	--	0.43	218	375	521	60	171	--	77	77	1.5	--	--	--	8.539	--	40.989	
A-6	25.0	00:25:00	736.640	--	--	0.43	218	376	520	60	172	--	77	77	1.5	--	--	--	10.260	--	41.039	
B-1	30.0	00:30:00	738.370	--	--	0.43	216	377	521	60	172	--	78	78	1.5	--	--	--	11.987	--	41.098	
B-2	35.0	00:35:00	740.110	--	--	0.43	217	377	520	61	171	--	78	78	1.5	--	--	--	13.674	--	41.023	
B-3	40.0	00:40:00	741.810	--	--	0.43	216	376	519	61	171	--	77	77	1.5	--	--	--	15.435	--	41.159	
B-4	45.0	00:45:00	743.580	--	--	0.43	216	376	518	61	172	--	77	77	1.5	--	--	--	17.145	--	41.148	
B-5	50.0	00:50:00	745.300	--	--	0.43	215	377	514	60	171	--	78	78	1.5	--	--	--	18.882	--	41.197	
B-6	55.0	00:55:00	747.050	--	--	0.43	214	376	517	60	172	--	77	77	1.5	--	--	--	20.682	--	41.364	
C-1	60.0	01:00:00	748.860	--	--	0.43	223	377	521	59	171	--	77	77	1.5	--	--	--	22.333	--	41.230	
C-2	65.0	01:05:00	750.520	--	--	0.43	222	376	523	59	172	--	78	78	1.5	--	--	--	24.050	--	41.229	
C-3	70.0	01:10:00	752.250	--	--	0.43	220	377	523	60	171	--	77	77	1.5	--	--	--	25.810	--	41.296	
C-4	75.0	01:15:00	754.020	--	--	0.43	218	377	524	61	170	--	77	77	1.5	--	--	--	27.551	--	41.326	
C-5	80.0	01:20:00	755.770	--	--	0.43	218	377	524	61	171	--	76	76	1.5	--	--	--	29.284	--	41.342	
C-6	85.0	01:25:00	757.510	--	--	0.43	218	377	524	61	171	--	76	76	1.5	--	--	--	31.048	--	41.397	
D-1	90.0	01:30:00	759.280	--	--	0.43	216	376	525	61	172	--	76	76	1.5	--	--	--	32.751	--	41.370	
D-2	95.0	01:35:00	760.990	--	--	0.43	217	376	525	62	171	--	75	75	1.5	--	--	--	34.468	--	41.362	
D-3	100.0	01:40:00	762.710	--	--	0.43	216	375	527	62	170	--	75	75	1.5	--	--	--	36.185	--	41.354	
D-4	105.0	01:45:00	764.430	--	--	0.43	216	376	527	62	171	--	75	75	1.5	--	--	--	37.912	--	41.359	
D-5	110.0	01:50:00	766.160	--	--	0.43	215	377	527	63	171	--	75	75	1.5	--	--	--	39.629	--	41.352	
D-6	115.0	01:55:00	767.880	--	--	0.43	214	377	525	63	170	--	74	74	1.5	--	--	--	41.359	--	41.359	
Last Pt	120.0	02:00:00	769.610	--	--	0.43																
Final Val	120.0	02:00:00	769.610																			
Average Values						0.43	218	376	522	61	171		77	77						41.359		

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP
Run Number	1-Base-SO3-3

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	205.0		°F
Average Meter Temp (t _m)	69.9		
Orifice Meter Coefficient (ΔH _@)	1.869		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _{ws})	9.39		%
Stack Dry Molecular Weight (M _d)	29.21		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.34		acfm
ΔP to ΔH Isokinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	NA	in H ₂ O for	NA	sec
	Pre (-)	NA	in H ₂ O for	NA	sec
	Post (+)	NA	in H ₂ O for	NA	sec
	Post (-)	NA	in H ₂ O for	NA	sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D _{na})	--		in
Suggested Nozzle Diameter (D _m)			in
Probe Number	1		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0005		
Impinger Case Number	samp-bc-0025		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	23:01	End 01:01

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	665.4	680.8	596.2	881.2				
Post	740.5	686.8	597.1	889.9				

Pressures			
Barometric Pressure (P _b)	29.94		in Hg
Stack Static Pressure (P _{static})	-0.87		in H ₂ O
Absolute Stack Pressure (P _s)	29.88		in Hg
Absolute Meter Pressure (P _m)	30.08		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024	samp-cp-0024	samp-cp-0024		1	1	samp-bh-0005	samp-bc-0025	3102		samp-cp-0024	samp-cp-0024							
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m, std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m, std})
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	775.610	--	--	0.43	205	374	523	66	170	71	71	1.0	--	--	1.729	--	41.488
A-2	5.0	00:05:00	777.330	--	--	0.43	206	375	523	66	171	70	70	1.0	--	--	3.450	--	41.406
A-3	10.0	00:10:00	779.040	--	--	0.43	206	375	524	66	171	70	70	1.0	--	--	5.142	--	41.137
A-4	15.0	00:15:00	780.720	--	--	0.43	205	374	522	67	171	70	70	1.0	--	--	6.864	--	41.184
A-5	20.0	00:20:00	782.430	--	--	0.43	206	374	522	66	170	70	70	1.0	--	--	8.576	--	41.164
A-6	25.0	00:25:00	784.130	--	--	0.43	207	374	523	62	172	70	70	1.0	--	--	10.308	--	41.231
B-1	30.0	00:30:00	785.850	--	--	0.43	204	375	524	59	172	70	70	1.0	--	--	12.030	--	41.244
B-2	35.0	00:35:00	787.560	--	--	0.43	205	374	523	57	172	70	70	1.0	--	--	13.761	--	41.284
B-3	40.0	00:40:00	789.280	--	--	0.43	204	375	523	57	171	70	70	1.0	--	--	15.493	--	41.316
B-4	45.0	00:45:00	791.000	--	--	0.43	204	375	526	57	171	70	70	1.0	--	--	17.215	--	41.316
B-5	50.0	00:50:00	792.710	--	--	0.43	204	375	525	57	171	70	70	1.0	--	--	18.947	--	41.339
B-6	55.0	00:55:00	794.430	--	--	0.43	204	376	526	58	172	71	71	1.0	--	--	20.565	--	41.130
C-1	60.0	01:00:00	796.040	--	--	0.43	205	377	527	57	171	70	70	1.0	--	--	22.297	--	41.164
C-2	65.0	01:05:00	797.760	--	--	0.43	206	376	526	57	171	70	70	1.0	--	--	24.029	--	41.193
C-3	70.0	01:10:00	799.480	--	--	0.43	206	375	526	57	172	69	69	1.0	--	--	25.764	--	41.223
C-4	75.0	01:15:00	801.200	--	--	0.43	205	376	525	57	171	70	70	1.0	--	--	27.496	--	41.244
C-5	80.0	01:20:00	802.920	--	--	0.43	206	375	524	58	171	70	70	1.0	--	--	29.258	--	41.306
C-6	85.0	01:25:00	804.670	--	--	0.43	207	375	524	58	171	71	71	1.0	--	--	31.007	--	41.343
D-1	90.0	01:30:00	806.410	--	--	0.43	204	374	520	58	172	70	70	1.0	--	--	32.709	--	41.316
D-2	95.0	01:35:00	808.100	--	--	0.43	205	375	522	58	170	70	70	1.0	--	--	34.431	--	41.317
D-3	100.0	01:40:00	809.810	--	--	0.43	204	375	523	59	170	69	69	1.0	--	--	36.115	--	41.275
D-4	105.0	01:45:00	811.480	--	--	0.43	204	376	524	59	170	69	69	1.0	--	--	37.790	--	41.225
D-5	110.0	01:50:00	813.140	--	--	0.43	204	377	525	60	171	69	69	1.0	--	--	39.525	--	41.244
D-6	115.0	01:55:00	814.860	--	--	0.43	204	377	525	60	171	69	69	1.0	--	--	41.260	--	41.260
Last Pt	120.0	02:00:00	816.580	--	--	0.43													
Final Val	120.0	02:00:00	816.580											Max Vac	1.0	Final Values	41.260		
Average Values						0.43	205	375	524	60	171	70	70						

Notes:

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
with Duct Burners Firing
Sulfuric Acid Mist Data**

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	1-100 w/DB-SO3-1	1-100 w/DB-SO3-2	1-100 w/DB-SO3-3	Average	Units	Limits
Run Start Time	00:32	03:14	06:31		hh:mm	
Run Stop Time	02:32	05:14	08:31		hh:mm	
Test Date	09/25/18	09/25/18	09/25/18		mm/dd/yy	
Load	Base w/DB	Base w/DB	Base w/DB		% or w/DB	--
Meter Calibration Factor	1.009	1.009	1.009			
Stack Test Data	1-100 w/DB-SO3-1	1-100 w/DB-SO3-2	1-100 w/DB-SO3-3	Average	Units	Limits
Initial Meter Volume	323.350	369.670	416.300		ft ³	
Final Meter Volume	364.050	410.430	457.750		ft ³	
Total Meter Volume	40.700	40.760	41.450	40.970	ft ³	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	73.42	70.50	69.17	71.03	°F	
Average Stack Temperature	192.42	191.21	191.75	191.79	°F	
Barometric Pressure	29.84	29.77	30.42	30.01	in Hg	
Stack Static Pressure	-0.87	-0.87	-0.87	-0.87	in H ₂ O	
Absolute Stack Pressure	29.78	29.71	30.36	29.95	in Hg	
Average Orifice Pressure Drop	0.43	0.43	0.43	0.43	in H ₂ O	
Absolute Meter Pressure	29.98	29.91	30.56	30.15	in Hg	
Moisture Content Data	1-100 w/DB-SO3-1	1-100 w/DB-SO3-2	1-100 w/DB-SO3-3	Average	Units	Limits
Impinger Water Weight Gain	99.30	96.60	83.80	93.23	g	
Silica Gel Weight Gain	10.70	8.70	14.40	11.27	g	
Total Water Volume Collected	110.20	105.49	98.38	104.69	ml	
Standard Water Vapor Volume	5.19	4.96	4.63	4.93	scf	
Standard Meter Volume	40.6	40.8	42.5	41.3	dscf	
Standard Metric Meter Volume	1.1	1.2	1.2	1.2	dscm	
Calculated Stack Moisture	11.33	10.86	9.83	10.67	%	
Saturated Stack Moisture	67.13	65.57	64.92	65.87	%	
Reported Stack Moisture Content	11.33	10.86	9.83	10.67	%	
Gas Analysis Data	1-100 w/DB-SO3-1	1-100 w/DB-SO3-2	1-100 w/DB-SO3-3	Average	Units	Limits
Carbon Dioxide Content	4.9	4.9	4.9	4.9	%	
Oxygen Content	12.3	12.3	12.3	12.3	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.8	82.8	82.8	82.8	%	
Stack Dry Molecular Weight	29.28	29.28	29.28	29.28	lb/lb-mole	
Stack Wet Molecular Weight	28.00	28.05	28.17	28.07	lb/lb-mole	
Calculated Fuel Factor	1.755	1.755	1.755	1.755		
Fuel F-Factor	8632.22	8632.22	8632.22	8632.22	dscf/MMBtu	
Percent Excess Air	128.7	128.7	128.7	128.7	%	
Volumetric Flow Rate Data	1-100 w/DB-SO3-1	1-100 w/DB-SO3-2	1-100 w/DB-SO3-3	Average	Units	Limits
Stack Cross-Sectional Area	285.40	285.40	285.40	285.40	ft ²	

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Sulfuric Acid Mist IC Analysis	1-100 w/DB-SO3-1	1-100 w/DB-SO3-2	1-100 w/DB-SO3-3	Average	Units	Limits
H ₂ SO ₄ (IC) Sample Volume - Front Half Rinse	124.0	106.0	100.0	110.00	ml	--
H ₂ SO ₄ (IC) Sample - Mass Per Volume	0.105	0.104	0.100	0.10	mg/L	--
H ₂ SO ₄ (IC) Mass	0.01	0.01	0.01	0.01	mg	--
H ₂ SO ₄ (IC) Concentration	3.20E-07	2.70E-07	2.35E-07	2.75E-07	g/dscf	--
	4.94E-06	4.16E-06	3.63E-06	4.25E-06	gr/dscf	--
	1.13E-08	9.53E-09	8.31E-09	9.72E-09	g/L	--
	0.0028	0.0023	0.0020	0.0024	ppmvd	--
H ₂ SO ₄ (IC) Emission Rate	0.000015	0.000012	0.000011	0.000013	lb/MMBtu	0.0007

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		MP	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	8a, 2.4.1.3	10.6	scf
Run Duration	10 L/min	120	minutes
Unit Number		CTG-1	
Base Run Number		1-100 w/DB-SO3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/25/18	09/25/18	09/25/18	
Load		Base w/DB	Base w/DB	Base w/DB	% or w/DB
Fuel F-Factor		8632.22	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0024	samp-cp-0024	samp-cp-0024	
Meter Calibration Factor	(Y)	1.009	1.009	1.009	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.869	1.869	1.869	in H ₂ O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	2	2	2	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-bh-0002	samp-bh-0002	samp-bh-0002	
Impinger Case Number	from ACS	samp-bc-0025	3028	samp-bc-0025	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/25/18		
Sampling Location	CTG-1 Stack	Operator	MP		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	1-100 w/DB-SO3-1		Date	09/25/18	Run Start Time	00:32	Run Stop Time	02:32
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.9	12.3	0.0	82.8	29.28	1.755	128.7	YES

Gas Analysis Data								
Run Number	1-100 w/DB-SO3-2		Date	09/25/18	Run Start Time	03:14	Run Stop Time	05:14
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.9	12.3	0.0	82.8	29.28	1.755	128.7	YES

Gas Analysis Data								
Run Number	1-100 w/DB-SO3-3		Date	09/25/18	Run Start Time	06:31	Run Stop Time	08:31
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.9	12.3	0.0	82.8	29.28	1.755	128.7	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/25/18
Sampling Location	CTG-1 Stack	Operator	MP
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/25/18	500	499.9	-0.1	Pass
Test Day 1	09/25/18	500	499.9	-0.1	Pass

Moisture Content Data									
Run Number	1-100 w/DB-SO3-1		Date	09/25/18	Start Time	00:32	Stop Time	02:32	
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009		
Total Meter Volume	(V _m)	40.700	dcf	Barometric Pressure			(P _b)	29.84	in Hg
Average Stack Temp	(t _s) _{avg}	192	°F	Stack Static Pressure			(P _{static})	-0.87	in H ₂ O
Average Meter Temp	(t _m) _{avg}	73	°F	Avg Orifice Pressure			(ΔH) _{avg}	0.43	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel					
Final Value	(V _f),(W _f)	799.30	736.80	614.50	961.90				
Initial Value	(V _i),(W _i)	710.00	729.30	612.00	951.20				
Net Value	(V _n),(W _n)	89.3	7.5	2.5	10.7				
Results									
Total Weight	(W _i)	110.00	g	Water Vol Weighed			(V _{wsg(std)})	5.186	scf
Std Meter Volume	(V _{m(std)})	40.584	dscf	Sat. Moisture Content			(B _{ws(svp)})	67.13	%
Calc Moisture Content	(B _{ws(calc)})	11.33	%	Final Moisture Content			(B _{ws})	11.33	%

Moisture Content Data									
Run Number	1-100 w/DB-SO3-2		Date	09/25/18	Start Time	03:14	Stop Time	05:14	
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009		
Total Meter Volume	(V _m)	40.760	dcf	Barometric Pressure			(P _b)	29.77	in Hg
Average Stack Temp	(t _s) _{avg}	191	°F	Stack Static Pressure			(P _{static})	-0.87	in H ₂ O
Average Meter Temp	(t _m) _{avg}	71	°F	Avg Orifice Pressure			(ΔH) _{avg}	0.43	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel					
Final Value	(V _f),(W _f)	774.90	686.90	586.60	877.80				
Initial Value	(V _i),(W _i)	688.30	678.20	585.30	869.10				
Net Value	(V _n),(W _n)	86.6	8.7	1.3	8.7				
Results									
Total Weight	(W _i)	105.30	g	Water Vol Weighed			(V _{wsg(std)})	4.965	scf
Std Meter Volume	(V _{m(std)})	40.771	dscf	Sat. Moisture Content			(B _{ws(svp)})	65.57	%
Calc Moisture Content	(B _{ws(calc)})	10.86	%	Final Moisture Content			(B _{ws})	10.86	%

Moisture Content Data									
Run Number	1-100 w/DB-SO3-3		Date	09/25/18	Start Time	06:31	Stop Time	08:31	
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009		
Total Meter Volume	(V _m)	41.450	dcf	Barometric Pressure			(P _b)	30.42	in Hg
Average Stack Temp	(t _s) _{avg}	192	°F	Stack Static Pressure			(P _{static})	-0.87	in H ₂ O
Average Meter Temp	(t _m) _{avg}	69	°F	Avg Orifice Pressure			(ΔH) _{avg}	0.43	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel					
Final Value	(V _f),(W _f)	794.50	692.70	596.20	881.20				
Initial Value	(V _i),(W _i)	721.90	683.10	594.60	866.80				
Net Value	(V _n),(W _n)	72.6	9.6	1.6	14.4				
Results									
Total Weight	(W _i)	98.20	g	Water Vol Weighed			(V _{wsg(std)})	4.630	scf
Std Meter Volume	(V _{m(std)})	42.472	dscf	Sat. Moisture Content			(B _{ws(svp)})	64.92	%
Calc Moisture Content	(B _{ws(calc)})	9.83	%	Final Moisture Content			(B _{ws})	9.83	%

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP
Run Number	1-100 w/DB-SO3-1

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	192.4	°F	
Average Meter Temp (t _m)	73.4		
Orifice Meter Coefficient (ΔH _@)	1.869	in H ₂ O	
Square Root ΔP (ΔP ^{1/2} _{avg})		in H ₂ O	
Stack Moisture Content (B _w)	11.33	%	
Stack Dry Molecular Weight (M _d)	29.28	lb/lb-mole	
Estimated Orifice Flow Rate (Q _m)	0.75	acfm	
ΔP to ΔH IsoKinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D _{na})	--	in	
Suggested Nozzle Diameter (D _m)		in	
Probe Number	2	in	
Probe Length	108	in	
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0002		
Impinger Case Number	samp-bc-0025		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	00:32	End	02:32

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	710.0	729.3	612.0	951.2				
Post	799.3	736.8	614.5	961.9				

Pressures			
Barometric Pressure (P _b)	29.84	in Hg	
Stack Static Pressure (P _{static})	-0.87	in H ₂ O	
Absolute Stack Pressure (P _s)	29.78	in Hg	
Absolute Meter Pressure (P _m)	29.98	in Hg	

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024	samp-cp-0024	samp-cp-0024		2	2	samp-bh-0002	samp-bc-0025	3102		samp-cp-0024	samp-cp-0024							
Traverse Point #	Sampling Time (Ø)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	323.350	--	--	0.43	191	374	501	61	174	74	74	1.0	--	--	1.713	--	41.117
A-1	5.0	00:05:00	325.070	--	--	0.43	191	375	522	59	176	74	74	1.0	--	--	3.416	--	40.997
A-1	10.0	00:10:00	326.780	--	--	0.43	193	377	524	56	175	74	74	1.0	--	--	5.120	--	40.958
A-1	15.0	00:15:00	328.490	--	--	0.43	193	376	523	55	174	73	73	1.0	--	--	6.806	--	40.837
A-1	20.0	00:20:00	330.180	--	--	0.43	193	377	524	55	175	74	74	1.0	--	--	8.499	--	40.797
A-1	25.0	00:25:00	331.880	--	--	0.43	193	377	524	55	174	73	73	1.0	--	--	10.206	--	40.824
A-1	30.0	00:30:00	333.590	--	--	0.43	192	376	522	55	175	74	74	1.0	--	--	11.889	--	40.763
A-1	35.0	00:35:00	335.280	--	--	0.43	191	374	524	55	174	74	74	1.0	--	--	13.573	--	40.718
A-1	40.0	00:40:00	336.970	--	--	0.43	191	374	522	55	174	74	74	1.0	--	--	15.236	--	40.629
A-1	45.0	00:45:00	338.640	--	--	0.43	192	375	523	55	174	74	74	1.0	--	--	16.899	--	40.558
A-1	50.0	00:50:00	340.310	--	--	0.43	193	374	525	55	173	74	74	1.0	--	--	18.613	--	40.609
A-1	55.0	00:55:00	342.030	--	--	0.43	193	374	523	55	172	73	73	1.0	--	--	20.329	--	40.658
A-1	60.0	01:00:00	343.750	--	--	0.43	193	375	522	56	173	74	74	1.0	--	--	22.032	--	40.675
A-1	65.0	01:05:00	345.460	--	--	0.43	193	374	524	55	172	74	74	1.0	--	--	23.726	--	40.672
A-1	70.0	01:10:00	347.160	--	--	0.43	193	373	524	55	171	74	74	1.0	--	--	25.429	--	40.686
A-1	75.0	01:15:00	348.870	--	--	0.43	193	372	523	56	172	73	73	1.0	--	--	27.115	--	40.673
A-1	80.0	01:20:00	350.560	--	--	0.43	192	374	525	57	172	73	73	1.0	--	--	28.802	--	40.661
A-1	85.0	01:25:00	352.250	--	--	0.43	193	373	525	56	172	73	73	1.0	--	--	30.488	--	40.651
A-1	90.0	01:30:00	353.940	--	--	0.43	193	372	523	56	172	73	73	1.0	--	--	32.175	--	40.642
A-1	95.0	01:35:00	355.630	--	--	0.43	193	371	523	57	171	72	72	1.0	--	--	33.864	--	40.637
A-1	100.0	01:40:00	357.320	--	--	0.43	192	371	524	55	172	73	73	1.0	--	--	35.571	--	40.652
A-1	105.0	01:45:00	359.030	--	--	0.43	193	372	523	55	172	73	73	1.0	--	--	37.257	--	40.644
A-1	110.0	01:50:00	360.720	--	--	0.43	192	371	523	55	171	73	73	1.0	--	--	38.934	--	40.627
A-1	115.0	01:55:00	362.400	--	--	0.43	192	372	524	55	171	72	72	1.0	--	--	40.583	--	40.583
Last Pt	120.0	02:00:00	364.050																
Final Val	120.0	02:00:00	364.050																
Average Values						0.43	192	374	523	56	173	73	73						

73

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP
Run Number	1-100 w/DB-SO3-2

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	191.2		°F
Average Meter Temp (t _m)	70.5		
Orifice Meter Coefficient (ΔH ₀)	1.869		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _w)	10.86		%
Stack Dry Molecular Weight (M _d)	29.28		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.34		acfm
ΔP to ΔH Isokinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D _{na})	--		in
Suggested Nozzle Diameter (D _m)			in
Probe Number	2		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0002		
Impinger Case Number	3028		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	03:14	End 05:14

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	688.3	678.2	585.3	869.1				
Post	774.9	686.9	586.6	877.8				

Pressures			
Barometric Pressure (P _b)	29.77		in Hg
Stack Static Pressure (P _{static})	-0.87		in H ₂ O
Absolute Stack Pressure (P _s)	29.71		in Hg
Absolute Meter Pressure (P _m)	29.91		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024	samp-cp-0024	samp-cp-0024		2	2	samp-bh-0002	3028	1013		samp-cp-0024	samp-cp-0024							
Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m) (ft ³)	Velocity Head (Δp) (in H ₂ O)	Desired Orifice ΔH (ΔH _d) (in H ₂ O)	Actual Orifice ΔH (ΔH _a) (in H ₂ O)	Stack Temp (t _s) (°F)	Probe Temp (375±25°F) (°F)	Filter Temp (525±25°F) (°F)	Impinger Exit Temp (≤68°F) (°F)	Cond. Temp (≤185°F) (°F)	Meter Inlet Temp (t _{mi}) (°F)	Meter Outlet Temp (t _{mo}) (°F)	Pump Vacuum (in Hg)	Square Root ΔP (ΔP ^{1/2}) (√(in H ₂ O))	Local Stack Velocity (v _s) (ft/sec)	Cumul. Meter Volume (V _{m, std}) (dscf)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m, std}) (dscf)
A-1	0.0	00:00:00	369.670	--	--	0.43	192	377	512	55	171	70	70	1.0	--	--	1.702	--	40.850
A-2	5.0	00:05:00	371.370	--	--	0.43	192	377	522	53	170	70	70	1.0	--	--	3.414	--	40.970
A-3	10.0	00:10:00	373.080	--	--	0.43	191	376	526	53	171	71	71	1.0	--	--	5.123	--	40.984
A-4	15.0	00:15:00	374.790	--	--	0.43	192	377	524	53	170	70	70	1.0	--	--	6.805	--	40.830
A-5	20.0	00:20:00	376.470	--	--	0.43	192	375	523	53	171	70	70	1.0	--	--	8.517	--	40.882
A-6	25.0	00:25:00	378.180	--	--	0.43	191	376	523	54	170	70	70	1.0	--	--	10.219	--	40.877
B-1	30.0	00:30:00	379.880	--	--	0.43	192	375	524	54	171	70	70	1.0	--	--	11.911	--	40.839
B-2	35.0	00:35:00	381.570	--	--	0.43	191	374	526	55	170	71	71	1.0	--	--	13.600	--	40.800
B-3	40.0	00:40:00	383.260	--	--	0.43	192	375	524	55	170	71	71	1.0	--	--	15.399	--	41.064
B-4	45.0	00:45:00	385.060	--	--	0.43	192	374	524	55	172	71	71	1.0	--	--	17.108	--	41.059
B-5	50.0	00:50:00	386.770	--	--	0.43	191	373	523	55	170	71	71	1.0	--	--	18.807	--	41.033
B-6	55.0	00:55:00	388.470	--	--	0.43	191	374	523	55	170	71	71	1.0	--	--	20.495	--	40.991
C-1	60.0	01:00:00	390.160	--	--	0.43	192	373	524	55	172	71	71	1.0	--	--	22.164	--	40.919
C-2	65.0	01:05:00	391.830	--	--	0.43	191	373	524	55	172	71	71	1.0	--	--	23.833	--	40.857
C-3	70.0	01:10:00	393.500	--	--	0.43	191	374	525	55	171	70	70	1.0	--	--	25.515	--	40.824
C-4	75.0	01:15:00	395.180	--	--	0.43	191	373	523	56	171	70	70	1.0	--	--	27.197	--	40.796
C-5	80.0	01:20:00	396.860	--	--	0.43	191	374	522	56	172	70	70	1.0	--	--	28.919	--	40.827
C-6	85.0	01:25:00	398.580	--	--	0.43	191	373	523	55	171	70	70	1.0	--	--	30.621	--	40.829
D-1	90.0	01:30:00	400.280	--	--	0.43	190	374	525	55	172	70	70	1.0	--	--	32.324	--	40.830
D-2	95.0	01:35:00	401.980	--	--	0.43	191	374	525	55	171	70	70	1.0	--	--	34.036	--	40.843
D-3	100.0	01:40:00	403.690	--	--	0.43	190	372	524	55	171	71	71	1.0	--	--	35.714	--	40.817
D-4	105.0	01:45:00	405.370	--	--	0.43	190	373	525	56	171	72	72	1.0	--	--	37.400	--	40.800
D-5	110.0	01:50:00	407.060	--	--	0.43	191	373	523	56	172	71	71	1.0	--	--	39.099	--	40.799
D-6	115.0	01:55:00	408.760	--	--	0.43	191	374	525	56	172	70	70	1.0	--	--	40.771	--	40.771
Last Pt	120.0	02:00:00	410.430																
Final Val	120.0	02:00:00	410.430																
Average Values						0.43	191	374	523	55	171	71	71	1.0	Final Values		40.771		

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP
Run Number	1-100 w/DB-SO3-3

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)			
Average Stack Temp (t_s)	191.8	°F	
Average Meter Temp (t_m)	69.2		
Orifice Meter Coefficient (ΔH_{or})	1.869	in H ₂ O	
Square Root ΔP ($\Delta P^{1/2}_{avg}$)		in H ₂ O	
Stack Moisture Content (B_{ws})	9.83	%	
Stack Dry Molecular Weight (M_d)	29.28	lb/lb-mole	
Estimated Orifice Flow Rate (Q_m)	0.34	acfm	
ΔP to ΔH Isokinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D_{na})	--	in	
Suggested Nozzle Diameter (D_m)		in	
Probe Number	2	in	
Probe Length	108	in	
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0002		
Impinger Case Number	samp-bc-0025		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	06:31	End 08:31

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	721.9	683.1	594.6	866.8				
Post	794.5	692.7	596.2	881.2				

Pressures			
Barometric Pressure (P_b)	30.42	in Hg	
Stack Static Pressure (P_{static})	-0.87	in H ₂ O	
Absolute Stack Pressure (P_s)	30.36	in Hg	
Absolute Meter Pressure (P_m)	30.56	in Hg	

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024	samp-cp-0024	samp-cp-0024	2				2		samp-bh-0002	samp-bc-0025	3102	samp-cp-0024		samp-cp-0024					
				Desired Orifice ΔH (ΔH_o)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (t_p)	Filter Temp (t_f)	Impinger Exit Temp (t_e)				Cond. Temp ($\leq 185^\circ F$)	Meter Inlet Temp (t_{mi})						
Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V_m) (ft ³)	Velocity Head (Δp) (in H ₂ O)	Desired Orifice ΔH (ΔH_o) (in H ₂ O)	Actual Orifice ΔH (ΔH_a) (in H ₂ O)	Stack Temp (t_s) (°F)	Probe Temp (t_p) (375±25°F)	Filter Temp (t_f) (525±25°F)	Impinger Exit Temp (t_e) (≤68°F)	Cond. Temp ($\leq 185^\circ F$) (°F)	Meter Inlet Temp (t_{mi}) (°F)	Meter Outlet Temp (t_{mo}) (°F)	Pump Vacuum (in Hg)	Square Root ΔP ($\Delta P^{1/2}$) (√(in H ₂ O))	Local Stack Velocity (v_s) (ft/sec)	Cumul. Meter Volume ($V_{m, std}$) (dscf)	Cumul. Percent IsoKinetic (I) (%)	Est-Run Meter Volume ($V_{m, std}$) (dscf)	
A-1	0.0	00:00:00	416.300	--	--	0.43	192	400	525	58	185	68	68	1.0	--	--	2.033	--	48.800	
A-2	5.0	00:05:00	418.280	--	--	0.43	193	375	525	58	185	68	68	1.0	--	--	3.697	--	44.363	
A-3	10.0	00:10:00	419.900	--	--	0.43	192	375	525	58	185	68	68	1.0	--	--	5.515	--	44.117	
A-4	15.0	00:15:00	421.670	--	--	0.43	193	376	520	58	182	68	68	1.0	--	--	7.209	--	43.254	
A-5	20.0	00:20:00	423.320	--	--	0.43	193	375	524	59	185	68	68	1.0	--	--	9.129	--	43.821	
A-6	25.0	00:25:00	425.190	--	--	0.43	193	374	525	60	184	69	69	1.0	--	--	10.985	--	43.938	
B-1	30.0	00:30:00	427.000	--	--	0.43	193	375	522	60	183	69	69	1.0	--	--	12.922	--	44.303	
B-2	35.0	00:35:00	428.890	--	--	0.43	193	374	525	60	185	69	69	1.0	--	--	14.377	--	43.132	
B-3	40.0	00:40:00	430.310	--	--	0.43	193	375	525	61	184	69	69	1.0	--	--	16.222	--	43.259	
B-4	45.0	00:45:00	432.110	--	--	0.43	193	374	524	61	185	69	69	1.0	--	--	18.160	--	43.583	
B-5	50.0	00:50:00	434.000	--	--	0.43	193	372	523	61	185	69	69	1.0	--	--	19.707	--	42.998	
B-6	55.0	00:55:00	435.510	--	--	0.43	191	374	525	61	184	69	69	1.0	--	--	21.634	--	43.268	
C-1	60.0	01:00:00	437.390	--	--	0.43	191	374	525	61	184	69	69	1.0	--	--	23.274	--	42.968	
C-2	65.0	01:05:00	438.990	--	--	0.43	191	375	524	61	183	69	69	1.0	--	--	25.047	--	42.938	
C-3	70.0	01:10:00	440.720	--	--	0.43	191	374	525	60	185	69	69	1.0	--	--	26.872	--	42.995	
C-4	75.0	01:15:00	442.500	--	--	0.43	191	373	525	61	184	70	70	1.0	--	--	28.519	--	42.779	
C-5	80.0	01:20:00	444.110	--	--	0.43	190	375	523	61	184	70	70	1.0	--	--	30.176	--	42.602	
C-6	85.0	01:25:00	445.730	--	--	0.43	190	374	525	61	185	70	70	1.0	--	--	31.997	--	42.663	
D-1	90.0	01:30:00	447.510	--	--	0.43	191	375	524	61	184	70	70	1.0	--	--	33.737	--	42.615	
D-2	95.0	01:35:00	449.210	--	--	0.43	191	373	525	61	185	70	70	1.0	--	--	35.496	--	42.595	
D-3	100.0	01:40:00	450.930	--	--	0.43	191	374	525	61	185	70	70	1.0	--	--	37.246	--	42.566	
D-4	105.0	01:45:00	452.640	--	--	0.43	191	375	524	61	185	70	70	1.0	--	--	38.944	--	42.484	
D-5	110.0	01:50:00	454.300	--	--	0.43	191	373	525	61	184	70	70	1.0	--	--	40.652	--	42.420	
D-6	115.0	01:55:00	455.970	--	--	0.43	191	371	525	60	184	70	70	1.0	--	--	42.473	--	42.473	
Last Pt	120.0	02:00:00	457.750																	
Final Val	120.0	02:00:00	457.750											Max Vac	1.0	Final Values	42.473			
Average Values						0.43	192	375	524	60	184	69	69							

Notes:

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
without Duct Burners Firing
NH₃ Data**

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Run Start Time	15:54	17:13	18:44		hh:mm	
Run Stop Time	16:58	18:13	19:44		hh:mm	
Test Date	09/25/18	09/25/18	09/25/18		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	1.009	1.009	1.009			
Pitot Tube Coefficient	0.8042	0.8042	0.8042			
Stack Test Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Initial Meter Volume	596.040	639.370	683.120		ft ³	
Final Meter Volume	638.860	682.850	727.780		ft ³	
Total Meter Volume	42.820	43.480	44.660	43.653	ft ³	
Total Sampling Time	60.00	60.00	60.00	60.00	min	
Average Meter Temperature	71.75	77.13	77.08	75.32	°F	
Average Stack Temperature	205.58	205.83	204.85	205.42	°F	
Barometric Pressure	30.08	30.02	29.98	30.03	in Hg	
Stack Static Pressure	-0.87	-0.87	-0.87	-0.87	in H ₂ O	
Absolute Stack Pressure	30.02	29.96	29.92	29.96	in Hg	
Average Orifice Pressure Drop	1.86	1.86	1.90	1.87	in H ₂ O	
Absolute Meter Pressure	30.22	30.16	30.12	30.16	in Hg	
Avg Square Root Pitot Pressure	1.24	1.25	1.22	1.24	√(in H ₂ O)	
Moisture Content Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Impinger Water Weight Gain	43.70	82.20	88.10	71.33	g	
Silica Gel Weight Gain	19.10	9.40	12.80	13.77	g	
Total Water Volume Collected	62.91	91.77	101.08	85.25	ml	
Standard Water Vapor Volume	2.96	4.32	4.76	4.01	scf	
Standard Meter Volume	43.3	43.5	44.6	43.8	dscf	
Standard Metric Meter Volume	1.2	1.2	1.3	1.2	dscm	
Calculated Stack Moisture	6.40	9.04	9.64	8.36	%	
Saturated Stack Moisture	87.58	88.20	86.56	87.45	%	
Reported Stack Moisture Content	6.40	9.04	9.64	8.36	%	
Gas Analysis Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Carbon Dioxide Content	4.1	4.2	4.2	4.2	%	
Oxygen Content	13.6	13.5	13.5	13.5	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.3	82.3	82.4	82.3	%	
Stack Dry Molecular Weight	29.20	29.21	29.20	29.21	lb/lb-mole	
Stack Wet Molecular Weight	28.48	28.20	28.12	28.27	lb/lb-mole	
Calculated Fuel Factor	1.780	1.762	1.783	1.775		
Fuel F-Factor	8632.22	8632.22	8632.22	8632.22	dscf/MMBtu	
Percent Excess Air	167.3	164.1	163.8	165.1	%	

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Average Stack Gas Velocity	75.31	76.60	74.85	75.58	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,281,134	1,303,015	1,273,337	1,285,829	acfm	
Wet Standard Stack Flow Rate	61,174	62,071	60,667	61,304	wkscfh	
Dry Standard Stack Flow Rate	57,260,937	56,461,397	54,818,659	56,180,331	dscfh	
Ammonia Analysis (CTM-027)	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Front Half Results (C _f)	19.6946	24.2706	23.7322	22.5658	mg/l	
Back Half Results (C _b)	0.1936	0.2504	0.2036	0.2159	mg/l	
Practical Quantitation Limit	0.1000	0.1000	0.1000	0.1000	mg/l	
Blank Results	0.0460	0.0460	0.0460	0.0460	mg/l	
Front Half Sample Volume	211	179	195	195	ml	
Back Half Sample Volume	239	215	218	224	ml	
Volume of NH ₃	0.00593	0.00621	0.00660	0.00625	L	
NH ₃ Concentration	4.83	5.04	5.22	5.03	ppmvd	--
NH ₃ Concentration	3.91	4.02	4.16	4.03	ppm@15%O ₂	5.00

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		CG/MP	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	35	scf
Run Duration	chk Subpart	60	minutes
Unit Number		CTG-1	
Base Run Number		1-Base-NH3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/25/18	09/25/18	09/25/18	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8632.22	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0024	samp-cp-0024	samp-cp-0024	
Meter Calibration Factor	(Y)	1.009	1.009	1.009	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.869	1.869	1.869	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	A3701	A3701	A3701	
Pitot Tube Coefficient	(C _p)	0.8042	0.8042	0.8042	
Probe Number	from ACS	samp-cp-0141	samp-cp-0141	samp-cp-0141	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-hb-0005	samp-hb-0005	samp-hb-0005	
Impinger Case Number	from ACS	samp-bc-0002	samp-bc-0002	samp-bc-0002	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date			
Sampling Location	CTG-1 Stack	Operator	CG/MP		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	1-Base-NH3-1		Date	09/25/18	Run Start Time	15:54	Run Stop Time	16:58
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:04	4.1	13.6	0.0	82.3	29.20	1.780	167.3	YES

Gas Analysis Data								
Run Number	1-Base-NH3-2		Date	09/25/18	Run Start Time	17:13	Run Stop Time	18:13
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:00	4.2	13.5	0.0	82.3	29.21	1.762	164.1	YES

Gas Analysis Data								
Run Number	1-Base-NH3-3		Date	09/25/18	Run Start Time	18:44	Run Stop Time	19:44
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:00	4.2	13.5	0.0	82.4	29.20	1.783	163.8	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	
Sampling Location	CTG-1 Stack	Operator	CG/MP
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	09/25/18	500	499.9	-0.1	Pass

Moisture Content Data								
Run Number	1-Base-NH3-1		Date	09/25/18	Start Time	15:54	Stop Time	16:58
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009	
Total Meter Volume	(V _m)	42.820	dcf	Barometric Pressure	(P _b)	30.08	in Hg	
Average Stack Temp	(t _s) _{avg}	206	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	72	°F	Avg Orifice Pressure	(ΔH) _{avg}	1.86	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel				
Final Value	(V _f),(W _f)	732.30	714.30	601.60	980.60			
Initial Value	(V _i),(W _i)	731.30	687.30	585.90	961.50			
Net Value	(V _n),(W _n)	1.0	27.0	15.7	19.1			
Results								
Total Weight	(W _t)	62.80	g	Water Vol Weighed	(V _{wsg(std)})	2.961	scf	
Std Meter Volume	(V _{m(std)})	43.326	dscf	Sat. Moisture Content	(B _{ws(svp)})	87.58	%	
Calc Moisture Content	(B _{ws(calc)})	6.40	%	Final Moisture Content	(B _{ws})	6.40	%	

Moisture Content Data								
Run Number	1-Base-NH3-2		Date	09/25/18	Start Time	17:13	Stop Time	18:13
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009	
Total Meter Volume	(V _m)	43.480	dcf	Barometric Pressure	(P _b)	30.02	in Hg	
Average Stack Temp	(t _s) _{avg}	206	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	77	°F	Avg Orifice Pressure	(ΔH) _{avg}	1.86	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel				
Final Value	(V _f),(W _f)	751.90	709.80	594.40	921.20			
Initial Value	(V _i),(W _i)	707.10	682.00	584.80	911.80			
Net Value	(V _n),(W _n)	44.8	27.8	9.6	9.4			
Results								
Total Weight	(W _t)	91.60	g	Water Vol Weighed	(V _{wsg(std)})	4.319	scf	
Std Meter Volume	(V _{m(std)})	43.467	dscf	Sat. Moisture Content	(B _{ws(svp)})	88.20	%	
Calc Moisture Content	(B _{ws(calc)})	9.04	%	Final Moisture Content	(B _{ws})	9.04	%	

Moisture Content Data								
Run Number	1-Base-NH3-3		Date	09/25/18	Start Time	18:44	Stop Time	19:44
Meter Box Number	samp-cp-0024		Meter Cal Factor			(Y)	1.009	
Total Meter Volume	(V _m)	44.660	dcf	Barometric Pressure	(P _b)	29.98	in Hg	
Average Stack Temp	(t _s) _{avg}	205	°F	Stack Static Pressure	(P _{static})	-0.87	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	77	°F	Avg Orifice Pressure	(ΔH) _{avg}	1.90	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel				
Final Value	(V _f),(W _f)	765.10	728.20	590.70	914.60			
Initial Value	(V _i),(W _i)	704.10	706.80	585.00	901.80			
Net Value	(V _n),(W _n)	61.0	21.4	5.7	12.8			
Results								
Total Weight	(W _t)	100.90	g	Water Vol Weighed	(V _{wsg(std)})	4.757	scf	
Std Meter Volume	(V _{m(std)})	44.596	dscf	Sat. Moisture Content	(B _{ws(svp)})	86.56	%	
Calc Moisture Content	(B _{ws(calc)})	9.64	%	Final Moisture Content	(B _{ws})	9.64	%	

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	CG
Run Number	1-Base-NH3-1

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8042	A3701	
Average Stack Temp (t_s)	205.6		°F
Average Meter Temp (t_m)	71.8		
Orifice Meter Coefficient ($\Delta H @$)	1.869		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.24		in H ₂ O
Stack Moisture Content (B_{ws})	6.40		%
Stack Dry Molecular Weight (M_d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	20.0	in Hg
PASS	Post	0.000	ft ³ /min@	20.0	in Hg
PASS	Pitot	Pre (+)	--	in H ₂ O for	--
		Pre (-)	--	in H ₂ O for	--
		Post (+)	--	in H ₂ O for	--
		Post (-)	--	in H ₂ O for	--

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D_{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D_m)	0.2067	in	
Probe Number	samp-cp-0141		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-hb-0005		
Impinger Case Number	samp-bc-0002		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	15:54	End 16:58

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	731.3	687.3	585.9	961.5				
Post	732.3	714.3	601.6	980.6				

Pressures		
Barometric Pressure (P_b)	30.08	in Hg
Stack Static Pressure (P_{static})	-0.87	in H ₂ O
Absolute Stack Pressure (P_s)	30.02	in Hg
Absolute Meter Pressure (P_m)	30.22	in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024		samp-cp-0024		samp-cp-0141		samp-cp-0141		samp-hb-0005		samp-bc-0002		samp-cp-0024		samp-cp-0024		Local Stack Velocity (v_s), ft/sec	Cumul. Meter Volume ($V_{m, std}$), dscf	Cumul. Percent IsoKinetic (I), %	Est-Run Meter Volume ($V_{m, std}$), dscf
	Traverse Point #	Sampling Time (h)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V_m), ft ³	Velocity Head (Δp), in H ₂ O	Desired Orifice ΔH (ΔH_d), in H ₂ O	Actual Orifice ΔH (ΔH_a), in H ₂ O	Stack Temp (t_s), °F	Probe Temp (248±25°F), °F	Filter Temp (248±25°F), °F	Impinger Exit Temp (≤68°F), °F	Meter Inlet Temp (t_{mi}), °F	Meter Outlet Temp (t_{mo}), °F	Pump Vacuum, in Hg	Square Root ΔP ($\Delta P^{1/2}$), $\sqrt{\text{in H}_2\text{O}}$					
A-1	0.0	00:00:00	596.040	1.50	--	1.86	205	253	261	64	--	--	70	70	2.5	1.22	74.26	3.756	--	45.073
A-2	5.0	00:05:00	599.740	1.50	--	1.86	205	255	264	64	--	--	70	70	2.5	1.22	74.26	7.390	--	44.342
A-3	10.0	00:10:00	603.320	1.50	--	1.86	206	255	265	64	--	--	70	70	2.5	1.22	74.32	11.055	--	44.220
B-1	15.0	00:15:00	606.930	1.50	--	1.86	206	254	263	64	--	--	70	70	2.5	1.22	74.32	14.700	--	44.099
B-2	20.0	00:20:00	610.520	1.50	--	1.86	206	253	264	64	--	--	71	71	2.5	1.22	74.32	18.550	--	44.520
B-3	25.0	00:25:00	614.320	1.50	--	1.86	206	255	264	63	--	--	71	71	2.5	1.22	74.32	22.056	--	44.112
C-1	30.0	00:30:00	617.780	1.50	--	1.86	206	254	264	63	--	--	71	71	2.5	1.22	74.32	25.501	--	43.716
C-2	35.0	00:35:00	621.180	1.60	--	1.86	206	254	265	64	--	--	73	73	2.5	1.26	76.75	29.084	--	43.627
C-3	40.0	00:40:00	624.730	1.60	--	1.86	205	254	264	64	--	--	73	73	2.5	1.26	76.70	33.152	--	44.203
D-1	45.0	00:45:00	628.760	1.60	--	1.86	204	254	264	64	--	--	74	74	2.5	1.26	76.64	36.487	--	43.785
D-2	50.0	00:50:00	632.070	1.60	--	1.86	206	254	264	64	--	--	74	74	2.5	1.26	76.75	39.651	--	43.256
D-3	55.0	00:55:00	635.210	1.60	--	1.86	206	255	264	65	--	--	74	74	2.5	1.26	76.75	43.329	--	43.329
Last Pt	60.0	01:00:00	638.860		#DIV/0!														--	
Final Val	60.0	01:00:00	638.860																	
Average Values				1.54		1.86	206	254	264	64			72	72		1.24	75.31			

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	CG
Run Number	1-Base-NH3-2

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8042	A3701	
Average Stack Temp (t_s)	205.8		°F
Average Meter Temp (t_m)	77.1		
Orifice Meter Coefficient (ΔH_{or})	1.869		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.25		in H ₂ O
Stack Moisture Content (B_{ws})	9.04		%
Stack Dry Molecular Weight (M_d)	29.21		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.72		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	--	in H ₂ O for	--
		Pre (-)	--	in H ₂ O for	--
		Post (+)	--	in H ₂ O for	--
		Post (-)	--	in H ₂ O for	--

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D_{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D_m)	0.2007	in	
Probe Number	samp-cp-0141		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-hb-0005		
Impinger Case Number	samp-bc-0002		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	17:13	End 18:13

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	707.1	682.0	584.8	911.8				
Post	751.9	709.8	594.4	921.2				

Pressures			
Barometric Pressure (P_b)	30.02		in Hg
Stack Static Pressure (P_{static})	-0.87		in H ₂ O
Absolute Stack Pressure (P_s)	29.96		in Hg
Absolute Meter Pressure (P_m)	30.16		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024		samp-cp-0024		samp-cp-0141		samp-cp-0141		samp-hb-0005		samp-bc-0002		samp-cp-0024		samp-cp-0024		Square Root ΔP ($\Delta P^{1/2}$)	Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)
	Traverse Point #	Sampling Time	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp ($248 \pm 25^\circ F$)	Filter Temp ($248 \pm 25^\circ F$)	Impinger Exit Temp ($\leq 68^\circ F$)	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Final Values	43.469					
A-1	0.0	00:00:00	639.370	1.60	--	1.86	206	256	264	62	--	--	75	75	2.5	1.26	77.22	3.643	--	43.720	
A-2	5.0	00:05:00	643.000	1.60	--	1.86	206	255	266	62	--	--	75	75	2.5	1.26	77.22	7.768	--	46.611	
A-3	10.0	00:10:00	647.110	1.60	--	1.86	207	254	264	62	--	--	77	77	2.5	1.26	77.28	11.448	--	45.793	
B-1	15.0	00:15:00	650.790	1.50	--	1.86	207	254	264	58	--	--	77	77	2.5	1.22	74.82	14.778	--	44.334	
B-2	20.0	00:20:00	654.120	1.50	--	1.86	207	254	264	57	--	--	77	77	2.5	1.22	74.82	18.568	--	44.563	
B-3	25.0	00:25:00	657.910	1.50	--	1.86	207	254	264	56	--	--	77	77	2.5	1.22	74.82	22.068	--	44.135	
C-1	30.0	00:30:00	661.410	1.60	--	1.86	207	254	264	56	--	--	78	78	2.5	1.26	77.28	25.780	--	44.195	
C-2	35.0	00:35:00	665.130	1.60	--	1.86	205	254	265	58	--	--	78	78	2.5	1.26	77.16	29.873	--	44.809	
C-3	40.0	00:40:00	669.230	1.60	--	1.86	205	251	264	58	--	--	77	78	2.5	1.26	77.16	33.059	--	44.079	
D-1	45.0	00:45:00	672.420	1.60	--	1.86	205	252	263	58	--	--	78	78	2.5	1.26	77.16	37.192	--	44.630	
D-2	50.0	00:50:00	676.560	1.60	--	1.86	204	248	264	54	--	--	78	78	2.5	1.26	77.10	40.296	--	43.959	
D-3	55.0	00:55:00	679.670	1.60	--	1.86	204	250	263	54	--	--	78	78	2.5	1.26	77.10	43.469	--	43.469	
Last Pt	60.0	01:00:00	682.850		--														--		
Final Val	60.0	01:00:00	682.850										Max Vac	2.5		Final Values	43.469				
Average Values				1.58		1.86	206	253	264	58			77	77		1.25	76.60				

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	MP
Run Number	1-Base-NH3-3

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8042	A3701	
Average Stack Temp (t_s)	204.8		°F
Average Meter Temp (t_m)	77.1		
Orifice Meter Coefficient ($\Delta H @$)	1.869		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.22		in H ₂ O
Stack Moisture Content (B_{ws})	9.64		%
Stack Dry Molecular Weight (M_d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.72		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D_{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D_m)	0.2020	in	
Probe Number	samp-cp-0141		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-hb-0005		
Impinger Case Number	samp-bc-0002		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	18:44	End	19:44

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	704.1	706.8	585.0	901.8				
Post	765.1	728.2	590.7	914.6				

Pressures			
Barometric Pressure (P_b)	29.98		in Hg
Stack Static Pressure (P_{static})	-0.87		in H ₂ O
Absolute Stack Pressure (P_s)	29.92		in Hg
Absolute Meter Pressure (P_m)	30.12		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024		samp-cp-0024		samp-cp-0141		samp-cp-0141		samp-hb-0005		samp-bc-0002		samp-cp-0024		samp-cp-0024		Local Stack Velocity (V_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)
	Traverse Point #	Sampling Time (h)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (ΔP)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$)	Final Values				
A-1	0.0	00:00:00	683.120	1.50	--	1.90	204	254	265	62	--	--	77	77	2.5	1.22	74.80	3.625	--	43.504
A-2	5.0	00:05:00	686.750	1.50	--	1.90	204	255	264	58	--	--	76	76	2.5	1.22	74.80	7.377	--	44.265
A-3	10.0	00:10:00	690.500	1.50	--	1.90	205	254	266	56	--	--	77	77	2.5	1.22	74.86	11.133	--	44.531
B-1	15.0	00:15:00	694.260	1.50	--	1.90	205	254	264	57	--	--	77	77	2.5	1.22	74.86	14.838	--	44.514
B-2	20.0	00:20:00	697.970	1.50	--	1.90	206	254	263	59	--	--	76	76	2.5	1.22	74.92	18.550	--	44.520
B-3	25.0	00:25:00	701.680	1.50	--	1.90	204	252	263	61	--	--	76	76	2.5	1.22	74.80	22.262	--	44.524
C-1	30.0	00:30:00	705.390	1.50	--	1.90	205	254	265	63	--	--	78	78	2.5	1.22	74.86	25.960	--	44.504
C-2	35.0	00:35:00	709.100	1.50	--	1.90	205	254	263	63	--	--	78	78	2.5	1.22	74.86	29.629	--	44.443
C-3	40.0	00:40:00	712.780	1.50	--	1.90	205	252	263	67	--	--	77	77	2.5	1.22	74.86	33.414	--	44.552
D-1	45.0	00:45:00	716.570	1.50	--	1.90	205	252	263	67	--	--	77	77	2.5	1.22	74.86	37.119	--	44.543
D-2	50.0	00:50:00	720.280	1.50	--	1.90	205	251	261	67	--	--	77	77	2.5	1.22	74.86	40.864	--	44.579
D-3	55.0	00:55:00	724.030	1.50	--	1.90	205	252	265	67	--	--	78	78	2.5	1.22	74.86	44.603	--	44.603
Last Pt	60.0	01:00:00	727.780	1.50	#DIV/0!	1.90	205	256	264	67			78	78	2.5	1.22	74.86		--	
Final Val	60.0	01:00:00	727.780										Max Vac	2.5	Final Values	44.603				
Average Values				1.50		1.90	205	253	264	63			77	77		1.22	74.85			

Notes:

EMISSION DATA RECORDS

**Unit #CTG-1
Base Load
with Duct Burners Firing
NH₃ Data**

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Run Start Time	09:21	10:45	12:10		hh:mm	
Run Stop Time	10:24	11:48	13:14		hh:mm	
Test Date	09/25/18	09/25/18	09/25/18		mm/dd/yy	
Load	w/DB	w/DB	w/DB		% or w/DB	--
Meter Calibration Factor	1.009	1.009	1.009			
Pitot Tube Coefficient	0.8264	0.8264	0.8264			
Stack Test Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Initial Meter Volume	465.500	508.670	552.770		ft ³	
Final Meter Volume	508.800	551.900	595.600		ft ³	
Total Meter Volume	43.300	43.230	42.830	43.120	ft ³	
Total Sampling Time	60.00	60.00	60.00	60.00	min	
Average Meter Temperature	69.17	70.42	70.67	70.08	°F	
Average Stack Temperature	190.33	190.00	190.67	190.33	°F	
Barometric Pressure	30.39	30.36	30.32	30.36	in Hg	
Stack Static Pressure	-1.10	-1.10	-1.10	-1.10	in H ₂ O	
Absolute Stack Pressure	30.31	30.28	30.24	30.28	in Hg	
Average Orifice Pressure Drop	1.86	1.86	1.80	1.84	in H ₂ O	
Absolute Meter Pressure	30.53	30.50	30.46	30.49	in Hg	
Avg Square Root Pitot Pressure	1.24	1.25	1.25	1.25	√(in H ₂ O)	
Moisture Content Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Impinger Water Weight Gain	88.10	133.90	99.60	107.20	g	
Silica Gel Weight Gain	18.20	12.50	9.60	13.43	g	
Total Water Volume Collected	106.49	146.66	109.40	120.85	ml	
Standard Water Vapor Volume	5.01	6.90	5.15	5.69	scf	
Standard Meter Volume	44.5	44.3	43.8	44.2	dscf	
Standard Metric Meter Volume	1.3	1.3	1.2	1.3	dscm	
Calculated Stack Moisture	10.13	13.49	10.53	11.38	%	
Saturated Stack Moisture	63.08	62.69	63.68	63.15	%	
Reported Stack Moisture Content	10.13	13.49	10.53	11.38	%	
Gas Analysis Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Carbon Dioxide Content	4.7	4.8	4.8	4.8	%	
Oxygen Content	12.0	12.3	12.2	12.2	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	83.3	82.9	83.0	83.1	%	
Stack Dry Molecular Weight	29.23	29.26	29.25	29.25	lb/lb-mole	
Stack Wet Molecular Weight	28.09	27.74	28.07	27.97	lb/lb-mole	
Calculated Fuel Factor	1.894	1.795	1.820	1.836		
Fuel F-Factor	8632.22	8632.22	8632.22	8632.22	dscf/MMBtu	
Percent Excess Air	120.1	128.3	125.5	124.6	%	

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Average Stack Gas Velocity	76.86	77.78	77.20	77.28	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,307,477	1,323,215	1,313,354	1,314,682	acfm	
Wet Standard Stack Flow Rate	64,520	65,266	64,627	64,804	wkscfh	
Dry Standard Stack Flow Rate	57,985,824	56,459,578	57,824,230	57,423,211	dscfh	
Ammonia Analysis (CTM-027)	Run - 1	Run - 2	Run - 3	Average	Units	Limits
Front Half Results (C _f)	16.8241	15.9351	16.2136	16.3243	mg/l	
Back Half Results (C _b)	0.2499	1.0103	0.1947	0.4850	mg/l	
Practical Quantitation Limit	0.1000	0.1000	0.1000	0.1000	mg/l	
Blank Results	0.0460	0.0460	0.0460	0.0460	mg/l	
Front Half Sample Volume	247	243	233	241	ml	
Back Half Sample Volume	223	215	228	222	ml	
Volume of NH ₃	0.00594	0.00577	0.00540	0.00570	L	
NH ₃ Concentration	4.72	4.61	4.35	4.56	ppmvd	--
NH ₃ Concentration	3.13	3.16	2.95	3.08	ppm@15%O ₂	5.00

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		CG	
Date for Preliminary Run	(mm/dd/yy)	09/25/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	35	scf
Run Duration	chk Subpart	60	minutes
Unit Number		CTG-1	
Base Run Number		1-100 w/DB-NH3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/25/18	09/25/18	09/25/18	
Load		w/DB	w/DB	w/DB	% or w/DB
Fuel F-Factor		8632.22	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0024	samp-cp-0024	samp-cp-0024	
Meter Calibration Factor	(Y)	1.009	1.009	1.009	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.869	1.869	1.869	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	A5702	A5702	A5702	
Pitot Tube Coefficient	(C _p)	0.8264	0.8264	0.8264	
Probe Number	from ACS	samp-hp-0141	samp-hp-0141	samp-hp-0141	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-hb-0005	samp-hb-0005	samp-hb-0005	
Impinger Case Number	from ACS	samp-bc-0002	samp-bc-0002	samp-bc-0002	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/25/18		
Sampling Location	CTG-1 Stack	Operator	CG		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	1-100 w/DB-NH3-1		Date	09/25/18	Run Start Time	09:21	Run Stop Time	10:24
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:03	4.7	12.0	0.0	83.3	29.23	1.894	120.1	NO

Gas Analysis Data								
Run Number	1-100 w/DB-NH3-2		Date	09/25/18	Run Start Time	10:45	Run Stop Time	11:48
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:03	4.8	12.3	0.0	82.9	29.26	1.795	128.3	YES

Gas Analysis Data								
Run Number	1-100 w/DB-NH3-3		Date	09/25/18	Run Start Time	12:10	Run Stop Time	13:14
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:04	4.8	12.2	0.0	83.0	29.25	1.820	125.5	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/25/18
Sampling Location	CTG-1 Stack	Operator	CG
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0022	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/25/18	500	499.9	-0.1	Pass
Test Day 1	09/25/18	500	499.9	-0.1	Pass

Moisture Content Data									
Run Number	1-100 w/DB-NH3-1		Date	09/25/18	Start Time	09:21	Stop Time	10:24	
Meter Box Number	samp-cp-0024				Meter Cal Factor	(Y)	1.009		
Total Meter Volume	(V _m)	43.300	dcf		Barometric Pressure	(P _b)	30.39	in Hg	
Average Stack Temp	(t _s) _{avg}	190	°F		Stack Static Pressure	(P _{static})	-1.10	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	69	°F		Avg Orifice Pressure	(ΔH) _{avg}	1.86	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	798.30	692.70	601.20	902.20				
Initial Value	(V _i),(W _i)	735.00	672.10	597.00	884.00				
Net Value	(V _n),(W _n)	63.3	20.6	4.2	18.2				
Results									
Total Weight	(W _i)	106.30	g		Water Vol Weighed	(V _{wsg(std)})	5.012	scf	
Std Meter Volume	(V _{m(std)})	44.477	dscf		Sat. Moisture Content	(B _{ws(svp)})	63.08	%	
Calc Moisture Content	(B _{ws(calc)})	10.13	%		Final Moisture Content	(B _{ws})	10.13	%	

Moisture Content Data									
Run Number	1-100 w/DB-NH3-2		Date	09/25/18	Start Time	10:45	Stop Time	11:48	
Meter Box Number	samp-cp-0024				Meter Cal Factor	(Y)	1.009		
Total Meter Volume	(V _m)	43.230	dcf		Barometric Pressure	(P _b)	30.36	in Hg	
Average Stack Temp	(t _s) _{avg}	190	°F		Stack Static Pressure	(P _{static})	-1.10	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	70	°F		Avg Orifice Pressure	(ΔH) _{avg}	1.86	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	765.80	722.20	592.30	961.50				
Initial Value	(V _i),(W _i)	700.60	697.10	548.70	949.00				
Net Value	(V _n),(W _n)	65.2	25.1	43.6	12.5				
Results									
Total Weight	(W _i)	146.40	g		Water Vol Weighed	(V _{wsg(std)})	6.903	scf	
Std Meter Volume	(V _{m(std)})	44.257	dscf		Sat. Moisture Content	(B _{ws(svp)})	62.69	%	
Calc Moisture Content	(B _{ws(calc)})	13.49	%		Final Moisture Content	(B _{ws})	13.49	%	

Moisture Content Data									
Run Number	1-100 w/DB-NH3-3		Date	09/25/18	Start Time	12:10	Stop Time	13:14	
Meter Box Number	samp-cp-0024				Meter Cal Factor	(Y)	1.009		
Total Meter Volume	(V _m)	42.830	dcf		Barometric Pressure	(P _b)	30.32	in Hg	
Average Stack Temp	(t _s) _{avg}	191	°F		Stack Static Pressure	(P _{static})	-1.10	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	71	°F		Avg Orifice Pressure	(ΔH) _{avg}	1.80	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	768.30	705.90	603.20	911.80				
Initial Value	(V _i),(W _i)	694.00	684.80	599.00	902.20				
Net Value	(V _n),(W _n)	74.3	21.1	4.2	9.6				
Results									
Total Weight	(W _i)	109.20	g		Water Vol Weighed	(V _{wsg(std)})	5.149	scf	
Std Meter Volume	(V _{m(std)})	43.763	dscf		Sat. Moisture Content	(B _{ws(svp)})	63.68	%	
Calc Moisture Content	(B _{ws(calc)})	10.53	%		Final Moisture Content	(B _{ws})	10.53	%	

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	CG
Run Number	1-100 w/DB-NH3-1

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8264	A5702	
Average Stack Temp (t_s)	190.3		°F
Average Meter Temp (t_m)	69.2		
Orifice Meter Coefficient ($\Delta H @$)	1.869		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.24		in H ₂ O
Stack Moisture Content (B_{ws})	10.13		%
Stack Dry Molecular Weight (M_d)	29.23		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pre (+)	5.0	in H ₂ O for	30.0	sec
	Pre (-)	5.0	in H ₂ O for	30.0	sec
	Post (+)	5.1	in H ₂ O for	15.0	sec
	Post (-)	5.2	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D_{na})	#DIV/0!		in
Suggested Nozzle Diameter (D_m)	0.2030		in
Probe Number	samp-hp-0141		
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-hb-0005		
Impinger Case Number	samp-bc-0002		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time			
Start	09:21	End	10:24

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	735.0	672.1	597.0	884.0				
Post	798.3	692.7	601.2	902.2				

Pressures			
Barometric Pressure (P_b)	30.39		in Hg
Stack Static Pressure (P_{static})	-1.10		in H ₂ O
Absolute Stack Pressure (P_s)	30.31		in Hg
Absolute Meter Pressure (P_m)	30.53		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024		samp-cp-0024		samp-cp-0024		samp-hp-0141		samp-hp-0141		samp-hb-0005		samp-bc-0002		samp-cp-0024		samp-cp-0024		Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)
	Traverse Point #	Sampling Time (h)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (t_p)	Filter Temp (t_f)	Impinger Temp (t_i)	Cond. Temp (t_c)	CPM Filter Temp (t_{cp})	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$)					
A-1	0.0	00:00:00	465.500	1.50	#DIV/0!	1.86	191	250	256	57					68	68	2.0	1.22	75.66	3.603	--	43.237
A-2	5.0	00:05:00	469.000	1.50	#DIV/0!	1.86	191	251	254	57				68	68	2.0	1.22	75.66	7.114	--	42.681	
A-3	10.0	00:10:00	472.410	1.60	#DIV/0!	1.86	191	251	254	57				68	68	2.0	1.26	78.14	10.809	--	43.237	
B-1	15.0	00:15:00	476.000	1.60	#DIV/0!	1.86	190	250	253	57				69	69	2.0	1.26	78.08	14.693	--	44.080	
B-2	20.0	00:20:00	479.780	1.50	#DIV/0!	1.86	190	251	252	58				69	69	2.0	1.22	75.60	18.382	--	44.117	
B-3	25.0	00:25:00	483.370	1.60	#DIV/0!	1.86	190	251	251	58				69	69	2.0	1.26	78.08	21.835	--	43.669	
C-1	30.0	00:30:00	486.730	1.50	#DIV/0!	1.86	190	250	250	57				69	69	2.0	1.22	75.60	25.893	--	44.388	
C-2	35.0	00:35:00	490.680	1.60	#DIV/0!	1.86	190	252	251	57				70	70	2.0	1.26	78.08	29.247	--	43.870	
C-3	40.0	00:40:00	493.950	1.60	#DIV/0!	1.86	190	252	251	57				70	70	2.0	1.26	78.08	32.734	--	43.645	
D-1	45.0	00:45:00	497.350	1.50	#DIV/0!	1.86	190	252	250	57				70	70	2.0	1.22	75.60	36.467	--	43.760	
D-2	50.0	00:50:00	500.990	1.50	#DIV/0!	1.86	190	250	251	58				70	70	2.0	1.22	75.60	40.128	--	43.776	
D-3	55.0	00:55:00	504.560	1.60	#DIV/0!	1.86	191	252	253	58				70	70	2.0	1.26	78.14	44.477	--	44.477	
Last Pt	60.0	01:00:00	508.800		#DIV/0!																--	
Final Val	60.0	01:00:00	508.800												Max Vac	2.0	Final Values		44.477			
Average Values				1.55		1.86	190	251	252	57				69	69		1.24	76.86				

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	CG
Run Number	1-100 w/DB-NH3-2

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8264	A5702	
Average Stack Temp (t_s)	190.0		°F
Average Meter Temp (t_m)	70.4		
Orifice Meter Coefficient ($\Delta H @$)	1.869		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.25		in H ₂ O
Stack Moisture Content (B_{ws})	13.49		%
Stack Dry Molecular Weight (M_d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.74		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	5.0	in H ₂ O for	30.0 sec
		Pre (-)	5.0	in H ₂ O for	30.0 sec
		Post (+)	5.1	in H ₂ O for	15.0 sec
		Post (-)	5.2	in H ₂ O for	15.0 sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D_{na})	#DIV/0!		in
Suggested Nozzle Diameter (D_m)	0.2005		in
Probe Number	samp-hp-0141		
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-hb-0005		
Impinger Case Number	samp-bc-0002		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time			
Start	10:45	End	11:48

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	700.6	697.1	548.7	949.0				
Post	765.8	722.2	592.3	961.5				

Pressures			
Barometric Pressure (P_b)	30.36		in Hg
Stack Static Pressure (P_{static})	-1.10		in H ₂ O
Absolute Stack Pressure (P_s)	30.28		in Hg
Absolute Meter Pressure (P_m)	30.50		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024		samp-cp-0024		samp-cp-0024		samp-hp-0141		samp-hp-0141		samp-hb-0005		samp-bc-0002		samp-cp-0024		samp-cp-0024		Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)
	Traverse Point #	Sampling Time (h)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Temp (≤68°F)	Cond. Temp (≤-°F)	CPM Filter Temp (-±-°F)	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$)					
A-1	0.0	00:00:00	508.670	1.60	#DIV/0!	1.86	190	246	261	63				69	69	2.0	1.26	78.61	4.044	--	48.533	
A-2	5.0	00:05:00	512.610	1.60	#DIV/0!	1.86	190	246	260	63				69	69	2.0	1.26	78.61	7.381	--	44.283	
A-3	10.0	00:10:00	515.860	1.60	#DIV/0!	1.86	190	247	261	63				69	69	2.0	1.26	78.61	11.220	--	44.879	
B-1	15.0	00:15:00	519.600	1.60	#DIV/0!	1.86	190	251	264	63				70	70	2.0	1.26	78.61	14.703	--	44.110	
B-2	20.0	00:20:00	523.000	1.50	#DIV/0!	1.86	190	250	263	62				71	71	2.0	1.22	76.12	18.190	--	43.657	
B-3	25.0	00:25:00	526.410	1.60	#DIV/0!	1.86	190	252	262	62				71	71	2.0	1.26	78.61	21.862	--	43.723	
C-1	30.0	00:30:00	530.000	1.50	#DIV/0!	1.86	190	253	260	60				71	71	2.0	1.22	76.12	25.625	--	43.929	
C-2	35.0	00:35:00	533.680	1.50	#DIV/0!	1.86	190	253	264	60				71	71	2.0	1.22	76.12	29.409	--	44.113	
C-3	40.0	00:40:00	537.380	1.50	#DIV/0!	1.86	189	249	255	61				71	71	2.0	1.22	76.06	33.111	--	44.148	
D-1	45.0	00:45:00	541.000	1.60	#DIV/0!	1.86	190	252	262	60				71	71	2.0	1.26	78.61	36.864	--	44.237	
D-2	50.0	00:50:00	544.670	1.60	#DIV/0!	1.86	190	254	263	60				71	71	2.0	1.26	78.61	40.699	--	44.399	
D-3	55.0	00:55:00	548.420	1.60	#DIV/0!	1.86	191	252	263	60				71	71	2.0	1.26	78.67	44.258	--	44.258	
Last Pt	60.0	01:00:00	551.900		#DIV/0!																--	
Final Val	60.0	01:00:00	551.900												Max Vac	2.0	Final Values		44.258			
Average Values				1.57		1.86	190	250	262	61				70	70		1.25	77.78				

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	CG
Run Number	1-100 w/DB-NH3-3

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8264	A5702	
Average Stack Temp (t_s)	190.7		°F
Average Meter Temp (t_m)	70.7		
Orifice Meter Coefficient (ΔH_{or})	1.869		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.25		in H ₂ O
Stack Moisture Content (B_{ws})	10.53		%
Stack Dry Molecular Weight (M_d)	29.25		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.74		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	5.0	in H ₂ O for	30.0 sec
		Pre (-)	5.0	in H ₂ O for	30.0 sec
		Post (+)	5.1	in H ₂ O for	15.0 sec
		Post (-)	5.2	in H ₂ O for	15.0 sec

Sampling Equipment			
Meter Box Number	samp-cp-0024		
Meter Cal Factor (Y)	1.009		
Nozzle Number			
Average Nozzle Diameter (D_{na})	#DIV/0!		in
Suggested Nozzle Diameter (D_m)	0.2007		in
Probe Number	samp-hp-0141		
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-hb-0005		
Impinger Case Number	samp-bc-0002		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time			
Start	12:10	End	13:14

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	694.0	684.8	599.0	902.2				
Post	768.3	705.9	603.2	911.8				

Pressures			
Barometric Pressure (P_b)	30.32		in Hg
Stack Static Pressure (P_{static})	-1.10		in H ₂ O
Absolute Stack Pressure (P_s)	30.24		in Hg
Absolute Meter Pressure (P_m)	30.46		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0024		samp-cp-0024		samp-cp-0024		samp-hp-0141		samp-hp-0141		samp-hb-0005		samp-bc-0002		samp-cp-0024		samp-cp-0024		Local Stack Velocity (v_s) ft/sec	Cumul. Meter Volume ($V_{m, std}$) dscf	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$) dscf
	Traverse Point #	Sampling Time (h)	Timer Time	Dry Gas Meter Reading (V_m) ft ³	Velocity Head (Δp) in H ₂ O	Desired Orifice ΔH (ΔH_d) in H ₂ O	Actual Orifice ΔH (ΔH_a) in H ₂ O	Stack Temp (t_s) °F	Probe Temp (248±25°F) °F	Filter Temp (248±25°F) °F	Impinger Temp (≤68°F) °F	Cond. Temp (≤-°F) °F	CPM Filter Temp (-±-°F) °F	Meter Inlet Temp (t_{mi}) °F	Meter Outlet Temp (t_{mo}) °F	Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$) √(in H ₂ O)					
A-1	0.0	00:00:00	552.770	1.60	#DIV/0!	1.80	190	256	262	57					70	70	2.0	1.26	78.20	3.826	--	45.916
A-2	5.0	00:05:00	556.510	1.70	#DIV/0!	1.80	191	251	262	57					70	70	2.0	1.30	80.67	7.397	--	44.381
A-3	10.0	00:10:00	560.000	1.60	#DIV/0!	1.80	191	257	261	58					70	70	2.0	1.26	78.26	11.489	--	45.957
B-1	15.0	00:15:00	564.000	1.60	#DIV/0!	1.80	191	256	261	58					70	70	2.0	1.26	78.26	15.796	--	47.389
B-2	20.0	00:20:00	568.210	1.50	#DIV/0!	1.80	190	252	263	58					71	71	2.0	1.22	75.72	18.451	--	44.283
B-3	25.0	00:25:00	570.810	1.50	#DIV/0!	1.80	190	255	262	57					71	71	2.0	1.22	75.72	22.638	--	45.276
C-1	30.0	00:30:00	574.910	1.50	#DIV/0!	1.80	190	253	261	57					71	71	2.0	1.22	75.72	25.793	--	44.217
C-2	35.0	00:35:00	578.000	1.60	#DIV/0!	1.80	191	253	260	57					71	71	2.0	1.26	78.26	29.490	--	44.235
C-3	40.0	00:40:00	581.620	1.60	#DIV/0!	1.80	191	252	260	57					71	71	2.0	1.26	78.26	33.064	--	44.085
D-1	45.0	00:45:00	585.120	1.50	#DIV/0!	1.80	191	248	262	58					71	71	2.0	1.22	75.78	36.914	--	44.296
D-2	50.0	00:50:00	588.890	1.50	#DIV/0!	1.80	191	255	262	58					71	71	2.0	1.22	75.78	40.304	--	43.968
D-3	55.0	00:55:00	592.210	1.50	#DIV/0!	1.80	191	253	262	58					71	71	2.0	1.22	75.78	43.766	--	43.766
Last Pt	60.0	01:00:00	595.600		#DIV/0!																--	
Final Val	60.0	01:00:00	595.600																			
Average Values				1.56		1.80	191	253	262	58					71	71		1.25	77.20			

Notes:

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
without Duct Burners Firing
Unit Operations Data**

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	205.84	2095738.09	0.00	89.29
Time	CT MEGAWATT SELECT MW 12HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 12HAD00EU001 XQ27	HRSG2 DB NG FLOW1 KPPH 12HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 12MBP10CF910 XQ07	
one hour from run time		208.26256	2115494.5	9.717435	90.182365
2018/09/25 16:40:00:000		206.24767	2092360.5	0.0041098	89.39595
2018/09/25 16:41:00:000		205.89044	2097055.9	0.0041098	89.281235
2018/09/25 16:42:00:000		205.89044	2096817.4	0.0041098	89.281235
2018/09/25 16:43:00:000		205.58824	2095475.4	0.0041098	89.44122
2018/09/25 16:44:00:000		205.58824	2087808.6	0.0041098	89.36877
2018/09/25 16:45:00:000		205.58824	2097139	0.0041098	89.321304
2018/09/25 16:46:00:000		205.92259	2095921.5	0.0041098	89.321304
2018/09/25 16:47:00:000		205.92259	2092500.8	0.0041098	89.321304
2018/09/25 16:48:00:000		205.92259	2096901.5	0.0041098	89.321304
2018/09/25 16:49:00:000		205.92259	2097027.8	0.0041098	89.321304
2018/09/25 16:50:00:000		205.92259	2096290.2	0.0041098	89.321304
2018/09/25 16:51:00:000		205.92259	2096216.4	0.0041098	89.321304
2018/09/25 16:52:00:000		205.79712	2094155.1	0.0041098	89.321304
2018/09/25 16:53:00:000		205.79712	2097158.5	0.0041098	89.321304
2018/09/25 16:54:00:000		206.20648	2097495	0.0041098	89.321304
2018/09/25 16:55:00:000		206.20648	2101022.2	0.0041098	89.321304
2018/09/25 16:56:00:000		205.92049	2096747.6	0.0041098	89.321304
2018/09/25 16:57:00:000		205.92049	2099435.5	0.0041098	89.321304
2018/09/25 16:58:00:000		205.92049	2094469.8	0.0041098	89.14992
2018/09/25 16:59:00:000		205.59128	2095520.2	0.0041098	89.145966
2018/09/25 17:00:00:000		205.59128	2096506.9	0.0041098	89.17352
2018/09/25 17:01:00:000		205.59128	2097518.5	0.0041098	89.23345
2018/09/25 17:02:00:000		205.59128	2093175.6	0.0041098	89.23345
2018/09/25 17:03:00:000		205.59128	2094745.2	0.0041098	89.23345
2018/09/25 17:04:00:000		205.59128	2092879.2	0.0041098	89.37938
2018/09/25 17:05:00:000		205.71599	2093777.5	0.0041098	89.25867
2018/09/25 17:06:00:000		205.71599	2092927	0.0041098	89.29986
2018/09/25 17:07:00:000		205.71599	2096785	0.0041098	89.29986
2018/09/25 17:08:00:000		206.25748	2098095.5	0.0041098	89.29986
2018/09/25 17:09:00:000		205.96689	2097092	0.0041098	89.34638
2018/09/25 17:10:00:000		205.72404	2094739.2	0.0041098	89.16539
2018/09/25 17:11:00:000		205.72404	2094536.9	0.0041098	89.170845
2018/09/25 17:12:00:000		205.72404	2092397.6	0.0041098	89.2612
2018/09/25 17:13:00:000		205.72404	2094711	0.0041098	89.289154
2018/09/25 17:14:00:000		205.72404	2091382.8	0.0041098	89.289154
2018/09/25 17:15:00:000		205.91135	2099468.8	0.0041098	89.289154
2018/09/25 17:16:00:000		205.91135	2096881.2	0.0041098	89.44478
2018/09/25 17:17:00:000		205.91135	2099928	0.0041098	89.189896
2018/09/25 17:18:00:000		205.91135	2097904	0.0041098	89.40729
2018/09/25 17:19:00:000		205.91135	2094504.1	0.0041098	89.41495
2018/09/25 17:20:00:000		205.91135	2096218.5	0.0041098	89.24975
2018/09/25 17:21:00:000		205.91135	2094623	0.0041098	89.24975
2018/09/25 17:22:00:000		205.62871	2098321.2	0.0041098	89.24975
2018/09/25 17:23:00:000		205.62871	2093932	0.0041098	89.24975
2018/09/25 17:24:00:000		205.62871	2094893.8	0.0041098	89.24975
2018/09/25 17:25:00:000		205.62871	2097000	0.0041098	89.13966
2018/09/25 17:26:00:000		205.9282	2096152.8	0.0041098	89.2944
2018/09/25 17:27:00:000		205.9282	2096028.9	0.0041098	89.251144
2018/09/25 17:28:00:000		205.9282	2096364.5	0.0041098	89.251144
2018/09/25 17:29:00:000		205.61543	2095293.1	0.0041098	89.251144
2018/09/25 17:30:00:000		205.61543	2093440.4	0.0041098	89.31034
2018/09/25 17:31:00:000		205.61543	2091535.5	0.0041098	89.148315
2018/09/25 17:32:00:000		205.61543	2094595.2	0.0041098	89.148315
2018/09/25 17:33:00:000		205.96396	2095418.8	0.0041098	89.33375
2018/09/25 17:34:00:000		205.96396	2097395.8	0.0041098	89.33375
2018/09/25 17:35:00:000		205.96396	2098120.2	0.0041098	89.538025
2018/09/25 17:36:00:000		205.96396	2096602.5	0.0041098	89.36985
2018/09/25 17:37:00:000		205.96396	2097145.2	0.0041098	89.36985
2018/09/25 17:38:00:000		206.25716	2095303.8	0.0041098	89.36985
2018/09/25 17:39:00:000		206.25716	2098425.5	0.0041098	89.36985

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	205.41	2092599.98	0.00	89.17
Time	CT MEGAWATT SELECT MW 12HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 12HAD00EU001 XQ27	HRSG2 DB NG FLOW1 KPPH 12HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 12MBP10CF910 XQ07	
one hour from run time		208.26256	2115494.5	9.717435	90.182365
2018/09/25 18:15:00:000		205.4413	2091904.8	0.0041098	89.07527
2018/09/25 18:16:00:000		205.4413	2091499.2	0.0041098	89.18875
2018/09/25 18:17:00:000		205.4413	2091112.2	0.0041098	89.18875
2018/09/25 18:18:00:000		205.4413	2093115	0.0041098	89.18875
2018/09/25 18:19:00:000		205.4413	2091249.6	0.0041098	89.18875
2018/09/25 18:20:00:000		205.89514	2096088.6	0.0041098	89.18875
2018/09/25 18:21:00:000		205.89514	2088463.1	0.0041098	89.18875
2018/09/25 18:22:00:000		205.39189	2092288.2	0.0041098	88.925705
2018/09/25 18:23:00:000		205.39189	2092828.1	0.0041098	88.913864
2018/09/25 18:24:00:000		205.39189	2092524.2	0.0041098	89.020325
2018/09/25 18:25:00:000		204.96315	2092601.5	0.0041098	89.020325
2018/09/25 18:26:00:000		205.46487	2092903.5	0.0041098	89.06441
2018/09/25 18:27:00:000		204.96396	2091099.6	0.0041098	89.19478
2018/09/25 18:28:00:000		204.96396	2091180.1	0.0041098	89.02205
2018/09/25 18:29:00:000		204.96396	2087604.2	0.0041098	89.02205
2018/09/25 18:30:00:000		205.12129	2090385.5	0.0041098	89.00064
2018/09/25 18:31:00:000		205.12129	2089131.2	0.0041098	89.18449
2018/09/25 18:32:00:000		205.12129	2089119	0.0041098	89.02658
2018/09/25 18:33:00:000		205.12129	2091158	0.0041098	89.05295
2018/09/25 18:34:00:000		205.12129	2092068	0.0041098	89.05295
2018/09/25 18:35:00:000		205.12129	2087562.2	0.0041098	89.05295
2018/09/25 18:36:00:000		204.8098	2091909.4	0.0041098	89.06737
2018/09/25 18:37:00:000		204.8098	2089781.5	0.0041098	89.06737
2018/09/25 18:38:00:000		205.13947	2090985.4	0.0041098	89.15773
2018/09/25 18:39:00:000		205.13947	2092750.8	0.0041098	89.15773
2018/09/25 18:40:00:000		205.46861	2091557.4	0.0041098	89.13451
2018/09/25 18:41:00:000		205.46861	2092080.5	0.0041098	89.13451
2018/09/25 18:42:00:000		205.26425	2094432	0.0041098	89.222984
2018/09/25 18:43:00:000		205.89644	2082490.6	0.0041098	89.222984
2018/09/25 18:44:00:000		204.72989	2075935.5	0.0041098	88.802
2018/09/25 18:45:00:000		205.88464	2116316.5	0.0041098	89.36588
2018/09/25 18:46:00:000		205.20335	2077692.6	0.0041098	88.96338
2018/09/25 18:47:00:000		206.1434	2117176	0.0041098	89.55749
2018/09/25 18:48:00:000		205.12022	2084763.5	0.0041098	89.15283
2018/09/25 18:49:00:000		205.91751	2088809.6	0.0041098	89.41896
2018/09/25 18:50:00:000		205.91751	2097231.8	0.0041098	89.14046
2018/09/25 18:51:00:000		205.27219	2082792	0.0041098	89.14046
2018/09/25 18:52:00:000		205.92683	2108925	0.0041098	89.44506
2018/09/25 18:53:00:000		205.09525	2091936.5	0.0041098	89.21609
2018/09/25 18:54:00:000		205.69266	2093560.1	0.0041098	89.33626
2018/09/25 18:55:00:000		205.69266	2099124.2	0.0041098	89.38675
2018/09/25 18:56:00:000		205.05446	2096052	0.0041098	89.22578
2018/09/25 18:57:00:000		205.26917	2086630.9	0.0041098	89.11319
2018/09/25 18:58:00:000		205.93385	2090325.2	0.0041098	89.3324
2018/09/25 18:59:00:000		205.26181	2093564.2	0.0041098	89.22734
2018/09/25 19:00:00:000		205.70825	2100847	0.0041098	89.22734
2018/09/25 19:01:00:000		205.70825	2096705.2	0.0041098	89.22734
2018/09/25 19:02:00:000		205.70825	2086795.9	0.0041098	89.22734
2018/09/25 19:03:00:000		205.51692	2091601.4	0.0041098	89.22734
2018/09/25 19:04:00:000		205.73085	2093492	0.0041098	89.265396
2018/09/25 19:05:00:000		205.73085	2096500	0.0041098	89.265396
2018/09/25 19:06:00:000		205.48166	2094076.1	0.0041098	89.156296
2018/09/25 19:07:00:000		205.48166	2094829.2	0.0041098	89.11783
2018/09/25 19:08:00:000		205.48166	2093009	0.0041098	89.28023
2018/09/25 19:09:00:000		205.48166	2094781.2	0.0041098	89.09398
2018/09/25 19:10:00:000		205.45447	2095616.4	0.0041098	89.337296
2018/09/25 19:11:00:000		205.45447	2092575	0.0041098	89.22472
2018/09/25 19:12:00:000		205.45447	2095655.5	0.0041098	89.22472
2018/09/25 19:13:00:000		205.45447	2092569.1	0.0041098	89.22472
2018/09/25 19:14:00:000		205.45447	2094236.8	0.0041098	89.193016

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	205.33	2091966.10	0.00	89.15
Time	CT MEGAWATT SELECT MW 12HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 12HAD00EU001 XQ27	HRSG2 DB NG FLOW1 KPPH 12HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 12MBP10CF910 XQ07	
one hour from run time		208.26256	2115494.5	9.717435	90.182365
2018/09/25 19:44:00:000		205.62181	2098109.2	0.0041098	89.193726
2018/09/25 19:45:00:000		205.62181	2096270.2	0.0041098	89.250885
2018/09/25 19:46:00:000		205.30849	2093009.4	0.0041098	89.250885
2018/09/25 19:47:00:000		205.30849	2085952	0.0041098	89.242966
2018/09/25 19:48:00:000		205.30849	2091745.2	0.0041098	89.08577
2018/09/25 19:49:00:000		205.30849	2089296.1	0.0041098	89.168335
2018/09/25 19:50:00:000		205.12155	2080668.4	0.0041098	89.01399
2018/09/25 19:51:00:000		205.89581	2108461.2	0.0041098	89.245575
2018/09/25 19:52:00:000		204.73494	2070095.9	0.0041098	89.05318
2018/09/25 19:53:00:000		204.49315	2073805.6	0.0041098	88.9532
2018/09/25 19:54:00:000		205.4747	2085199.4	0.0041098	89.23692
2018/09/25 19:55:00:000		204.9842	2117542	0.0041098	89.194565
2018/09/25 19:56:00:000		205.29218	2082786.8	0.0041098	89.14554
2018/09/25 19:57:00:000		205.29218	2091502.1	0.0041098	89.02115
2018/09/25 19:58:00:000		205.29218	2089676.1	0.0041098	89.30353
2018/09/25 19:59:00:000		205.29218	2081525.8	0.0041098	88.996124
2018/09/25 20:00:00:000		205.29218	2100983.5	0.0041098	89.22641
2018/09/25 20:01:00:000		205.29218	2086681.5	0.0041098	88.93245
2018/09/25 20:02:00:000		205.73373	2089303.9	0.0041098	89.1837
2018/09/25 20:03:00:000		205.73373	2101691.8	0.0041098	89.10413
2018/09/25 20:04:00:000		205.48999	2089134.6	0.0041098	89.10413
2018/09/25 20:05:00:000		205.91316	2095190.4	0.0041098	89.30655
2018/09/25 20:06:00:000		205.91316	2110107	0.0041098	89.30655
2018/09/25 20:07:00:000		205.36569	2094138.9	0.0041098	89.13858
2018/09/25 20:08:00:000		205.84503	2092928.1	0.0041098	89.282394
2018/09/25 20:09:00:000		205.84503	2093474.4	0.0041098	89.282394
2018/09/25 20:10:00:000		205.44351	2092166.4	0.0041098	89.23071
2018/09/25 20:11:00:000		205.44351	2092197.6	0.0041098	88.95992
2018/09/25 20:12:00:000		204.90398	2091716.8	0.0041098	89.04744
2018/09/25 20:13:00:000		205.49847	2093352.4	0.0041098	89.239
2018/09/25 20:14:00:000		205.1521	2091044.9	0.0041098	89.20442
2018/09/25 20:15:00:000		205.1521	2097362	0.0041098	89.27843
2018/09/25 20:16:00:000		205.4455	2092194.9	0.0041098	89.14888
2018/09/25 20:17:00:000		205.17586	2091581.6	0.0041098	89.14888
2018/09/25 20:18:00:000		205.17586	2088924.6	0.0041098	89.08343
2018/09/25 20:19:00:000		205.17586	2091140.6	0.0041098	89.08343
2018/09/25 20:20:00:000		205.17586	2093178.8	0.0041098	89.08343
2018/09/25 20:21:00:000		205.17586	2089411.8	0.0041098	89.07748
2018/09/25 20:22:00:000		205.17586	2092928.1	0.0041098	88.930435
2018/09/25 20:23:00:000		205.17586	2092306.9	0.0041098	89.0553
2018/09/25 20:24:00:000		205.17586	2089203.1	0.0041098	89.10501
2018/09/25 20:25:00:000		205.17586	2087958.2	0.0041098	89.10501
2018/09/25 20:26:00:000		205.17586	2088378.9	0.0041098	89.10501
2018/09/25 20:27:00:000		205.17586	2090848.6	0.0041098	89.10501
2018/09/25 20:28:00:000		205.17586	2092712.5	0.0041098	89.10501
2018/09/25 20:29:00:000		205.17586	2094674.6	0.0041098	89.183334
2018/09/25 20:30:00:000		205.17586	2089681.5	0.0041098	89.024734
2018/09/25 20:31:00:000		205.17586	2095321.9	0.0041098	89.22619
2018/09/25 20:32:00:000		205.44022	2096172.2	0.0041098	89.04292
2018/09/25 20:33:00:000		205.44022	2094647.2	0.0041098	89.113815
2018/09/25 20:34:00:000		205.44022	2091948.2	0.0041098	89.243256
2018/09/25 20:35:00:000		205.44022	2093974.8	0.0041098	89.21405
2018/09/25 20:36:00:000		205.44022	2094365	0.0041098	89.277695
2018/09/25 20:37:00:000		205.44022	2093030.1	0.0041098	89.25983
2018/09/25 20:38:00:000		205.44022	2091508.8	0.0041098	89.20712
2018/09/25 20:39:00:000		205.13737	2092728.9	0.0041098	89.20968
2018/09/25 20:40:00:000		205.13737	2090295.2	0.0041098	89.02124
2018/09/25 20:41:00:000		205.13737	2090487.9	0.0041098	89.14995
2018/09/25 20:42:00:000		205.45293	2087114.2	0.0041098	89.14995
2018/09/25 20:43:00:000		205.45293	2094127.4	0.0041098	89.31183

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
with Duct Burners Firing
Unit Operations Data**

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	209.99	2129501.23	16.25	90.84
Time	CT MEGAWATT SELECT MW 12HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 12HAD00EU001 XQ27	HRSG2 DB NG FLOW1 KPPH 12HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 12MBP10CF910 XQ07	
one hour from run time		208.26256	2115494.5	9.717435	90.182365
2018/09/25 10:25:00:000		210.34167	2129650.5	16.255562	90.824875
2018/09/25 10:26:00:000		210.34167	2121710.5	16.255562	90.95378
2018/09/25 10:27:00:000		210.34167	2143790.2	16.255562	91.194664
2018/09/25 10:28:00:000		210.34167	2124144.5	16.255562	91.04726
2018/09/25 10:29:00:000		210.34167	2122236.2	16.255562	91.04726
2018/09/25 10:30:00:000		210.34167	2150243	16.255562	91.04726
2018/09/25 10:31:00:000		210.34167	2125659.8	16.255562	90.87898
2018/09/25 10:32:00:000		210.34167	2124597.8	16.255562	90.87898
2018/09/25 10:33:00:000		210.34167	2140539.8	16.255562	91.003784
2018/09/25 10:34:00:000		209.96764	2123398.8	16.255562	90.791985
2018/09/25 10:35:00:000		209.96764	2124818.8	16.255562	90.963936
2018/09/25 10:36:00:000		210.65047	2147515.8	16.255562	90.963936
2018/09/25 10:37:00:000		210.0563	2126500.8	16.255562	90.872604
2018/09/25 10:38:00:000		210.0563	2126224.5	16.255562	90.872604
2018/09/25 10:39:00:000		210.55162	2144717.8	16.255562	90.89636
2018/09/25 10:40:00:000		210.16628	2128050	16.255562	90.7135
2018/09/25 10:41:00:000		210.16628	2127245.2	16.255562	90.99036
2018/09/25 10:42:00:000		210.16628	2139348.8	16.255562	90.87698
2018/09/25 10:43:00:000		210.16628	2134826.2	16.255562	90.778366
2018/09/25 10:44:00:000		209.81244	2121190.5	16.255562	90.778366
2018/09/25 10:45:00:000		210.06734	2127073.2	16.255562	90.77782
2018/09/25 10:46:00:000		210.06734	2132372.8	16.255562	90.906006
2018/09/25 10:47:00:000		209.87819	2132164.8	16.255562	90.875595
2018/09/25 10:48:00:000		209.87819	2119877.2	16.255562	90.875595
2018/09/25 10:49:00:000		209.87819	2124049.2	16.255562	90.875595
2018/09/25 10:50:00:000		209.87819	2132403.2	16.255562	90.875595
2018/09/25 10:51:00:000		210.52708	2127674.8	16.255562	90.875595
2018/09/25 10:52:00:000		210.229	2133283.5	16.255562	90.81177
2018/09/25 10:53:00:000		209.88647	2129827.2	16.255562	90.81177
2018/09/25 10:54:00:000		209.88647	2130858.2	16.255562	90.81177
2018/09/25 10:55:00:000		209.88647	2131989.8	16.255562	90.81177
2018/09/25 10:56:00:000		210.19487	2130818.8	16.255562	90.86705
2018/09/25 10:57:00:000		209.55972	2125228.5	16.255562	90.78553
2018/09/25 10:58:00:000		209.55972	2127922.8	16.255562	90.78553
2018/09/25 10:59:00:000		210.0228	2126919	16.255562	90.9365
2018/09/25 11:00:00:000		210.0228	2127523.8	16.255562	90.80879
2018/09/25 11:01:00:000		210.0228	2132295	16.255562	90.918465
2018/09/25 11:02:00:000		210.0228	2130980.8	16.245287	90.71399
2018/09/25 11:03:00:000		210.0228	2131676.2	16.245287	90.86785
2018/09/25 11:04:00:000		210.0228	2134236	16.245287	90.65413
2018/09/25 11:05:00:000		210.0228	2131612	16.245287	90.7798
2018/09/25 11:06:00:000		209.55865	2131416	16.245287	90.92738
2018/09/25 11:07:00:000		209.92476	2128498.5	16.245287	90.797104
2018/09/25 11:08:00:000		209.92476	2123762.8	16.245287	90.875336
2018/09/25 11:09:00:000		209.92476	2131413.8	16.245287	90.875336
2018/09/25 11:10:00:000		209.92476	2128575.8	16.256245	90.824554
2018/09/25 11:11:00:000		209.92476	2128942.5	16.256245	90.67366
2018/09/25 11:12:00:000		209.58052	2128403	16.256245	90.67366
2018/09/25 11:13:00:000		209.58052	2128895	16.256245	90.754074
2018/09/25 11:14:00:000		209.96727	2131070	16.256245	90.754074
2018/09/25 11:15:00:000		209.96727	2130645.8	16.256245	90.711784
2018/09/25 11:16:00:000		209.36874	2129501.8	16.256245	90.711784
2018/09/25 11:17:00:000		209.61476	2127106.8	16.256245	90.711784
2018/09/25 11:18:00:000		209.61476	2119651.2	16.256245	90.711784
2018/09/25 11:19:00:000		209.61476	2126207	16.24597	90.711784
2018/09/25 11:20:00:000		209.61476	2121406.5	16.24597	90.88292
2018/09/25 11:21:00:000		209.96019	2127117.5	16.24597	90.781784
2018/09/25 11:22:00:000		209.68304	2127144.5	16.24597	90.781784
2018/09/25 11:23:00:000		209.68304	2127220.2	16.24597	90.618835
2018/09/25 11:24:00:000		209.68304	2125898.5	16.24597	90.854675

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	208.89	2119978.09	16.26	90.47
Time	CT MEGAWATT SELECT MW 12HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 12HAD00EU001 XQ27	HRSG2 DB NG FLOW1 KPPH 12HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 12MBP10CF910 XQ07	
Note: System time offset					
one hour from run time		208.26256	2115494.5	9.717435	90.182365
2018/09/25 12:24:00:000		208.92174	2121056.8	16.25419	90.55608
2018/09/25 12:25:00:000		208.92174	2120376.8	16.25419	90.5323
2018/09/25 12:26:00:000		208.92174	2121865.2	16.25419	90.5323
2018/09/25 12:27:00:000		208.92174	2119209.2	16.25419	90.5323
2018/09/25 12:28:00:000		208.92174	2119988	16.25419	90.61719
2018/09/25 12:29:00:000		209.37889	2121904.5	16.25419	90.61719
2018/09/25 12:30:00:000		209.37889	2124121	16.272	90.61719
2018/09/25 12:31:00:000		209.10283	2127368	16.272	90.52468
2018/09/25 12:32:00:000		209.10283	2120561	16.272	90.52468
2018/09/25 12:33:00:000		209.10283	2122960.8	16.272	90.52468
2018/09/25 12:34:00:000		208.99284	2124505.8	16.272	90.43117
2018/09/25 12:35:00:000		208.99284	2123329	16.272	90.43117
2018/09/25 12:36:00:000		208.99284	2122994.2	16.263094	90.56219
2018/09/25 12:37:00:000		209.3272	2122991.8	16.263094	90.41248
2018/09/25 12:38:00:000		209.3272	2122479.8	16.263094	90.43365
2018/09/25 12:39:00:000		208.6839	2121392.8	16.263094	90.57236
2018/09/25 12:40:00:000		209.32439	2122519.8	16.263094	90.596375
2018/09/25 12:41:00:000		208.88614	2121176.5	16.263094	90.596954
2018/09/25 12:42:00:000		208.88614	2120491.8	16.263094	90.40294
2018/09/25 12:43:00:000		208.88614	2118828	16.263094	90.4937
2018/09/25 12:44:00:000		208.88614	2119872	16.263094	90.4937
2018/09/25 12:45:00:000		208.91225	2120845.8	16.263094	90.4937
2018/09/25 12:46:00:000		208.91225	2122788.8	16.263094	90.43784
2018/09/25 12:47:00:000		208.91225	2115861.8	16.263094	90.52432
2018/09/25 12:48:00:000		208.91225	2119957.2	16.263094	90.52432
2018/09/25 12:49:00:000		208.91225	2120038.2	16.263094	90.52432
2018/09/25 12:50:00:000		208.91225	2123920	16.263094	90.52432
2018/09/25 12:51:00:000		208.91225	2118409.2	16.263094	90.39606
2018/09/25 12:52:00:000		208.91225	2118540.8	16.263094	90.5195
2018/09/25 12:53:00:000		208.91225	2123854.5	16.263094	90.38455
2018/09/25 12:54:00:000		208.91225	2121080.8	16.263094	90.510666
2018/09/25 12:55:00:000		208.91225	2120025.8	16.263094	90.52342
2018/09/25 12:56:00:000		208.91225	2120026.2	16.263094	90.434
2018/09/25 12:57:00:000		208.91225	2121287.2	16.263094	90.2155
2018/09/25 12:58:00:000		208.69537	2119591	16.263094	90.40068
2018/09/25 12:59:00:000		208.69537	2118072	16.263094	90.54521
2018/09/25 13:00:00:000		208.96832	2119333.5	16.263094	90.5486
2018/09/25 13:01:00:000		208.96832	2120930.8	16.263094	90.488205
2018/09/25 13:02:00:000		208.96832	2119798.8	16.263094	90.488205
2018/09/25 13:03:00:000		208.96832	2120779	16.263094	90.488205
2018/09/25 13:04:00:000		208.96832	2118633	16.263094	90.41441
2018/09/25 13:05:00:000		208.96832	2120913.2	16.263094	90.41441
2018/09/25 13:06:00:000		208.69426	2121405.5	16.263094	90.47332
2018/09/25 13:07:00:000		208.69426	2121251.5	16.263094	90.47332
2018/09/25 13:08:00:000		208.69426	2119688.2	16.263094	90.47332
2018/09/25 13:09:00:000		208.69426	2117035.5	16.263094	90.52148
2018/09/25 13:10:00:000		208.69426	2117644.5	16.25145	90.52148
2018/09/25 13:11:00:000		208.81116	2117360.2	16.25145	90.3887
2018/09/25 13:12:00:000		208.81116	2115929	16.25145	90.60927
2018/09/25 13:13:00:000		208.81116	2116667	16.25145	90.4377
2018/09/25 13:14:00:000		208.81116	2118112.5	16.25145	90.37689
2018/09/25 13:15:00:000		208.81116	2115455.5	16.25145	90.37689
2018/09/25 13:16:00:000		208.81116	2120634.5	16.25145	90.44726
2018/09/25 13:17:00:000		208.81116	2118167.8	16.25145	90.44726
2018/09/25 13:18:00:000		208.81116	2116848	16.26926	90.15732
2018/09/25 13:19:00:000		208.40971	2115352.2	16.26926	90.3138
2018/09/25 13:20:00:000		208.65428	2116279.8	16.26926	90.379074
2018/09/25 13:21:00:000		208.65428	2116191.5	16.26926	90.241425
2018/09/25 13:22:00:000		208.2755	2116337.8	16.26926	90.39374
2018/09/25 13:23:00:000		208.2755	2113644.2	16.26926	90.39374

Site = SPPA-T3000-AGR

Time Range = 2018/09/25 00:00:00.000 to 2018/09/26 02:30:00.000

	Average	207.38	2109111.26	16.26	89.96
Time	CT MEGAWATT SELECT MW 12HAD00EU001 XQ04	VOLUMETRIC TOTAL GAS FLOW SCFH 12HAD00EU001 XQ27	HRSG2 DB NG FLOW1 KPPH 12HHA10CF001 XQ01	TOTAL GAS FUEL FLOW KPPH 12MBP10CF910 XQ07	
one hour from run time		208.26256	2115494.5	9.717435	90.182365
2018/09/25 13:57:00:000		208.19147	2117667	16.26515	90.14734
2018/09/25 13:58:00:000		208.19147	2116003.8	16.26515	90.14734
2018/09/25 13:59:00:000		208.19147	2117245.8	16.278164	90.14734
2018/09/25 14:00:00:000		208.19147	2114076.5	16.278164	90.14734
2018/09/25 14:01:00:000		207.64957	2114965.5	16.278164	90.14734
2018/09/25 14:02:00:000		207.64957	2112196.5	16.278164	90.14734
2018/09/25 14:03:00:000		207.99226	2115050.5	16.278164	90.14734
2018/09/25 14:04:00:000		207.99226	2117863.8	16.278164	90.10892
2018/09/25 14:05:00:000		207.99226	2111761	16.278164	90.081924
2018/09/25 14:06:00:000		207.99226	2110094.5	16.26789	90.081924
2018/09/25 14:07:00:000		207.21968	2106861.2	16.26789	89.975876
2018/09/25 14:08:00:000		207.62433	2111290.5	16.26789	89.975876
2018/09/25 14:09:00:000		207.62433	2111040	16.26789	89.975876
2018/09/25 14:10:00:000		207.62433	2113115.5	16.26789	89.975876
2018/09/25 14:11:00:000		207.62433	2109242	16.26789	90.01497
2018/09/25 14:12:00:000		207.9451	2109394.2	16.26789	89.83426
2018/09/25 14:13:00:000		207.62628	2112109.5	16.26789	89.88118
2018/09/25 14:14:00:000		207.62628	2108533	16.26515	89.984314
2018/09/25 14:15:00:000		207.62628	2111503.5	16.26515	89.88199
2018/09/25 14:16:00:000		207.62628	2107465	16.26515	90.097145
2018/09/25 14:17:00:000		207.45758	2108195	16.26515	90.222855
2018/09/25 14:18:00:000		206.94484	2109492	16.26515	90.17563
2018/09/25 14:19:00:000		207.48169	2107944.2	16.26515	90.17563
2018/09/25 14:20:00:000		207.48169	2111260.5	16.26515	90.22912
2018/09/25 14:21:00:000		207.48169	2107660.2	16.26515	90.22912
2018/09/25 14:22:00:000		207.48169	2112153.2	16.26515	90.08103
2018/09/25 14:23:00:000		207.48169	2111580	16.26515	90.08103
2018/09/25 14:24:00:000		207.48169	2108598.8	16.26515	90.08103
2018/09/25 14:25:00:000		207.48169	2112037.2	16.26515	90.08103
2018/09/25 14:26:00:000		207.48169	2112848.8	16.26515	90.08103
2018/09/25 14:27:00:000		207.14697	2111635.2	16.26515	90.10779
2018/09/25 14:28:00:000		207.14697	2110195	16.26515	90.066734
2018/09/25 14:29:00:000		207.14697	2109638.8	16.26515	89.86426
2018/09/25 14:30:00:000		207.41396	2108641.5	16.26515	89.919495
2018/09/25 14:31:00:000		207.08165	2104592.5	16.26515	89.919495
2018/09/25 14:32:00:000		207.08165	2105553.5	16.26515	89.919495
2018/09/25 14:33:00:000		207.32797	2106854	16.26515	89.78245
2018/09/25 14:34:00:000		207.32797	2105265.5	16.26515	89.908035
2018/09/25 14:35:00:000		207.32797	2110946.2	16.26515	89.908035
2018/09/25 14:36:00:000		207.32797	2104469.5	16.26515	89.908035
2018/09/25 14:37:00:000		206.86316	2104943.5	16.26515	90.11373
2018/09/25 14:38:00:000		207.40622	2106212	16.26515	89.95135
2018/09/25 14:39:00:000		207.40622	2105572.8	16.26515	89.76143
2018/09/25 14:40:00:000		206.96724	2106232.5	16.26515	89.7835
2018/09/25 14:41:00:000		206.96724	2106515.8	16.26515	89.7835
2018/09/25 14:42:00:000		206.96724	2104227.5	16.26515	89.7835
2018/09/25 14:43:00:000		206.96724	2106178	16.256245	89.7835
2018/09/25 14:44:00:000		206.96724	2106418	16.256245	89.8311
2018/09/25 14:45:00:000		206.96724	2108859.8	16.256245	89.72662
2018/09/25 14:46:00:000		206.96724	2106648.8	16.256245	89.72662
2018/09/25 14:47:00:000		206.96724	2108530.2	16.256245	89.72662
2018/09/25 14:48:00:000		206.96724	2108473.8	16.256245	89.72662
2018/09/25 14:49:00:000		206.96724	2103707.2	16.256245	89.72662
2018/09/25 14:50:00:000		206.96724	2100713	16.256245	89.72662
2018/09/25 14:51:00:000		206.96724	2106668.8	16.256245	89.697174
2018/09/25 14:52:00:000		206.96724	2105491	16.256245	89.77079
2018/09/25 14:53:00:000		206.96724	2105233.5	16.256245	89.77079
2018/09/25 14:54:00:000		206.96724	2110372	16.256245	89.8561
2018/09/25 14:55:00:000		206.96724	2102559.5	16.256245	89.82621
2018/09/25 14:56:00:000		206.96724	2106077.2	16.256245	90.04213

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
without Duct Burners Firing
NO_x, CO, VOC, CO₂, and O₂ Data**

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-2
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,052,599	SCFH
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,052,599	SCFH

Weather Data

Barometric Pressure	29.68	in. Hg
Relative Humidity	98	%
Ambient Temperature	58	°F
Specific Humidity	0.010141	lb H ₂ O / lb air

Unit Data

Unit Load	205.6	megawatts
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	49,960,821	SCFH

Base Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	THC (ppmw)	CO ₂ (%)
09/25/18 17:15:24	106920	13.40	1.96	0.61	2.18	4.05
09/25/18 17:16:24	106980	13.40	1.97	0.61	2.01	4.05
09/25/18 17:17:24	107040	13.40	2.01	0.63	2.06	4.05
09/25/18 17:18:24	107100	13.40	2.03	0.63	2.43	4.05
09/25/18 17:19:24	107160	13.41	2.02	0.62	2.40	4.05
09/25/18 17:20:24	107220	13.40	2.05	0.62	2.47	4.05
09/25/18 17:21:24	107280	13.41	2.03	0.63	2.19	4.06
09/25/18 17:22:24	107340	13.40	1.99	0.59	2.16	4.06
09/25/18 17:23:24	107400	13.39	2.02	0.66	2.15	4.05
09/25/18 17:24:24	107460	13.40	2.02	0.65	2.01	4.05
09/25/18 17:25:24	107520	13.41	2.07	0.58	1.88	4.05
09/25/18 17:26:24	107580	13.40	2.01	0.64	1.85	4.05
09/25/18 17:27:24	107640	13.41	2.01	0.64	1.72	4.05
09/25/18 17:28:24	107700	13.41	2.00	0.58	1.76	4.05
09/25/18 17:29:24	107760	13.40	2.03	0.62	1.90	4.06
09/25/18 17:30:24	107820	13.40	2.05	0.63	1.91	4.05
09/25/18 17:31:24	107880	13.42	2.01	0.67	1.99	4.05
09/25/18 17:32:24	107940	13.41	2.03	0.60	1.93	4.06
09/25/18 17:33:24	108000	13.41	2.05	0.60	1.73	4.05
09/25/18 17:34:24	108060	13.41	2.01	0.61	1.62	4.05
09/25/18 17:35:24	108120	13.41	2.11	0.61	1.61	4.06
09/25/18 17:36:24	108180	13.41	2.20	0.58	1.57	4.05
09/25/18 17:37:24	108240	13.41	2.11	0.59	1.45	4.05
09/25/18 17:38:24	108300	13.41	2.08	0.64	1.40	4.06
09/25/18 17:39:24	108360	13.40	2.08	0.62	1.38	4.05
09/25/18 17:40:24	108420	13.41	2.10	0.59	1.27	4.05
09/25/18 17:41:24	108480	13.41	2.10	0.59	1.32	4.06
09/25/18 17:42:24	108540	13.41	2.07	0.61	1.29	4.05
09/25/18 17:43:24	108600	13.41	2.04	0.63	1.25	4.05
09/25/18 17:44:24	108660	13.41	2.00	0.62	1.22	4.05
09/25/18 17:45:24	108720	13.41	2.05	0.60	0.80	4.06
09/25/18 17:46:24	108780	13.42	1.99	0.61	0.90	4.04
09/25/18 17:47:24	108840	13.40	2.06	0.60	0.98	4.06
09/25/18 17:48:24	108900	13.41	1.98	0.61	1.02	4.05
09/25/18 17:49:24	108960	13.39	2.03	0.56	1.15	4.06
09/25/18 17:50:24	109020	13.40	1.99	0.59	1.23	4.05
09/25/18 17:51:24	109080	13.39	1.99	0.60	1.09	4.06
09/25/18 17:52:24	109140	13.43	2.03	0.58	0.96	4.05
09/25/18 17:53:24	109200	13.39	1.97	0.60	1.01	4.05
09/25/18 17:54:24	109260	13.40	2.04	0.58	1.13	4.05
09/25/18 17:55:24	109320	13.41	2.05	0.60	1.16	4.05
09/25/18 17:56:24	109380	13.41	2.03	0.62	1.27	4.06
09/25/18 17:57:24	109440	13.41	1.98	0.60	1.35	4.06
09/25/18 17:58:24	109500	13.42	1.97	0.63	1.28	4.05
09/25/18 17:59:24	109560	13.41	1.95	0.65	0.61	4.06
09/25/18 18:00:24	109620	13.41	1.99	0.65	0.80	4.05
09/25/18 18:01:24	109680	13.40	1.98	0.62	0.86	4.06
09/25/18 18:02:24	109740	13.40	1.97	0.63	0.28	4.05
09/25/18 18:03:24	109800	13.41	1.96	0.61	0.55	4.05
09/25/18 18:04:24	109860	13.40	1.99	0.60	0.29	4.06
09/25/18 18:05:24	109920	13.40	2.01	0.60	0.50	4.06
09/25/18 18:06:24	109980	13.40	2.01	0.59	0.53	4.06
09/25/18 18:07:24	110040	13.41	1.99	0.66	0.56	4.05
09/25/18 18:08:24	110100	13.39	2.02	0.61	0.62	4.06
09/25/18 18:09:24	110160	13.39	2.11	0.62	0.77	4.05
09/25/18 18:10:24	110220	13.40	2.07	0.61	0.81	4.05
09/25/18 18:11:24	110280	13.40	2.00	0.59	1.05	4.05
09/25/18 18:12:24	110340	13.39	1.99	0.58	0.88	4.06
09/25/18 18:13:24	110400	13.40	2.01	0.63	0.71	4.06
09/25/18 18:14:24	110460	13.41	1.99	0.62	0.66	4.06
RAW AVERAGE		13.40	2.02	0.61	1.33	4.05

Bias	Serial Number:	O ₂	NOx	CO	THC	CO ₂
		(%)	(ppmvd)	(ppmvd)	(ppmw)	(%)
	INST-O2-0017	0.09	-0.04	0.38	0.02	-0.04
	INST-NX-0043	0.10	0.11	0.32	-0.11	-0.03
	INST-CO-0018	0.10	0.04	0.35	-0.05	-0.04
	INST-TH-0009					
	INST-C2-0018					
	Initial UpScale	11.97	5.58	5.87	3.00	8.82
	Final UpScale	11.94	5.48	5.80	3.09	8.78
	Avg. UpScale	11.96	5.53	5.84	3.05	8.80
	Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92

EMISSIONS DATA	O ₂	NOx	CO	THC	CO ₂
Corrected Raw Average (ppm/% dry basis)	13.44	2.00	0.27	1.46	4.13
Concentration (ppm@15%O ₂)	N/A	1.58	0.22	1.15	N/A

Non-Bias Adjusted Averages Include:

CH ₄ (as CH ₄)	C ₂ H ₆ (as CH ₄)	VOC (as CH ₄)
2.00	0.10	0.00
N/A	N/A	0.00

Note: Reported at RDL

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-2
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,091,966	SCFH
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,091,966	SCFH

Weather Data

Barometric Pressure	29.66	in. Hg
Relative Humidity	98	%
Ambient Temperature	58	°F
Specific Humidity	0.010148	lb H ₂ O / lb air

Unit Data

Unit Load	205.5	megawatts
Meas. Stack Moisture	9.4	%
Stack Exhaust Flow (M19)	50,933,540	SCFH

Base Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	THC (ppmw)	CO ₂ (%)
09/25/18 18:44:24	112260	13.38	1.99	0.57	2.57	4.05
09/25/18 18:45:24	112320	13.38	2.02	0.58	2.53	4.05
09/25/18 18:46:24	112380	13.38	2.01	0.61	2.46	4.05
09/25/18 18:47:24	112440	13.38	1.99	0.60	2.45	4.06
09/25/18 18:48:24	112500	13.39	1.97	0.57	2.47	4.06
09/25/18 18:49:24	112560	13.39	2.00	0.59	2.40	4.05
09/25/18 18:50:24	112620	13.39	2.03	0.56	2.43	4.05
09/25/18 18:51:24	112680	13.39	2.00	0.56	2.50	4.05
09/25/18 18:52:24	112740	13.38	1.98	0.59	2.64	4.05
09/25/18 18:53:24	112800	13.41	2.05	0.59	2.61	4.05
09/25/18 18:54:24	112860	13.37	1.99	0.61	2.58	4.05
09/25/18 18:55:24	112920	13.38	2.00	0.65	2.62	4.06
09/25/18 18:56:24	112980	13.39	2.03	0.63	2.57	4.05
09/25/18 18:57:24	113040	13.40	2.05	0.62	2.45	4.05
09/25/18 18:58:24	113100	13.39	2.01	0.61	2.39	4.06
09/25/18 18:59:24	113160	13.40	2.00	0.59	2.45	4.05
09/25/18 19:00:24	113220	13.39	2.04	0.62	2.38	4.05
09/25/18 19:01:24	113280	13.39	2.01	0.60	2.46	4.05
09/25/18 19:02:24	113340	13.39	2.02	0.59	2.63	4.06
09/25/18 19:03:24	113400	13.39	2.01	0.58	2.73	4.05
09/25/18 19:04:24	113460	13.38	2.13	0.56	2.91	4.06
09/25/18 19:05:24	113520	13.39	2.32	0.53	2.90	4.04
09/25/18 19:06:24	113580	13.39	2.19	0.53	2.72	4.05
09/25/18 19:07:24	113640	13.38	2.10	0.52	2.63	4.06
09/25/18 19:08:24	113700	13.38	2.05	0.50	2.58	4.06
09/25/18 19:09:24	113760	13.39	1.99	0.52	2.49	4.06
09/25/18 19:10:24	113820	13.39	2.02	0.52	2.56	4.06
09/25/18 19:11:24	113880	13.38	1.96	0.53	2.51	4.06
09/25/18 19:12:24	113940	13.38	1.97	0.55	2.69	4.06
09/25/18 19:13:24	114000	13.38	1.95	0.53	2.53	4.06
09/25/18 19:14:24	114060	13.39	2.01	0.55	2.46	4.06
09/25/18 19:15:24	114120	13.39	2.07	0.57	2.57	4.06
09/25/18 19:16:24	114180	13.39	2.07	0.55	2.69	4.06
09/25/18 19:17:24	114240	13.38	2.06	0.57	2.84	4.06
09/25/18 19:18:24	114300	13.39	2.10	0.56	3.11	4.06
09/25/18 19:19:24	114360	13.39	2.13	0.56	3.10	4.06
09/25/18 19:20:24	114420	13.39	2.02	0.57	2.96	4.05
09/25/18 19:21:24	114480	13.38	2.05	0.58	2.67	4.06
09/25/18 19:22:24	114540	13.38	2.04	0.60	2.39	4.06
09/25/18 19:23:24	114600	13.39	2.01	0.59	2.30	4.06
09/25/18 19:24:24	114660	13.38	1.97	0.61	2.31	4.06
09/25/18 19:25:24	114720	13.39	2.08	0.59	2.30	4.06
09/25/18 19:26:24	114780	13.39	2.11	0.60	2.23	4.06
09/25/18 19:27:24	114840	13.39	2.07	0.60	2.17	4.05
09/25/18 19:28:24	114900	13.39	2.08	0.60	2.25	4.06
09/25/18 19:29:24	114960	13.39	2.19	0.63	2.19	4.05
09/25/18 19:30:24	115020	13.39	2.14	0.59	2.12	4.05
09/25/18 19:31:24	115080	13.39	2.02	0.59	2.27	4.05
09/25/18 19:32:24	115140	13.39	2.11	0.58	2.24	4.06
09/25/18 19:33:24	115200	13.39	2.11	0.54	2.40	4.05
09/25/18 19:34:24	115260	13.39	2.06	0.59	2.48	4.05
09/25/18 19:35:24	115320	13.40	2.05	0.58	2.47	4.06
09/25/18 19:36:24	115380	13.39	2.04	0.59	2.49	4.06
09/25/18 19:37:24	115440	13.40	2.03	0.58	2.35	4.05
09/25/18 19:38:24	115500	13.38	2.00	0.60	2.33	4.05
09/25/18 19:39:24	115560	13.40	2.04	0.58	2.32	4.06
09/25/18 19:40:24	115620	13.39	2.00	0.57	2.51	4.06
09/25/18 19:41:24	115680	13.39	1.99	0.59	2.29	4.06
09/25/18 19:42:24	115740	13.39	1.99	0.57	2.16	4.05
09/25/18 19:43:24	115800	13.39	2.05	0.58	2.23	4.06

RAW AVERAGE

13.39 2.04 0.58 2.50 4.05

Bias	Serial Number:	O ₂	NOx	CO	THC	CO ₂	
		(%)	(ppmvd)	(ppmvd)	(ppmw)	(%)	
		INST-O2-0017	0.10	0.11	0.32	-0.11	-0.03
		INST-NX-0043	0.12	0.06	0.34	0.18	-0.03
INST-CO-0018	0.11	0.09	0.33	0.04	-0.03		
Upscale	INST-TH-0009	11.94	5.48	5.80	3.09	8.78	
	INST-C2-0018	11.94	5.56	5.83	3.06	8.78	
	Final UpScale	11.94	5.52	5.82	3.08	8.78	
	Avg. UpScale	11.94	5.52	5.82	3.08	8.78	

Upscale Cal Gas

11.98 5.53 5.73 3.08 8.92

EMISSIONS DATA		O ₂	NOx	CO	THC	CO ₂
Corrected Raw Average (ppm% dry basis)		13.45	1.99	0.26	2.76	4.14
Concentration (ppm@ 15%O ₂)		N/A	1.58	0.21	2.18	N/A

Non-Bias Adjusted Averages Include:

CH ₄	C ₂ H ₆	VOC
(as CH ₄)	(as CH ₄)	(as CH ₄)
2.00	0.10	0.66
N/A	N/A	0.52

Note: Reported at RDL

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
with Duct Burners Firing
NO_x, CO, VOC, CO₂, and O₂ Data**

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-2
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,129,501	SCFH
Duct Burner Fuel Flow	271	lb/min
Total Fuel Flow	2,512,210	SCFH

Weather Data

Barometric Pressure	29.78	in. Hg
Relative Humidity	97	%
Ambient Temperature	52	° F
Specific Humidity	0.008014	lb H ₂ O / lb air

Unit Data

Unit Load	210.7	megawatts
Meas. Stack Moisture	10.2	%
Stack Exhaust Flow (M19)	50,847.815	SCFH

100% W/Db Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)	THC (ppmvw)	CO ₂ (%)
09/25/18 09:25:24	78720	12.01	2.44	0.62	1.81	4.92
09/25/18 09:26:24	78780	12.02	2.46	0.61	1.75	4.91
09/25/18 09:27:24	78840	12.04	2.40	0.62	1.71	4.91
09/25/18 09:28:24	78900	12.01	2.41	0.61	1.69	4.91
09/25/18 09:29:24	78960	12.01	2.50	0.62	1.65	4.91
09/25/18 09:30:24	79020	12.03	2.48	0.63	1.46	4.91
09/25/18 09:31:24	79080	12.00	2.54	0.62	1.50	4.92
09/25/18 09:32:24	79140	12.01	2.60	0.64	1.47	4.92
09/25/18 09:33:24	79200	12.02	2.44	0.62	1.62	4.92
09/25/18 09:34:24	79260	12.00	2.46	0.61	1.81	4.92
09/25/18 09:35:24	79320	12.02	2.47	0.62	1.86	4.91
09/25/18 09:36:24	79380	12.02	2.47	0.64	1.63	4.91
09/25/18 09:37:24	79440	12.00	2.43	0.61	1.78	4.92
09/25/18 09:38:24	79500	12.02	2.46	0.63	1.60	4.92
09/25/18 09:39:24	79560	12.00	2.39	0.64	1.64	4.91
09/25/18 09:40:24	79620	12.00	2.48	0.61	1.37	4.92
09/25/18 09:41:24	79680	12.01	2.52	0.60	1.60	4.91
09/25/18 09:42:24	79740	12.02	2.37	0.64	1.71	4.91
09/25/18 09:43:24	79800	12.00	2.36	0.59	1.73	4.91
09/25/18 09:44:24	79860	12.01	2.39	0.59	1.62	4.91
09/25/18 09:45:24	79920	12.02	2.38	0.59	1.67	4.91
09/25/18 09:46:24	79980	12.00	2.35	0.62	1.53	4.91
09/25/18 09:47:24	80040	12.02	2.39	0.64	1.87	4.91
09/25/18 09:48:24	80100	12.02	2.37	0.61	1.98	4.91
09/25/18 09:49:24	80160	12.00	2.34	0.61	1.73	4.91
09/25/18 09:50:24	80220	12.00	2.38	0.60	1.75	4.91
09/25/18 09:51:24	80280	12.00	2.44	0.61	1.78	4.91
09/25/18 09:52:24	80340	12.01	2.46	0.59	1.57	4.92
09/25/18 09:53:24	80400	12.01	2.49	0.60	1.47	4.91
09/25/18 09:54:24	80460	12.01	2.43	0.64	1.69	4.91
09/25/18 09:55:24	80520	12.02	2.48	0.62	1.76	4.91
09/25/18 09:56:24	80580	12.02	2.37	0.61	1.66	4.91
09/25/18 09:57:24	80640	12.01	2.44	0.63	1.38	4.91
09/25/18 09:58:24	80700	12.01	2.48	0.62	1.51	4.91
09/25/18 09:59:24	80760	12.02	2.47	0.59	1.65	4.91
09/25/18 10:00:24	80820	12.01	2.41	0.61	1.43	4.91
09/25/18 10:01:24	80880	12.00	2.45	0.60	1.49	4.91
09/25/18 10:02:24	80940	12.00	2.42	0.62	1.47	4.91
09/25/18 10:03:24	81000	12.00	2.39	0.60	1.41	4.92
09/25/18 10:04:24	81060	12.01	2.43	0.59	1.51	4.91
09/25/18 10:05:24	81120	12.00	2.46	0.59	1.53	4.91
09/25/18 10:06:24	81180	12.01	2.43	0.60	1.45	4.91
09/25/18 10:07:24	81240	12.02	2.47	0.60	1.43	4.90
09/25/18 10:08:24	81300	11.99	2.42	0.59	1.80	4.91
09/25/18 10:09:24	81360	12.00	2.43	0.62	1.81	4.91
09/25/18 10:10:24	81420	12.01	2.44	0.59	1.35	4.91
09/25/18 10:11:24	81480	11.99	2.52	0.61	1.55	4.92
09/25/18 10:12:24	81540	12.00	2.48	0.64	1.61	4.92
09/25/18 10:13:24	81600	12.02	2.44	0.58	1.80	4.91
09/25/18 10:14:24	81660	12.01	2.45	0.61	1.64	4.91
09/25/18 10:15:24	81720	12.00	2.45	0.61	1.59	4.91
09/25/18 10:16:24	81780	12.00	2.42	0.60	1.50	4.91
09/25/18 10:17:24	81840	12.01	2.43	0.61	1.38	4.91
09/25/18 10:18:24	81900	12.00	2.47	0.64	1.37	4.91
09/25/18 10:19:24	81960	12.01	2.44	0.66	1.76	4.91
09/25/18 10:20:24	82020	12.00	2.41	0.61	1.78	4.90
09/25/18 10:21:24	82080	12.00	2.43	0.62	1.78	4.91
09/25/18 10:22:24	82140	12.01	2.42	0.62	1.56	4.91
09/25/18 10:23:24	82200	12.00	2.50	0.61	1.76	4.91
09/25/18 10:24:24	82260	12.01	2.46	0.61	2.08	4.91

RAW AVERAGE

12.01 2.44 0.61 1.63 4.91

Serial Number:	O ₂	NO _x	CO	THC	CO ₂
	(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
Initial Zero	0.09	0.00	0.07	0.01	-0.02
Final Zero	0.09	0.01	0.33	0.11	0.03
Avg. Zero	0.09	0.01	0.20	0.06	0.01
Initial UpScale	12.07	5.58	5.74	2.94	8.99
Final UpScale	12.04	5.51	5.79	2.98	8.92
Avg. UpScale	12.06	5.55	5.77	2.96	8.96
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92

EMISSIONS DATA	O ₂	NO _x	CO	THC	CO ₂
Corrected Raw Average (ppm/% dry basis)	11.93	2.43	0.42	1.81	4.89
Concentration (ppm@ 15%O ₂)	N/A	1.60	0.28	1.19	N/A

Non-Bias Adjusted Averages Include:

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-2
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,119,978	SCFH
Duct Burner Fuel Flow	271	lb/min
Total Fuel Flow	2,502,922	SCFH

Weather Data

Barometric Pressure	29.78	in. Hg
Relative Humidity	97	%
Ambient Temperature	53	° F
Specific Humidity	0.008318	lb H ₂ O / lb air

Unit Data

Unit Load	209.5	megawatts
Meas. Stack Moisture	11.0	%
Stack Exhaust Flow (M19)	50,755,979	SCFH

100% W/Db Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)	THC (ppmvw)	CO ₂ (%)
09/25/18 11:24:24	85860	11.99	2.48	0.61	2.77	4.90
09/25/18 11:25:24	85920	11.98	2.50	0.59	2.45	4.90
09/25/18 11:26:24	85980	11.99	2.54	0.61	2.57	4.90
09/25/18 11:27:24	86040	12.00	2.52	0.61	2.63	4.89
09/25/18 11:28:24	86100	11.99	2.50	0.65	3.03	4.90
09/25/18 11:29:24	86160	11.99	2.47	0.63	3.15	4.90
09/25/18 11:30:24	86220	12.00	2.49	0.58	3.07	4.90
09/25/18 11:31:24	86280	11.97	2.48	0.62	3.17	4.91
09/25/18 11:32:24	86340	11.99	2.49	0.61	3.25	4.90
09/25/18 11:33:24	86400	11.99	2.51	0.62	3.14	4.91
09/25/18 11:34:24	86460	11.98	2.51	0.61	2.98	4.91
09/25/18 11:35:24	86520	11.98	2.49	0.60	2.91	4.90
09/25/18 11:36:24	86580	12.00	2.51	0.63	2.88	4.90
09/25/18 11:37:24	86640	11.99	2.48	0.65	2.67	4.90
09/25/18 11:38:24	86700	11.99	2.52	0.58	2.71	4.90
09/25/18 11:39:24	86760	11.99	2.47	0.63	2.74	4.90
09/25/18 11:40:24	86820	12.00	2.55	0.63	2.43	4.90
09/25/18 11:41:24	86880	11.99	2.46	0.59	2.07	4.89
09/25/18 11:42:24	86940	11.99	2.47	0.59	2.34	4.90
09/25/18 11:43:24	87000	12.00	2.44	0.58	2.51	4.90
09/25/18 11:44:24	87060	11.99	2.52	0.60	2.53	4.90
09/25/18 11:45:24	87120	11.99	2.45	0.61	2.80	4.90
09/25/18 11:46:24	87180	11.98	2.51	0.58	2.78	4.90
09/25/18 11:47:24	87240	12.00	2.42	0.60	2.72	4.89
09/25/18 11:48:24	87300	11.99	2.44	0.61	2.57	4.91
09/25/18 11:49:24	87360	11.99	2.44	0.58	2.47	4.90
09/25/18 11:50:24	87420	11.99	2.51	0.62	2.52	4.93
09/25/18 11:51:24	87480	11.98	2.46	0.60	2.41	4.90
09/25/18 11:52:24	87540	12.00	2.56	0.59	2.38	4.90
09/25/18 11:53:24	87600	11.99	2.49	0.61	2.27	4.90
09/25/18 11:54:24	87660	11.98	2.51	0.61	1.97	4.90
09/25/18 11:55:24	87720	11.99	2.48	0.60	1.95	4.90
09/25/18 11:56:24	87780	11.98	2.50	0.62	1.95	4.90
09/25/18 11:57:24	87840	12.00	2.48	0.62	1.98	4.90
09/25/18 11:58:24	87900	11.98	2.48	0.60	2.00	4.90
09/25/18 11:59:24	87960	11.99	2.42	0.59	2.01	4.89
09/25/18 12:00:24	88020	11.99	2.41	0.58	2.21	4.90
09/25/18 12:01:24	88080	11.99	2.44	0.58	2.03	4.89
09/25/18 12:02:24	88140	11.99	2.41	0.60	2.00	4.89
09/25/18 12:03:24	88200	11.98	2.48	0.58	2.04	4.90
09/25/18 12:04:24	88260	11.98	2.48	0.58	1.80	4.90
09/25/18 12:05:24	88320	11.98	2.50	0.57	1.96	4.90
09/25/18 12:06:24	88380	11.98	2.48	0.55	1.91	4.90
09/25/18 12:07:24	88440	11.98	2.48	0.60	1.65	4.90
09/25/18 12:08:24	88500	11.99	2.43	0.56	1.86	4.89
09/25/18 12:09:24	88560	11.99	2.42	0.57	1.83	4.89
09/25/18 12:10:24	88620	11.99	2.43	0.58	1.74	4.90
09/25/18 12:11:24	88680	11.98	2.50	0.59	1.60	4.90
09/25/18 12:12:24	88740	11.98	2.57	0.58	1.70	4.89
09/25/18 12:13:24	88800	11.98	2.64	0.58	1.75	4.89
09/25/18 12:14:24	88860	11.98	2.48	0.59	1.62	4.90
09/25/18 12:15:24	88920	11.98	2.51	0.58	1.90	4.90
09/25/18 12:16:24	88980	12.00	2.53	0.57	1.89	4.89
09/25/18 12:17:24	89040	11.98	2.56	0.58	1.52	4.89
09/25/18 12:18:24	89100	11.97	2.52	0.56	1.67	4.90
09/25/18 12:19:24	89160	11.98	2.57	0.54	1.79	4.89
09/25/18 12:20:24	89220	11.97	2.48	0.55	1.76	4.89
09/25/18 12:21:24	89280	11.97	2.46	0.56	1.63	4.90
09/25/18 12:22:24	89340	11.98	2.47	0.56	1.43	4.90
09/25/18 12:23:24	89400	11.98	2.44	0.58	1.51	4.89

RAW AVERAGE

11.99 2.49 0.59 2.26 4.90

Serial Number:	O ₂	NO _x	CO	THC	CO ₂
	(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
Initial Zero	0.09	0.01	0.33	0.11	0.03
Final Zero	0.08	0.01	0.35	0.28	-0.03
Avg. Zero	0.09	0.01	0.34	0.20	0.00
Initial UpScale	12.04	5.51	5.79	2.98	8.92
Final UpScale	11.99	5.48	5.80	2.72	8.86
Avg. UpScale	12.02	5.50	5.80	2.85	8.89
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92

EMISSIONS DATA	O ₂	NO _x	CO	THC	CO ₂
Corrected Raw Average (ppm/% dry basis)	11.95	2.50	0.27	2.54	4.92
Concentration (ppm@ 15%O ₂)	N/A	1.65	0.18	1.67	N/A

Non-Bias Adjusted Averages Include:

CPV Valley, LLC
September 25, 2018
Siemens, SCC6-5000F, Unit #CTG-2
CPV Valley Energy Center

Fuel Data

Fuel Fd factor	8.632	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,006	Btu/SCF fuel
Turbine Fuel Flow	2,109,939	SCFH
Duct Burner Fuel Flow	271	lb/min
Total Fuel Flow	2,493,119	SCFH

Weather Data

Barometric Pressure	29.75	in. Hg
Relative Humidity	97	%
Ambient Temperature	54	° F
Specific Humidity	0.008642	lb H ₂ O / lb air

Unit Data

Unit Load	208.6	megawatts
Meas. Stack Moisture	11.3	%
Stack Exhaust Flow (M19)	50,611,217	SCFH

100% W/Db Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)	THC (ppmvw)	CO ₂ (%)
09/25/18 12:57:24	91440	11.97	2.59	0.57	1.97	4.89
09/25/18 12:58:24	91500	11.97	2.49	0.59	2.03	4.89
09/25/18 12:59:24	91560	11.96	2.48	0.53	2.03	4.89
09/25/18 13:00:24	91620	11.97	2.56	0.55	1.88	4.89
09/25/18 13:01:24	91680	11.96	2.45	0.54	1.97	4.90
09/25/18 13:02:24	91740	11.97	2.51	0.56	1.87	4.89
09/25/18 13:03:24	91800	11.97	2.46	0.58	1.74	4.89
09/25/18 13:04:24	91860	11.98	2.49	0.56	1.76	4.89
09/25/18 13:05:24	91920	11.97	2.49	0.58	1.46	4.89
09/25/18 13:06:24	91980	11.95	2.52	0.56	1.62	4.90
09/25/18 13:07:24	92040	11.96	2.53	0.58	1.62	4.89
09/25/18 13:08:24	92100	11.95	2.56	0.57	1.59	4.89
09/25/18 13:09:24	92160	11.97	2.50	0.56	1.49	4.89
09/25/18 13:10:24	92220	11.97	2.60	0.56	1.42	4.89
09/25/18 13:11:24	92280	11.96	2.51	0.56	1.55	4.89
09/25/18 13:12:24	92340	11.97	2.55	0.56	1.65	4.88
09/25/18 13:13:24	92400	11.96	2.53	0.62	1.40	4.89
09/25/18 13:14:24	92460	11.96	2.59	0.58	1.55	4.88
09/25/18 13:15:24	92520	11.96	2.52	0.56	1.65	4.89
09/25/18 13:16:24	92580	11.96	2.49	0.58	1.42	4.89
09/25/18 13:17:24	92640	11.97	2.50	0.55	1.50	4.89
09/25/18 13:18:24	92700	11.95	2.53	0.56	1.57	4.89
09/25/18 13:19:24	92760	11.97	2.43	0.57	1.68	4.88
09/25/18 13:20:24	92820	11.97	2.47	0.57	1.40	4.89
09/25/18 13:21:24	92880	11.96	2.51	0.57	1.45	4.89
09/25/18 13:22:24	92940	11.95	2.49	0.56	1.55	4.89
09/25/18 13:23:24	93000	11.96	2.53	0.59	1.54	4.89
09/25/18 13:24:24	93060	11.95	2.49	0.57	1.62	4.88
09/25/18 13:25:24	93120	11.96	2.49	0.56	1.58	4.88
09/25/18 13:26:24	93180	11.96	2.52	0.60	1.49	4.88
09/25/18 13:27:24	93240	11.93	2.55	0.58	1.65	4.89
09/25/18 13:28:24	93300	11.94	2.51	0.56	1.55	4.88
09/25/18 13:29:24	93360	11.94	2.47	0.58	1.58	4.89
09/25/18 13:30:24	93420	11.96	2.50	0.62	1.59	4.89
09/25/18 13:31:24	93480	11.95	2.47	0.58	1.19	4.89
09/25/18 13:32:24	93540	11.95	2.47	0.57	1.18	4.89
09/25/18 13:33:24	93600	11.95	2.50	0.57	1.41	4.89
09/25/18 13:34:24	93660	11.95	2.47	0.59	1.47	4.88
09/25/18 13:35:24	93720	11.96	2.57	0.57	1.44	4.89
09/25/18 13:36:24	93780	11.95	2.44	0.54	1.52	4.89
09/25/18 13:37:24	93840	11.95	2.47	0.57	1.71	4.88
09/25/18 13:38:24	93900	11.97	2.52	0.60	1.52	4.88
09/25/18 13:39:24	93960	11.95	2.48	0.56	1.39	4.88
09/25/18 13:40:24	94020	11.94	2.50	0.57	1.67	4.89
09/25/18 13:41:24	94080	11.94	2.51	0.58	1.77	4.88
09/25/18 13:42:24	94140	11.96	2.50	0.56	1.36	4.88
09/25/18 13:43:24	94200	11.95	2.50	0.59	1.66	4.88
09/25/18 13:44:24	94260	11.95	2.41	0.57	1.66	4.88
09/25/18 13:45:24	94320	11.95	2.47	0.58	1.35	4.88
09/25/18 13:46:24	94380	11.95	2.48	0.61	1.54	4.89
09/25/18 13:47:24	94440	11.93	2.53	0.55	1.56	4.89
09/25/18 13:48:24	94500	11.95	2.50	0.56	1.59	4.88
09/25/18 13:49:24	94560	11.95	2.47	0.55	1.57	4.89
09/25/18 13:50:24	94620	11.94	2.52	0.55	1.18	4.89
09/25/18 13:51:24	94680	11.96	2.48	0.63	1.06	4.88
09/25/18 13:52:24	94740	11.96	2.50	0.58	1.47	4.88
09/25/18 13:53:24	94800	11.96	2.47	0.60	1.62	4.87
09/25/18 13:54:24	94860	11.94	2.49	0.59	1.78	4.88
09/25/18 13:55:24	94920	11.96	2.51	0.56	1.69	4.88
09/25/18 13:56:24	94980	11.95	2.49	0.60	1.43	4.89

RAW AVERAGE

11.96 2.50 0.57 1.57 4.89

Serial Number:	O ₂	NO _x	CO	THC	CO ₂
	(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
INST-O2-0017	0.08	0.01	0.35	0.28	-0.03
INST-NX-0043	0.05	-0.03	0.32	0.12	-0.04
INST-CO-0018	0.07	-0.01	0.34	0.20	-0.04
INST-TH-0009					
INST-C2-0018					
Bias					
Initial UpScale	11.99	5.48	5.80	2.72	8.86
Final UpScale	11.96	5.51	5.81	2.89	8.80
Avg. UpScale	11.98	5.50	5.81	2.81	8.83

Upscale Cal Gas

11.98 5.53 5.73 3.08 8.92

EMISSIONS DATA	O ₂	NO _x	CO	THC	CO ₂
Corrected Raw Average (ppm/% dry basis)	11.96	2.52	0.25	1.77	4.95
Concentration (ppm@ 15%O ₂)	N/A	1.67	0.16	1.17	N/A

Non-Bias Adjusted Averages Include:

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
without Duct Burners Firing
Opacity Data**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940


Process: Unit # Operating Mode
 CTG-2 Base Load
 Control Equipment: Operating Mode
 Base Load

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start clear End clear
 Emission Color Water Droplet Plume
 Start clear End clear Start none End none

Describe Plume Background
 Start cloudy End cloudy
 Background Color Sky Conditions
 Start white/gray End white/gray Start Broken End Broken
 Wind Speed Wind Direction
 Start 10mph End 12mph Start ESE End E
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 60°F End 61°F 72%

Source Layout Sketch
 Draw North Arrow

 Latitude: 41.416 Longitude: -74.4362 Declination: _____

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 2
 sle-18-middletown.ny-start#1

Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time					
9/24/18		11:15am	12:15pm					
Min.	Sec.	0	15	30	45	Comments		
1		0	0	0	0			
2		0	0	0	0			
3		0	0	0	0			
4		0	0	0	0			
5		0	0	0	0			
6		0	0	0	0			
7		0	0	0	0			
8		0	0	0	0			
9		0	0	0	0			
10		0	0	0	0			
11		0	0	0	0			
12		0	0	0	0			
13		0	0	0	0			
14		0	0	0	0			
15		0	0	0	0			
16		0	0	0	0			
17		0	0	0	0			
18		0	0	0	0			
19		0	0	0	0			
20		0	0	0	0			
21		0	0	0	0			
22		0	0	0	0			
23		0	0	0	0			
24		0	0	0	0			
25		0	0	0	0			
26		0	0	0	0			
27		0	0	0	0			
28		0	0	0	0			
29		0	0	0	0			
30		0	0	0	0			

Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: _____ Date: 09/24/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc. Date: 07/06/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 2
sie-18-middletown.ny-start#1

Company Name CPV Valley LLC
 Facility Name CPV Valley Energy Center
 Street Address 3330 US Route 6
 City Middletown State NY Zip 10940

Continued on Form Number (AHI Project Code)

Observation Date 9/24/18 Time Zone _____ Start Time 11:15am End Time 12:15pm

Process Unit # Operating Mode
CTG-2 Base Load
 Control Equipment Operating Mode
Base Load


Min. Sec	Time Zone				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Point
 Height of Emiss. Pt. _____ Height of Emiss. Pt. Rel. to Observer _____
 Start _____ End _____ Start _____ End _____
 Distance to Emiss. Pt. _____ Direction to Emiss. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____

Vertical Angle to Obs. Pt. _____ Direction to Obs. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____
 Distance and Direction to Observation Point from Emission Point _____
 Start _____ End _____

Describe Emissions
 Start clear End clear
 Emission Color clear Water Droplet Plume none
 Start clear End clear Start none End none

Describe Plume Background
 Start cloudy End cloudy
 Background Color white/gray Sky Conditions broken
 Start white/gray End white/gray Start broken End broken
 Wind Speed _____ Wind Direction ESE End E
 Start _____ End _____ Start _____ End _____
 Ambient Temp. 60°F Wet Bulb Temp. 72%
 Start _____ End 61°F RH Percent _____



Observer's Name (Print) Axel Carrido-Martinez
 Observer's Signature _____ Date 09/24/18
 Organization Air Hygiene International, Inc.
 Certified By Compliance Assurance Associates, Inc. Date 07/06/18

Additional Information

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940

Process: Unit # Operating Mode
 CTG-2 Base Load
 Control Equipment: Operating Mode
 Base Load

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: clear End: clear
 Emission Color: Water Droplet Plume
 Start: clear End: clear Start: none End: none

Describe Plume Background
 Start: cloudy End: cloudy
 Background Color: Sky Conditions
 Start: white/gray End: white/gray Start: Broken End: Broken
 Wind Speed: Wind Direction
 Start: 11 mph End: 11 mph Start: ENE End: E
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start: 61°F End: 62°F 72%

Source Layout Sketch
 Draw North Arrow
 TN MN
 FEET
 FEET
 Side View
 Stack with Plume
 Sun
 Wind
 Latitude: 41.4068 Longitude: -74.4305 Declination:
 Emissions Point
 Observer
 140°
 Sun Location Line

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 2
 sie-18-middletown.ny-start#1

Continued on Form Number (AHI Project Code)

Observation Date: 9/24/18 Time Zone: Start Time: 12:30 pm End Time: 1:30 pm

Min	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Axel Garrido-Marinero
 Observer's Signature: [Signature] Date: 09/24/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc. Date: 07/06/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10840

Form Number (AHI Project Code): sie-18-middletown.ny-start#1
 Page 2 of 2
 Continued on Form Number (AHI Project Code):

Process: Unit # Operating Mode
 CTG-2 Base Load
 Control Equipment: Operating Mode
 Base Load

Observation Date: Time Zone: Start Time: 12:30 pm End Time: 1:30 pm


Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start clear End clear
 Emission Color Water Droplet Plume
 Start clear End clear Start none End none

Describe Plume Background
 Start cloudy End Cloudy
 Background Color Sky Conditions
 Start white/gray End white/gray Start Broken End Broken
 Wind Speed Wind Direction
 Start 11 mph End 11 mph Start ENE End E
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 61°F End 62°F 72%



Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: [Signature] Date: 09/24/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc. Date: 07/06/18

Additional Information

Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) **sie-18-middletown.ny-start#1** Page **1** of **2**

Company Name **CPV Valley LLC**
 Facility Name **CPV Valley Energy Center**
 Street Address **3330 US Route 6**
 City **Middletown** State **NY** Zip **10940**

Continued on Form Number (AHI Project Code)

Process **CTG-2** Unit # **CTG-2** Operating Mode **Base Load**
 Control Equipment **Base Load** Operating Mode **Base Load**

Observation Date **9/24/18** Time Zone _____ Start Time **1:45pm** End Time **2:45pm**

Describe Emissions Point
 Height of Emiss. Pt. **Start** _____ **End** _____ Height of Emiss. Pt. Rel. to Observer **Start** _____ **End** _____
 Distance to Emiss. Pt. **Start** _____ **End** _____ Direction to Emiss. Pt. (Degrees) **Start** _____ **End** _____

Min.	Sec.	0	15	30	45	Comments
------	------	---	----	----	----	----------

Vertical Angle to Obs. Pt. **Start** _____ **End** _____ Direction to Obs. Pt. (Degrees) **Start** _____ **End** _____
 Distance and Direction to Observation Point from Emission Point **Start** _____ **End** _____

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions **Start Clear** **End Clear**
 Emission Color **Start Clear** **End Clear** **Start none** **End none**

Describe Plume Background **Start cloudy** **End cloudy**
 Background Color **Start white/gray** **End white/gray** Sky Conditions **Start Broken** **End Broken**
 Wind Speed **Start 11mph** **End 10mph** Wind Direction **Start E** **End E**
 Ambient Temp. **Start 61°F** **End 61°F** Wet Bulb Temp. _____ RH Percent **74%**

Source Layout Sketch Draw North Arrow

Latitude **41.4068** Longitude **-74.4305** Declination _____

Observer's Name (Print) **Axel Garrido-Martinez**
 Observer's Signature _____ Date **9/24/18**
 Organization **Air Hygiene International, Inc.**
 Certified By **Compliance Assurance Associates, Inc.** Date **7/06/18**

Additional Information

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940

Process: Unit # Operating Mode
 CTG-2 Base Load
 Control Equipment: Operating Mode
 Base Load

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: clear End: clear
 Emission Color: Water Droplet Plume
 Start: clear End: clear Start: none End: none

Describe Plume Background
 Start: Cloudy End: cloudy
 Background Color: Start: white/gray End: white/gray Sky Conditions: Start: Broken End: Broken
 Wind Speed: Start: 11 mph End: 10 mph Wind Direction: Start: E End: E
 Ambient Temp.: Start: 61°F End: 61°F Wet Bulb Temp.: RH Percent: 74%

Source Layout Sketch
 Draw North Arrow
 Emissions Point
 Observer
 140°
 Sun Location Line
 Stack with Plume
 Sun
 Wind
 Latitude: 41.4068 Longitude: -74.4305 Declination:

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): sie-18-middletown.ny-start#1 Page 2 of 2

Continued on Form Number (AHI Project Code)

Observation Date: 9/24/18 Time Zone: Start Time: 1:45pm End Time: 2:45pm

Min. / Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Axel Garrido Martinez Date: 9/24/18
 Observer's Signature: [Signature] Date: 9/24/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc. Date: 7/06/18

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
with Duct Burners Firing
Opacity Data**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940


Process: Unit # CTG-2 Operating Mode: 100% w/ DB
 Control Equipment: Operating Mode: 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: clear End: clear
 Emission Color Water Droplet Plume
 Start: clear End: clear Start: detached End: detached

Describe Plume Background
 Start: gray clouds End: gray clouds
 Background Color Sky Conditions
 Start: gray End: gray Start: overcast End: overcast
 Wind Speed Wind Direction
 Start: 3 mph End: 3 mph Start: NNE End: NE
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start: 58°F End: 58°F 97%



Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): sie-18-middletown.ny-start#1 Page 1 of 2

Continued on Form Number (AHI Project Code)

Observation Date: 9/25/18 Time Zone: Start Time: 3:30pm End Time: 4:30pm

Min.	Sec.				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Axel Garrido-Martinez Date: 9/25/18

Observer's Signature: *[Signature]* Organization: Air Hygiene International, Inc.

Certified By: Compliance Assurance Associates, Inc. Date: 7/6/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) _____ Page 2 of 2
 sie-18-middletown.ny.start#1

Company Name: **CPV Valley LLC**
 Facility Name: **CPV Valley Energy Center**
 Street Address: **3330 US Route 6**
 City: **Middletown** State: **NY** Zip: **10940**

Continued on Form Number (AHI Project Code) _____

Process: _____ Unit #: _____ Operating Mode: _____
 Control Equipment: _____ Operating Mode: _____
 100% w/ DB

Observation Date: **9/25/18** Time Zone: _____ Start Time: **3:30pm** End Time: **4:30pm**


Describe Emissions Point
 Height of Emiss. Pt. _____ Height of Emiss. Pt. Rel. to Observer _____
 Start _____ End _____ Start _____ End _____
 Distance to Emiss. Pt. _____ Direction to Emiss. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____

Min.	Time				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Vertical Angle to Obs. Pt. _____ Direction to Obs. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____
 Distance and Direction to Observation Point from Emission Point
 Start _____ End _____

Describe Emissions
 Start **clear** End **clear**
 Emission Color _____ Water Droplet Plume _____
 Start **clear** End **clear** Start **detached** End **detached**

Describe Plume Background
 Start **gray/droplets** End **gray clouds**
 Background Color _____ Sky Conditions _____
 Start **gray** End **gray** Start **overcast** End **overcast**
 Wind Speed _____ Wind Direction _____
 Start **5mph** End **5mph** Start **NNE** End **NE**
 Ambient Temp. _____ Wet Bulb Temp. _____ RH Percent _____
 Start **58°F** End **58°F** _____ **97%**



Additional Information

Observer's Name (Print): **Axel Garrido-Martinez**
 Observer's Signature: _____ Date: **9/25/18**
 Organization: **Air Hygiene International, Inc.**
 Certified By: **Compliance Assurance Associates, Inc.** Date: **7/6/18**

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940


Process: Unit # CTG-2 Operating Mode 100% w/ DB
 Control Equipment: Operating Mode 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start Clear End clear
 Emission Color Water Droplet Plume
 Start clear End clear Start detached End detached

Describe Plume Background
 Start gray clouds End gray clouds
 Background Color Sky Conditions
 Start gray End gray Start overcast End overcast
 Wind Speed Wind Direction
 Start 4 mph End 4 mph Start NNE End N
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 56°F End 56°F 100%

Source Layout Sketch
 Draw North Arrow

 Latitude: 41.4069 Longitude: -74.4305 Declination: _____

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 2
 sie-18-middletown.ny-start#1

Continued on Form Number (AHI Project Code)

Observation Date: 9/25/18 Time Zone: Start Time: 1:00pm End Time: 2:00pm

Min	Sec	0	15	30	45	Comments
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11		0	0	0	0	
12		0	0	0	0	
13		0	0	0	0	
14		0	0	0	0	
15		0	0	0	0	
16		0	0	0	0	
17		0	0	0	0	
18		0	0	0	0	
19		0	0	0	0	
20		0	0	0	0	
21		0	0	0	0	
22		0	0	0	0	
23		0	0	0	0	
24		0	0	0	0	
25		0	0	0	0	
26		0	0	0	0	
27		0	0	0	0	
28		0	0	0	0	
29		0	0	0	0	
30		0	0	0	0	

Observer's Name (Print): Axel Garrido-Martinez
 Observer's Signature: _____ Date: 9/25/18
 Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc. Date: 7/6/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name CPV Valley LLC
 Facility Name CPV Valley Energy Center
 Street Address 3330 US Route 6
 City State Zip
 Middletown NY 10940

Process Unit # Operating Mode
 CTG-2 100% w/ DB
 Control Equipment Operating Mode
 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start clear End clear
 Emission Color Water Droplet Plume
 Start clear End clear Start detached End detached

Describe Plume Background
 Start gray clouds End gray clouds
 Background Color Sky Conditions
 Start gray End gray Start overcast End overcast
 Wind Speed Wind Direction
 Start 4mph End 4mph Start NNE End N
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 56°F End 56°F 100%

Source Layout Sketch
 Draw North Arrow
 TN MN
 FEET
 FEET
 Side View
 Stack with Plume
 Sun
 Wind
 Latitude Longitude Declination
 41.4069 -74.4305

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 2
 sie-18-middletown.ny-start#1
 Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time	Comments	
9/25/18		1:00pm	2:00pm		
Min.	Sec.	0	15	30	45
1	0	0	0	0	0
2	0	0	0	0	0
3	0	0	0	0	0
4	0	0	0	0	0
5	0	0	0	0	0
6	0	0	0	0	0
7	0	0	0	0	0
8	0	0	0	0	0
9	0	0	0	0	0
10	0	0	0	0	0
11	0	0	0	0	0
12	0	0	0	0	0
13	0	0	0	0	0
14	0	0	0	0	0
15	0	0	0	0	0
16	0	0	0	0	0
17	0	0	0	0	0
18	0	0	0	0	0
19	0	0	0	0	0
20	0	0	0	0	0
21	0	0	0	0	0
22	0	0	0	0	0
23	0	0	0	0	0
24	0	0	0	0	0
25	0	0	0	0	0
26	0	0	0	0	0
27	0	0	0	0	0
28	0	0	0	0	0
29	0	0	0	0	0
30	0	0	0	0	0

Observer's Name (Print) Axel Garrido-Martinez
 Observer's Signature Date 9/25/18
 Organization Air Hygiene International, Inc.
 Certified By Compliance Assurance Associates, Inc. Date 7/6/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: CPV Valley LLC
 Facility Name: CPV Valley Energy Center
 Street Address: 3330 US Route 6
 City: Middletown State: NY Zip: 10940


Process: Unit # CTG-2 Operating Mode: 100% w/ DB
 Control Equipment: Operating Mode: 100% w/ DB

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: clear End: clear
 Emission Color: Water Droplet Plume
 Start: clear End: clear Start: detached End: detached

Describe Plume Background
 Start: gray clouds End: gray clouds
 Background Color: Sky Conditions
 Start: gray End: gray Start: overcast End: overcast
 Wind Speed: Wind Direction
 Start: 9mph End: 9mph Start: NNE End: NE
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start: 51°F End: 51°F 95%

Source Layout Sketch
 Draw North Arrow

 Latitude: 41.4069 Longitude: -74.4305 Declination:
 TN MN
 FEET
 Side View
 Stack with Plume
 Sun
 Wind


Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): sie-18-middletown.ny-start#1 Page 1 of 2
 Continued on Form Number (AHI Project Code)

Observation Date: 9/25/18 Time Zone: Start Time: 8:30am End Time: 9:30am

Min	Sec				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Axel Garrido-Martinez Date: 9/25/18
 Observer's Signature:  Organization: Air Hygiene International, Inc.
 Certified By: Compliance Assurance Associates, Inc. Date: 7/06/18

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name: **CPV Valley LLC**
 Facility Name: **CPV Valley Energy Center**
 Street Address: **3330 US Route 6**
 City: **Middletown** State: **NY** Zip: **10940**


Process: **CTG-2** Unit #: **CTG-2** Operating Mode: **100% w/ DB**
 Control Equipment: **100% w/ DB**

Describe Emissions Point
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start End Start End
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start End Start End

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start End Start End
 Distance and Direction to Observation Point from Emission Point
 Start End

Describe Emissions
 Start: **clear** End: **clear**
 Emission Color: **clear** Water Droplet Plume: **detached**
 Start: **clear** End: **clear** Start: **detached** End: **detached**

Describe Plume Background
 Start: **gray clouds** End: **gray clouds**
 Background Color: **gray** Sky Conditions: **overcast**
 Start: **gray** End: **gray** Start: **overcast** End: **overcast**
 Wind Speed: **9mph** Wind Direction: **NNE**
 Start: **9mph** End: **9mph** Start: **NNE** End: **NE**
 Ambient Temp.: **51°F** Wet Bulb Temp.: **51°F** RH Percent: **75%**



Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): **sie-18-middletown.ny-start#1** Page **2** of **2**
 Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time	Comments				
9/25/18		8:30am	9:30am					
				0	15	30	45	
1				0	0	0	0	
2				0	0	0	0	
3				0	0	0	0	
4				0	0	0	0	
5				0	0	0	0	
6				0	0	0	0	
7				0	0	0	0	
8				0	0	0	0	
9				0	0	0	0	
10				0	0	0	0	
11				0	0	0	0	
12				0	0	0	0	
13				0	0	0	0	
14				0	0	0	0	
15				0	0	0	0	
16				0	0	0	0	
17				0	0	0	0	
18				0	0	0	0	
19				0	0	0	0	
20				0	0	0	0	
21				0	0	0	0	
22				0	0	0	0	
23				0	0	0	0	
24				0	0	0	0	
25				0	0	0	0	
26				0	0	0	0	
27				0	0	0	0	
28				0	0	0	0	
29				0	0	0	0	
30				0	0	0	0	

Observer's Name (Print): **Axel Garrido-Martinez**
 Observer's Signature: _____ Date: **9/25/18**
 Organization: **Air Hygiene International, Inc.**
 Certified By: **Compliance Assurance Associates, Inc.** Date: **7/6/18**

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
without Duct Burners Firing
PM Data**

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Historical Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Run Start Time	19:14	23:30	04:17		hh:mm	
Run Stop Time	23:24	03:57	08:32		hh:mm	
Test Date	10/10/18	10/10/18	10/11/18		mm/dd/yy	
Meter Calibration Factor	0.984	0.995	0.984			
Pitot Tube Coefficient	0.7240	0.7720	0.7240			
Average Nozzle Diameter	0.156	0.156	0.156		in	
Stack Test Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Initial Meter Volume	809.830	545.710	903.850		ft ³	
Final Meter Volume	896.960	641.330	995.000		ft ³	
Total Meter Volume	87.130	95.620	91.150	91.300	ft ³	
Total Sampling Time	237.75	258.00	241.25	245.67	min	
Average Meter Temperature	77.25	73.50	75.42	75.39	°F	
Average Stack Temperature	197.83	197.58	208.42	201.28	°F	
Barometric Pressure	29.40	29.39	29.40	29.40	in Hg	
Stack Static Pressure	-0.88	-0.88	-0.88	-0.88	in H ₂ O	
Absolute Stack Pressure	29.34	29.33	29.34	29.33	in Hg	
Average Orifice Pressure Drop	0.44	0.43	0.44	0.44	in H ₂ O	
Absolute Meter Pressure	29.53	29.52	29.53	29.53	in Hg	
Avg Square Root Pitot Pressure	1.13	1.12	1.14	1.13	√(in H ₂ O)	
Moisture Content Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Impinger Water Weight Gain	172.40	191.30	180.40	181.37	g	
Silica Gel Weight Gain	18.10	23.20	21.60	20.97	g	
Total Water Volume Collected	190.84	214.89	202.36	202.70	ml	
Standard Water Vapor Volume	8.98	10.11	9.52	9.54	scf	
Standard Meter Volume	82.9	92.6	87.0	87.5	dscf	
Standard Metric Meter Volume	2.3	2.6	2.5	2.5	dscm	
Calculated Stack Moisture	9.78	9.85	9.87	9.83	%	
Saturated Stack Moisture	76.38	76.01	94.90	82.43	%	
Reported Stack Moisture Content	9.78	9.85	9.87	9.83	%	
Gas Analysis Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Carbon Dioxide Content	4.5	4.5	4.5	4.5	%	
Oxygen Content	13.4	13.4	13.4	13.4	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.1	82.1	82.1	82.1	%	
Stack Dry Molecular Weight	29.26	29.26	29.26	29.26	lb/lb-mole	
Stack Wet Molecular Weight	28.16	28.15	28.15	28.15	lb/lb-mole	
Calculated Fuel Factor	1.667	1.667	1.667	1.667		
Fuel F-Factor	8710.00	8710.00	8710.00	8710.00	dscf/MMBtu	
Percent Excess Air	161.9	161.9	161.9	161.9	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Volumetric Flow Rate Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Average Stack Gas Velocity	62.49	65.80	63.26	63.85	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,063,069	1,119,451	1,076,097	1,086,205	acfm	
Wet Standard Stack Flow Rate	50,195	52,859	50,006	51,020	wkscfh	
Dry Standard Stack Flow Rate	45,287,271	47,654,049	45,071,742	46,004,354	dscfh	
Percent of Isokinetic Rate	98.8	96.7	102.7	99.4	%	
Emission Rate Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Total PM ₁₀ /PM _{2.5} Mass	2.96	2.15	2.30	2.47	mg	--
Total PM ₁₀ /PM _{2.5} Concentration	3.58E-05	2.32E-05	2.64E-05	2.85E-05	g/dscf	--
	5.52E-04	3.59E-04	4.08E-04	4.39E-04	gr/dscf	--
Total PM ₁₀ /PM _{2.5} Emission Rate	1.62	1.11	1.19	1.31	kg/hr	--
	3.57	2.44	2.63	2.88	lb/hr	--
	15.63	10.69	11.50	12.61	tpy	--
	0.0019	0.0012	0.0014	0.0015	lb/MMBtu	0.0073
Filterable PM ₁₀ Mass	0.14	0.18	0.40	0.24	mg	--
Filterable PM ₁₀ Concentration	1.68E-06	1.93E-06	4.58E-06	2.73E-06	g/dscf	--
	2.59E-05	2.98E-05	7.07E-05	4.21E-05	gr/dscf	--
Filterable PM ₁₀ Emission Rate	0.08	0.09	0.21	0.12	kg/hr	--
	0.17	0.20	0.46	0.28	lb/hr	--
	0.73	0.89	1.99	1.21	tpy	--
	0.0001	0.0001	0.0002	0.0001	lb/MMBtu	--
Filterable PM _{2.5} Mass	0.52	0.57	0.70	0.60	mg	--
Filterable PM _{2.5} Concentration	6.33E-06	6.18E-06	8.06E-06	6.86E-06	g/dscf	--
	9.76E-05	9.54E-05	1.24E-04	1.06E-04	gr/dscf	--
Filterable PM _{2.5} Emission Rate	0.29	0.29	0.36	0.31	kg/hr	--
	0.63	0.65	0.80	0.69	lb/hr	--
	2.77	2.85	3.51	3.04	tpy	--
	0.0003	0.0003	0.0004	0.0004	lb/MMBtu	--
Condensable PM _{2.5} Mass	2.30	1.40	1.20	1.63	mg	--
Condensable PM _{2.5} Concentration	2.77E-05	1.51E-05	1.38E-05	1.89E-05	g/dscf	--
	4.28E-04	2.33E-04	2.13E-04	2.91E-04	gr/dscf	--
Condensable PM _{2.5} Emission Rate	1.26	0.72	0.62	0.87	kg/hr	--
	2.77	1.59	1.37	1.91	lb/hr	--
	12.13	6.96	6.00	8.36	tpy	--
	0.0015	0.0008	0.0007	0.0010	lb/MMBtu	--
RM 201A Quality Control	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Cyclone Flow Rate	0.49	0.51	0.52	0.50	ft ³ /min	
Stack Viscosity	202.69	202.56	205.11	203.45	μP	
Cunningham Correction Factor	1.08	1.08	1.08	1.08		
Recalculated D50-1 for CIV	2.43	2.35	2.35	2.38		
Recalculated Cunninham	1.08	1.08	1.08	1.08		
Lower Limit Cut Diameter, CI (NRE<3162), D50LL	2.43	2.35	2.35	2.38		
Reynolds Number	2628.00	2708.37	2688.24	2,674.87		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Dp	0	0	0	0	points	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#4	
Operator		MS	
Date for Preliminary Run	(mm/dd/yy)	10/10/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		CTG-2	
Base Run Number		2-Base-PM	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	10/10/18	10/10/18	10/11/18	
Fuel F-Factor		8710.00	8710.00	8710.00	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0030	samp-cp-0032	samp-cp-0030	
Meter Calibration Factor	(Y)	0.984	0.995	0.984	
Orifice Meter Coefficient	(ΔH_{or})	1.812	1.825	1.812	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	4187/10	P-980/10	4187/10	
Pitot Tube Coefficient	(C _p)	0.7240	0.7720	0.7240	
Nozzle Number	from ACS	3	3	3	must match cyc nozz tab (e.g. 3, 4, etc.)
Nozzle Diameter	(D _n)	0.156	0.156	0.156	in
Probe Number	from ACS	samp-hp-0155	samp-hp-0149	samp-hp-0155	
Probe Length		96.0	96.0	96.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-bh-0029	samp-bh-0029	samp-bh-0029	
Impinger Case Number	from ACS	samp-cc-0014	samp-cc-0014	samp-cc-0014	

Note: no fuel analysis available, utilizing EPA Method 19 F-Factor


Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Michael Stockwell
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830


METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	CPV Valley Energy Center	Date	10/10/18
Sampling Location	CTG-2 Stack	Stack Type	Circular
Operator	MS	Ports Available	4
Project #	sie-18-middletown.ny-start#4	Ports Used	4
Stack Size	Large (>24 inch diameter)	Port ID (inches)	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	235.25	in
Distance to Near Wall of Stack	(L _{nw})	7.25	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A _s)	283.53	ft ²



Distance from Port to Disturbances			
Distance Upstream	(A)	1200.00	in
Diameters Upstream	(A _D)	5.26	diameters
Distance Downstream	(B)	1095.00	in
Diameters Downstream	(B _D)	4.80	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		24	16
Traverse Pts Required		24	16

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

² 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

- Method 1 Trav
- 12 Point PM Trav
- Velocity

Number of Traverse Points Used			
4	Ports by	3	Across
12	Pts Used	12	Required

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
	Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.044	10	17 2/8
2	0.146	33 2/8	40 4/8
3	0.296	67 4/8	74 6/8
4			
5			
6			
7			
8			
9			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	2-Base-PM-4	2-Base-PM-5	2-Base-PM-6	
Carbon Dioxide Content	4.5	4.5	4.5	4.5				%
Oxygen Content	13.4	13.4	13.4	13.4				%
Stack Moisture Content	10.0	9.8	9.8	9.9				%
Nitrogen plus CO Content	82.1	82.1	82.1	82.1				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H₂O)	Min.	1.14	Max.	1.59
---	------	------	------	------

Stack and Equipment Information	Prelim	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	2-Base-PM-4	2-Base-PM-5	2-Base-PM-6	
Barometric Pressure	29.45	29.40	29.39	29.40				in Hg
Stack Static Pressure	-0.88	-0.88	-0.88	-0.88				in H ₂ O
Absolute Stack Pressure	29.39	29.34	29.33	29.34				in Hg
Average Stack Temp	193	198	198	208				0.00
Average Stack Temp	653	658	658	668				°R
Average Meter Temp	85	77	74	75				0.00
Orifice Meter Coefficient	1.812	1.812	1.825	1.812				in H ₂ O
Pitot Coefficient	0.724	0.724	0.772	0.724				
Stack Dry Molecular Weight	29.26	29.26	29.26	29.26				lb/lb mole
Stack Wet Molecular Weight	28.13	28.16	28.15	28.15				lb/lb mole
Stack Viscosity	201.39	202.69	202.56	205.11				μP
Cunningham Correction Factor, for a 2.25 μm particle	1.08							
Cunningham Correction Factor, for a 2.5 μm particle		1.08	1.08	1.08				
Prelim Cut Dia., Cyclone I, D _{50LL} , N _{re} <3162	10.21	2.43	2.35	2.35				μm
Middle Zone Dia., Cyclone I, D _{50T} , N _{re} <3162	10.60							μm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic), N _{re} <3162	0.49							dscfm
Reynolds Number, Cyc I & IV, N _{re} <3162	2664.15	2628.00	2708.37	2688.24				
Dia. of 50% Prob. (D ₅₀) Cyc IV (N _{re} <3162)	2.40	2.44	2.35	2.35				μm
Sampling Rate, Cyc IV, N _{re} <3,162	0.49							dscfm
Reynolds Number, Cyc IV, N _{re} <3162	2664.11	2628.00	2708.37	2688.24				
Prelim Cut Dia., Cyclone I, D _{50LL} ≥3162	10.61							μm
Middle Zone Dia., Cyclone I, D _{50T} ≥3162	10.80							μm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic)≥3162	0.48							dscfm
Reynolds Number, Cyc I & IV, N _{re} ≥3162	2594.68							
Dia. of 50% Prob. (D ₅₀) CIV (N _{re} ≥3162)	2.30							μm
Sampling Rate, Cyc IV, N _{re} ≥3,162	4.78							dscfm
Reynolds Number ≥ 3162	25946.95							
Cyclone Flow Rate	0.49	0.49	0.51	0.52				ft ³ /min
Recalculated D ₅₀₋₁ for C _{IV}		2.43	2.35	2.35				
Recalculated Cunningham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		98.81	96.72	102.75				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.156	0.156	0.156				in

Orifice Head and Nozzle Selection Calculation

	0	1	2	3	4	5	6	7	8	9	10
Nozzle No.											
Nozzle diameter, D _n , in.	0.113	0.128	0.134	0.156	0.175	0.193	0.209	0.229	0.264	0.296	0.339
Nozzle velocity, v _n , ft/sec	117.44	91.53	83.52	61.62	48.97	40.26	34.33	28.60	21.52	17.12	13.05
R _{min}	0.77	0.76	0.75	0.73	0.69	0.65	0.60	0.50	0.50	0.50	0.50
v _{min} , ft/sec	90.82	69.63	63.03	44.77	33.93	26.17	20.56	14.43	10.76	8.56	6.52
R _{max}	1.22	1.23	1.23	1.25	1.27	1.29	1.31	1.35	1.41	1.49	1.50
v _{max} , ft/sec	143.15	112.34	102.83	76.95	62.09	51.93	45.06	38.47	30.42	25.48	19.57
Δp _{min} , in. H ₂ O @ t _s -50°F	2.95	1.73	1.42	0.72	0.41	0.24	0.15	0.07	0.04	0.03	0.02
Δp _{min} , in. H ₂ O @ t _s	2.72	1.60	1.31	0.66	0.38	0.23	0.14	0.07	0.04	0.02	0.01
Δp _{max} , in. H ₂ O @ t _s	6.77	4.17	3.49	1.96	1.27	0.89	0.67	0.49	0.31	0.21	0.13
Δp _{min} , in. H ₂ O @ t _s +50°F	6.29	3.87	3.25	1.82	1.18	0.83	0.62	0.45	0.28	0.20	0.12
ΔH, in. H ₂ O @ t _s +50°F						0.362					
ΔH, in. H ₂ O @ t _s						0.419					
ΔH, in. H ₂ O @ t _s -50°F						0.492					

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	10/10/18		
Sampling Location	CTG-2 Stack	Operator	MS		
Project #	sie-18-middletown.ny-start#4	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	2-Base-PM-1		Date	10/10/18	Run Start Time	19:14	Run Stop Time	23:24
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:10	4.5	13.4	0.0	82.1	29.26	1.667	161.9	YES

Gas Analysis Data								
Run Number	2-Base-PM-2		Date	10/10/18	Run Start Time	23:30	Run Stop Time	03:57
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:27	4.5	13.4	0.0	82.1	29.26	1.667	161.9	YES

Gas Analysis Data								
Run Number	2-Base-PM-3		Date	10/11/18	Run Start Time	04:17	Run Stop Time	08:32
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:15	4.5	13.4	0.0	82.1	29.26	1.667	161.9	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	10/10/18
Sampling Location	CTG-2 Stack	Operator	MS
Project #	sie-18-middletown.ny-start#4	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0025	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	10/10/18	500	500.1	0.1	Pass
Test Day 1	10/10/18	500	500.1	0.1	Pass

Moisture Content Data									
Run Number	2-Base-PM-1		Date	10/10/18	Start Time	19:14	Stop Time	23:24	
Meter Box Number	samp-cp-0030		Meter Cal Factor			(Y)	0.984		
Total Meter Volume	(V _m)	87.130	dcf	Barometric Pressure		(P _b)	29.40	in Hg	
Average Stack Temp	(t _s) _{avg}	198	°F	Stack Static Pressure		(P _{static})	-0.88	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	77	°F	Avg Orifice Pressure		(ΔH) _{avg}	0.44	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	507.60	613.10	707.60	860.30				
Initial Value	(V _i),(W _i)	350.60	611.60	693.70	842.20				
Net Value	(V _n),(W _n)	157.0	1.5	13.9	18.1				
Results									
Total Weight	(W _i)	190.50	g	Water Vol Weighed		(V _{wsg(std)})	8.982	scf	
Std Meter Volume	(V _{m(std)})	82.886	dscf	Sat. Moisture Content		(B _{ws(svp)})	76.38	%	
Calc Moisture Content	(B _{ws(calc)})	9.78	%	Final Moisture Content		(B _{ws})	9.78	%	

Moisture Content Data									
Run Number	2-Base-PM-2		Date	10/10/18	Start Time	23:30	Stop Time	03:57	
Meter Box Number	samp-cp-0032		Meter Cal Factor			(Y)	0.995		
Total Meter Volume	(V _m)	95.620	dcf	Barometric Pressure		(P _b)	29.39	in Hg	
Average Stack Temp	(t _s) _{avg}	198	°F	Stack Static Pressure		(P _{static})	-0.88	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	74	°F	Avg Orifice Pressure		(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	537.90	610.10	706.70	870.10				
Initial Value	(V _i),(W _i)	366.30	608.40	688.70	846.90				
Net Value	(V _n),(W _n)	171.6	1.7	18.0	23.2				
Results									
Total Weight	(W _i)	214.50	g	Water Vol Weighed		(V _{wsg(std)})	10.114	scf	
Std Meter Volume	(V _{m(std)})	92.594	dscf	Sat. Moisture Content		(B _{ws(svp)})	76.01	%	
Calc Moisture Content	(B _{ws(calc)})	9.85	%	Final Moisture Content		(B _{ws})	9.85	%	

Moisture Content Data									
Run Number	2-Base-PM-3		Date	10/11/18	Start Time	04:17	Stop Time	08:32	
Meter Box Number	samp-cp-0030		Meter Cal Factor			(Y)	0.984		
Total Meter Volume	(V _m)	91.150	dcf	Barometric Pressure		(P _b)	29.40	in Hg	
Average Stack Temp	(t _s) _{avg}	208	°F	Stack Static Pressure		(P _{static})	-0.88	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	75	°F	Avg Orifice Pressure		(ΔH) _{avg}	0.44	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	512.50	572.70	726.70	858.00				
Initial Value	(V _i),(W _i)	352.40	571.50	707.60	836.40				
Net Value	(V _n),(W _n)	160.1	1.2	19.1	21.6				
Results									
Total Weight	(W _i)	202.00	g	Water Vol Weighed		(V _{wsg(std)})	9.524	scf	
Std Meter Volume	(V _{m(std)})	87.008	dscf	Sat. Moisture Content		(B _{ws(svp)})	94.90	%	
Calc Moisture Content	(B _{ws(calc)})	9.87	%	Final Moisture Content		(B _{ws})	9.87	%	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Date	10/10/18
Operator	MS
Run Number	2-Base-PM-1

Filter #	05335/0418-026
	1

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7240	4187/10	
Average Stack Temp (t_s)	197.8		°F
Average Meter Temp (t_m)	77.3		
Orifice Meter Coefficient (ΔH_{or})	1.812		in H ₂ O
Square Root ΔP ($\Delta P_{avg}^{1/2}$)	1.13		in H ₂ O
Stack Moisture Content (B_{ws})	9.78		%
Stack Dry Molecular Weight (M_d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	0.33		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	5.0	in H ₂ O for	15.0 sec
	Pre (-)	4.0	in H ₂ O for	15.0 sec	
	Post (+)	5.5	in H ₂ O for	15.0 sec	
	Post (-)	6.0	in H ₂ O for	15.0 sec	

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor (Y)	0.984		
Nozzle Number	3		
Average Nozzle Diameter (D_{na})	0.1560	in	
Suggested Nozzle Diameter (D_m)	0.2193	in	
Probe Number	samp-hp-0155		
Probe Length	96		
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0029		
Impinger Case Number	samp-cc-0014		

Nozzle Measurements					ID: 3
Pre	0.156	0.156	0.156	PASS	
Post	0.156	0.156	0.156	PASS	

Barometer ID	
SAMP-WE-0032	
Scale ID	
SAMP-SC-0025	

Run Time		
Start	19:14	End 23:24

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	350.6	611.6	693.7	842.2				
Post	507.6	613.1	707.6	860.3				

Pressures			
Barometric Pressure (P_b)	29.40	in Hg	
Stack Static Pressure (P_{static})	-0.88	in H ₂ O	
Absolute Stack Pressure (P_s)	29.34	in Hg	
Absolute Meter Pressure (P_m)	29.53	in Hg	

Wash Volumes					ml
					ml

Identification Nos.	smp-cp-0030	smp-cp-0030	smp-cp-0030	smp-hp-0155	smp-hp-0155	smp-bh-0029	smp-cc-0014	smp-cp-0030										smp-cp-0030					
								Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)						
A-1	0.0	00:00:00	809.830	1.50	0.419	0.40	199	256	251	66	75	83	74	74	3.0	1.22	67.71	7.206	87.7	79.687			
A-2	21.5	00:21:30	817.360	1.50	0.419	0.42	198	258	250	64	38	75	76	76	3.0	1.22	67.66	14.758	89.9	81.596			
A-3	43.0	00:43:00	825.280	1.20	0.419	0.45	198	256	249	57	40	71	77	77	3.0	1.10	60.52	21.587	94.3	82.445			
B-1	62.3	01:02:15	832.455	1.30	0.419	0.45	198	249	246	64	51	79	77	77	3.0	1.14	62.99	28.596	95.3	82.660			
B-2	82.3	01:22:15	839.820	1.30	0.419	0.45	198	259	251	56	55	78	78	78	3.0	1.14	62.99	35.593	95.9	82.760			
B-3	102.3	01:42:15	847.185	1.30	0.419	0.45	199	257	249	56	59	79	78	78	3.0	1.14	63.04	42.637	96.4	82.920			
C-1	122.3	02:02:15	854.600	1.10	0.419	0.45	197	255	250	57	63	74	78	78	3.0	1.05	57.90	49.088	97.9	83.065			
C-2	140.5	02:20:30	861.390	1.10	0.419	0.44	198	255	249	55	61	68	78	78	3.0	1.05	57.94	55.452	98.9	83.048			
C-3	158.8	02:38:45	868.090	1.10	0.419	0.44	197	257	251	54	55	69	78	78	3.0	1.05	57.90	61.827	99.7	83.047			
D-1	177.0	02:57:00	874.800	1.30	0.419	0.43	197	257	247	58	60	71	77	77	3.0	1.14	62.94	68.784	99.5	83.012			
D-2	197.0	03:17:00	882.110	1.30	0.419	0.43	198	258	252	56	56	76	78	78	3.0	1.14	62.99	75.718	99.3	82.959			
D-3	217.0	03:37:00	889.410	1.40	0.419	0.43	197	255	247	57	73	76	78	78	3.0	1.18	65.32	82.890	98.8	82.890			
Last Pt	237.8	03:57:45	896.960																				
Final Val	237.8	03:57:45	896.960												Max Vac	3.0	Final Values		82.890	98.8			
Average Values				1.28		0.44	198	256	249	58	57	75	77	77			1.13	62.49					

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Date	10/10/18
Operator	MS
Run Number	2-Base-PM-2

Filter #	05334/0818-188
	2

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7720	P-980/10	
Average Stack Temp (t_s)	197.6		°F
Average Meter Temp (t_m)	73.5		
Orifice Meter Coefficient ($\Delta H @$)	1.825		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.12		in H ₂ O
Stack Moisture Content (B_{ws})	9.85		%
Stack Dry Molecular Weight (M_d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.35		acfm
ΔP to ΔH Isokinetic Factor (K)	0.37		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	5.0	in H ₂ O for	15.0 sec
		Pre (-)	5.3	in H ₂ O for	15.0 sec
		Post (+)	5.9	in H ₂ O for	15.0 sec
		Post (-)	4.8	in H ₂ O for	15.0 sec

Sampling Equipment			
Meter Box Number	samp-cp-0032		
Meter Cal Factor (Y)	0.995		
Nozzle Number	3		
Average Nozzle Diameter (D_{na})	0.1560		in
Suggested Nozzle Diameter (D_m)	0.1457		in
Probe Number	samp-hp-0149		in
Probe Length	96		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0029		
Impinger Case Number	samp-cc-0014		

Nozzle Measurements				ID: 3
Pre	0.156	0.156	0.156	PASS
Post	0.156	0.156	0.156	PASS

Barometer ID	
SAMP-WE-0032	
Scale ID	
SAMP-SC-0025	

Run Time		
Start	23:30	End 03:57

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	366.3	608.4	688.7	846.9				
Post	537.9	610.1	706.7	870.1				

Pressures			
Barometric Pressure (P_b)	29.39		in Hg
Stack Static Pressure (P_{static})	-0.88		in H ₂ O
Absolute Stack Pressure (P_s)	29.33		in Hg
Absolute Meter Pressure (P_m)	29.52		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0032		samp-cp-0032		samp-cp-0032		samp-hp-0149		samp-hp-0149		samp-bh-0029		samp-cc-0014		samp-cp-0032				samp-cp-0032					
	Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (V _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}			
A-1	0.0	00:00:00	545.710	1.40	0.419	0.42	200	249	251	66	49	75	72	72	3.0	1.18	69.83	7.982	88.3	89.537				
A-2	23.0	00:23:00	553.930	1.30	0.419	0.43	197	250	249	63	61	73	72	72	3.0	1.14	67.13	15.741	90.1	89.749				
A-3	45.3	00:45:15	561.920	1.20	0.419	0.43	195	250	251	63	60	74	74	74	3.0	1.10	64.40	23.190	92.0	89.970				
B-1	66.5	01:06:30	569.620	1.20	0.419	0.43	197	251	251	67	70	76	75	75	3.0	1.10	64.50	30.741	93.3	90.385				
B-2	87.8	01:27:45	577.440	1.40	0.419	0.43	199	249	250	56	48	71	75	75	3.0	1.18	69.77	38.910	92.7	90.645				
B-3	110.8	01:50:45	585.900	1.40	0.419	0.43	198	250	252	62	63	77	74	74	3.0	1.18	69.72	47.095	92.3	90.845				
C-1	133.8	02:13:45	594.360	1.20	0.419	0.44	197	250	249	67	66	80	73	73	3.0	1.10	64.50	54.403	93.7	91.589				
C-2	153.3	02:33:15	601.900	1.20	0.419	0.44	197	251	246	65	58	81	73	73	3.0	1.10	64.50	61.527	94.5	91.890				
C-3	172.8	02:52:45	609.250	1.20	0.419	0.44	197	249	251	64	59	77	73	73	3.0	1.10	64.50	68.671	95.1	92.157				
D-1	192.3	03:12:15	616.620	1.10	0.419	0.44	196	248	250	66	65	77	73	73	3.0	1.05	61.71	76.503	96.2	92.448				
D-2	213.5	03:33:30	624.700	1.30	0.419	0.44	199	251	250	67	66	78	74	74	3.0	1.14	67.24	84.949	96.1	92.573				
D-3	236.8	03:56:45	633.430	1.10	0.419	0.44	199	250	250	65	60	79	74	74	3.0	1.05	61.85	92.591	96.7	92.591				
Last Pt	258.0	04:18:00	641.330																					
Final Val	258.0	04:18:00	641.330												Max Vac	3.0	Final Values	92.591	96.7					
Average Values				1.25		0.43	198	250	250	64	60	77	74	74			1.12	65.80						

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Date	10/11/18
Operator	MS
Run Number	2-Base-PM-3

Filter #	05272/0818-188
	3

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7240	4187/10	
Average Stack Temp (t_s)	208.4		°F
Average Meter Temp (t_m)	75.4		
Orifice Meter Coefficient ($\Delta H @$)	1.812		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.14		in H ₂ O
Stack Moisture Content (B_{ws})	9.87		%
Stack Dry Molecular Weight (M_d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.36		acfm
ΔP to ΔH Isokinetic Factor (K)	0.32		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	4.7	in H ₂ O for	15.0
		Pre (-)	5.0	in H ₂ O for	15.0
		Post (+)	5.0	in H ₂ O for	15.0
		Post (-)	5.4	in H ₂ O for	15.0

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor (Y)	0.984		
Nozzle Number	3		
Average Nozzle Diameter (D_{na})	0.1560	in	
Suggested Nozzle Diameter (D_m)	0.1524	in	
Probe Number	samp-hp-0155		
Probe Length	96		
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0029		
Impinger Case Number	samp-cc-0014		

Nozzle Measurements				ID: 3
Pre	0.156	0.156	0.156	PASS
Post	0.156	0.156	0.156	PASS

Barometer ID	
SAMP-WE-0032	
Scale ID	
SAMP-SC-0025	

Run Time		
Start	04:17	End 08:32

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	352.4	571.5	707.6	836.4				
Post	512.5	572.7	726.7	858.0				

Pressures		
Barometric Pressure (P_b)	29.40	in Hg
Stack Static Pressure (P_{static})	-0.88	in H ₂ O
Absolute Stack Pressure (P_s)	29.34	in Hg
Absolute Meter Pressure (P_m)	29.53	in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0030	samp-cp-0030	samp-cp-0030	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	samp-cp-0030			Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$)	Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)
												Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	in Hg						
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (Δp)	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	903.850	1.40	0.419	0.44	208	259	246	68	53	80	73	73	3.0	1.18	65.87	7.777	98.8	87.260
A-2	21.5	00:21:30	911.960	1.40	0.419	0.44	207	257	249	53	52	74	75	75	3.0	1.18	65.82	15.581	98.9	87.418
A-3	43.0	00:43:00	920.130	1.30	0.419	0.44	209	254	255	55	60	75	75	75	3.0	1.14	63.52	23.023	99.8	87.127
B-1	63.8	01:03:45	927.920	1.30	0.419	0.44	208	256	252	62	63	80	75	75	3.0	1.14	63.48	30.264	100.5	87.179
B-2	83.8	01:23:45	935.500	1.30	0.419	0.44	209	257	249	53	71	77	76	76	3.0	1.14	63.52	37.444	100.7	87.069
B-3	103.8	01:43:45	943.030	1.40	0.419	0.44	209	256	246	56	75	79	76	76	3.0	1.18	65.92	44.872	100.2	86.951
C-1	124.5	02:04:30	950.820	1.30	0.419	0.44	208	254	249	61	78	79	76	76	3.0	1.14	63.48	51.480	100.5	87.002
C-2	142.8	02:22:45	957.750	1.30	0.419	0.44	209	257	248	55	63	79	76	76	3.0	1.14	63.52	58.050	100.7	86.984
C-3	161.0	02:41:00	964.640	1.30	0.419	0.44	208	257	249	60	74	80	76	76	3.0	1.14	63.48	64.686	101.0	87.060
D-1	179.3	02:59:15	971.600	1.10	0.419	0.44	209	252	262	59	60	81	75	75	3.0	1.05	58.43	72.051	102.2	87.239
D-2	199.3	03:19:15	979.310	1.20	0.419	0.44	209	261	261	51	50	75	76	76	3.0	1.10	61.03	79.718	102.8	87.319
D-3	220.3	03:40:15	987.350	1.20	0.419	0.44	208	257	261	53	61	77	76	76	3.0	1.10	60.99	87.012	102.7	87.012
Last Pt	241.3	04:01:15	995.000																	
Final Val	241.3	04:01:15	995.000												Max Vac	3.0	Final Values	87.012	102.7	
Average Values				1.29		0.44	208	256	252	57	63	78	75	75		1.14	63.26			

Notes:

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
with Duct Burners Firing
PM Data**

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	Average	Units	Limits
Run Start Time	23:36	05:03	10:20		hh:mm	
Run Stop Time	03:53	09:10	14:39		hh:mm	
Test Date	09/24/18	09/25/18	09/25/18		mm/dd/yy	
Load	w/DB	w/DB	w/DB		% or w/DB	--
Meter Calibration Factor	1.000	1.000	1.000			
Pitot Tube Coefficient	0.7420	0.7420	0.7420			
Average Nozzle Diameter	0.156	0.156	0.156		in	
Stack Test Data	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	Average	Units	Limits
Initial Meter Volume	48.770	140.470	234.480		ft ³	
Final Meter Volume	140.060	234.920	340.710		ft ³	
Total Meter Volume	91.290	94.450	106.230	97.323	ft ³	
Total Sampling Time	246.75	246.75	247.75	247.08	min	
Average Meter Temperature	80.00	81.08	78.58	79.89	°F	
Average Stack Temperature	189.69	189.50	188.83	189.34	°F	
Barometric Pressure	29.98	29.91	29.78	29.89	in Hg	
Stack Static Pressure	0.55	0.55	0.55	0.55	in H ₂ O	
Absolute Stack Pressure	30.02	29.95	29.82	29.93	in Hg	
Average Orifice Pressure Drop	0.43	0.43	0.43	0.43	in H ₂ O	
Absolute Meter Pressure	30.11	30.04	29.91	30.02	in Hg	
Avg Square Root Pitot Pressure	1.15	1.16	1.18	1.16	√(in H ₂ O)	
Moisture Content Data	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	Average	Units	Limits
Impinger Water Weight Gain	306.20	129.40	226.90	220.83	g	
Silica Gel Weight Gain	37.10	16.50	47.10	33.57	g	
Total Water Volume Collected	343.92	146.16	274.49	254.86	ml	
Standard Water Vapor Volume	16.19	6.88	12.92	11.99	scf	
Standard Meter Volume	89.5	92.2	103.8	95.2	dscf	
Standard Metric Meter Volume	2.5	2.6	2.9	2.7	dscm	
Calculated Stack Moisture	15.31	6.94	11.07	11.11	%	
Saturated Stack Moisture	62.81	62.70	62.08	62.53	%	
Reported Stack Moisture Content	15.31	6.94	11.07	11.11	%	
Gas Analysis Data	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	Average	Units	Limits
Carbon Dioxide Content	4.9	4.9	4.9	4.9	%	
Oxygen Content	12.0	12.0	12.0	12.0	%	
Carbon Monoxide Content	0.4	0.5	0.5	0.5	ppm	
Nitrogen Content	83.1	83.1	83.1	83.1	%	
Stack Dry Molecular Weight	29.26	29.26	29.26	29.26	lb/lb-mole	
Stack Wet Molecular Weight	27.54	28.48	28.02	28.01	lb/lb-mole	
Calculated Fuel Factor	1.816	1.816	1.816	1.816		
Fuel F-Factor	8633.27	8632.22	8632.22	8632.57	dscf/MMBtu	
Percent Excess Air	120.7	120.7	120.7	120.7	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	Average	Units	Limits
Average Stack Gas Velocity	64.57	64.42	66.08	65.02	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,098,491	1,095,865	1,124,082	1,106,146	acfm	
Wet Standard Stack Flow Rate	53,744	53,506	54,702	53,984	wkscfh	
Dry Standard Stack Flow Rate	45,515,391	49,792,509	48,645,409	47,984,436	dscfh	
Percent of Isokinetic Rate	102.9	96.0	111.1	103.4	%	
Emission Rate Data	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	Average	Units	Limits
Total PM ₁₀ /PM _{2.5} Mass	5.35	26.09	14.84	15.43	mg	--
Total PM ₁₀ /PM _{2.5} Concentration	5.97E-05	2.83E-04	1.43E-04	1.62E-04	g/dscf	--
	9.21E-04	4.37E-03	2.21E-03	2.50E-03	gr/dscf	--
Total PM ₁₀ /PM _{2.5} Emission Rate	2.72	14.09	6.96	7.92	kg/hr	--
	5.99	31.06	15.34	17.46	lb/hr	--
	26.24	136.02	67.19	76.48	tpy	--
	0.0027	0.0126	0.0064	0.0072	lb/MMBtu	0.0073
Filterable PM ₁₀ Mass	0.24	0.11	0.45	0.27	mg	--
Filterable PM ₁₀ Concentration	2.66E-06	1.24E-06	4.33E-06	2.74E-06	g/dscf	--
	4.10E-05	1.91E-05	6.68E-05	4.23E-05	gr/dscf	--
Filterable PM ₁₀ Emission Rate	0.12	0.06	0.21	0.13	kg/hr	--
	0.27	0.14	0.46	0.29	lb/hr	--
	1.17	0.60	2.03	1.27	tpy	--
	0.0001	0.0001	0.0002	0.0001	lb/MMBtu	--
Filterable PM _{2.5} Mass	3.61	0.98	1.99	2.19	mg	--
Filterable PM _{2.5} Concentration	4.03E-05	1.06E-05	1.92E-05	2.34E-05	g/dscf	--
	6.22E-04	1.64E-04	2.96E-04	3.61E-04	gr/dscf	--
Filterable PM _{2.5} Emission Rate	1.83	0.53	0.93	1.10	kg/hr	--
	4.04	1.16	2.06	2.42	lb/hr	--
	17.71	5.10	9.02	10.61	tpy	--
	0.0018	0.0005	0.0009	0.0010	lb/MMBtu	--
Condensable PM _{2.5} Mass	1.50	25.00	12.40	12.97	mg	--
Condensable PM _{2.5} Concentration	1.68E-05	2.71E-04	1.20E-04	1.36E-04	g/dscf	--
	2.59E-04	4.18E-03	1.84E-03	2.10E-03	gr/dscf	--
Condensable PM _{2.5} Emission Rate	0.76	13.50	5.81	6.69	kg/hr	--
	1.68	29.75	12.82	14.75	lb/hr	--
	7.36	130.32	56.13	64.61	tpy	--
	0.0007	0.0121	0.0053	0.0061	lb/MMBtu	--
RM 201A Quality Control	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	Average	Units	Limits
Cyclone Flow Rate	0.53	0.49	0.58	0.53	ft ³ /min	
Stack Viscosity	194.88	202.59	198.60	198.69	μP	
Cunningham Correction Factor	1.08	1.08	1.09	1.09		
Recalculated D50-1 for CIV	2.12	2.34	1.92	2.13		
Recalculated Cunninham	1.08	1.08	1.09	1.09		
Lower Limit Cut Diameter, CI (NRE<3162), D50LL	2.12	2.34		2.23		
Dia. of 50% Prob. (D50) CIV (NRE>3162)			1.92	1.92		
Reynolds Number	2964.42	2764.85	3252.96	2,994.08		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Dp	0	0	0	0	points	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		SB	
Date for Preliminary Run	(mm/dd/yy)	09/24/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		CTG-1	
Base Run Number		2-100 w/DB-PM	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/24/18	09/25/18	09/25/18	
Load		w/DB	w/DB	w/DB	% or w/DB
Fuel F-Factor		8633.27	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	SAMP-CP-0029	SAMP-CP-0029	SAMP-CP-0029	
Meter Calibration Factor	(Y)	1.000	1.000	1.000	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.824	1.824	1.824	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	5273/10	5273/10	5273/10	
Pitot Tube Coefficient	(C _p)	0.7420	0.7420	0.7420	
Nozzle Number	from ACS	3	3	3	must match cyc nozz tab (e.g. 3, 4, etc.)
Nozzle Diameter	(D _n)	0.156	0.156	0.156	in
Probe Number	from ACS	SAMP-HP-0140	SAMP-HP-0140	SAMP-HP-0140	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	5143	5143	5143	
Impinger Case Number	from ACS	SAMP-CC-0001	SAMP-CC-0001	SAMP-CC-0001	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	2-100 w/DB-PM-4	2-100 w/DB-PM-5	2-100 w/DB-PM-6	
Carbon Dioxide Content	4.9	4.9	4.9	4.9				%
Oxygen Content	12.0	12.0	12.0	12.0				%
Stack Moisture Content	9.5	15.3	6.9	11.1				%
Nitrogen plus CO Content	83.1	83.1	83.1	83.1				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H₂O)	Min.	1.10	Max.	1.70
---	------	------	------	------

Stack and Equipment Information	Prelim	2-100 w/DB-PM-1	2-100 w/DB-PM-2	2-100 w/DB-PM-3	2-100 w/DB-PM-4	2-100 w/DB-PM-5	2-100 w/DB-PM-6	
Barometric Pressure	29.98	29.98	29.91	29.78				in Hg
Stack Static Pressure	0.55	0.55	0.55	0.55				in H ₂ O
Absolute Stack Pressure	30.02	30.02	29.95	29.82				in Hg
Average Stack Temp	195	190	190	189				0.00
Average Stack Temp	655	650	650	649				°R
Average Meter Temp	85	80	81	79				0.00
Orifice Meter Coefficient	1.824	1.824	1.824	1.824				in H ₂ O
Pitot Coefficient	0.742	0.742	0.742	0.742				
Stack Dry Molecular Weight	29.26	29.26	29.26	29.26				lb/lb mole
Stack Wet Molecular Weight	28.19	27.54	28.48	28.02				lb/lb mole
Stack Viscosity	201.48	194.88	202.59	198.60				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.08							
Cunningham Correction Factor, for a 2.5 µm particle		1.07	1.07	1.07				
Prelim Cut Dia., Cyclone I, D _{50LL} , N _{re} <3162	10.25	2.12	2.34					µm
Middle Zone Dia., Cyclone I, D _{50T} , N _{re} <3162	10.62							µm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic), N _{re} <3162	0.49							dscfm
Reynolds Number, Cyc I & IV, N _{re} <3162	2697.43	2964.42	2764.85	3252.96				
Dia. of 50% Prob. (D ₅₀) Cyc IV (N _{re} <3162)	2.39	2.13	2.35					µm
Sampling Rate, Cyc IV, N _{re} <3,162	0.49							dscfm
Reynolds Number, Cyc IV, N _{re} <3162	2697.39	2964.42	2764.85	3252.96				
Prelim Cut Dia., Cyclone I, D _{50LL} ≥3162	10.62							µm
Middle Zone Dia., Cyclone I, D _{50T} ≥3162	10.81							µm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic)≥3162	0.47							dscfm
Reynolds Number, Cyc I & IV, N _{re} ≥3162	2632.75							
Dia. of 50% Prob. (D ₅₀) CIV (N _{re} ≥3162)	2.30			1.94				µm
Sampling Rate, Cyc IV, N _{re} ≥3,162	4.75							dscfm
Reynolds Number ≥ 3162	26327.67							
Cyclone Flow Rate	0.49	0.53	0.49	0.58				ft ³ /min
Recalculated D ₅₀₋₁ for C _{IV}		2.12	2.34	1.92				
Recalculated Cunningham		1.08	1.08	1.09				
Z		1.00	1.00	1.00				
Isokinetics		102.94	96.01	111.12				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.156	0.156	0.156				in

Orifice Head and Nozzle Selection Calculation

	1	2	3	4	5	6	7	8	9	10	11
Nozzle No.											
Nozzle diameter, D _n , in.	0.125	0.138	0.156	0.172	0.188	0.200	0.216	0.234	0.253	0.274	0.296
Nozzle velocity, v _n , ft/sec	95.18	78.09	61.11	50.27	42.08	37.18	31.87	27.16	23.23	19.81	16.97
R _{min}	0.76	0.75	0.73	0.70	0.66	0.63	0.57	0.50	0.50	0.50	0.50
v _{min} , ft/sec	72.64	58.56	44.36	35.09	27.85	23.33	18.11	13.58	11.62	9.90	8.49
R _{max}	1.23	1.23	1.25	1.27	1.28	1.30	1.32	1.36	1.39	1.44	1.49
v _{max} , ft/sec	116.66	96.39	76.34	63.60	54.03	48.34	42.22	36.81	32.34	28.48	25.30
Δp _{min} , in. H ₂ O @ t _s -50°F	1.84	1.19	0.68	0.43	0.27	0.19	0.11	0.06	0.05	0.03	0.03
Δp _{min} , in. H ₂ O @ t _s	1.70	1.10	0.63	0.40	0.25	0.17	0.11	0.06	0.04	0.03	0.02
Δp _{max} , in. H ₂ O @ t _s	4.37	2.99	1.87	1.30	0.94	0.75	0.57	0.44	0.34	0.26	0.21
Δp _{min} , in. H ₂ O @ t _s +50°F	4.06	2.77	1.74	1.21	0.87	0.70	0.53	0.40	0.31	0.24	0.19
ΔH, in. H ₂ O @ t _s +50°F						0.370					
ΔH, in. H ₂ O @ t _s						0.428					
ΔH, in. H ₂ O @ t _s -50°F						0.502					

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18		
Sampling Location	CTG-2 Stack	Operator	SB		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	2-100 w/DB-PM-1		Date	09/24/18	Run Start Time	23:36	Run Stop Time	03:53
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:17	4.9	12.0	0.4	83.1	29.26	1.816	120.7	YES

Gas Analysis Data								
Run Number	2-100 w/DB-PM-2		Date	09/25/18	Run Start Time	05:03	Run Stop Time	09:10
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:07	4.9	12.0	0.5	83.1	29.26	1.816	120.7	YES

Gas Analysis Data								
Run Number	2-100 w/DB-PM-3		Date	09/25/18	Run Start Time	10:20	Run Stop Time	14:39
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:19	4.9	12.0	0.5	83.1	29.26	1.816	120.7	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18
Sampling Location	CTG-2 Stack	Operator	SB
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0022	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/24/18	500	499.9	-0.1	Pass
Test Day 1	09/24/18	500	499.9	-0.1	Pass

Moisture Content Data									
Run Number	2-100 w/DB-PM-1		Date	09/24/18	Start Time	23:36	Stop Time	03:53	
Meter Box Number	SAMP-CP-0029				Meter Cal Factor	(Y)	1.000		
Total Meter Volume	(V _m)	91.290	dcf		Barometric Pressure	(P _b)	29.98	in Hg	
Average Stack Temp	(t _s) _{avg}	190	°F		Stack Static Pressure	(P _{static})	0.55	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	80	°F		Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	638.60	611.00	654.10	857.50				
Initial Value	(V _i),(W _i)	362.00	598.90	636.60	820.40				
Net Value	(V _n),(W _n)	276.6	12.1	17.5	37.1				
Results									
Total Weight	(W _t)	343.30	g		Water Vol Weighed	(V _{wsg(std)})	16.187	scf	
Std Meter Volume	(V _{m(std)})	89.535	dscf		Sat. Moisture Content	(B _{ws(svp)})	62.81	%	
Calc Moisture Content	(B _{ws(calc)})	15.31	%		Final Moisture Content	(B _{ws})	15.31	%	

Moisture Content Data									
Run Number	2-100 w/DB-PM-2		Date	09/25/18	Start Time	05:03	Stop Time	09:10	
Meter Box Number	SAMP-CP-0029				Meter Cal Factor	(Y)	1.000		
Total Meter Volume	(V _m)	94.450	dcf		Barometric Pressure	(P _b)	29.91	in Hg	
Average Stack Temp	(t _s) _{avg}	190	°F		Stack Static Pressure	(P _{static})	0.55	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	81	°F		Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	484.50	597.60	757.10	898.30				
Initial Value	(V _i),(W _i)	357.00	597.00	755.80	881.80				
Net Value	(V _n),(W _n)	127.5	0.6	1.3	16.5				
Results									
Total Weight	(W _t)	145.90	g		Water Vol Weighed	(V _{wsg(std)})	6.879	scf	
Std Meter Volume	(V _{m(std)})	92.233	dscf		Sat. Moisture Content	(B _{ws(svp)})	62.70	%	
Calc Moisture Content	(B _{ws(calc)})	6.94	%		Final Moisture Content	(B _{ws})	6.94	%	

Moisture Content Data									
Run Number	2-100 w/DB-PM-3		Date	09/25/18	Start Time	10:20	Stop Time	14:39	
Meter Box Number	SAMP-CP-0029				Meter Cal Factor	(Y)	1.000		
Total Meter Volume	(V _m)	106.230	dcf		Barometric Pressure	(P _b)	29.78	in Hg	
Average Stack Temp	(t _s) _{avg}	189	°F		Stack Static Pressure	(P _{static})	0.55	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	79	°F		Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	Dry		Dry	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	566.50	608.50	668.50	895.10				
Initial Value	(V _i),(W _i)	361.80	600.80	654.00	848.00				
Net Value	(V _n),(W _n)	204.7	7.7	14.5	47.1				
Results									
Total Weight	(W _t)	274.00	g		Water Vol Weighed	(V _{wsg(std)})	12.919	scf	
Std Meter Volume	(V _{m(std)})	103.765	dscf		Sat. Moisture Content	(B _{ws(svp)})	62.08	%	
Calc Moisture Content	(B _{ws(calc)})	11.07	%		Final Moisture Content	(B _{ws})	11.07	%	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	SB
Run Number	2-100 w/DB-PM-1

Filter #	000009
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7420	5273/10	
Average Stack Temp (t_s)	189.7		°F
Average Meter Temp (t_m)	80.0		
Orifice Meter Coefficient ($\Delta H @$)	1.824		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.15		in H ₂ O
Stack Moisture Content (B_{ws})	15.31		%
Stack Dry Molecular Weight (M_d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	0.32		

Leak Checks					
Train	Pre	0.001	ft ³ /min@	16.0	in Hg
PASS	Post	0.000	ft ³ /min@	10.0	in Hg
PASS	Pitot	Pre (+)	4.6	in H ₂ O for	15.0 sec
		Pre (-)	4.1	in H ₂ O for	15.0 sec
		Post (+)	5.3	in H ₂ O for	15.0 sec
		Post (-)	6.2	in H ₂ O for	15.0 sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0029		
Meter Cal Factor (Y)	1.000		
Nozzle Number	3		
Average Nozzle Diameter (D_{na})	0.1560	in	
Suggested Nozzle Diameter (D_m)	0.2143	in	
Probe Number	SAMP-HP-0140	in	
Probe Length	108	in	
Liner Material	glass		
Sample Case / Oven Number	5143		
Impinger Case Number	SAMP-CC-0001		

Nozzle Measurements				ID: 3
Pre	0.156	0.156	0.156	PASS
Post	0.156	0.156	0.156	PASS

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time		
Start	23:36	End 03:53

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	362.0	598.9	636.6	820.4				
Post	638.6	611.0	654.1	857.5				

Pressures		
Barometric Pressure (P_b)	29.98	in Hg
Stack Static Pressure (P_{static})	0.55	in H ₂ O
Absolute Stack Pressure (P_s)	30.02	in Hg
Absolute Meter Pressure (P_m)	30.11	in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0029			SAMP-CP-0029			SAMP-CP-0029			SAMP-HP-0140			SAMP-HP-0140			5143			SAMP-CC-0001			SAMP-CP-0029			SAMP-CP-0029		
	Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (ΔP)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (V _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m,Std})						
A-1	0.0	00:00:00	48.770	1.40	0.428	0.43	191	233	265	47	74	74	74	74	5.0	1.18	66.60	7.240	97.9	88.222							
A-2	20.3	00:20:15	56.070	1.50	0.428	0.43	190	244	261	48	59	54	76	76	5.0	1.22	68.89	14.611	95.3	87.402							
A-3	41.3	00:41:15	63.530	1.50	0.428	0.43	190	242	261	50	65	60	78	78	5.0	1.22	68.89	22.014	94.6	87.261							
B-1	62.3	01:02:15	71.050	1.10	0.428	0.43	189	250	265	53	68	61	80	80	5.0	1.05	58.95	28.458	98.1	87.501							
B-2	80.3	01:20:15	77.620	1.10	0.428	0.43	190	268	264	51	71	61	80	80	5.0	1.05	58.99	35.009	100.8	87.924							
B-3	98.3	01:38:15	84.300	1.20	0.428	0.43	190	267	257	53	75	63	81	81	5.0	1.10	61.61	41.833	101.9	88.224							
C-1	117.0	01:57:00	91.270	1.20	0.428	0.43	188	267	263	53	74	61	81	81	5.0	1.10	61.52	49.508	102.4	88.202							
C-2	138.5	02:18:30	99.110	1.20	0.428	0.43	190	268	266	54	76	62	81	81	5.0	1.10	61.61	57.330	103.1	88.413							
C-3	160.0	02:40:00	107.100	1.20	0.428	0.43	190	267	261	53	76	61	81	81	5.0	1.10	61.61	65.220	103.8	88.667							
D-1	181.5	03:01:30	115.160	1.40	0.428	0.43	190	227	253	52	74	58	82	82	5.0	1.18	66.55	73.154	103.4	88.920							
D-2	203.0	03:23:00	123.280	1.40	0.428	0.43	190	229	257	53	72	57	82	82	5.0	1.18	66.55	81.206	103.3	89.254							
D-3	224.5	03:44:30	131.520	1.50	0.428	0.43	189	237	250	56	73	59	82	82	5.0	1.22	68.83	89.551	102.9	89.551							
Last Pt	246.8	04:06:45	140.060	1.50	0.428	0.43	189	235	254	58	72	60	82	82	5.0	1.22	68.83										
Final Val	246.8	04:06:45	140.060												Max Vac 5.0		Final Values	89.551	102.9								
Average Values				1.32		0.43	190	249	260	52	71	61	80	80			1.15	64.57									

Notes:

CPM filter temp out of specification due to: Ambient conditions

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	SB
Run Number	2-100 w/DB-PM-2

Filter #	05305
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.7420	5273/10	
Average Stack Temp (t _s)	189.5		°F
Average Meter Temp (t _m)	81.1		
Orifice Meter Coefficient (ΔH@)	1.824		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.16		in H ₂ O
Stack Moisture Content (B _{ws})	6.94		%
Stack Dry Molecular Weight (M _d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.36		acfm
ΔP to ΔH Isokinetic Factor (K)	0.37		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	17.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	4.5	in H ₂ O for	15.0	sec
	Pre (-)	5.7	in H ₂ O for	15.0	sec
	Post (+)	3.6	in H ₂ O for	15.0	sec
	Post (-)	5.1	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0029		
Meter Cal Factor (Y)	1.000		
Nozzle Number	3		
Average Nozzle Diameter (D _{na})	0.1560	in	
Suggested Nozzle Diameter (D _m)	0.1495	in	
Probe Number	SAMP-HP-0140		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	5143		
Impinger Case Number	SAMP-CC-0001		

Nozzle Measurements					ID: 3
Pre	0.156	0.156	0.156	PASS	
Post	0.156	0.156	0.156	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time			
Start	05:03	End	09:10

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	357.0	597.0	755.8	881.8				
Post	484.5	597.6	757.1	898.3				

Pressures			
Barometric Pressure (P _b)	29.91	in Hg	
Stack Static Pressure (P _{static})	0.55	in H ₂ O	
Absolute Stack Pressure (P _s)	29.95	in Hg	
Absolute Meter Pressure (P _m)	30.04	in Hg	

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0029	SAMP-CP-0029	SAMP-CP-0029									SAMP-CP-0029				SAMP-CP-0029				
	Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	140.470	1.30	0.428	0.43	189	250	268	55	54	53	77	77	3.0	1.14	63.08	7.517	97.6	91.601
A-2	20.3	00:20:15	148.110	1.30	0.428	0.43	188	270	265	54	54	53	79	79	3.0	1.14	63.04	15.301	99.3	93.223
A-3	40.5	00:40:30	156.050	1.30	0.428	0.43	190	270	259	54	55	52	82	82	3.0	1.14	63.13	22.603	97.8	91.806
B-1	60.8	01:00:45	163.540	1.20	0.428	0.43	190	246	260	52	55	55	80	80	3.0	1.10	60.66	29.609	99.9	92.774
B-2	78.8	01:18:45	170.700	1.20	0.428	0.43	189	255	261	52	56	55	81	81	3.0	1.10	60.61	36.348	100.4	92.701
B-3	96.8	01:36:45	177.600	1.10	0.428	0.43	189	266	261	53	56	59	82	82	3.0	1.05	58.03	41.905	99.3	90.701
C-1	114.0	01:54:00	183.300	1.40	0.428	0.43	190	243	258	55	57	60	82	82	3.0	1.18	65.52	49.899	98.5	90.867
C-2	135.5	02:15:30	191.500	1.50	0.428	0.43	190	245	248	61	65	65	81	81	3.0	1.22	67.82	58.259	97.5	91.128
C-3	157.8	02:37:45	200.060	1.60	0.428	0.43	189	250	238	55	67	65	82	82	3.0	1.26	69.99	67.257	96.9	91.815
D-1	180.8	03:00:45	209.290	1.40	0.428	0.43	190	255	255	56	70	66	82	82	3.0	1.18	65.52	75.212	96.5	91.760
D-2	202.3	03:22:15	217.450	1.50	0.428	0.43	190	250	252	55	71	67	82	82	3.0	1.22	67.82	83.840	96.4	92.149
D-3	224.5	03:44:30	226.300	1.50	0.428	0.43	190	255	250	55	71	69	83	83	3.0	1.22	67.82	92.227	96.0	92.227
Last Pt	246.8	04:06:45	234.920																	
Final Val	246.8	04:06:45	234.920												Max Vac	3.0	Final Values	92.227	96.0	
Average Values				1.36		0.43	190	255	256	55	61	60	81	81		1.16	64.42			

Notes:

CPM filter temp out of specification due to: Ambient conditions

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	SB
Run Number	2-100 w/DB-PM-3

Filter #	05290
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7420	5273/10	
Average Stack Temp (t_s)	188.8		°F
Average Meter Temp (t_m)	78.6		
Orifice Meter Coefficient (ΔH_{or})	1.824		in H ₂ O
Square Root ΔP ($\Delta P_{avg}^{1/2}$)	1.18		in H ₂ O
Stack Moisture Content (B_{ws})	11.07		%
Stack Dry Molecular Weight (M_d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.37		acfm
ΔP to ΔH Isokinetic Factor (K)	0.35		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot Pre (+)	3.6	in H ₂ O for	15.0	sec
	Pre (-)	4.5	in H ₂ O for	15.0	sec
	Post (+)	5.8	in H ₂ O for	15.0	sec
	Post (-)	6.1	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0029		
Meter Cal Factor (Y)	1.000		
Nozzle Number	3		
Average Nozzle Diameter (D_{na})	0.1560	in	
Suggested Nozzle Diameter (D_m)	0.1507	in	
Probe Number	SAMP-HP-0140	in	
Probe Length	108	in	
Liner Material	glass		
Sample Case / Oven Number	5143		
Impinger Case Number	SAMP-CC-0001		

Nozzle Measurements				ID: 3
Pre	0.156	0.156	0.156	PASS
Post	0.156	0.156	0.156	PASS

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time		
Start	10:20	End 14:39

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	361.8	600.8	654.0	848.0				
Post	566.5	608.5	668.5	895.1				

Pressures		
Barometric Pressure (P_b)	29.78	in Hg
Stack Static Pressure (P_{static})	0.55	in H ₂ O
Absolute Stack Pressure (P_s)	29.82	in Hg
Absolute Meter Pressure (P_m)	29.91	in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0029	SAMP-CP-0029	SAMP-CP-0029									SAMP-CP-0029				SAMP-CP-0029				
	Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (I)
A-1	0.0	00:00:00	234.480	1.40	0.428	0.43	190	254	245	58	62	68	78	78	5.0	1.18	66.20	7.353	95.7	89.967
A-2	20.3	00:20:15	242.000	1.50	0.428	0.43	190	253	254	58	65	68	78	78	5.0	1.22	68.53	16.545	104.5	99.372
A-3	41.3	00:41:15	251.400	1.50	0.428	0.43	188	256	250	58	65	70	78	78	5.0	1.22	68.42	25.102	104.2	99.902
B-1	62.3	01:02:15	260.150	1.40	0.428	0.43	183	259	253	65	71	70	78	78	5.0	1.18	65.84	31.604	102.2	97.570
B-2	80.3	01:20:15	266.800	1.50	0.428	0.43	190	251	253	65	71	70	78	78	5.0	1.22	68.53	39.779	104.3	99.801
B-3	98.8	01:38:45	275.160	1.50	0.428	0.43	190	258	260	58	75	80	79	79	5.0	1.22	68.53	48.202	106.4	101.852
C-1	117.3	01:57:15	283.790	1.20	0.428	0.43	190	256	257	52	70	75	79	79	5.0	1.10	61.29	57.582	109.3	102.818
C-2	138.8	02:18:45	293.400	1.20	0.428	0.43	189	257	264	55	70	78	79	79	5.0	1.10	61.24	66.611	110.7	102.982
C-3	160.3	02:40:15	302.650	1.20	0.428	0.43	189	244	257	55	75	78	79	79	5.0	1.10	61.24	75.454	111.4	102.854
D-1	181.8	03:01:45	311.710	1.40	0.428	0.43	189	246	259	56	79	78	79	79	5.0	1.18	66.15	84.619	111.5	103.145
D-2	203.3	03:23:15	321.100	1.50	0.428	0.43	189	250	263	60	81	80	79	79	5.0	1.22	68.47	94.233	111.3	103.531
D-3	225.5	03:45:30	330.950	1.50	0.428	0.43	189	260	263	60	81	80	79	79	5.0	1.22	68.47	103.759	111.1	103.759
Last Pt	247.8	04:07:45	340.710																	
Final Val	247.8	04:07:45	340.710												Max Vac	5.0	Final Values	103.759	111.1	
Average Values				1.40		0.43	189	254	257	58	72	75	79	79			1.18	66.08		

Notes:

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
without Duct Burners Firing
Sulfuric Acid Mist Data**

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	2-Base-SO3-1	2-Base-SO3-2	2-Base-SO3-3	Average	Units	Limits
Run Start Time	12:22	20:29	23:10		hh:mm	
Run Stop Time	14:22	22:29	01:10		hh:mm	
Test Date	09/24/18	09/25/18	09/25/18		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	1.017	1.017	1.017			
Stack Test Data	2-Base-SO3-1	2-Base-SO3-2	2-Base-SO3-3	Average	Units	Limits
Initial Meter Volume	0.133	88.713	135.626		ft ³	
Final Meter Volume	41.206	129.911	176.778		ft ³	
Total Meter Volume	41.073	41.198	41.152	41.141	ft ³	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	76.50	72.67	74.04	74.40	°F	
Average Stack Temperature	220.13	203.83	205.04	209.67	°F	
Barometric Pressure	29.97	29.65	29.61	29.74	in Hg	
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89	in H ₂ O	
Absolute Stack Pressure	29.90	29.58	29.54	29.68	in Hg	
Average Orifice Pressure Drop	0.44	0.42	0.42	0.43	in H ₂ O	
Absolute Meter Pressure	30.10	29.78	29.74	29.88	in Hg	
Avg Square Root Pitot Pressure					$\sqrt{\text{in H}_2\text{O}}$	
Moisture Content Data	2-Base-SO3-1	2-Base-SO3-2	2-Base-SO3-3	Average	Units	Limits
Impinger Water Weight Gain	82.30	95.20	82.00	86.50	g	
Silica Gel Weight Gain	8.90	10.50	7.30	8.90	g	
Total Water Volume Collected	91.36	105.89	89.46	95.57	ml	
Standard Water Vapor Volume	4.30	4.98	4.21	4.50	scf	
Standard Meter Volume	41.2	41.2	41.0	41.1	dscf	
Standard Metric Meter Volume	1.2	1.2	1.2	1.2	dscm	
Calculated Stack Moisture	9.45	10.79	9.31	9.85	%	
Saturated Stack Moisture	100.00	85.74	88.00	91.25	%	
Reported Stack Moisture Content	9.45	10.79	9.31	9.85	%	
Gas Analysis Data	2-Base-SO3-1	2-Base-SO3-2	2-Base-SO3-3	Average	Units	Limits
Carbon Dioxide Content	4.1	4.1	4.1	4.1	%	
Oxygen Content	13.5	13.5	13.5	13.5	%	
Carbon Monoxide Content	0.7	0.6	0.6	0.6	ppm	
Nitrogen Content	82.4	82.4	82.4	82.4	%	
Stack Dry Molecular Weight	29.20	29.20	29.20	29.20	lb/lb-mole	
Stack Wet Molecular Weight	28.14	27.99	28.15	28.09	lb/lb-mole	
Calculated Fuel Factor	1.805	1.805	1.805	1.805		
Fuel F-Factor	8633.27	8632.22	8632.22	8632.57	dscf/MMBtu	
Percent Excess Air	163.6	163.6	163.6	163.6	%	
Volumetric Flow Rate Data	2-Base-SO3-1	2-Base-SO3-2	2-Base-SO3-3	Average	Units	Limits
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Sulfuric Acid Mist IC Analysis	2-Base-SO3-1	2-Base-SO3-2	2-Base-SO3-3	Average	Units	Limits
H ₂ SO ₄ (IC) Sample Volume - Front Half Rinse	121.0	100.0	121.0	114.00	ml	--
H ₂ SO ₄ (IC) Sample - Mass Per Volume	0.099	0.100	0.116	0.10	mg/L	--
H ₂ SO ₄ (IC) Mass	0.01	0.01	0.01	0.01	mg	--
H ₂ SO ₄ (IC) Concentration	2.91E-07	2.43E-07	3.42E-07	2.92E-07	g/dscf	--
	4.49E-06	3.75E-06	5.27E-06	4.50E-06	gr/dscf	--
	1.03E-08	8.57E-09	1.21E-08	1.03E-08	g/L	--
	0.00	0.00	0.00	0.00	ppmvd	--
H ₂ SO ₄ (IC) Emission Rate	0.000016	0.000013	0.000018	0.000016	lb/MMBtu	0.0007

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		PM/BL/SB	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	8a, 2.4.1.3	10.6	scf
Run Duration	10 L/min	120	minutes
Unit Number		CTG-2	
Base Run Number		2-Base-SO3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/24/18	09/25/18	09/25/18	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8633.27	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	
Meter Calibration Factor	(Y)	1.017	1.017	1.017	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.820	1.820	1.820	in H ₂ O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-S3-0005	SAMP-S3-0005	SAMP-S3-0005	
Probe Length		72.0	72.0	72.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-MBH-0009	SAMP-MBH-0009	SAMP-MBH-0009	
Impinger Case Number	from ACS	5410	SAMP-BC-0009	5410	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/06/18		
Sampling Location	CTG-2 Stack	Operator	PM/BL/SB		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	2-Base-SO3-1		Date	09/24/18	Run Start Time	12:22	Run Stop Time	14:22
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.1	13.5	0.7	82.4	29.20	1.805	163.6	YES

Gas Analysis Data								
Run Number	2-Base-SO3-2		Date	09/25/18	Run Start Time	20:29	Run Stop Time	22:29
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.1	13.5	0.6	82.4	29.20	1.805	163.6	YES

Gas Analysis Data								
Run Number	2-Base-SO3-3		Date	09/25/18	Run Start Time	23:10	Run Stop Time	01:10
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.1	13.5	0.6	82.4	29.20	1.805	163.6	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/06/18
Sampling Location	CTG-2 Stack	Operator	PM/BL/SB
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/06/18	500	499.9	-0.1	Pass
Test Day 1	09/24/18	500	500.0	0.0	Pass

Moisture Content Data									
Run Number	2-Base-SO3-1		Date	09/24/18	Start Time	12:22	Stop Time	14:22	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor			(Y)	1.017		
Total Meter Volume	(V _m)	41.073	dcf	Barometric Pressure	(P _b)	29.97	in Hg		
Average Stack Temp	(t _s) _{avg}	220	°F	Stack Static Pressure	(P _{static})	-0.89	in H ₂ O		
Average Meter Temp	(t _m) _{avg}	77	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.44	in H ₂ O		
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel					
Final Value	(V _f),(W _f)	806.20	656.50	597.50	869.10				
Initial Value	(V _i),(W _i)	736.20	646.20	595.50	860.20				
Net Value	(V _n),(W _n)	70.0	10.3	2.0	8.9				
Results									
Total Weight	(W _t)	91.20	g	Water Vol Weighed	(V _{wsg(std)})	4.300	scf		
Std Meter Volume	(V _{m(std)})	41.223	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.00	%		
Calc Moisture Content	(B _{ws(calc)})	9.45	%	Final Moisture Content	(B _{ws})	9.45	%		

Moisture Content Data									
Run Number	2-Base-SO3-2		Date	09/25/18	Start Time	20:29	Stop Time	22:29	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor			(Y)	1.017		
Total Meter Volume	(V _m)	41.198	dcf	Barometric Pressure	(P _b)	29.65	in Hg		
Average Stack Temp	(t _s) _{avg}	204	°F	Stack Static Pressure	(P _{static})	-0.89	in H ₂ O		
Average Meter Temp	(t _m) _{avg}	73	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O		
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel					
Final Value	(V _f),(W _f)	767.30	718.60	588.70	888.30				
Initial Value	(V _i),(W _i)	685.30	707.50	586.60	877.80				
Net Value	(V _n),(W _n)	82.0	11.1	2.1	10.5				
Results									
Total Weight	(W _t)	105.70	g	Water Vol Weighed	(V _{wsg(std)})	4.984	scf		
Std Meter Volume	(V _{m(std)})	41.199	dscf	Sat. Moisture Content	(B _{ws(svp)})	85.74	%		
Calc Moisture Content	(B _{ws(calc)})	10.79	%	Final Moisture Content	(B _{ws})	10.79	%		

Moisture Content Data									
Run Number	2-Base-SO3-3		Date	09/25/18	Start Time	23:10	Stop Time	01:10	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor			(Y)	1.017		
Total Meter Volume	(V _m)	41.152	dcf	Barometric Pressure	(P _b)	29.61	in Hg		
Average Stack Temp	(t _s) _{avg}	205	°F	Stack Static Pressure	(P _{static})	-0.89	in H ₂ O		
Average Meter Temp	(t _m) _{avg}	74	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O		
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel					
Final Value	(V _f),(W _f)	735.70	706.90	615.20	867.10				
Initial Value	(V _i),(W _i)	658.70	701.50	615.60	859.80				
Net Value	(V _n),(W _n)	77.0	5.4	-0.4	7.3				
Results									
Total Weight	(W _t)	89.30	g	Water Vol Weighed	(V _{wsg(std)})	4.210	scf		
Std Meter Volume	(V _{m(std)})	40.992	dscf	Sat. Moisture Content	(B _{ws(svp)})	88.00	%		
Calc Moisture Content	(B _{ws(calc)})	9.31	%	Final Moisture Content	(B _{ws})	9.31	%		

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	PM/BL/SB
Run Number	2-Base-SO3-1

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	220.1		°F
Average Meter Temp (t _m)	76.5		
Orifice Meter Coefficient (ΔH ₀)	1.820		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _{ws})	9.45		%
Stack Dry Molecular Weight (M _d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.75		acfm
ΔP to ΔH IsoKinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter (D _{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D _m)	in		
Probe Number	SAMP-S3-0005		
Probe Length	72		
Liner Material	glass		
Sample Case / Oven Number	SAMP-MBH-0009		
Impinger Case Number	5410		

Nozzle Measurements				ID:
Pre	--	--	--	PASS
Post	--	--	--	PASS

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	12:22	End	14:22

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	736.2	646.2	595.5	860.2				
Post	806.2	656.5	597.5	869.1				

Pressures			
Barometric Pressure (P _b)	29.97		in Hg
Stack Static Pressure (P _{static})	-0.89		in H ₂ O
Absolute Stack Pressure (P _s)	29.90		in Hg
Absolute Meter Pressure (P _m)	30.10		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025			SAMP-S3-0005	SAMP-S3-0005	SAMP-MBH-0009	5410					SAMP-CP-0025		SAMP-CP-0025						
									Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})		Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m, std})							
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m, std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m, std})			
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf			
A-1	0.0	00:00:00	0.133	--	--	0.44	221	352	506	68	175	--	73	73	2.0	--	1.861	--	44.660			
A-1	5.0	00:05:00	1.975	--	--	0.44	221	362	520	68	185	--	73	73	2.0	--	3.588	--	43.060			
A-1	10.0	00:10:00	3.685	--	--	0.44	221	368	513	68	172	--	73	73	2.0	--	5.336	--	42.688			
A-1	15.0	00:15:00	5.415	--	--	0.44	221	373	512	62	174	--	74	74	2.0	--	7.141	--	42.846			
A-1	20.0	00:20:00	7.205	--	--	0.44	221	374	512	63	177	--	75	75	2.0	--	8.973	--	43.069			
A-1	25.0	00:25:00	9.025	--	--	0.44	218	375	515	64	176	--	75	75	2.0	--	10.874	--	43.496			
A-1	30.0	00:30:00	10.914	--	--	0.44	218	373	513	61	176	--	76	76	2.0	--	12.823	--	43.964			
A-1	35.0	00:35:00	12.854	--	--	0.44	217	374	512	60	176	--	76	76	2.0	--	14.456	--	43.369			
A-1	40.0	00:40:00	14.480	--	--	0.44	218	374	513	68	176	--	76	76	2.0	--	16.435	--	43.827			
A-1	45.0	00:45:00	16.450	--	--	0.44	221	374	508	64	176	--	76	76	2.0	--	18.053	--	43.326			
A-1	50.0	00:50:00	18.060	--	--	0.44	221	375	515	63	175	--	76	76	2.0	--	20.077	--	43.804			
A-1	55.0	00:55:00	20.075	--	--	0.44	222	373	511	63	176	--	77	77	2.0	--	21.606	--	43.212			
A-1	60.0	01:00:00	21.600	--	--	0.44	221	373	510	63	176	--	78	78	2.0	--	23.247	--	42.918			
A-1	65.0	01:05:00	23.240	--	--	0.44	222	374	513	64	176	--	78	78	2.0	--	25.129	--	43.078			
A-1	70.0	01:10:00	25.120	--	--	0.44	221	374	513	64	175	--	78	78	2.0	--	26.961	--	43.137			
A-1	75.0	01:15:00	26.950	--	--	0.44	221	373	515	64	176	--	78	78	2.0	--	28.192	--	42.287			
A-1	80.0	01:20:00	28.180	--	--	0.44	221	374	514	65	176	--	78	78	2.0	--	29.743	--	41.990			
A-1	85.0	01:25:00	29.730	--	--	0.44	219	373	515	66	175	--	78	78	2.0	--	31.524	--	42.032			
A-1	90.0	01:30:00	31.510	--	--	0.44	219	374	511	66	175	--	78	78	2.0	--	33.096	--	41.805			
A-1	95.0	01:35:00	33.080	--	--	0.44	220	373	512	66	173	--	78	78	2.0	--	34.717	--	41.660			
A-1	100.0	01:40:00	34.700	--	--	0.44	220	372	514	65	169	--	78	78	2.0	--	36.318	--	41.507			
A-1	105.0	01:45:00	36.300	--	--	0.44	220	371	516	65	164	--	78	78	2.0	--	37.970	--	41.422			
A-1	110.0	01:50:00	37.950	--	--	0.44	220	371	512	65	162	--	78	78	2.0	--	39.841	--	41.574			
A-1	115.0	01:55:00	39.820	--	--	0.44	219	371	514	66	182	--	78	78	2.0	--	41.229	--	41.229			
Last Pt	120.0	02:00:00	41.206	--	--																	
Final Val	120.0	02:00:00	41.206																			
Average Values						0.44	220	372	513	65	175		77	77								

77

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	PM/BL/SB
Run Number	2-Base-SO3-2

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	203.8		°F
Average Meter Temp (t _m)	72.7		
Orifice Meter Coefficient (ΔH _@)	1.820		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _{ws})	10.79		%
Stack Dry Molecular Weight (M _d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.34		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	9.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter (D _{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D _m)	in		
Probe Number	SAMP-S3-0005		
Probe Length	72		
Liner Material	glass		
Sample Case / Oven Number	SAMP-MBH-0009		
Impinger Case Number	SAMP-BC-0009		

Nozzle Measurements				ID:
Pre	--	--	--	PASS
Post	--	--	--	PASS

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	20:29	End	22:29

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	685.3	707.5	586.6	877.8				
Post	767.3	718.6	588.7	888.3				

Pressures			
Barometric Pressure (P _b)	29.65		in Hg
Stack Static Pressure (P _{static})	-0.89		in H ₂ O
Absolute Stack Pressure (P _s)	29.58		in Hg
Absolute Meter Pressure (P _m)	29.78		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025			SAMP-S3-0005	SAMP-S3-0005	SAMP-MBH-0009	SAMP-BC-0009			SAMP-CP-0025		SAMP-CP-0025						
												Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})							
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2} _{in H₂O})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m,Std})	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	88.713	--	--	0.42	206	375	512	65	185	--	70	70	2.0	--	--	1.772	#DIV/0!	42.526
A-2	5.0	00:05:00	90.476	--	--	0.42	202	374	515	60	184	--	71	71	2.0	--	--	3.567	#DIV/0!	42.799
A-3	10.0	00:10:00	92.265	--	--	0.42	202	372	515	60	179	--	71	71	2.0	--	--	5.274	#DIV/0!	42.192
A-4	15.0	00:15:00	93.967	--	--	0.42	203	372	515	61	179	--	71	71	2.0	--	--	6.986	#DIV/0!	41.919
A-5	20.0	00:20:00	95.674	--	--	0.42	203	375	523	62	173	--	71	71	2.0	--	--	8.715	#DIV/0!	41.831
A-6	25.0	00:25:00	97.397	--	--	0.42	203	374	516	62	170	--	71	71	2.0	--	--	10.437	#DIV/0!	41.749
B-1	30.0	00:30:00	99.114	--	--	0.42	203	373	522	63	169	--	71	71	2.0	--	--	12.154	#DIV/0!	41.670
B-2	35.0	00:35:00	100.825	--	--	0.42	203	375	522	63	167	--	71	71	2.0	--	--	13.876	#DIV/0!	41.629
B-3	40.0	00:40:00	102.542	--	--	0.42	203	375	523	64	165	--	71	71	2.0	--	--	15.592	#DIV/0!	41.578
B-4	45.0	00:45:00	104.252	--	--	0.42	203	375	517	63	161	--	71	71	2.0	--	--	17.305	#DIV/0!	41.532
B-5	50.0	00:50:00	105.960	--	--	0.42	203	374	517	63	157	--	71	71	2.0	--	--	19.013	#DIV/0!	41.484
B-6	55.0	00:55:00	107.663	--	--	0.42	204	373	517	63	154	--	72	72	2.0	--	--	20.720	#DIV/0!	41.439
C-1	60.0	01:00:00	109.367	--	--	0.42	203	374	511	63	153	--	72	72	2.0	--	--	22.430	#DIV/0!	41.409
C-2	65.0	01:05:00	111.075	--	--	0.42	204	374	514	64	149	--	73	73	2.0	--	--	24.156	#DIV/0!	41.410
C-3	70.0	01:10:00	112.802	--	--	0.42	203	374	520	64	147	--	73	73	2.0	--	--	25.820	#DIV/0!	41.312
C-4	75.0	01:15:00	114.467	--	--	0.42	203	373	515	64	148	--	74	74	2.0	--	--	27.530	#DIV/0!	41.294
C-5	80.0	01:20:00	116.181	--	--	0.42	203	375	515	65	149	--	74	74	2.0	--	--	29.238	#DIV/0!	41.278
C-6	85.0	01:25:00	117.894	--	--	0.42	203	375	514	66	151	--	75	75	2.0	--	--	30.935	#DIV/0!	41.247
D-1	90.0	01:30:00	119.598	--	--	0.42	205	374	523	65	149	--	75	75	2.0	--	--	32.625	#DIV/0!	41.210
D-2	95.0	01:35:00	121.295	--	--	0.42	206	374	518	56	138	--	75	75	2.0	--	--	34.348	#DIV/0!	41.218
D-3	100.0	01:40:00	123.026	--	--	0.42	206	374	515	54	137	--	75	75	2.0	--	--	36.062	#DIV/0!	41.213
D-4	105.0	01:45:00	124.747	--	--	0.42	206	374	508	53	131	--	75	75	2.0	--	--	37.780	#DIV/0!	41.215
D-5	110.0	01:50:00	126.473	--	--	0.42	206	375	510	52	126	--	75	75	2.0	--	--	39.499	#DIV/0!	41.216
D-6	115.0	01:55:00	128.199	--	--	0.42	206	375	519	53	130	--	76	76	2.0	--	--	41.200	#DIV/0!	41.200
Last Pt	120.0	02:00:00	129.911	--	--														#DIV/0!	
Final Val	120.0	02:00:00	129.911											Max Vac	2.0	Final Values	41.200			
Average Values						0.42	204	374	517	61	156		73	73						

73

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	PM/BL/SB
Run Number	2-Base-SO3-3

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	205.0		°F
Average Meter Temp (t _m)	74.0		
Orifice Meter Coefficient (ΔH ₀)	1.820		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _{ws})	9.31		%
Stack Dry Molecular Weight (M _d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.34		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	17.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter (D _{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D _m)		in	
Probe Number	SAMP-S3-0005		
Probe Length	72		
Liner Material	glass		
Sample Case / Oven Number	SAMP-MBH-0009		
Impinger Case Number	5410		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	23:10	End 01:10

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	658.7	701.5	615.6	859.8				
Post	735.7	706.9	615.2	867.1				

Pressures			
Barometric Pressure (P _b)	29.61		in Hg
Stack Static Pressure (P _{static})	-0.89		in H ₂ O
Absolute Stack Pressure (P _s)	29.54		in Hg
Absolute Meter Pressure (P _m)	29.74		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025			SAMP-S3-0005	SAMP-S3-0005	SAMP-MBH-0009	5410				SAMP-CP-0025	SAMP-CP-0025						
									Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})								
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (%)	Est-Run Meter Volume (V _{m,Std})	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	135.626	--	--	0.42	205	377	510	57	64	--	74	74	2.0	--	1.792	#DIV/0!	43.012	
A-2	5.0	00:05:00	137.425	--	--	0.42	205	377	521	54	67	--	74	74	2.0	--	3.471	#DIV/0!	41.649	
A-3	10.0	00:10:00	139.110	--	--	0.42	205	375	517	53	69	--	74	74	2.0	--	5.149	#DIV/0!	41.195	
A-4	15.0	00:15:00	140.795	--	--	0.42	205	375	511	55	74	--	74	74	2.0	--	6.830	#DIV/0!	40.979	
A-5	20.0	00:20:00	142.482	--	--	0.42	205	375	520	56	73	--	74	74	2.0	--	8.507	#DIV/0!	40.836	
A-6	25.0	00:25:00	144.166	--	--	0.42	205	375	521	56	77	--	74	74	2.0	--	10.208	#DIV/0!	40.832	
B-1	30.0	00:30:00	145.873	--	--	0.42	205	375	512	57	75	--	75	75	2.0	--	11.910	#DIV/0!	40.835	
B-2	35.0	00:35:00	147.585	--	--	0.42	206	375	515	57	77	--	74	74	2.0	--	13.609	#DIV/0!	40.826	
B-3	40.0	00:40:00	149.290	--	--	0.42	205	375	518	58	80	--	74	74	2.0	--	15.308	#DIV/0!	40.822	
B-4	45.0	00:45:00	150.996	--	--	0.42	205	375	518	60	81	--	74	74	2.0	--	17.002	#DIV/0!	40.804	
B-5	50.0	00:50:00	152.696	--	--	0.42	205	375	522	60	76	--	74	74	2.0	--	18.694	#DIV/0!	40.788	
B-6	55.0	00:55:00	154.395	--	--	0.42	205	375	519	59	81	--	74	74	2.0	--	20.381	#DIV/0!	40.762	
C-1	60.0	01:00:00	156.088	--	--	0.42	204	375	516	59	76	--	74	74	2.0	--	22.068	#DIV/0!	40.742	
C-2	65.0	01:05:00	157.782	--	--	0.42	205	375	515	59	77	--	74	74	2.0	--	23.745	#DIV/0!	40.706	
C-3	70.0	01:10:00	159.465	--	--	0.42	205	375	518	58	77	--	74	74	2.0	--	25.426	#DIV/0!	40.681	
C-4	75.0	01:15:00	161.152	--	--	0.42	205	375	516	60	80	--	74	74	2.0	--	27.100	#DIV/0!	40.650	
C-5	80.0	01:20:00	162.833	--	--	0.42	204	376	515	62	83	--	74	74	2.0	--	28.772	#DIV/0!	40.619	
C-6	85.0	01:25:00	164.511	--	--	0.42	204	376	514	63	82	--	74	74	2.0	--	30.526	#DIV/0!	40.701	
D-1	90.0	01:30:00	166.272	--	--	0.42	204	375	518	63	82	--	74	74	2.0	--	32.277	#DIV/0!	40.771	
D-2	95.0	01:35:00	168.030	--	--	0.42	204	375	513	63	86	--	74	74	2.0	--	34.033	#DIV/0!	40.839	
D-3	100.0	01:40:00	169.792	--	--	0.42	204	375	520	64	85	--	74	74	2.0	--	35.775	#DIV/0!	40.886	
D-4	105.0	01:45:00	171.541	--	--	0.42	208	375	522	65	84	--	74	74	2.0	--	37.516	#DIV/0!	40.927	
D-5	110.0	01:50:00	173.289	--	--	0.42	205	375	522	63	73	--	74	74	2.0	--	39.266	#DIV/0!	40.973	
D-6	115.0	01:55:00	175.045	--	--	0.42	208	375	516	64	85	--	74	74	2.0	--	40.992	#DIV/0!	40.992	
Last Pt	120.0	02:00:00	176.778	--	--														#DIV/0!	
Final Val	120.0	02:00:00	176.778											Max Vac	2.0	Final Values	40.992			
Average Values						0.42	205	375	517	59	78		74	74						

74

Notes:

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
with Duct Burners Firing
Sulfuric Acid Mist Data**

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	2-100 w/DB-SO3-1	2-100 w/DB-SO3-2	2-100 w/DB-SO3-3	Average	Units	Limits
Run Start Time	12:31	03:47	06:29		hh:mm	
Run Stop Time	14:31	05:47	08:29		hh:mm	
Test Date	09/25/18	09/25/18	09/25/18		mm/dd/yy	
Load	w/DB	w/DB	w/DB		% or w/DB	--
Meter Calibration Factor	1.017	1.017	1.017			
Stack Test Data	2-100 w/DB-SO3-1	2-100 w/DB-SO3-2	2-100 w/DB-SO3-3	Average	Units	Limits
Initial Meter Volume	0.265	47.005	0.000		ft ³	
Final Meter Volume	41.132	88.117	41.760		ft ³	
Total Meter Volume	40.867	41.112	41.760	41.246	ft ³	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	70.24	71.92	73.75	71.97	°F	
Average Stack Temperature	189.92	188.68	190.00	189.53	°F	
Barometric Pressure	29.98	29.91	29.91	29.93	in Hg	
Stack Static Pressure	0.55	0.55	0.55	0.55	in H ₂ O	
Absolute Stack Pressure	30.02	29.95	29.95	29.97	in Hg	
Average Orifice Pressure Drop	0.42	0.42	0.42	0.42	in H ₂ O	
Absolute Meter Pressure	30.11	30.04	30.04	30.07	in Hg	
Moisture Content Data	2-100 w/DB-SO3-1	2-100 w/DB-SO3-2	2-100 w/DB-SO3-3	Average	Units	Limits
Impinger Water Weight Gain	99.30	36.60	92.50	76.13	g	
Silica Gel Weight Gain	10.70	8.70	14.00	11.13	g	
Total Water Volume Collected	110.20	45.38	106.69	87.42	ml	
Standard Water Vapor Volume	5.19	2.14	5.02	4.11	scf	
Standard Meter Volume	41.5	41.5	42.0	41.7	dscf	
Standard Metric Meter Volume	1.2	1.2	1.2	1.2	dscm	
Calculated Stack Moisture	11.11	4.89	10.67	8.89	%	
Saturated Stack Moisture	63.12	61.60	63.38	62.70	%	
Reported Stack Moisture Content	11.11	4.89	10.67	8.89	%	
Gas Analysis Data	2-100 w/DB-SO3-1	2-100 w/DB-SO3-2	2-100 w/DB-SO3-3	Average	Units	Limits
Carbon Dioxide Content	4.9	4.9	5.0	4.9	%	
Oxygen Content	12.0	12.0	12.0	12.0	%	
Carbon Monoxide Content	0.3	0.2	0.2	0.2	ppm	
Nitrogen Content	83.1	83.1	83.0	83.1	%	
Stack Dry Molecular Weight	29.26	29.27	29.27	29.27	lb/lb-mole	
Stack Wet Molecular Weight	28.01	28.72	28.07	28.27	lb/lb-mole	
Calculated Fuel Factor	1.824	1.809	1.796	1.810		
Fuel F-Factor	8632.22	8632.22	8632.22	8632.22	dscf/MMBtu	
Percent Excess Air	120.2	120.8	121.2	120.7	%	
Volumetric Flow Rate Data	2-100 w/DB-SO3-1	2-100 w/DB-SO3-2	2-100 w/DB-SO3-3	Average	Units	Limits
Stack Cross-Sectional Area	285.40	285.40	285.40	285.40	ft ²	

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Sulfuric Acid Mist IC Analysis	2-100 w/DB-SO3-1	2-100 w/DB-SO3-2	2-100 w/DB-SO3-3	Average	Units	Limits
H ₂ SO ₄ (IC) Sample Volume - Front Half Rinse	76.0	105.0	114.0	98.33	ml	--
H ₂ SO ₄ (IC) Sample - Mass Per Volume	0.105	0.105	0.105	0.11	mg/L	--
H ₂ SO ₄ (IC) Mass	0.01	0.01	0.01	0.01	mg	--
H ₂ SO ₄ (IC) Concentration	1.93E-07	2.65E-07	2.85E-07	2.48E-07	g/dscf	--
	2.97E-06	4.09E-06	4.40E-06	3.82E-06	gr/dscf	--
	6.81E-09	9.35E-09	1.01E-08	8.75E-09	g/L	--
	0.0017	0.0023	0.0025	0.0021	ppmvd	--
H ₂ SO ₄ (IC) Emission Rate	0.000009	0.000012	0.000013	0.000011	lb/MMBtu	0.0007

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		SB	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	8a, 2.4.1.3	10.6	scf
Run Duration	10 L/min	120	minutes
Unit Number		CTG-2	
Base Run Number		2-100 w/DB-SO3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/25/18	09/25/18	09/25/18	
Load		w/DB	w/DB	w/DB	% or w/DB
Fuel F-Factor		8632.22	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	
Meter Calibration Factor	(Y)	1.017	1.017	1.017	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.820	1.820	1.820	in H ₂ O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-S3-0005	SAMP-S3-0005	SAMP-S3-0005	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-bh-0009	samp-bh-0009	samp-bh-0009	
Impinger Case Number	from ACS	samp-bc-0029	samp-bc-0029	samp-bc-0029	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18		
Sampling Location	CTG-2 Stack	Operator	SB		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	2-100 w/DB-SO3-1		Date	09/25/18	Run Start Time	12:31	Run Stop Time	14:31
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.9	12.0	0.3	83.1	29.26	1.824	120.2	YES

Gas Analysis Data								
Run Number	2-100 w/DB-SO3-2		Date	09/25/18	Run Start Time	03:47	Run Stop Time	05:47
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.9	12.0	0.2	83.1	29.27	1.809	120.8	YES

Gas Analysis Data								
Run Number	2-100 w/DB-SO3-3		Date	09/25/18	Run Start Time	06:29	Run Stop Time	08:29
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	5.0	12.0	0.2	83.0	29.27	1.796	121.2	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18
Sampling Location	CTG-2 Stack	Operator	SB
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0022	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	09/25/18	500	499.9	-0.1	Pass

Moisture Content Data									
Run Number	2-100 w/DB-SO3-1		Date	09/25/18	Start Time	12:31	Stop Time	14:31	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor		(Y)	1.017			
Total Meter Volume	(V _m)	40.867	dcf	Barometric Pressure	(P _b)	29.98	in Hg		
Average Stack Temp	(t _s) _{avg}	190	°F	Stack Static Pressure	(P _{static})	0.55	in H ₂ O		
Average Meter Temp	(t _m) _{avg}	70	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O		
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
		(g)	(g)	(g)	(g)				
Contents		H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	799.30	736.80	614.50	961.90				
Initial Value	(V _i),(W _i)	710.00	729.30	612.00	951.20				
Net Value	(V _n),(W _n)	89.3	7.5	2.5	10.7				
Results									
Total Weight	(W _t)	110.00	g	Water Vol Weighed	(V _{wsg(std)})	5.186	scf		
Std Meter Volume	(V _{m(std)})	41.512	dscf	Sat. Moisture Content	(B _{ws(svp)})	63.12	%		
Calc Moisture Content	(B _{ws(calc)})	11.11	%	Final Moisture Content	(B _{ws})	11.11	%		

Moisture Content Data									
Run Number	2-100 w/DB-SO3-2		Date	09/25/18	Start Time	03:47	Stop Time	05:47	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor		(Y)	1.017			
Total Meter Volume	(V _m)	41.112	dcf	Barometric Pressure	(P _b)	29.91	in Hg		
Average Stack Temp	(t _s) _{avg}	189	°F	Stack Static Pressure	(P _{static})	0.55	in H ₂ O		
Average Meter Temp	(t _m) _{avg}	72	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O		
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
		(g)	(g)	(g)	(g)				
Contents		H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	714.90	686.90	586.60	877.80				
Initial Value	(V _i),(W _i)	688.30	678.20	585.30	869.10				
Net Value	(V _n),(W _n)	26.6	8.7	1.3	8.7				
Results									
Total Weight	(W _t)	45.30	g	Water Vol Weighed	(V _{wsg(std)})	2.136	scf		
Std Meter Volume	(V _{m(std)})	41.532	dscf	Sat. Moisture Content	(B _{ws(svp)})	61.60	%		
Calc Moisture Content	(B _{ws(calc)})	4.89	%	Final Moisture Content	(B _{ws})	4.89	%		

Moisture Content Data									
Run Number	2-100 w/DB-SO3-3		Date	09/25/18	Start Time	06:29	Stop Time	08:29	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor		(Y)	1.017			
Total Meter Volume	(V _m)	41.760	dcf	Barometric Pressure	(P _b)	29.91	in Hg		
Average Stack Temp	(t _s) _{avg}	190	°F	Stack Static Pressure	(P _{static})	0.55	in H ₂ O		
Average Meter Temp	(t _m) _{avg}	74	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.42	in H ₂ O		
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
		(g)	(g)	(g)	(g)				
Contents		H ₂ O ₂	H ₂ O ₂	DI Water	Sil Gel				
Final Value	(V _f),(W _f)	771.10	718.80	615.60	859.80				
Initial Value	(V _i),(W _i)	685.90	713.00	614.10	845.80				
Net Value	(V _n),(W _n)	85.2	5.8	1.5	14.0				
Results									
Total Weight	(W _t)	106.50	g	Water Vol Weighed	(V _{wsg(std)})	5.021	scf		
Std Meter Volume	(V _{m(std)})	42.042	dscf	Sat. Moisture Content	(B _{ws(svp)})	63.38	%		
Calc Moisture Content	(B _{ws(calc)})	10.67	%	Final Moisture Content	(B _{ws})	10.67	%		

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	SB
Run Number	2-100 w/DB-SO3-1

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	189.9		°F
Average Meter Temp (t _m)	70.2		
Orifice Meter Coefficient (ΔH ₀)	1.820		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _{ws})	11.11		%
Stack Dry Molecular Weight (M _d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	17.0	in Hg
PASS	Post	0.000	ft ³ /min@	10.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter	(D _{na})	--	in
Suggested Nozzle Diameter	(D _m)		in
Probe Number	SAMP-S3-0005		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0009		
Impinger Case Number	samp-bc-0029		

Nozzle Measurements				ID:
Pre	--	--	--	PASS
Post	--	--	--	PASS

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time		
Start	12:31	End 14:31

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	710.0	729.3	612.0	951.2				
Post	799.3	736.8	614.5	961.9				

Pressures		
Barometric Pressure (P _b)	29.98	in Hg
Stack Static Pressure (P _{static})	0.55	in H ₂ O
Absolute Stack Pressure (P _s)	30.02	in Hg
Absolute Meter Pressure (P _m)	30.11	in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025			SAMP-S3-0005	SAMP-S3-0005	samp-bh-0009	samp-bc-0029	1015		SAMP-CP-0025		SAMP-CP-0025						
												Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})							
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m, std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m, std})	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	0.265	--	--	0.42	191	371	501	56	77	--	67	67	1.0	--	--	1.715	--	41.159
A-1	5.0	00:05:00	1.943	--	--	0.42	191	359	512	50	108	--	67	67	1.0	--	--	3.430	--	41.159
A-1	10.0	00:10:00	3.621	--	--	0.42	190	363	514	50	111	--	67	67	1.0	--	--	5.176	--	41.404
A-1	15.0	00:15:00	5.329	--	--	0.42	190	371	515	50	124	--	68	68	1.0	--	--	6.860	--	41.158
A-1	20.0	00:20:00	6.980	--	--	0.42	191	373	518	50	133	--	68	68	1.0	--	--	8.568	--	41.128
A-1	25.0	00:25:00	8.655	--	--	0.42	190	372	507	51	147	--	69	69	1.0	--	--	10.268	--	41.071
A-1	30.0	00:30:00	10.324	--	--	0.42	190	368	519	51	159	--	69	69	1.0	--	--	11.964	--	41.019
A-1	35.0	00:35:00	11.990	--	--	0.42	190	364	512	51	162	--	69	69	1.0	--	--	13.659	--	40.977
A-1	40.0	00:40:00	13.655	--	--	0.42	190	366	515	52	165	--	70	70	1.0	--	--	15.910	--	42.427
A-1	45.0	00:45:00	15.870	--	--	0.42	190	369	516	51	170	--	70	70	1.0	--	--	17.170	--	41.209
A-1	50.0	00:50:00	17.110	--	--	0.42	189	373	515	52	182	--	70	70	1.0	--	--	18.954	--	41.354
A-1	55.0	00:55:00	18.865	--	--	0.42	189	369	511	52	179	--	70	70	1.0	--	--	20.686	--	41.373
A-1	60.0	01:00:00	20.570	--	--	0.42	189	364	514	52	166	--	71	71	1.0	--	--	22.446	--	41.439
A-1	65.0	01:05:00	22.305	--	--	0.42	189	368	511	52	170	--	71	71	2.0	--	--	24.198	--	41.482
A-1	70.0	01:10:00	24.032	--	--	0.42	190	370	514	53	153	--	71	71	2.0	--	--	25.935	--	41.495
A-1	75.0	01:15:00	25.744	--	--	0.42	190	372	513	53	157	--	73	73	2.0	--	--	27.663	--	41.494
A-1	80.0	01:20:00	27.454	--	--	0.42	190	369	513	53	156	--	71	71	2.0	--	--	29.418	--	41.532
A-1	85.0	01:25:00	29.185	--	--	0.42	190	366	512	53	153	--	72	72	2.0	--	--	31.173	--	41.564
A-1	90.0	01:30:00	30.918	--	--	0.42	190	368	512	53	150	--	71	71	2.0	--	--	32.918	--	41.580
A-1	95.0	01:35:00	32.638	--	--	0.42	190	371	512	53	149	--	72	72	2.0	--	--	34.622	--	41.547
A-1	100.0	01:40:00	34.322	--	--	0.42	190	373	510	54	148	--	72	72	2.0	--	--	36.341	--	41.532
A-1	105.0	01:45:00	36.019	--	--	0.42	190	372	514	54	147	--	72	72	2.0	--	--	38.047	--	41.506
A-1	110.0	01:50:00	37.705	--	--	0.42	190	369	517	54	149	--	72	72	2.0	--	--	39.782	--	41.511
A-1	115.0	01:55:00	39.418	--	--	0.42	189	366	515	53	151	--	72	72	2.0	--	--	41.517	--	41.517
Last Pt	120.0	02:00:00	41.132	--	--	0.42	190	364	517	53	150	--	72	72	2.0	--	--	--	--	--
Final Val	120.0	02:00:00	41.132																	
Average Values						0.42	190	368	513	52	149		70	70	2.0			41.517		

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	SB
Run Number	2-100 w/DB-SO3-2

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	188.7		°F
Average Meter Temp (t _m)	71.9		
Orifice Meter Coefficient (ΔH ₀)	1.820		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _{ws})	4.89		%
Stack Dry Molecular Weight (M _d)	29.27		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.35		acfm
ΔP to ΔH Isokinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	17.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter (D _{na})	--	in	
Suggested Nozzle Diameter (D _m)			
Probe Number	SAMP-S3-0005		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0009		
Impinger Case Number	samp-bc-0029		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time			
Start	03:47	End	05:47

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	688.3	678.2	585.3	869.1				
Post	714.9	686.9	586.6	877.8				

Pressures			
Barometric Pressure (P _b)	29.91		in Hg
Stack Static Pressure (P _{static})	0.55		in H ₂ O
Absolute Stack Pressure (P _s)	29.95		in Hg
Absolute Meter Pressure (P _m)	30.04		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025			SAMP-S3-0005	SAMP-S3-0005	samp-bh-0009	samp-bc-0029	1015		SAMP-CP-0025	SAMP-CP-0025								
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH ₀)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m, std})	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _{m, std})		
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf		
A-1	0.0	00:00:00	47.005	--	--	0.42	189	387	506	55	169	--	69	69	1.0		1.744		41.859		
A-2	5.0	00:05:00	48.722	--	--	0.42	189	384	514	52	167	--	70	70	2.0		3.497		41.965		
A-3	10.0	00:10:00	50.451	--	--	0.42	189	381	516	52	163	--	70	70	2.0		5.270		42.163		
A-4	15.0	00:15:00	52.200	--	--	0.42	189	376	511	54	167	--	70	70	2.0		7.045		42.268		
A-5	20.0	00:20:00	53.950	--	--	0.42	189	376	516	52	167	--	71	71	2.0		8.707		41.795		
A-6	25.0	00:25:00	55.593	--	--	0.42	188	375	514	53	163	--	71	71	2.0		10.444		41.775		
B-1	30.0	00:30:00	57.309	--	--	0.42	188	376	511	54	165	--	72	72	2.0		12.178		41.753		
B-2	35.0	00:35:00	59.026	--	--	0.42	189	374	519	54	164	--	72	72	2.0		13.912		41.737		
B-3	40.0	00:40:00	60.743	--	--	0.42	189	376	514	54	163	--	72	72	2.0		15.647		41.724		
B-4	45.0	00:45:00	62.460	--	--	0.42	189	375	519	54	164	--	72	72	2.0		17.363		41.670		
B-5	50.0	00:50:00	64.159	--	--	0.42	189	374	518	54	165	--	73	73	2.0		19.076		41.619		
B-6	55.0	00:55:00	65.858	--	--	0.42	189	375	516	54	162	--	73	73	2.0		20.787		41.575		
C-1	60.0	01:00:00	67.556	--	--	0.42	188	376	516	53	164	--	73	73	2.0		22.522		41.580		
C-2	65.0	01:05:00	69.277	--	--	0.42	188	368	513	54	169	--	73	73	2.0		24.271		41.607		
C-3	70.0	01:10:00	71.011	--	--	0.42	189	372	511	55	165	--	73	73	2.0		25.962		41.540		
C-4	75.0	01:15:00	72.689	--	--	0.42	188	374	519	54	165	--	73	73	2.0		27.672		41.508		
C-5	80.0	01:20:00	74.385	--	--	0.42	188	369	516	54	166	--	73	73	2.0		29.386		41.486		
C-6	85.0	01:25:00	76.085	--	--	0.42	188	372	514	54	164	--	73	73	2.0		30.800		41.067		
D-1	90.0	01:30:00	77.488	--	--	0.42	189	376	518	54	165	--	73	73	2.0		32.865		41.514		
D-2	95.0	01:35:00	79.536	--	--	0.42	189	375	519	54	166	--	72	72	2.0		34.617		41.540		
D-3	100.0	01:40:00	81.270	--	--	0.42	188	376	516	54	167	--	72	72	2.0		36.337		41.528		
D-4	105.0	01:45:00	82.973	--	--	0.42	189	371	511	54	168	--	72	72	2.0		38.070		41.531		
D-5	110.0	01:50:00	84.689	--	--	0.42	189	375	513	54	168	--	72	72	2.0		39.803		41.534		
D-6	115.0	01:55:00	86.405	--	--	0.42	189	372	511	54	165	--	72	72	2.0		41.533		41.533		
Last Pt	120.0	02:00:00	88.117	--	--	0.42	189	371	515	54	167		72	72	2.0						
Final Val	120.0	02:00:00	88.117											Max Vac	2.0		Final Values	41.533			
Average Values						0.42	189	375	515	54	166		72	72							

72

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	SB
Run Number	2-100 w/DB-SO3-3

Filter #	--
----------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)			
Average Stack Temp (t _s)	190.0		°F
Average Meter Temp (t _m)	73.8		
Orifice Meter Coefficient (ΔH ₀)	1.820		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})			in H ₂ O
Stack Moisture Content (B _{ws})	10.67		%
Stack Dry Molecular Weight (M _d)	29.27		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.35		acfm
ΔP to ΔH Isokinetic Factor (K)			

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	--	in H ₂ O for	--	sec
	Pre (-)	--	in H ₂ O for	--	sec
	Post (+)	--	in H ₂ O for	--	sec
	Post (-)	--	in H ₂ O for	--	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter	(D _{na})	--	in
Suggested Nozzle Diameter	(D _m)		
Probe Number	SAMP-S3-0005		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0009		
Impinger Case Number	samp-bc-0029		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0022	

Run Time			
Start	06:29	End	08:29

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	685.9	713.0	614.1	845.8				
Post	771.1	718.8	615.6	859.8				

Pressures			
Barometric Pressure (P _b)	29.91		in Hg
Stack Static Pressure (P _{static})	0.55		in H ₂ O
Absolute Stack Pressure (P _s)	29.95		in Hg
Absolute Meter Pressure (P _m)	30.04		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025			SAMP-S3-0005	SAMP-S3-0005	samp-bh-0009	samp-bc-0029	1015		SAMP-CP-0025		SAMP-CP-0025						
												Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})							
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (375±25°F)	Filter Temp (525±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤185°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	0.000	--	0.42	190	375	519	56	180		74	74	2.0			1.738		41.708	
A-2	5.0	00:05:00	1.727	--	0.42	190	374	518	53	176		74	74	2.0			3.498		41.974	
A-3	10.0	00:10:00	3.476	--	0.42	190	375	517	54	185		74	74	2.0			5.255		42.038	
A-4	15.0	00:15:00	5.222	--	0.42	190	373	514	54	185		75	75	2.0			7.011		42.069	
A-5	20.0	00:20:00	6.971	--	0.42	190	370	511	54	185		75	75	2.0			8.765		42.073	
A-6	25.0	00:25:00	8.717	--	0.42	190	375	511	56	179		75	75	2.0			10.511		42.043	
B-1	30.0	00:30:00	10.455	--	0.42	190	375	514	56	175		75	75	2.0			12.247		41.991	
B-2	35.0	00:35:00	12.184	--	0.42	190	375	511	56	168		74	74	2.0			14.024		42.073	
B-3	40.0	00:40:00	13.950	--	0.42	190	375	513	56	167		73	73	2.0			15.740		41.974	
B-4	45.0	00:45:00	15.652	--	0.42	190	374	513	57	165		73	73	2.0			17.511		42.026	
B-5	50.0	00:50:00	17.408	--	0.42	190	375	512	57	163		73	73	2.0			19.270		42.043	
B-6	55.0	00:55:00	19.153	--	0.42	190	374	519	57	165		73	73	2.0			21.031		42.062	
C-1	60.0	01:00:00	20.900	--	0.42	190	375	518	58	163		73	73	2.0			22.793		42.080	
C-2	65.0	01:05:00	22.648	--	0.42	190	375	518	58	164		73	73	2.0			24.545		42.076	
C-3	70.0	01:10:00	24.385	--	0.42	190	373	516	60	164		73	73	2.0			26.296		42.073	
C-4	75.0	01:15:00	26.122	--	0.42	190	375	517	60	164		73	73	2.0			28.064		42.096	
C-5	80.0	01:20:00	27.876	--	0.42	190	375	512	61	164		73	73	2.0			29.811		42.086	
C-6	85.0	01:25:00	29.609	--	0.42	190	374	514	61	162		73	73	2.0			31.561		42.082	
D-1	90.0	01:30:00	31.345	--	0.42	190	376	514	60	162		74	74	2.0			33.306		42.071	
D-2	95.0	01:35:00	33.079	--	0.42	190	377	516	61	164		74	74	2.0			35.063		42.076	
D-3	100.0	01:40:00	34.825	--	0.42	190	377	516	61	163		74	74	2.0			36.809		42.068	
D-4	105.0	01:45:00	36.560	--	0.42	190	376	518	62	162		74	74	2.0			38.560		42.066	
D-5	110.0	01:50:00	38.300	--	0.42	190	375	518	63	163		74	74	2.0			40.306		42.058	
D-6	115.0	01:55:00	40.035	--	0.42	190	375	518	63	163		74	74	2.0			42.042		42.042	
Last Pt	120.0	02:00:00	41.760	--																
Final Val	120.0	02:00:00	41.760	--										2.0		Final Values	42.042			
Average Values					0.42	190	375	515	58	169		74	74							

74

Notes:

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
without Duct Burners Firing
NH₃ Data**

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	2-Base-NH3-1	2-Base-NH3-2	2-Base-NH3-3	Average	Units	Limits
Run Start Time	15:40	17:15	18:44		hh:mm	
Run Stop Time	16:40	18:15	19:44		hh:mm	
Test Date	09/25/18	09/25/18	09/25/18		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	1.017	1.017	1.017			
Pitot Tube Coefficient	0.8390	0.8390	0.8390			
Stack Test Data	2-Base-NH3-1	2-Base-NH3-2	2-Base-NH3-3	Average	Units	Limits
Initial Meter Volume	0.000	0.000	44.281		ft³	
Final Meter Volume	43.346	43.950	88.300		ft³	
Total Meter Volume	43.346	43.950	44.019	43.772	ft³	
Total Sampling Time	60.00	60.00	60.00	60.00	min	
Average Meter Temperature	70.58	73.75	77.08	73.81	°F	
Average Stack Temperature	203.67	205.08	204.08	204.28	°F	
Barometric Pressure	29.69	29.68	29.67	29.68	in Hg	
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89	in H ₂ O	
Absolute Stack Pressure	29.62	29.61	29.60	29.61	in Hg	
Average Orifice Pressure Drop	1.82	1.82	1.80	1.81	in H ₂ O	
Absolute Meter Pressure	29.82	29.81	29.80	29.81	in Hg	
Avg Square Root Pitot Pressure	1.19	1.20	1.27	1.22	√(in H ₂ O)	
Moisture Content Data	2-Base-NH3-1	2-Base-NH3-2	2-Base-NH3-3	Average	Units	Limits
Impinger Water Weight Gain	77.80	71.10	87.70	78.87	g	
Silica Gel Weight Gain	14.10	17.60	8.60	13.43	g	
Total Water Volume Collected	92.07	88.86	96.47	92.47	ml	
Standard Water Vapor Volume	4.33	4.18	4.54	4.35	scf	
Standard Meter Volume	43.7	44.1	43.8	43.9	dscf	
Standard Metric Meter Volume	1.2	1.2	1.2	1.2	dscm	
Calculated Stack Moisture	9.02	8.67	9.39	9.02	%	
Saturated Stack Moisture	85.33	87.87	86.12	86.44	%	
Reported Stack Moisture Content	9.02	8.67	9.39	9.02	%	
Gas Analysis Data	2-Base-NH3-1	2-Base-NH3-2	2-Base-NH3-3	Average	Units	Limits
Carbon Dioxide Content	4.1	4.1	4.1	4.1	%	
Oxygen Content	13.5	13.5	13.5	13.5	%	
Carbon Monoxide Content	0.6	0.6	0.6	0.6	ppm	
Nitrogen Content	82.4	82.4	82.4	82.4	%	
Stack Dry Molecular Weight	29.20	29.20	29.20	29.20	lb/lb-mole	
Stack Wet Molecular Weight	28.19	28.23	28.15	28.19	lb/lb-mole	
Calculated Fuel Factor	1.792	1.792	1.787	1.790		
Fuel F-Factor	8632.22	8632.22	8632.22	8632.22	dscf/MMBtu	
Percent Excess Air	163.7	163.7	163.8	163.7	%	

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	2-Base-NH3-1	2-Base-NH3-2	2-Base-NH3-3	Average	Units	Limits
Average Stack Gas Velocity	75.86	76.58	81.59	78.01	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,290,513	1,302,779	1,387,914	1,327,068	acfm	
Wet Standard Stack Flow Rate	60,994	61,422	65,512	62,643	wkscfh	
Dry Standard Stack Flow Rate	55,494,901	56,097,006	59,363,478	56,985,128	dscfh	
Ammonia Analysis (CTM-027)	2-Base-NH3-1	2-Base-NH3-2	2-Base-NH3-3	Average	Units	Limits
Front Half Results (C _f)	19.7674	28.2182	22.4031	23.4629	mg/l	
Back Half Results (C _b)	0.2588	0.1448	0.0566	0.1534	mg/l	
Practical Quantitation Limit	0.1000	0.1000	0.1000	0.1000	mg/l	
Blank Results	0.0460	0.0460	0.0460	0.0460	mg/l	
Front Half Sample Volume	215	164	215	198	ml	
Back Half Sample Volume	281	274	217	257	ml	
Volume of NH ₃	0.00610	0.00659	0.00682	0.00650	L	
NH ₃ Concentration	4.93	5.28	5.49	5.23	ppmvd	--
NH ₃ Concentration	3.93	4.21	4.38	4.17	ppm@15%O ₂	5.00

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		BL/SB	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	35	scf
Run Duration	chk Subpart	60	minutes
Unit Number		CTG-2	
Base Run Number		2-Base-NH3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/25/18	09/25/18	09/25/18	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8632.22	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	
Meter Calibration Factor	(Y)	1.017	1.017	1.017	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.820	1.820	1.820	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	A8169	A8169	A8169	
Pitot Tube Coefficient	(C _p)	0.8390	0.8390	0.8390	
Probe Number	from ACS	SAMP-HP-0152	SAMP-HP-0152	SAMP-HP-0152	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	5238	5238	5238	
Impinger Case Number	from ACS	SAMP-BC-0017	SAMP-BC-0022	SAMP-BC-0017	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18		
Sampling Location	CTG-2 Stack	Operator	BL/SB		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	2-Base-NH3-1		Date	09/25/18	Run Start Time	15:40	Run Stop Time	16:40
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:00	4.1	13.5	0.6	82.4	29.20	1.792	163.7	YES

Gas Analysis Data								
Run Number	2-Base-NH3-2		Date	09/25/18	Run Start Time	17:15	Run Stop Time	18:15
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:00	4.1	13.5	0.6	82.4	29.20	1.792	163.7	YES

Gas Analysis Data								
Run Number	2-Base-NH3-3		Date	09/25/18	Run Start Time	18:44	Run Stop Time	19:44
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:00	4.1	13.5	0.6	82.4	29.20	1.787	163.8	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18
Sampling Location	CTG-2 Stack	Operator	BL/SB
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/24/18	500	499.9	-0.1	Pass
Test Day 1	09/25/18	500	499.9	-0.1	Pass

Moisture Content Data									
Run Number	2-Base-NH3-1		Date	09/25/18	Start Time	15:40	Stop Time	16:40	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor			(Y)	1.017		
Total Meter Volume	(V _m)	43.346	dcf	Barometric Pressure			(P _b)	29.69	in Hg
Average Stack Temp	(t _s) _{avg}	204	°F	Stack Static Pressure			(P _{static})	-0.89	in H ₂ O
Average Meter Temp	(t _m) _{avg}	71	°F	Avg Orifice Pressure			(ΔH) _{avg}	1.82	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	651.50	707.60	690.30	880.30				
Initial Value	(V _i),(W _i)	652.60	696.40	622.60	866.20				
Net Value	(V _n),(W _n)	-1.1	11.2	67.7	14.1				
Results									
Total Weight	(W _t)	91.90	g	Water Vol Weighed			(V _{wsg(std)})	4.333	scf
Std Meter Volume	(V _{m(std)})	43.727	dscf	Sat. Moisture Content			(B _{ws(svp)})	85.33	%
Calc Moisture Content	(B _{ws(calc)})	9.02	%	Final Moisture Content			(B _{ws})	9.02	%

Moisture Content Data									
Run Number	2-Base-NH3-2		Date	09/25/18	Start Time	17:15	Stop Time	18:15	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor			(Y)	1.017		
Total Meter Volume	(V _m)	43.950	dcf	Barometric Pressure			(P _b)	29.68	in Hg
Average Stack Temp	(t _s) _{avg}	205	°F	Stack Static Pressure			(P _{static})	-0.89	in H ₂ O
Average Meter Temp	(t _m) _{avg}	74	°F	Avg Orifice Pressure			(ΔH) _{avg}	1.82	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	682.30	765.90	642.30	946.20				
Initial Value	(V _i),(W _i)	659.30	732.80	627.30	928.60				
Net Value	(V _n),(W _n)	23.0	33.1	15.0	17.6				
Results									
Total Weight	(W _t)	88.70	g	Water Vol Weighed			(V _{wsg(std)})	4.182	scf
Std Meter Volume	(V _{m(std)})	44.059	dscf	Sat. Moisture Content			(B _{ws(svp)})	87.87	%
Calc Moisture Content	(B _{ws(calc)})	8.67	%	Final Moisture Content			(B _{ws})	8.67	%

Moisture Content Data									
Run Number	2-Base-NH3-3		Date	09/25/18	Start Time	18:44	Stop Time	19:44	
Meter Box Number	SAMP-CP-0025		Meter Cal Factor			(Y)	1.017		
Total Meter Volume	(V _m)	44.019	dcf	Barometric Pressure			(P _b)	29.67	in Hg
Average Stack Temp	(t _s) _{avg}	204	°F	Stack Static Pressure			(P _{static})	-0.89	in H ₂ O
Average Meter Temp	(t _m) _{avg}	77	°F	Avg Orifice Pressure			(ΔH) _{avg}	1.80	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	736.50	712.70	628.70	888.90				
Initial Value	(V _i),(W _i)	670.90	695.90	623.40	880.30				
Net Value	(V _n),(W _n)	65.6	16.8	5.3	8.6				
Results									
Total Weight	(W _t)	96.30	g	Water Vol Weighed			(V _{wsg(std)})	4.541	scf
Std Meter Volume	(V _{m(std)})	43.837	dscf	Sat. Moisture Content			(B _{ws(svp)})	86.12	%
Calc Moisture Content	(B _{ws(calc)})	9.39	%	Final Moisture Content			(B _{ws})	9.39	%

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	BL/SB
Run Number	2-Base-NH3-1

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8390	A8169	
Average Stack Temp (t_s)	203.7		°F
Average Meter Temp (t_m)	70.6		
Orifice Meter Coefficient (ΔH_{or})	1.820		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.19		in H ₂ O
Stack Moisture Content (B_{ws})	9.02		%
Stack Dry Molecular Weight (M_d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	--		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	20.0	in Hg
PASS	Post	0.000	ft ³ /min@	20.0	in Hg
PASS	Pitot	Pre (+)	5.0	in H ₂ O for	15.0
		Pre (-)	5.0	in H ₂ O for	15.0
		Post (+)	5.0	in H ₂ O for	15.0
		Post (-)	5.0	in H ₂ O for	15.0

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor (Y)	1.017		
Nozzle Number			
Average Nozzle Diameter (D_{na})	--		in
Suggested Nozzle Diameter (D_m)	0.2036		in
Probe Number	SAMP-HP-0152		
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	5238		
Impinger Case Number	SAMP-BC-0017		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	15:40	End	16:40

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	652.6	696.4	622.6	866.2				
Post	651.5	707.6	690.3	880.3				

Pressures			
Barometric Pressure (P_b)	29.69		in Hg
Stack Static Pressure (P_{static})	-0.89		in H ₂ O
Absolute Stack Pressure (P_s)	29.62		in Hg
Absolute Meter Pressure (P_m)	29.82		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-HP-0152	SAMP-HP-0152	5238	SAMP-BC-0017	SAMP-CP-0025		SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025
								Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})										
Traverse Point #	Sampling Time (Ø)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (ΔP)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$)	Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	0.000	1.50	1.82	203	256	256	58	68	68	4.0	1.22	78.27	3.526	--	42.309		
A-2	5.0	00:05:00	3.478	1.40	1.82	203	256	256	58	68	68	4.0	1.18	75.62	7.066	--	42.394		
A-3	10.0	00:10:00	6.970	1.40	1.82	204	256	258	61	68	68	4.0	1.18	75.67	10.543	--	42.171		
A-1	15.0	00:15:00	10.400	1.50	1.82	205	255	259	66	68	68	4.0	1.22	78.39	14.042	--	42.127		
A-2	20.0	00:20:00	13.852	1.40	1.82	205	255	256	68	70	70	4.0	1.18	75.73	17.642	--	42.340		
A-3	25.0	00:25:00	17.416	1.30	1.82	203	256	255	68	71	71	4.0	1.14	72.87	21.338	--	42.676		
A-1	30.0	00:30:00	21.083	1.50	1.82	204	255	260	68	71	71	4.0	1.22	78.33	25.069	--	42.976		
A-2	35.0	00:35:00	24.785	1.40	1.82	202	257	260	68	72	72	4.0	1.18	75.56	28.795	--	43.193		
A-3	40.0	00:40:00	28.488	1.30	1.82	203	255	257	67	72	72	4.0	1.14	72.87	32.515	--	43.353		
A-1	45.0	00:45:00	32.185	1.40	1.82	204	255	257	67	73	73	4.0	1.18	75.67	36.243	--	43.492		
A-2	50.0	00:50:00	35.898	1.40	1.82	204	255	257	66	73	73	4.0	1.18	75.67	40.122	--	43.769		
A-3	55.0	00:55:00	39.760	1.40	1.82	204	255	257	66	73	73	4.0	1.18	75.67	43.723	--	43.723		
Last Pt	60.0	01:00:00	43.346														--		
Final Val	60.0	01:00:00	43.346																
Average Values				1.41	1.82	204	256	257	65	71	71			1.19	75.86				

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	BL/SB
Run Number	2-Base-NH3-2

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8390	A8169	
Average Stack Temp (t_s)	205.1		°F
Average Meter Temp (t_m)	73.8		
Orifice Meter Coefficient (ΔH_{or})	1.820		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.20		in H ₂ O
Stack Moisture Content (B_{ws})	8.67		%
Stack Dry Molecular Weight (M_d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.73		acfm
ΔP to ΔH Isokinetic Factor (K)	--		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	16.0	in Hg
PASS	Pitot	Pre (+)	3.5	in H ₂ O for	15.0
		Pre (-)	6.2	in H ₂ O for	15.0
		Post (+)	5.5	in H ₂ O for	15.0
		Post (-)	6.1	in H ₂ O for	15.0

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter	(D_{na})	--	in
Suggested Nozzle Diameter	(D_m)	0.1998	in
Probe Number	SAMP-HP-0152		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	5238		
Impinger Case Number	SAMP-BC-0022		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	17:15	End 18:15

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	659.3	732.8	627.3	928.6				
Post	682.3	765.9	642.3	946.2				

Pressures		
Barometric Pressure (P_b)	29.68	in Hg
Stack Static Pressure (P_{static})	-0.89	in H ₂ O
Absolute Stack Pressure (P_s)	29.61	in Hg
Absolute Meter Pressure (P_m)	29.81	in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-HP-0152	SAMP-HP-0152	5238	SAMP-BC-0022			SAMP-CP-0025		SAMP-CP-0025							
										Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})								
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V_m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH_d)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (t_p)	Filter Temp (t_f)	Impinger Exit Temp (t_e)	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$)	Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m, std}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$)	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	in Hg	$\sqrt{\text{in H}_2\text{O}}$	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	0.000	1.50	1.82	203	256	259	62	72	72	4.0	1.22	78.23	3.691	--	44.294		
A-2	5.0	00:05:00	3.670	1.40	1.82	204	256	259	62	72	72	4.0	1.18	75.63	7.292	--	43.751		
A-3	10.0	00:10:00	7.250	1.40	1.82	204	256	256	64	72	72	4.0	1.18	75.63	10.980	--	43.920		
A-1	15.0	00:15:00	10.917	1.50	1.82	205	256	260	68	73	73	4.0	1.22	78.35	14.758	--	44.273		
A-2	20.0	00:20:00	14.680	1.40	1.82	206	257	257	68	73	73	4.0	1.18	75.75	19.195	--	46.068		
A-3	25.0	00:25:00	19.100	1.40	1.82	206	256	257	68	73	73	4.0	1.18	75.75	22.041	--	44.082		
A-1	30.0	00:30:00	21.935	1.50	1.82	206	256	257	68	73	73	4.0	1.22	78.41	25.740	--	44.126		
A-2	35.0	00:35:00	25.620	1.40	1.82	206	255	258	66	75	75	4.0	1.18	75.75	29.391	--	44.086		
A-3	40.0	00:40:00	29.270	1.40	1.82	205	256	259	66	75	75	4.0	1.18	75.69	33.211	--	44.281		
A-1	45.0	00:45:00	33.090	1.50	1.82	204	256	258	66	75	75	4.0	1.22	78.29	36.737	--	44.084		
A-2	50.0	00:50:00	36.615	1.40	1.82	206	256	259	68	76	76	4.0	1.18	75.75	40.495	--	44.176		
A-3	55.0	00:55:00	40.380	1.40	1.82	206	256	259	68	76	76	4.0	1.18	75.75	44.059	--	44.059		
Last Pt	60.0	01:00:00	43.950														--		
Final Val	60.0	01:00:00	43.950																
Average Values				1.43		1.82	205	256	258	66	74	74		1.20	76.58				

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	BL/SB
Run Number	2-Base-NH3-3

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.8390	A8169	
Average Stack Temp (t _s)	204.1		°F
Average Meter Temp (t _m)	77.1		
Orifice Meter Coefficient (ΔH ₀)	1.820		in H ₂ O
Square Root ΔP (ΔP _{static} ^{1/2})	1.27		in H ₂ O
Stack Moisture Content (B _{ws})	9.39		%
Stack Dry Molecular Weight (M _d)	29.20		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.73		acfm
ΔP to ΔH Isokinetic Factor (K)	--		

Leak Checks					
Train	Pre	0.001	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pre (+)	5.0	in H ₂ O for	15.0	sec
	Pre (-)	5.2	in H ₂ O for	15.0	sec
	Post (+)	5.4	in H ₂ O for	15.0	sec
	Post (-)	6.0	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number			
Average Nozzle Diameter (D _{na})	--	in	
Suggested Nozzle Diameter (D _m)	0.1966	in	
Probe Number	SAMP-HP-0152		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	5238		
Impinger Case Number	SAMP-BC-0017		

Nozzle Measurements					ID:
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0031	

Run Time			
Start	18:44	End	19:44

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	670.9	695.9	623.4	880.3				
Post	736.5	712.7	628.7	888.9				

Pressures			
Barometric Pressure (P _b)	29.67		in Hg
Stack Static Pressure (P _{static})	-0.89		in H ₂ O
Absolute Stack Pressure (P _s)	29.60		in Hg
Absolute Meter Pressure (P _m)	29.80		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-HP-0152	SAMP-HP-0152	5238	SAMP-BC-0017	SAMP-CP-0025		SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025	SAMP-CP-0025
								Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})										
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}	
A-1	0.0	00:00:00	44.281	1.70	1.80	206	259	262	56	75	75	4.0	1.30	83.60	3.563	--	42.757		
A-2	5.0	00:05:00	47.845	1.70	1.80	205	259	262	52	76	76	4.0	1.30	83.54	7.242	--	43.454		
A-3	10.0	00:10:00	51.532	1.50	1.80	204	259	261	53	76	76	4.0	1.22	78.41	10.911	--	43.642		
A-1	15.0	00:15:00	55.208	1.50	1.80	204	258	261	54	77	77	4.0	1.22	78.41	14.584	--	43.752		
A-2	20.0	00:20:00	58.896	1.50	1.80	204	259	264	55	77	77	4.0	1.22	78.41	18.262	--	43.829		
A-3	25.0	00:25:00	62.589	1.70	1.80	202	259	263	55	77	77	4.0	1.30	83.35	21.914	--	43.827		
A-1	30.0	00:30:00	66.255	1.70	1.80	204	258	260	55	78	78	4.0	1.30	83.48	25.574	--	43.841		
A-2	35.0	00:35:00	69.937	1.60	1.80	204	258	258	57	78	78	4.0	1.26	80.98	29.250	--	43.874		
A-3	40.0	00:40:00	73.634	1.80	1.80	204	258	257	57	78	78	4.0	1.34	85.90	32.888	--	43.851		
A-1	45.0	00:45:00	77.294	1.60	1.80	203	258	259	58	78	78	4.0	1.26	80.92	36.540	--	43.848		
A-2	50.0	00:50:00	80.967	1.60	1.80	204	258	260	57	77	77	4.0	1.26	80.98	40.190	--	43.844		
A-3	55.0	00:55:00	84.632	1.60	1.80	205	258	259	57	78	78	4.0	1.26	81.04	43.837	--	43.837		
Last Pt	60.0	01:00:00	88.300																
Final Val	60.0	01:00:00	88.300									Max Vac	4.0	Final Values	43.837				
Average Values				1.63		1.80	204	258	261	56	77	77		1.27	81.59				

Notes:

EMISSION DATA RECORDS

**Unit #CTG-2
Base Load
with Duct Burners Firing
NH₃ Data**

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	2-100 w/DB-NH3-1	2-100 w/DB-NH3-2	2-100 w/DB-NH3-3	Average	Units	Limits
Run Start Time	09:25	11:24	12:57		hh:mm	
Run Stop Time	10:26	12:24	13:57		hh:mm	
Test Date	09/25/18	09/25/18	09/25/18		mm/dd/yy	
Load	w/DB	w/DB	w/DB		% or w/DB	--
Meter Calibration Factor	1.017	1.017	1.017			
Pitot Tube Coefficient	0.8390	0.8390	0.8390			
Stack Test Data	2-100 w/DB-NH3-1	2-100 w/DB-NH3-2	2-100 w/DB-NH3-3	Average	Units	Limits
Initial Meter Volume	0.000	0.000	0.000		ft ³	
Final Meter Volume	44.206	44.444	43.675		ft ³	
Total Meter Volume	44.206	44.444	43.675	44.108	ft ³	
Total Sampling Time	60.00	60.00	60.00	60.00	min	
Average Meter Temperature	74.77	68.23	70.08	71.03	°F	
Average Stack Temperature	191.08	190.00	190.00	190.36	°F	
Barometric Pressure	29.78	29.78	29.75	29.77	in Hg	
Stack Static Pressure	0.55	0.55	0.55	0.55	in H ₂ O	
Absolute Stack Pressure	29.82	29.82	29.79	29.81	in Hg	
Average Orifice Pressure Drop	1.82	1.82	1.82	1.82	in H ₂ O	
Absolute Meter Pressure	29.91	29.91	29.88	29.90	in Hg	
Moisture Content Data	2-100 w/DB-NH3-1	2-100 w/DB-NH3-2	2-100 w/DB-NH3-3	Average	Units	Limits
Impinger Water Weight Gain	68.50	93.40	96.00	85.97	g	
Silica Gel Weight Gain	13.30	19.10	18.10	16.83	g	
Total Water Volume Collected	81.95	112.70	114.31	102.99	ml	
Standard Water Vapor Volume	3.86	5.30	5.38	4.85	scf	
Standard Meter Volume	44.4	45.2	44.2	44.6	dscf	
Standard Metric Meter Volume	1.3	1.3	1.3	1.3	dscm	
Calculated Stack Moisture	8.00	10.51	10.85	9.79	%	
Saturated Stack Moisture	65.14	63.65	63.72	64.17	%	
Reported Stack Moisture Content	8.00	10.51	10.85	9.79	%	
Gas Analysis Data	2-100 w/DB-NH3-1	2-100 w/DB-NH3-2	2-100 w/DB-NH3-3	Average	Units	Limits
Carbon Dioxide Content	4.9	4.9	5.0	4.9	%	
Oxygen Content	12.0	12.0	12.0	12.0	%	
Carbon Monoxide Content	0.4	0.3	0.3	0.3	ppm	
Nitrogen Content	83.1	83.1	83.0	83.1	%	
Stack Dry Molecular Weight	29.26	29.27	29.27	29.27	lb/lb-mole	
Stack Wet Molecular Weight	28.36	28.08	28.05	28.16	lb/lb-mole	
Calculated Fuel Factor	1.824	1.809	1.796	1.810		
Fuel F-Factor	8632.22	8632.22	8632.22	8632.22	dscf/MMBtu	
Percent Excess Air	120.2	120.8	121.2	120.7	%	

CTM 027 (AMMONIA) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	2-100 w/DB-NH3-1	2-100 w/DB-NH3-2	2-100 w/DB-NH3-3	Average	Units	Limits
Average Stack Gas Velocity	74.20	73.86	71.42	73.16	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,262,325	1,256,517	1,215,000	1,244,614	acfm	
Wet Standard Stack Flow Rate	61,218	61,037	58,961	60,405	wkscfh	
Dry Standard Stack Flow Rate	56,322,805	54,622,585	52,561,784	54,502,391	dscfh	
Ammonia Analysis (CTM-027)	2-100 w/DB-NH3-1	2-100 w/DB-NH3-2	2-100 w/DB-NH3-3	Average	Units	Limits
Front Half Results (C _f)	7.8704	24.4697	22.4464	18.2622	mg/l	
Back Half Results (C _b)	0.1293	0.1294	0.1082	0.1223	mg/l	
Practical Quantitation Limit	0.1000	0.1000	0.1000	0.1000	mg/l	
Blank Results	0.0460	0.0460	0.0460	0.0460	mg/l	
Front Half Sample Volume	168	220	223	204	ml	
Back Half Sample Volume	263	219	288	257	ml	
Volume of NH ₃	0.00191	0.00764	0.00711	0.00555	L	
NH ₃ Concentration	1.52	5.97	5.68	4.39	ppmvd	--
NH ₃ Concentration	1.01	3.96	3.77	2.91	ppm@15%O ₂	5.00

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		BL	
Date for Preliminary Run	(mm/dd/yy)	09/25/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	35	scf
Run Duration	chk Subpart	60	minutes
Unit Number		CTG-2	
Base Run Number		2-100 w/DB-NH3	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/25/18	09/25/18	09/25/18	
Load		w/DB	w/DB	w/DB	% or w/DB
Fuel F-Factor		8632.22	8632.22	8632.22	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0025	samp-cp-0025	samp-cp-0025	
Meter Calibration Factor	(Y)	1.017	1.017	1.017	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.820	1.820	1.820	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	A8169	A8169	A8169	
Pitot Tube Coefficient	(C _p)	0.8390	0.8390	0.8390	
Probe Number	from ACS	SAMP-HP-0152	SAMP-HP-0152	SAMP-HP-0152	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	5238	5238	5238	
Impinger Case Number	from ACS	SAMP-BC-0017	SAMP-BC-0017	SAMP-BC-0017	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/25/18		
Sampling Location	CTG-2 Stack	Operator	BL		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	2-100 w/DB-NH3-1		Date	09/25/18	Run Start Time	09:25	Run Stop Time	10:26
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:01	4.9	12.0	0.4	83.1	29.26	1.824	120.2	YES

Gas Analysis Data								
Run Number	2-100 w/DB-NH3-2		Date	09/25/18	Run Start Time	11:24	Run Stop Time	12:24
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:00	4.9	12.0	0.3	83.1	29.27	1.809	120.8	YES

Gas Analysis Data								
Run Number	2-100 w/DB-NH3-3		Date	09/25/18	Run Start Time	12:57	Run Stop Time	13:57
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:00	5.0	12.0	0.3	83.0	29.27	1.796	121.2	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/25/18
Sampling Location	CTG-2 Stack	Operator	BL
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0031	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	09/25/18	500	499.9	-0.1	Pass
Test Day 1	09/25/18	500	499.9	-0.1	Pass

Moisture Content Data									
Run Number	2-100 w/DB-NH3-1		Date	09/25/18	Start Time	09:25	Stop Time	10:26	
Meter Box Number	samp-cp-0025				Meter Cal Factor	(Y)	1.017		
Total Meter Volume	(V _m)	44.206	dcf		Barometric Pressure	(P _b)	29.78	in Hg	
Average Stack Temp	(t _s) _{avg}	191	°F		Stack Static Pressure	(P _{static})	0.55	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	75	°F		Avg Orifice Pressure	(ΔH) _{avg}	1.82	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	744.30	741.90	632.10	916.90				
Initial Value	(V _i),(W _i)	692.00	725.70	632.10	903.60				
Net Value	(V _n),(W _n)	52.3	16.2	0.0	13.3				
Results									
Total Weight	(W _t)	81.80	g		Water Vol Weighed	(V _{wsg(std)})	3.857	scf	
Std Meter Volume	(V _{m(std)})	44.379	dscf		Sat. Moisture Content	(B _{ws(svp)})	65.14	%	
Calc Moisture Content	(B _{ws(calc)})	8.00	%		Final Moisture Content	(B _{ws})	8.00	%	

Moisture Content Data									
Run Number	2-100 w/DB-NH3-2		Date	09/25/18	Start Time	11:24	Stop Time	12:24	
Meter Box Number	samp-cp-0025				Meter Cal Factor	(Y)	1.017		
Total Meter Volume	(V _m)	44.444	dcf		Barometric Pressure	(P _b)	29.78	in Hg	
Average Stack Temp	(t _s) _{avg}	190	°F		Stack Static Pressure	(P _{static})	0.55	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	68	°F		Avg Orifice Pressure	(ΔH) _{avg}	1.82	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	731.70	711.60	633.30	866.20				
Initial Value	(V _i),(W _i)	687.60	675.30	620.30	847.10				
Net Value	(V _n),(W _n)	44.1	36.3	13.0	19.1				
Results									
Total Weight	(W _t)	112.50	g		Water Vol Weighed	(V _{wsg(std)})	5.304	scf	
Std Meter Volume	(V _{m(std)})	45.170	dscf		Sat. Moisture Content	(B _{ws(svp)})	63.65	%	
Calc Moisture Content	(B _{ws(calc)})	10.51	%		Final Moisture Content	(B _{ws})	10.51	%	

Moisture Content Data									
Run Number	2-100 w/DB-NH3-3		Date	09/25/18	Start Time	12:57	Stop Time	13:57	
Meter Box Number	samp-cp-0025				Meter Cal Factor	(Y)	1.017		
Total Meter Volume	(V _m)	43.675	dcf		Barometric Pressure	(P _b)	29.75	in Hg	
Average Stack Temp	(t _s) _{avg}	190	°F		Stack Static Pressure	(P _{static})	0.55	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	70	°F		Avg Orifice Pressure	(ΔH) _{avg}	1.82	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8	
	(g)	(g)	(g)	(g)					
Contents	H ₂ SO ₄	H ₂ SO ₄	-	Sil Gel					
Final Value	(V _f),(W _f)	720.30	774.80	637.00	928.60				
Initial Value	(V _i),(W _i)	665.30	742.80	628.00	910.50				
Net Value	(V _n),(W _n)	55.0	32.0	9.0	18.1				
Results									
Total Weight	(W _t)	114.10	g		Water Vol Weighed	(V _{wsg(std)})	5.380	scf	
Std Meter Volume	(V _{m(std)})	44.190	dscf		Sat. Moisture Content	(B _{ws(svp)})	63.72	%	
Calc Moisture Content	(B _{ws(calc)})	10.85	%		Final Moisture Content	(B _{ws})	10.85	%	

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	BL
Run Number	2-100 w/DB-NH3-1

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8390	A8169	
Average Stack Temp (t_s)	191.1		°F
Average Meter Temp (t_m)	74.8		
Orifice Meter Coefficient (ΔH_{or})	1.820		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{\text{avg}}$)	1.18		in H ₂ O
Stack Moisture Content (B_{ws})	8.00		%
Stack Dry Molecular Weight (M_d)	29.26		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.004	ft ³ /min@	15.0	in Hg
PASS	Pre (+)	3.5	in H ₂ O for	15.0	sec
	Pre (-)	3.1	in H ₂ O for	15.0	sec
	Post (+)	6.8	in H ₂ O for	15.0	sec
	Post (-)	5.1	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	samp-cp-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number	na		
Average Nozzle Diameter (D_{na})	#DIV/0!		in
Suggested Nozzle Diameter (D_m)	0.2024		in
Probe Number	SAMP-HP-0152		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	5238		
Impinger Case Number	SAMP-BC-0017		

Nozzle Measurements					ID: na
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	09:25	End 10:26

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	692.0	725.7	632.1	903.6				
Post	744.3	741.9	632.1	916.9				

Pressures			
Barometric Pressure (P_b)	29.78		in Hg
Stack Static Pressure (P_{static})	0.55		in H ₂ O
Absolute Stack Pressure (P_s)	29.82		in Hg
Absolute Meter Pressure (P_m)	29.91		in Hg

Wash Volumes					ml
					ml

Identification Nos.	smp-cp-0025	smp-cp-0025	smp-cp-0025	Desired Orifice ΔH (ΔH_o)	Actual Orifice ΔH (ΔH_a)	Stack Temp (t_s)	Probe Temp (t_p)	Filter Temp (t_f)	Impinger Temp (t_i)	Cond. Temp (t_c)	CPM Filter Temp (t_{cpm})	Meter Inlet Temp (t_{mi})	Meter Outlet Temp (t_{mo})	Pump Vacuum	Square Root ΔP ($\Delta P^{1/2}$)	Local Stack Velocity (v_s)	Cumul. Meter Volume ($V_{m\text{std}}$)	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m\text{std}}$)
A-1	0.0	00:00:00	0.000	1.40	#DIV/0!	1.82	192	254	258	60		73	73	4.0	1.18	74.52	3.702	--	44.420
A-2	5.0	00:05:00	3.675	1.50	#DIV/0!	1.82	192	255	256	63		74	74	4.0	1.22	77.13	7.406	--	44.439
A-3	10.0	00:10:00	7.360	1.50	#DIV/0!	1.82	192	255	255	67		75	75	4.0	1.22	77.13	11.019	--	44.076
B-1	15.0	00:15:00	10.960	1.50	#DIV/0!	1.82	192	255	255	68		75	75	4.0	1.22	77.13	14.660	--	43.979
B-2	20.0	00:20:00	14.588	1.50	#DIV/0!	1.82	192	255	260	68		75	75	4.0	1.22	77.13	18.184	--	43.641
B-3	25.0	00:25:00	18.100	1.30	#DIV/0!	1.82	192	255	258	66		75	75	4.0	1.14	71.80	22.050	--	44.101
C-1	30.0	00:30:00	21.953	1.30	#DIV/0!	1.82	192	255	255	65		75	75	4.0	1.14	71.80	25.798	--	44.226
C-2	35.0	00:35:00	25.688	1.30	#DIV/0!	1.82	192	255	256	64		75	75	4.0	1.14	71.80	29.512	--	44.268
C-3	40.0	00:40:00	29.389	1.30	#DIV/0!	1.82	188	255	259	64		75	75	4.0	1.14	71.58	33.256	--	44.342
D-1	45.0	00:45:00	33.120	1.30	#DIV/0!	1.82	190	256	259	63		75	75	4.0	1.14	71.69	36.970	--	44.364
D-2	50.0	00:50:00	36.821	1.30	#DIV/0!	1.82	190	254	258	65		75	75	4.0	1.14	71.69	40.692	--	44.391
D-3	55.0	00:55:00	40.530	1.50	#DIV/0!	1.82	190	254	258	65		75	75	4.0	1.22	77.01	44.381	--	44.381
Last Pt	60.0	01:00:00	44.206		#DIV/0!	1.82	190	254	258	65		75	75	4.0				--	
Final Val	60.0	01:00:00	44.206											4.0	Final Values		44.381		
Average Values				1.39		1.82	191	255	257	65		75	75		1.18	74.20			

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	BL
Run Number	2-100 w/DB-NH3-2

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.8390	A8169	
Average Stack Temp (t _s)	190.0		°F
Average Meter Temp (t _m)	68.2		
Orifice Meter Coefficient (ΔH@)	1.820		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.17		in H ₂ O
Stack Moisture Content (B _{ws})	10.51		%
Stack Dry Molecular Weight (M _d)	29.27		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.74		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	3.5	in H ₂ O for	15.0
		Pre (-)	3.1	in H ₂ O for	15.0
		Post (+)	6.8	in H ₂ O for	15.0
		Post (-)	5.1	in H ₂ O for	15.0

Sampling Equipment			
Meter Box Number	samp-cp-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number	na		
Average Nozzle Diameter (D _{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D _m)	0.2021	in	
Probe Number	SAMP-HP-0152		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	5238		
Impinger Case Number	SAMP-BC-0017		

Nozzle Measurements					ID: na
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	11:24	End 12:24

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	687.6	675.3	620.3	847.1				
Post	731.7	711.6	633.3	866.2				

Pressures			
Barometric Pressure (P _b)	29.78		in Hg
Stack Static Pressure (P _{static})	0.55		in H ₂ O
Absolute Stack Pressure (P _s)	29.82		in Hg
Absolute Meter Pressure (P _m)	29.91		in Hg

Wash Volumes					ml
					ml

Identification Nos.	smp-cp-0025	smp-cp-0025	smp-cp-0025	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤-°F)	CPM Filter Temp (-±-°F)	smp-cp-0025		smp-cp-0025	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}	
												Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})							
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	0.000	1.40	#DIV/0!	1.82	190	256	260	59			65	65	4.0	1.18	74.77	3.740	--	44.876
A-2	5.0	00:05:00	3.657	1.40	#DIV/0!	1.82	190	256	257	59			66	66	4.0	1.18	74.77	7.459	--	44.754
A-3	10.0	00:10:00	7.301	1.40	#DIV/0!	1.82	190	255	255	63			66	66	4.0	1.18	74.77	11.171	--	44.684
B-1	15.0	00:15:00	10.938	1.40	#DIV/0!	1.82	190	256	257	68			68	68	4.0	1.18	74.77	14.884	--	44.653
B-2	20.0	00:20:00	14.590	1.30	#DIV/0!	1.82	190	256	260	68			68	68	4.0	1.14	72.05	18.608	--	44.659
B-3	25.0	00:25:00	18.252	1.30	#DIV/0!	1.82	190	255	257	68			68	68	4.0	1.14	72.05	22.346	--	44.691
C-1	30.0	00:30:00	21.928	1.30	#DIV/0!	1.82	190	256	256	68			69	69	4.0	1.14	72.05	26.046	--	44.650
C-2	35.0	00:35:00	25.574	1.30	#DIV/0!	1.82	190	255	259	68			69	69	4.0	1.14	72.05	29.751	--	44.627
C-3	40.0	00:40:00	29.225	1.40	#DIV/0!	1.82	190	255	256	68			69	69	4.0	1.18	74.77	33.511	--	44.682
D-1	45.0	00:45:00	32.930	1.40	#DIV/0!	1.82	190	255	257	68			69	69	4.0	1.18	74.77	37.190	--	44.628
D-2	50.0	00:50:00	36.555	1.40	#DIV/0!	1.82	190	251	255	68			70	70	4.0	1.18	74.77	40.910	--	44.629
D-3	55.0	00:55:00	40.227	1.40	#DIV/0!	1.82	190	256	258	66			70	70	4.0	1.18	74.77	45.181	--	45.181
Last Pt	60.0	01:00:00	44.444		#DIV/0!	1.82	190	256	258	66			70	70	4.0				--	
Final Val	60.0	01:00:00	44.444																	
Average Values				1.37		1.82	190	255	257	66			68	68		1.17	73.86			

Notes:

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	BL
Run Number	2-100 w/DB-NH3-3

Filter #	--
-----------------	----

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.8390	A8169	
Average Stack Temp (t_s)	190.0		°F
Average Meter Temp (t_m)	70.1		
Orifice Meter Coefficient ($\Delta H @$)	1.820		in H ₂ O
Square Root ΔP ($\Delta P^{1/2}_{avg}$)	1.13		in H ₂ O
Stack Moisture Content (B_{ws})	10.85		%
Stack Dry Molecular Weight (M_d)	29.27		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	#DIV/0!		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	3.5	in H ₂ O for	15.0 sec
		Pre (-)	3.1	in H ₂ O for	15.0 sec
		Post (+)	6.8	in H ₂ O for	15.0 sec
		Post (-)	5.1	in H ₂ O for	15.0 sec

Sampling Equipment			
Meter Box Number	samp-cp-0025		
Meter Cal Factor	(Y)	1.017	
Nozzle Number	na		
Average Nozzle Diameter (D_{na})	#DIV/0!	in	
Suggested Nozzle Diameter (D_m)	0.2052	in	
Probe Number	SAMP-HP-0152		
Probe Length	108		
Liner Material	glass		
Sample Case / Oven Number	5238		
Impinger Case Number	SAMP-BC-0017		

Nozzle Measurements					ID: na
Pre	--	--	--	PASS	
Post	--	--	--	PASS	

Barometer ID	
SAMP-WE-0041	
Scale ID	
SAMP-SC-0031	

Run Time		
Start	12:57	End 13:57

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	665.3	742.8	628.0	910.5				
Post	720.3	774.8	637.0	928.6				

Pressures			
Barometric Pressure (P_b)	29.75		in Hg
Stack Static Pressure (P_{static})	0.55		in H ₂ O
Absolute Stack Pressure (P_s)	29.79		in Hg
Absolute Meter Pressure (P_m)	29.88		in Hg

Wash Volumes					ml
					ml

Identification Nos.	samp-cp-0025		samp-cp-0025		samp-cp-0025		SAMP-HP-0152		SAMP-HP-0152		5238		SAMP-BC-0017		samp-cp-0025		samp-cp-0025		Local Stack Velocity (v_s) ft/sec	Cumul. Meter Volume ($V_{m, std}$) dscf	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume ($V_{m, std}$) dscf
	Traverse Point #	Sampling Time (h)	Timer Time	Dry Gas Meter Reading (V_m) ft ³	Velocity Head (Δp) in H ₂ O	Desired Orifice ΔH (ΔH_d) in H ₂ O	Actual Orifice ΔH (ΔH_a) in H ₂ O	Stack Temp (t_s) °F	Probe Temp (248±25°F) °F	Filter Temp (248±25°F) °F	Impinger Exit Temp (≤68°F) °F	Cond. Temp (≤-°F) °F	CPM Filter Temp (-±-°F) °F	Meter Inlet Temp (t_{mi}) °F	Meter Outlet Temp (t_{mo}) °F	Pump Vacuum in Hg	Square Root ΔP ($\Delta P^{1/2}$) √(in H ₂ O)					
A-1	0.0	00:00:00	0.000	1.30	#DIV/0!	1.82	190	246	255	59			68	68	4.0	1.14	72.13	3.612	--	43.345		
A-2	5.0	00:05:00	3.556	1.30	#DIV/0!	1.82	190	246	255	59			68	68	4.0	1.14	72.13	7.306	--	43.839		
A-3	10.0	00:10:00	7.193	1.20	#DIV/0!	1.82	190	256	258	60			69	69	4.0	1.10	69.30	10.969	--	43.878		
B-1	15.0	00:15:00	10.806	1.20	#DIV/0!	1.82	190	256	260	62			69	69	4.0	1.10	69.30	14.725	--	44.174		
B-2	20.0	00:20:00	14.510	1.20	#DIV/0!	1.82	190	255	257	66			70	70	4.0	1.10	69.30	18.418	--	44.204		
B-3	25.0	00:25:00	18.160	1.30	#DIV/0!	1.82	190	255	261	68			70	70	4.0	1.14	72.13	22.127	--	44.254		
C-1	30.0	00:30:00	21.825	1.30	#DIV/0!	1.82	190	255	257	68			71	71	4.0	1.14	72.13	26.031	--	44.624		
C-2	35.0	00:35:00	25.690	1.30	#DIV/0!	1.82	190	255	255	68			71	71	4.0	1.14	72.13	29.483	--	44.225		
C-3	40.0	00:40:00	29.108	1.30	#DIV/0!	1.82	190	256	258	68			71	71	4.0	1.14	72.13	33.172	--	44.229		
D-1	45.0	00:45:00	32.760	1.30	#DIV/0!	1.82	190	256	258	67			71	71	4.0	1.14	72.13	36.858	--	44.230		
D-2	50.0	00:50:00	36.410	1.30	#DIV/0!	1.82	190	255	260	66			71	71	4.0	1.14	72.13	40.747	--	44.451		
D-3	55.0	00:55:00	40.260	1.30	#DIV/0!	1.82	190	256	258	68			71	71	4.0	1.14	72.13	44.196	--	44.196		
Last Pt	60.0	01:00:00	43.675		#DIV/0!	1.82	190	256	258	68			71	71	4.0				--			
Final Val	60.0	01:00:00	43.675												Max Vac 4.0		Final Values	44.196				
Average Values				1.28		1.82	190	254	258	65			70	70		1.13	71.42					

Notes:

APPENDIX C
CALIBRATION GAS CERTIFICATIONS

CALIBRATION GAS CERTIFICATIONS

**Unit #CTG-1
Cylinder Certifications**



Assay Laboratory: Red Ball TGS
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150

CERTIFICATE OF ANALYSIS (Zero Ambient Nitrogen)

Cylinder Number:	EB0072319	Certification Date:	08/17/2018
Product ID Number:	121026	Expiration Date:	08/15/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport-LA
COA #	EB0072319.20180817-0	Lot Number:	EB0072319.20180817
Customer PO. NO.:		Tracking Number:	084249645
Customer:		Previous Certification Dates:	

This mixture is for laboratory use only, not for drug, household or other use.
 This mixture is certified in Mole % to be within $\pm 2\%$ of the actual number reported with a confidence of 95%.
 This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
 Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
 PGVP Vendor ID # G12018
 Information and Ordering
 800-551-8150
 Fax (318-425-6309)



Amisha Jewitt

Amisha Jewitt
 Analytical Chemist

Version 02-B, Revised on 2015-05-27



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0101662	Certification Date:	11/15/2017
Product ID Number:	124605	Expiration Date:	11/13/2025
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0101662.20171106-0	Lot Number:	EB0101662.20171106
Customer PO. NO.:		Tracking Number:	095706076
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	18.7 %	±0.16 %	NDIR	11/15/2017
Oxygen	21.0 %	±0.11 %	MPA	11/10/2017
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0060638	EB0060638.20170112-0	10/23/2025	GMIS	N2	CO2	19.5 %	0.724	C1309410.01
EB0060740	EB0060740.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0064384	EB0064384.20170112	08/13/2025	GMIS	N2	CO2	19.6 %	0.761	101001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	10/16/2017
CO2	NDIR	Thermo	410i	1162980025	10/23/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0032368	Certification Date:	06/05/2018
Product ID Number:	124606	Expiration Date:	06/03/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0032368.20180530-0	Lot Number:	EB0032368.20180530
Customer PO. NO.:		Tracking Number:	056559239
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	8.92 %	±0.08 %	NDIR	06/05/2018
Oxygen	12.05 %	±0.06 %	MPA	06/05/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC237204	CC237204.071001a	04/05/2023	NTRM	N2	O2	24.31 %	0.49	071001
EB0032313	EB0032313.20170112	05/22/2025	GMIS	N2	O2	9.34 %	0.235	2658a
EB0072967	EB0072967.20170424	11/25/2025	GMIS	N2	CO2	9.52 %	0.753	C1309410.01
EB0097755	EB0097755.20171018-0	12/26/2025	GMIS	N2	CO2	24.86 %	0.212	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	05/11/2018
CO2	NDIR	Thermo	410i	1162980025	05/11/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0027601	Certification Date:	08/28/2018
Product ID Number:	124737	Expiration Date:	08/27/2021
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0027601.20180724-0	Lot Number:	EB0027601.20180724
Customer PO. NO.:		Tracking Number:	048406543
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	9.2 PPM	±0.12 PPM	FTIR	08/21/2018
Nitric Oxide	8.8 PPM	±0.10 PPM	Chemiluminescence	08/02/2018, 08/16/2018, 08/28/2018
Total Oxides of Nitrogen	8.9 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
CC238257	CC238257.20171116	07/25/2022	GMIS	N2	NO	9.9 PPM	1.107	12100115
EB0005969	EB0005969.20171228	07/17/2026	GMIS	N2	NO	62.3 PPM	1.065	12100115
EB0010962	EB0010962.20171116	05/31/2021	GMIS	N2	NO	15.1 PPM	1.085	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/25/2018
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	08/20/2018
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	08/28/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Laboratory Supervisor
 Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0004881	Certification Date:	08/24/2018
Product ID Number:	125564	Expiration Date:	08/23/2021
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0004881.20180720-0	Lot Number:	EB0004881.20180720
Customer PO. NO.:		Tracking Number:	5945179
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	5.13 PPM	±0.06 PPM	FTIR	07/25/2018
Nitric Oxide	4.85 PPM	±0.07 PPM	Chemiluminescence	08/17/2018, 08/24/2018
Total Oxides of Nitrogen	4.92 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC238257	CC238257.20171116	07/25/2022	GMIS	N2	NO	9.9 PPM	1.107	12100115
EB0004076	EB0004076.20160721	08/05/2025	GMIS	N2	CO	12.2 PPM	1.046	091002
EB0012241	EB0012241.20151012	07/25/2021	GMIS	N2	NO	3.05 PPM	1.062	12100115
EB0032297	EB0032297.20160725	09/06/2025	GMIS	N2	CO	6.15 PPM	1.067	091002

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	07/09/2018
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	08/10/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Laboratory Supervisor
 Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Assay Laboratory: Red Ball TGS
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0045218	Certification Date:	07/17/2017
Product ID Number:	126123	Expiration Date:	07/15/2025
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport-LA
COA #	EB0045218.20170713-0	Lot Number:	EB0045218.20170713
Customer PO. NO.:		Tracking Number:	065086081
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)				
Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	8.29 PPM	±0.03 PPM	FTIR	07/17/2017
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)								
Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation					
Component	Analytical Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/30/2017

Red Ball Technical Gas Service
 PGVP Vendor ID # G12017
 Information and Ordering
 800-551-8150
 Fax (318-425-6309)



Anthony Cyr
 Analytical Chemist

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Version 02-E, Revised on 2016-04-27



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0099513	Certification Date:	01/05/2018
Product ID Number:	124609	Expiration Date:	01/03/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0099513.20171227-0	Lot Number:	EB0099513.20171227
Customer PO. NO.:		Tracking Number:	095685612
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	5.11 PPM	±0.03 PPM	FTIR	01/05/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	01/05/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
 Analyst
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC719271	Certification Date:	08/14/2018
Product ID Number:	125892	Expiration Date:	08/12/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	CC719271.20180806-0	Lot Number:	CC719271.20180806
Customer PO. NO.:		Tracking Number:	098505502
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	3.22 PPM	±0.02 PPM	FTIR	08/14/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0042063	EB0042063.20171231	03/17/2023	GMIS	N2	CH4	30.37 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	08/14/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Laboratory Supervisor
 Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0049796	Certification Date:	11/14/2017
Product ID Number:	124731	Expiration Date:	11/13/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0049796.20171101-0	Lot Number:	EB0049796.20171101
Customer PO. NO.:		Tracking Number:	073562832
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	50.8 PPM	±0.6 PPM	FTIR	11/07/2017, 11/14/2017
<div style="display: flex; justify-content: space-between;"> Air Balance </div>				

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0085284	EB0085284.20161201	11/02/2020	GMS	AIR	NO2	97 PPM	1.027	5605008

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/06/2017
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/14/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07

CALIBRATION GAS CERTIFICATIONS

**Unit #CTG-2
Cylinder Certifications**



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0101677	Certification Date:	11/15/2017
Product ID Number:	124605	Expiration Date:	11/13/2025
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0101677.20171106-0	Lot Number:	EB0101677.20171106
Customer PO. NO.:		Tracking Number:	095706155
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	18.7 %	±0.16 %	NDIR	11/15/2017
Oxygen	21.0 %	±0.11 %	MPA	11/10/2017
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0060638	EB0060638.20170112-0	10/23/2025	GMIS	N2	CO2	19.5 %	0.724	C1309410.01
EB0060740	EB0060740.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0064384	EB0064384.20170112	08/13/2025	GMIS	N2	CO2	19.6 %	0.761	101001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	10/16/2017
CO2	NDIR	Thermo	410i	1162980025	10/23/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC719163	Certification Date:	08/24/2018
Product ID Number:	124606	Expiration Date:	08/22/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	CC719163.20180814-0	Lot Number:	CC719163.20180814
Customer PO. NO.:		Tracking Number:	098490486
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	8.92 %	±0.08 %	NDIR	08/24/2018
Oxygen	11.98 %	±0.07 %	MPA	08/24/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0032246	EB0032246.20170209	08/05/2025	GMS	N2	O2	24 %	0.502	071001
EB0034340	EB0034340.20170209	05/09/2026	GMS	N2	O2	20 %	0.5	071001
EB0087453	EB0087453.20170424	11/25/2025	GMS	N2	CO2	9.51 %	0.724	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	07/27/2018
CO2	NDIR	Thermo	410i	1162980025	07/30/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Assay Laboratory: Red Ball TGS
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0052316	Certification Date:	07/03/2017
Product ID Number:	124604	Expiration Date:	07/02/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport-LA
COA #	EB0052316.20170621-0	Lot Number:	EB0052316.20170621
Customer PO. NO.:		Tracking Number:	074202432
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	11.18 PPM	±0.05 PPM	FTIR	07/03/2017
Nitric Oxide	11.12 PPM	±0.03 PPM	Chemiluminescence	06/26/2017, 07/03/2017
Total Oxides of Nitrogen	11.32 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC-349582	12100115CC-349582	07/22/2019	NTRM	N2	NO	95.2 PPM	1.05	12100115
EB0003194	EB0003194.20160721	01/11/2025	GMS	N2	CO	12.16 PPM	1.033	091002
EB0005492	EB0005492.20160721	01/10/2025	GMS	N2	CO	18.63 PPM	1.014	091002
EB0064245	EB0064245.20150713	11/29/2019	GMS	N2	NO	9.86 PPM	1.16	121001

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	06/05/2017
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/06/2017

Red Ball Technical Gas Service
 PGPV Vendor ID # G12017
 Information and Ordering
 800-551-8150
 Fax (318-425-6309)



Anthony Cyr
 Anthony Cyr
 Analytical Chemist

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Version 02-E, Revised on 2016-04-27



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0078112	Certification Date:	05/14/2018
Product ID Number:	124744	Expiration Date:	05/13/2021
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0078112.20180502-0	Lot Number:	EB0078112.20180502
Customer PO. NO.:		Tracking Number:	084266785
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	5.73 PPM	±0.06 PPM	FTIR	05/09/2018
Nitric Oxide	5.44 PPM	±0.06 PPM	Chemiluminescence	05/07/2018, 05/14/2018
Total Oxides of Nitrogen	5.53 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004076	EB0004076.20160721	08/05/2025	GMIS	N2	CO	12.2 PPM	1.046	091002
EB0027596	EB0027596.20151012g	12/20/2018	GMIS	N2	NO	5.802 PPM	1.01	2628a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	04/30/2018
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	05/09/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0100138	Certification Date:	01/05/2018
Product ID Number:	126123	Expiration Date:	01/03/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0100138.20171227-0	Lot Number:	EB0100138.20171227
Customer PO. NO.:		Tracking Number:	095685603
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	8.61 PPM	±0.03 PPM	FTIR	01/05/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	01/05/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
 Analyst
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Assay Laboratory: Red Ball TGS
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0072999	Certification Date:	04/24/2017
Product ID Number:	124609	Expiration Date:	04/22/2025
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport-LA
COA #	EB0072999.20170420-0	Lot Number:	EB0072999.20170420
Customer PO. NO.:		Tracking Number:	084252065
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)				
Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	5.05 PPM	±0.019 PPM	FTIR	04/24/2017
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)								
Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation					
Component	Analytical Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/24/2017

Red Ball Technical Gas Service
 PGVP Vendor ID # G12017
 Information and Ordering
 800-551-8150
 Fax (318-425-6309)



Brandon Theus
 Brandon Theus
 Analytical Chemist

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0079029	Certification Date:	01/05/2018
Product ID Number:	125892	Expiration Date:	01/03/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0079029.20171226-0	Lot Number:	EB0079029.20171226
Customer PO. NO.:		Tracking Number:	084090535
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	3.08 PPM	±0.02 PPM	FTIR	01/05/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	01/05/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
Analyst

Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0051214	Certification Date:	06/15/2018
Product ID Number:	124731	Expiration Date:	06/14/2021
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0051214.20180529-0	Lot Number:	EB0051214.20180529
Customer PO. NO.:		Tracking Number:	073563585
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	49.1 PPM	±0.5 PPM	FTIR	06/08/2018, 06/15/2018
Air				
Balance				

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0085284	EB0085284.20161201	11/02/2020	GMIS	AIR	NO2	97 PPM	1.027	5605008

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/07/2018
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/14/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0087648	Certification Date:	03/15/2018
Product ID Number:	124605	Expiration Date:	03/13/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0087648.20180306-0	Lot Number:	EB0087648.20180306
Customer PO. NO.:		Tracking Number:	095285944
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	19.0 %	±0.18 %	NDIR	03/15/2018
Oxygen	21.0 %	±0.11 %	MPA	03/12/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0019964	EB0019964.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0045483	EB0045483.20170424	11/25/2025	GMIS	N2	CO2	9.53 %	0.724	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	02/23/2018
CO2	NDIR	Thermo	410i	1162980025	03/14/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC719798	Certification Date:	09/06/2018
Product ID Number:	124606	Expiration Date:	09/04/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	CC719798.20180823-0	Lot Number:	CC719798.20180823
Customer PO. NO.:		Tracking Number:	098506981
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	8.92 %	±0.08 %	NDIR	09/06/2018
Oxygen	12.07 %	±0.06 %	MPA	08/30/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0034340	EB0034340.20170209	05/09/2026	GMIS	N2	O2	20 %	0.5	071001
EB0087453	EB0087453.20170424	11/25/2025	GMIS	N2	CO2	9.51 %	0.724	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	08/30/2018
CO2	NDIR	Thermo	410i	1162980025	08/31/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the “hands of the test” on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the “hands of the test” on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene’s review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer’s instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3. A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO₂ to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO₂ in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS QUALITY ASSURANCE DATA

Date: September 24-25, 2018
Company: CPV Valley, LLC
Location: Middletown, New York
Techs: AR/TP/DA

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
September 24-25, 2018	1 and 2	0



Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 General requirements for the competence of testing and calibration laboratories. This laboratory also meets the R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated 8 January 2009).



Presented this 10th day of October 2017

A handwritten signature in black ink, appearing to read 'L. L. L.', positioned above a horizontal line.

President and CEO
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2019

For the types of tests to which this accreditation applies, please refer to the laboratory's Environmental Scope of Accreditation.



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 10th day of October 2017



President and CEO
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2019

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

PATRICK K. MCGOVERN

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE SAMPLING METHODS

ISSUED THIS 25TH DAY OF SEPTEMBER 2015 AND EFFECTIVE UNTIL SEPTEMBER 25TH, 2020

Peter R. Westlin, QSTI/QSTO Review Board

Theresa M. Lowe, QSTI/QSTO Review Board

Theresa Lowe, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Karen D. Kajjya-Mills, QSTI/QSTO Review Board

Glenn C. England, QSTI/QSTO Review Board



CERTIFICATE
NO.
2008-133

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

PATRICK K. MCGOVERN, Jr.


HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR


GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 10TH DAY OF NOVEMBER 2017 AND EFFECTIVE UNTIL NOVEMBER 9TH, 2022





Peter R. Westlin, QSTI/QSTO Review Board


Peter S. Pakalnis, QSTI/QSTO Review Board


Theresa M. Lowe, QSTI/QSTO Review Board


J. Wade Bice, QSTI/QSTO Review Board


Karen D. Kajiyama-Mills, QSTI/QSTO Review Board


Bruce Randall, QSTI/QSTO Review Board

CERTIFICATE
NO.
2008-133

COMPLIANCE ASSURANCE ASSOCIATES INC.

Helping Industry Comply with Environmental Regulations

This is to acknowledge that

Axel Garrido Martinez

BRO180706-16529

Certificate verification is available at www.Compliance.Assurance.com/certs.php using the last name and 16529

successfully participated in Visible Emissions Evaluation field training and certification and pursuant to US EPA 40 CFR 60 Appendix A, Reference Method 9, as amended, is certified to evaluate Visible Emissions for a period of six (6) months from the date of this certification.



Anthony Ferro - Field Manager

Broken Arrow, OK

Location

07/06/2018

Date

Compliance Assurance Associates, Inc. 682 Orvil Smith Rd, Harvest, AL, 35749. 901-381-9960. compliance-assurance.com

QUALITY ASSURANCE AND QUALITY CONTROL DATA


**Unit #CTG-1
Daily Analyzer Calibrations**

Calibration Date: September 25, 2018
 Client: CPV Valley, LLC

Location: CPV Valley Energy Center - Unit CTG-1


NOx Span (ppm) = 8.90

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.00	-0.02	0.00	YES (%)
4.92	4.83	-1.01	0.09	YES (%)
8.90	8.91	0.11	0.01	YES (%)
Linearity = 0.999				




CO Span (ppm) = 9.20

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	-0.03	-0.33	0.03	YES (%)
5.13	5.26	1.41	0.13	YES (%)
9.20	9.19	-0.11	0.01	YES (%)
Linearity = 0.996				




O₂ Span (%) = 21.00

SERVOMEX 1440 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.00	0.01	0.00	YES (%)
12.05	12.19	0.66	0.14	YES (%)
21.00	20.99	-0.04	0.01	YES (%)
Linearity = 1.000				



VOC Range (ppm) = 10


THERMO 51C (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail (±2.5% ¹)
0.00	0.00	0.01	N/A	YES
3.22	3.07	-4.61	3.22	YES
5.11	4.85	-4.97	5.10	YES
8.29	8.28	-0.10	N/A	YES
Linearity = 0.967				



¹zero/high based on 2% of span, low/mid based on 5% of concentration

CO₂ Span (%) = 18.70

SERVOMEX 1440 (CO ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.06	0.31	0.06	YES (%)
8.92	8.94	0.11	0.02	YES (%)
18.70	18.74	0.23	0.04	YES (%)
Linearity = 1.001				



NOx Converter Efficiency

Date: September 25, 2018

Analyzer: INST-NX-0043

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO₂ to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO₂ concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO ₂ Concentration (C _v), ppmvd	50.80
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	2.40
	Analyzer Reading, NOx Channel, ppmvd	48.39
	Analyzer Reading, NO ₂ Channel (C _{Dir(NO₂)}), ppmvd	45.99
	Converter Efficiency, %	90.53

RM 7E, (02-27-14), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_v} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{45.99 \text{ ppmvd}}{50.80 \text{ ppmvd}} \times 100 = 90.53\%$$


Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
09/25/18 06:28:26	68080	46.69	2.49
09/25/18 06:28:36	68090	46.98	2.49
09/25/18 06:28:46	68100	47.26	2.49
09/25/18 06:28:56	68110	47.48	2.43
09/25/18 06:29:06	68120	47.75	2.39
09/25/18 06:29:16	68130	47.99	2.41
09/25/18 06:29:26	68140	48.19	2.39
09/25/18 06:29:36	68150	48.39	2.40
09/25/18 06:29:46	68160	48.50	2.33
09/25/18 06:29:56	68170	48.67	2.32
09/25/18 06:30:06	68180	48.81	2.32

Calibration Date: September 26, 2018
 Client: CPV Valley, LLC

Location: CPV Valley Energy Center - Unit CTG-1


NOx Span (ppm) = 8.90

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.00	0.00	0.00	YES (%)
4.92	4.96	0.48	0.04	YES (%)
8.90	8.95	0.60	0.05	YES (%)
Linearity = 0.994				




CO Span (ppm) = 9.20

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.04	0.43	0.04	YES (%)
5.13	5.14	0.10	0.01	YES (%)
9.20	9.28	0.87	0.08	YES (%)
Linearity = 0.996				




O2 Span (%) = 21.00

SERVOMEX 1440 (O2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.03	0.12	0.03	YES (%)
12.05	12.43	1.81	0.38	YES (%)
21.00	20.98	-0.12	0.02	YES (%)
Linearity = 1.000				



THC Range (ppm) = 10


THERMO 51C (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail (±2.5% ¹)
0.00	0.00	0.00	N/A	YES
3.22	3.13	-2.58	3.21	YES
5.11	4.99	-2.11	5.10	YES
8.29	8.27	-0.20	N/A	YES
Linearity = 0.984				



¹zero/high based on 2% of span, low/mid based on 5% of concentration

CO2 Span (%) = 18.70

SERVOMEX 1440 (CO2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.05	0.28	0.05	YES (%)
8.92	8.92	-0.02	0.00	YES (%)
18.70	18.80	0.55	0.10	YES (%)
Linearity = 0.997				



NOx Converter Efficiency

Date: September 26, 2018

Analyzer: INST-NX-0043

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO₂ to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO₂ concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO ₂ Concentration (C _v), ppmvd	50.80
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	1.78
	Analyzer Reading, NOx Channel, ppmvd	51.89
	Analyzer Reading, NO ₂ Channel (C _{Dir(NO₂)}), ppmvd	50.11
	Converter Efficiency, %	98.64

RM 7E, (02-27-14), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_v} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{50.11 \text{ ppmvd}}{50.80 \text{ ppmvd}} \times 100 = 98.64\%$$

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
09/27/18 03:23:56	229810	51.08	9.32
09/27/18 03:24:06	229820	51.21	9.27
09/27/18 03:24:16	229830	51.29	9.31
09/27/18 03:24:26	229840	51.39	9.31
09/27/18 03:24:36	229850	51.56	9.37
09/27/18 03:24:46	229860	51.62	3.48
09/27/18 03:24:56	229870	51.73	1.89
09/27/18 03:25:06	229880	51.82	1.82
09/27/18 03:25:16	229890	51.89	1.78
09/27/18 03:25:26	229900	51.94	1.80

DRIFT AND BIAS CHECK		
Strat Test Pre and Post QA/QC Check	O2	NOx
Initial Zero	0.04	-0.06
Final Zero	0.02	0.00
Avg. Zero	0.03	-0.03
Initial UpScale	12.23	4.82
Final UpScale	12.01	4.97
Avg. UpScale	12.12	4.90
Sys Resp (Zero)	0.04	-0.06
Sys Resp (Upscale)	12.23	4.82
Upscale Cal Gas	12.05	4.92
Initial Zero Bias	0.00%	0.00%
Final Zero Bias	-0.10%	0.67%
Zero Drift	0.10%	0.67%
Initial Upscale Bias	0.00%	0.00%
Final Upscale Bias	-1.05%	1.69%
Upscale Drift	1.05%	1.69%
Alternative Specification n Abs Diff	Initial Zero	0.00
	Final Zero	0.02
	Initial Upscale	0.00
	Final Upscale	0.15
Calibration Span	21.00	8.90
3% of Range (drift)	0.63	0.27
5% of Range (bias)	1.05	0.45

Response Time (min)	0.7	2.0
Sys. Response (min)	2.0	

INJECTIONS

Date/Time mm/dd/yy hh:mm:ss	Z	O ₂ %	s	Z	NOx ppm	s
09/24/18 06:43:27		0.10			0.74	
09/24/18 06:43:37		0.06			1.84	
09/24/18 06:43:47		0.05			3.35	
09/24/18 06:43:57		0.04			3.89	
09/24/18 06:44:07	x	0.04			3.99	
09/24/18 06:44:17		0.03			4.04	
09/24/18 06:44:27		0.02			4.04	
09/24/18 06:44:37		0.02			4.05	
09/24/18 06:44:47		0.02			4.07	
09/24/18 06:44:57		0.01			4.08	
09/24/18 06:45:07		0.01			4.08	
09/24/18 06:45:17		0.01			4.07	
09/24/18 06:45:27		0.01			4.96	x
09/24/18 06:45:37		0.02			4.93	
09/24/18 06:45:47		0.01			4.98	
09/24/18 06:45:57		0.03			4.96	
09/24/18 07:30:57		13.53			2.32	x
09/24/18 07:31:07		13.55			2.29	
09/24/18 07:31:17		12.65			2.29	
09/24/18 07:31:27		9.45			2.27	
09/24/18 07:31:37		11.94	x		1.83	
09/24/18 07:31:47		12.09			1.50	
09/24/18 07:31:57		12.10			0.89	
09/24/18 07:32:07		12.10		x	0.11	
09/24/18 07:32:17		12.11			-0.03	
09/24/18 07:32:27		12.10			-0.07	
09/24/18 07:32:37		12.11			-0.09	
09/24/18 07:32:47		12.11			-0.09	

DRIFT AND BIAS CHECK						
Base Load, Run - 1	O ₂	NOx	CO	VOC	CO ₂	
Raw Average	13.51	2.08	-0.39	0.51	4.12	
Corrected Average	13.59	2.11	0.00	0.54	4.14	
Initial Zero	0.03	0.00	0.06	0.01	0.08	
Final Zero	0.03	-0.02	-0.07	0.01	0.08	
Avg. Zero	0.03	-0.01	-0.01	0.01	0.08	
Initial UpScale	12.00	4.85	5.09	3.07	8.79	
Final UpScale	11.98	4.91	4.97	3.13	8.75	
Avg. UpScale	11.99	4.88	5.03	3.10	8.77	
Sys Resp (Zero)	0.00	0.00	-0.03	0.00	0.06	
Sys Resp (Upscale)	12.19	4.83	5.26	3.07	8.94	
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92	
Initial Zero Bias	0.13%	0.00%	0.98%	0.08%	0.12%	
Final Zero Bias	0.12%	-0.15%	-0.48%	0.09%	0.12%	
Zero Drift	0.01%	0.16%	1.46%	0.01%	0.01%	
Initial Upscale Bias	-0.90%	0.22%	-1.87%	0.04%	-0.82%	
Final Upscale Bias	-1.01%	0.94%	-3.21%	0.66%	-1.02%	
Upscale Drift	0.11%	0.72%	1.34%	0.62%	0.20%	
Alternative Specification Abs Diff	Initial Zero	0.03	0.00	0.09	--	0.02
	Final Zero	0.03	0.01	0.04	--	0.02
	Initial Upscale	0.19	0.02	0.17	--	0.15
	Final Upscale	0.21	0.08	0.30	--	0.19
Calibration Span	21.00	8.90	9.20	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.27	0.28	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.45	0.46	0.50	0.94	

DRIFT AND BIAS CHECK						
Base Load, Run - 2	O ₂	NOx	CO	VOC	CO ₂	
Raw Average	13.40	1.68	-0.45	0.17	4.16	
Corrected Average	13.53	1.75	0.00	0.19	4.17	
Initial Zero	0.03	-0.02	-0.07	0.01	0.08	
Final Zero	0.02	0.05	-0.14	0.08	0.06	
Avg. Zero	0.02	0.02	-0.11	0.05	0.07	
Initial UpScale	11.98	4.91	4.97	3.13	8.75	
Final UpScale	11.91	4.45	5.05	3.24	8.89	
Avg. UpScale	11.94	4.68	5.01	3.19	8.82	
Sys Resp (Zero)	0.00	0.00	-0.03	0.00	0.06	
Sys Resp (Upscale)	12.19	4.83	5.26	3.07	8.94	
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92	
Initial Zero Bias	0.12%	-0.15%	-0.48%	0.09%	0.12%	
Final Zero Bias	0.08%	0.62%	-1.19%	0.79%	0.01%	
Zero Drift	0.05%	0.77%	0.71%	0.70%	0.11%	
Initial Upscale Bias	-1.01%	0.94%	-3.21%	0.66%	-1.02%	
Final Upscale Bias	-1.32%	-4.27%	-2.26%	1.72%	-0.27%	
Upscale Drift	0.31%	5.21%	0.95%	1.06%	0.75%	
Alternative Specification Abs Diff	Initial Zero	0.03	0.01	0.04	--	0.02
	Final Zero	0.02	0.06	0.11	--	0.00
	Initial Upscale	0.21	0.08	0.30	--	0.19
	Final Upscale	0.28	0.38	0.21	--	0.05
Calibration Span	21.00	8.90	9.20	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.27	0.28	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.45	0.46	0.50	0.94	

DRIFT AND BIAS CHECK						
Base Load, Run - 3	O ₂	NOx	CO	VOC	CO ₂	
Raw Average	13.39	1.54	-0.46	0.44	4.15	
Corrected Average	13.59	1.65	0.00	0.49	4.16	
Initial Zero	0.02	0.05	-0.14	0.08	0.06	
Final Zero	0.02	-0.02	-0.03	0.05	0.05	
Avg. Zero	0.02	0.02	-0.08	0.07	0.06	
Initial UpScale	11.91	4.45	5.05	3.24	8.89	
Final UpScale	11.85	4.68	5.16	3.04	8.80	
Avg. UpScale	11.88	4.57	5.11	3.14	8.85	
Sys Resp (Zero)	0.00	0.00	-0.03	0.00	0.06	
Sys Resp (Upscale)	12.19	4.83	5.26	3.07	8.94	
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92	
Initial Zero Bias	0.08%	0.62%	-1.19%	0.79%	0.01%	
Final Zero Bias	0.10%	-0.20%	0.02%	0.53%	-0.02%	
Zero Drift	0.02%	0.82%	1.21%	0.27%	0.03%	
Initial Upscale Bias	-1.32%	-4.27%	-2.26%	1.72%	-0.27%	
Final Upscale Bias	-1.61%	-1.69%	-1.09%	-0.28%	-0.75%	
Upscale Drift	0.29%	2.58%	1.17%	2.00%	0.48%	
Alternative Specification Abs Diff	Initial Zero	0.02	0.06	0.11	--	0.00
	Final Zero	0.02	0.02	0.00	--	0.00
	Initial Upscale	0.28	0.38	0.21	--	0.05
	Final Upscale	0.34	0.15	0.10	--	0.14
Calibration Span	21.00	8.90	9.20	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.27	0.28	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.45	0.46	0.50	0.94	

DRIFT AND BIAS CHECK						
100% W/Db Load, Run - 1	O ₂	NOx	CO	VOC	CO ₂	
Raw Average	12.14	2.58	-0.30	0.07	4.78	
Corrected Average	12.11	2.61	0.00	0.08	4.80	
Initial Zero	0.00	-0.02	0.05	0.00	0.07	
Final Zero	0.05	-0.05	-0.01	0.00	0.08	
Avg. Zero	0.02	-0.03	0.02	0.00	0.07	
Initial UpScale	11.85	4.90	5.15	3.13	8.86	
Final UpScale	11.86	4.89	5.11	3.07	8.79	
Avg. UpScale	11.86	4.89	5.13	3.10	8.82	
Sys Resp (Zero)	0.00	0.00	-0.03	0.00	0.06	
Sys Resp (Upscale)	12.19	4.83	5.26	3.07	8.94	
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92	
Initial Zero Bias	-0.01%	-0.20%	0.89%	0.01%	0.04%	
Final Zero Bias	0.20%	-0.55%	0.22%	-0.02%	0.12%	
Zero Drift	0.21%	0.35%	0.67%	0.03%	0.08%	
Initial Upscale Bias	-1.61%	0.77%	-1.20%	0.62%	-0.43%	
Final Upscale Bias	-1.56%	0.67%	-1.65%	0.01%	-0.82%	
Upscale Drift	0.05%	0.10%	0.46%	0.61%	0.39%	
Alternative Specification Abs Diff	Initial Zero	0.00	0.02	0.08	--	0.01
	Final Zero	0.04	0.05	0.02	--	0.02
	Initial Upscale	0.34	0.07	0.11	--	0.08
	Final Upscale	0.33	0.06	0.15	--	0.15
Calibration Span	21.00	8.90	9.20	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.27	0.28	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.45	0.46	0.50	0.94	

DRIFT AND BIAS CHECK						
100% W/Db Load, Run - 2	O ₂	NOx	CO	VOC	CO ₂	
Raw Average	12.28	2.71	-0.31	0.00	4.79	
Corrected Average	12.40	2.75	0.00	0.00	4.82	
Initial Zero	0.05	-0.05	-0.01	0.00	0.08	
Final Zero	0.03	-0.06	0.09	0.00	0.08	
Avg. Zero	0.04	-0.06	0.04	0.00	0.08	
Initial UpScale	11.86	4.89	5.11	3.07	8.79	
Final UpScale	12.00	4.90	5.12	3.12	8.79	
Avg. UpScale	11.93	4.90	5.11	3.10	8.79	
Sys Resp (Zero)	0.00	0.00	-0.03	0.00	0.06	
Sys Resp (Upscale)	12.19	4.83	5.26	3.07	8.94	
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92	
Initial Zero Bias	0.20%	-0.55%	0.22%	-0.02%	0.12%	
Final Zero Bias	0.15%	-0.70%	1.25%	-0.01%	0.13%	
Zero Drift	0.05%	0.16%	1.03%	0.01%	0.02%	
Initial Upscale Bias	-1.56%	0.67%	-1.65%	0.01%	-0.82%	
Final Upscale Bias	-0.90%	0.79%	-1.54%	0.56%	-0.82%	
Upscale Drift	0.67%	0.11%	0.11%	0.55%	0.00%	
Alternative Specification Abs Diff	Initial Zero	0.04	0.05	0.02	--	0.02
	Final Zero	0.03	0.06	0.11	--	0.02
	Initial Upscale	0.33	0.06	0.15	--	0.15
	Final Upscale	0.19	0.07	0.14	--	0.15
Calibration Span	21.00	8.90	9.20	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.27	0.28	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.45	0.46	0.50	0.94	

DRIFT AND BIAS CHECK						
100% W/Db Load, Run - 3	O ₂	NOx	CO	VOC	CO ₂	
Raw Average	12.20	2.73	-0.26	0.13	4.78	
Corrected Average	12.25	2.77	0.00	0.14	4.82	
Initial Zero	0.03	-0.06	0.09	0.00	0.08	
Final Zero	0.03	0.00	0.06	0.01	0.08	
Avg. Zero	0.03	-0.03	0.07	0.00	0.08	
Initial UpScale	12.00	4.90	5.12	3.12	8.79	
Final UpScale	12.00	4.85	5.09	3.07	8.79	
Avg. UpScale	12.00	4.88	5.10	3.10	8.79	
Sys Resp (Zero)	0.00	0.00	-0.03	0.00	0.06	
Sys Resp (Upscale)	12.19	4.83	5.26	3.07	8.94	
Upscale Cal Gas	12.05	4.92	5.13	3.22	8.92	
Initial Zero Bias	0.15%	-0.70%	1.25%	-0.01%	0.13%	
Final Zero Bias	0.13%	0.00%	0.98%	0.08%	0.12%	
Zero Drift	0.02%	0.71%	0.27%	0.09%	0.01%	
Initial Upscale Bias	-0.90%	0.79%	-1.54%	0.56%	-0.82%	
Final Upscale Bias	-0.90%	0.22%	-1.87%	0.04%	-0.82%	
Upscale Drift	0.00%	0.56%	0.33%	0.52%	0.00%	
Alternative Specification Abs Diff	Initial Zero	0.03	0.06	0.11	--	0.02
	Final Zero	0.03	0.00	0.09	--	0.02
	Initial Upscale	0.19	0.07	0.14	--	0.15
	Final Upscale	0.19	0.02	0.17	--	0.15
Calibration Span	21.00	8.90	9.20	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.27	0.28	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.45	0.46	0.50	0.94	



AIR HYGIENE

MULTI LOAD TEST - FIELD DATA SHEET

Company:	Siemens
Location:	Middletown, NY
Date:	Project Code: sle-18-middletown.ny-start#1
Unit Make and Model:	Siemens NG fired combined cycle turbine
Unit Number:	CT-1
Serial Number:	Andrew McMahhan
Data Recorded By:	Truck(s): 149
Trailer(s):	217
Tested With AHJ Unit(s):	On (Day/Time): 07/25/18 Cal (Day/Time):
LDEQ Warmup/Cal Req:	

CYLINDER SERIAL NUMBERS	O ₂		NO _x		CO		THC		CO ₂		SO ₂		
	Low	Mid	High	EB0072319	EB0004881	EB0027801	EB0072319	EB0004881	EB0098513	EB0027801	EB0072319	EB0032368	EB0101662
				EB0072319	EB0004881	EB0027801	EB0072319	EB0004881	EB0098513	EB0027801	EB0072319	EB0032368	EB0101662

NO ₂ CONVERSION			
NO ₂ Gas (ppm)	50.8	NO _x Reading (ppm)	45.44
NO Reading (ppm)	2.40	Cylinder Num	EB0049796

Stack Dia. =
Measured By:
Measured With:

RUN INFORMATION	Base Load with out Duct Burners						Base Load with Duct Burners						60%						
	% #1		% #2		% #3		% #1		% #2		% #3		% #1		% #2		% #3		
	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	
Time Start (hh:mm:ss)	15:52:48	17:13:46	18:51:46	10:40:46	12:10:46														
Time Stop (hh:mm:ss)	16:52:18	18:13:16	19:51:16	10:20:16	11:40:16	13:10:16													
Rated MegaWatts (MW or hp)																			
Actual MegaWatts (MW or hp)																			
Barometric Pressure (in. Hg)	30.28	30.22	29.98	30.36	29.49														
Ambient Temperature (°F)	58	60	59	58	58														
Relative Humidity (%)	96	93	99	94	96														
Fuel Flow (lb/min)																			
Fuel Flow (SCF/hr)=(lb/min)*21.7																			
Specific Humidity (gr/lb)																			
Specific Humidity (lb H ₂ O/lb air)=(gr/lb)/7000																			
RSD (psi)	0.00731	0.010153	0.010514	0.009718	0.009509	0.009718													
PSD (mm Hg)=(psi*14.24)*57.71493																			
NO _x Water Injection (gpm)																			

CALIBRATION	O ₂		NO _x		CO		THC		CO ₂		SO ₂	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00
Low Gas												
Mid Gas	12.05	12.19	4.92	4.83	5.13	5.26	5.11	4.85	8.92	8.94	8.92	8.94
High Gas	21	20.99	8.9	8.91	9.2	9.19	8.92	8.21	18.7	18.74	18.7	18.74

BIAS	O ₂		NO _x		CO		THC		CO ₂		SO ₂	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Initial Low Load Run #1	0.07	12.00	0.00	4.85	0.06	5.09	0.01	3.07	0.08	8.79	0.00	0.00
Load 1 Run #1 / Load 1 Run #2	0.03	11.98	-0.02	4.91	-0.07	4.97	0.01	3.13	0.08	8.75	0.00	0.00
Load 1 Run #2 / Load 1 Run #3	0.02	11.91	0.05	4.45	-0.14	5.05	0.08	3.24	0.06	8.89	0.00	0.00
Load 1 Run #3 / Load 2 Run #1	0.02	11.85	-0.02	4.88	-0.03	5.16	0.05	3.04	0.05	8.80	0.00	0.00
Load 2 Run #1 / Load 2 Run #2	0.05	11.86	-0.01	4.89	-0.01	5.11	0.00	3.07	0.08	8.79	0.00	0.00
Load 2 Run #2 / Load 2 Run #3	0.03	12.00	-0.06	4.90	0.09	5.12	0.00	3.12	0.08	8.79	0.00	0.00
Load 3 Run #1 / Load 3 Run #2	0.03	12.00	0.00	4.85	0.06	5.09	0.01	3.07	0.08	8.79	0.00	0.00
Load 3 Run #2 / Load 3 Run #3												
Load 4 Run #1 / Load 4 Run #2												
Load 4 Run #2 / Load 4 Run #3												
Load 4 Run #3 Final												



AIR HYGIENE

MULTI LOAD TEST - FIELD DATA SHEET

Company:	Siemens
Location:	Middletown, Ny
Date:	Project Code: sie-18-middletown-ny-start#1
Unit Make and Model:	Siemens NG fired combined cycle turbine
Unit Number:	CT-1
Serial Number:	Andrew McMahen
Data Recorded By:	Truck(s): 149
Trailer(s):	217
Tested With AHI Unit(s):	On (Day/Time): 09/27/18 Cal (Day/Time):
LDEQ Warmup/Cal Req:	

CYLINDER SERIAL NUMBERS	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Low	EB0072319	EB0072319	EB0072319	EB0072319	EB0072319	CC719271	EB0072319	EB0072319	EB0072319	EB0072319	EB0072319
	Mid	EB00032368	EB0004881	EB0004881	EB0004881	EB0004881	EB0059513	EB0004881	EB0004881	EB0004881	EB0004881	EB0004881
High	EB0101662	EB0027801	EB0027801	EB0027801	EB0027801	EB0045218	EB0027801	EB0045218	EB0027801	EB0101662	EB0101662	

NO ₂ CONVERSION			
NO ₂ Gas (ppm)	50.8	NOx Reading (ppm)	49.8
NO Reading (ppm)	2.8	Cylinder Num	EB0049796

Stack Dia. =	
Measured By:	
Measured With:	

RUN INFORMATION	Base Load with out Duct Burners			Base Load with Duct Burners			60%		
	% #1	% #2	% #3	% #1	% #2	% #3	% #1	% #2	% #3
Time Start (hh:mm:ss)									
Time Stop (hh:mm:ss)									
Rated MegaWatts (MW or hp)									
Actual MegaWatts (MW or hp)									
Barometric Pressure (in. Hg)									
Ambient Temperature (°F)									
Relative Humidity (%)									
Fuel Flow (lb/min)									
Fuel Flow (SCF/hr)=(lb/min)*2.17									
Specific Humidity (gr/lb)									
Specific Humidity (lb H ₂ O/lb air)=(gr/lb)/7000									
PSD (psi)									
PSD (mm Hg)=(psi)*14.24)*51.71493									
NOx Water Injection (gpm)									

CALIBRATION	O ₂			NOx			CO			THC			CO ₂			SO ₂		
	Conc.	Actual	Mid	Zero	Conc.	Actual	Mid	Zero	Conc.	Actual	Mid	Zero	Conc.	Actual	Mid	Zero	Conc.	Actual
Zero Gas	0	6.00		0	0.06		0	0.04	0	0.00		0	0.05					
Low Gas																		
Mid Gas	12.05	12.43		4.92	4.96		5.14	5.14	5.11	4.94		8.92	8.92					
High Gas	21	20.98		8.9	8.95		9.28	9.28	8.92	8.27		18.7	18.7					

BIAS	O ₂			NOx			CO			THC			CO ₂			SO ₂		
	Zero	Mid	Actual	Zero	Conc.	Actual	Zero	Conc.	Actual	Zero	Conc.	Actual	Zero	Conc.	Actual	Zero	Conc.	Actual
Initial Low Load Run #1	0.03	12.00	4.83	0.00	4.83	5.09	0.01	4.07	3.07	0.09	8.79							
Load 1 Run #1 / Load 1 Run #2	0.03	11.98	4.91	0.02	4.91	4.87	0.01	4.13	3.13	0.08	8.75							
Load 1 Run #2 / Load 1 Run #3																		
Load 1 Run #3 / Load 2 Run #1																		
Load 2 Run #1 / Load 2 Run #2																		
Load 2 Run #2 / Load 2 Run #3																		
Load 2 Run #3 / Load 3 Run #1	0.02	12.01	4.91	0.04	4.91	5.13	0.02	3.13	3.13	0.05	8.92							
Load 3 Run #1 / Load 3 Run #2	0.00	12.00	4.78	0.02	4.78	5.19	0.00	2.79	2.79	0.08	8.90							
Load 3 Run #2 / Load 3 Run #3	0.01	12.03	4.95	0.13	4.95	4.95	0.00	2.58	2.58	0.08	8.89							
Load 3 Run #3 / Load 4 Run #1	0.00	12.05	4.72	0.05	4.72	5.14	0.04	0.69	0.69	0.11	9.02							
Load 4 Run #1 / Load 4 Run #2																		
Load 4 Run #2 / Load 4 Run #3																		
Load 4 Run #3 Final																		

QUALITY ASSURANCE AND QUALITY CONTROL DATA


**Unit #CTG-2
Daily Analyzer Calibrations**

Calibration Date: September 25, 2018
 Client: CPV Valley, LLC

Location: CPV Valley Energy Center - Unit CTG-2


NOx Span (ppm) = 11.32

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2% ≤0.5ppm)
0.00	0.00	0.00	0.00	YES (%)
5.53	5.58	0.44	0.05	YES (%)
11.32	11.38	0.53	0.06	YES (%)
Linearity = 0.995				




CO Span (ppm) = 11.18

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2% ≤0.5ppm)
0.00	0.07	0.63	0.07	YES (%)
5.73	5.74	0.09	0.01	YES (%)
11.18	11.15	-0.27	0.03	YES (%)
Linearity = 1.009				




O₂ Span (%) = 21.00

SERVOMEX 1440 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2% ≤0.5%)
0.00	0.09	0.43	0.09	YES (%)
11.98	12.07	0.43	0.09	YES (%)
21.00	21.01	0.05	0.01	YES (%)
Linearity = 1.004				



THC Range (ppm) = 10


THERMO 51C (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail (±2.5% ¹)
0.00	0.01	0.10	N/A	YES
3.08	2.94	-4.99	3.09	YES
5.05	5.09	0.48	5.07	YES
8.61	8.63	0.20	N/A	YES
Linearity = 0.975				



¹zero/high based on 2% of span, low/mid based on 5% of concentration

CO₂ Span (%) = 18.70

SERVOMEX 1440 (CO ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2% ≤0.5%)
0.00	-0.02	-0.11	0.02	YES (%)
8.92	8.99	0.37	0.07	YES (%)
18.70	18.83	0.70	0.13	YES (%)
Linearity = 0.992				



NOx Converter Efficiency

Date: September 25, 2018

Analyzer: INST-NX-0043

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO₂ to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO₂ concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO ₂ Concentration (C _v), ppmvd	49.10
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	0.70
	Analyzer Reading, NOx Channel, ppmvd	46.05
	Analyzer Reading, NO ₂ Channel (C _{Dir(NO₂)}), ppmvd	45.35
	Converter Efficiency, %	92.36

RM 7E, (02-27-14), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{45.35 \text{ ppmvd}}{49.10 \text{ ppmvd}} \times 100 = 92.36\%$$


Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
09/25/18 07:08:24	70500	-0.07	-0.11
09/25/18 07:09:24	70560	-0.09	-0.12
09/25/18 07:10:24	70620	-0.09	-0.12
09/25/18 07:11:24	70680	17.71	0.39
09/25/18 07:12:24	70740	40.12	2.01
09/25/18 07:13:24	70800	43.48	1.64
09/25/18 07:14:24	70860	44.75	1.23
09/25/18 07:15:24	70920	45.43	0.99
09/25/18 07:16:24	70980	45.88	0.83
09/25/18 07:17:24	71040	46.05	0.70

Calibration Date: September 26, 2018
 Client: CPV Valley, LLC

Location: CPV Valley Energy Center - Unit CTG-2


NOx Span (ppm) = 11.32

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	-0.11	-0.97	0.11	YES (%)
5.53	5.56	0.27	0.03	YES (%)
11.32	11.51	1.68	0.19	YES (%)
Linearity = 0.974				




CO Span (ppm) = 11.18

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.08	0.72	0.08	YES (%)
5.73	5.97	2.15	0.24	YES (abs)
11.18	11.07	-0.98	0.11	YES (%)
Linearity = 1.016				




O2 Span (%) = 21.00

SERVOMEX 1440 (O2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.02	0.10	0.02	YES (%)
11.98	12.01	0.14	0.03	YES (%)
21.00	21.01	0.05	0.01	YES (%)
Linearity = 1.000				



THC Range (ppm) = 10


THERMO 51C (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail (±2.5% ¹)
0.00	-0.01	-0.10	N/A	YES
3.08	3.18	1.83	3.12	YES
5.05	5.02	-2.14	5.13	YES
8.61	8.75	1.40	N/A	YES
Linearity = 0.987				



¹zero/high based on 2% of span, low/mid based on 5% of concentration

CO2 Span (%) = 18.70

SERVOMEX 1440 (CO2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	-0.05	-0.27	0.05	YES (%)
8.92	8.92	0.00	0.00	YES (%)
18.70	18.73	0.16	0.03	YES (%)
Linearity = 0.996				



NOx Converter Efficiency

Date: September 26, 2018

Analyzer: INST-NX-0043

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO₂ to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO₂ concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO ₂ Concentration (C _v), ppmvd	49.10
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	0.48
	Analyzer Reading, NOx Channel, ppmvd	45.83
	Analyzer Reading, NO ₂ Channel (C _{Dir(NO₂)}), ppmvd	45.35
	Converter Efficiency, %	92.36

RM 7E, (02-27-14), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_v} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{45.35 \text{ ppmvd}}{49.10 \text{ ppmvd}} \times 100 = 92.36\%$$

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
09/26/18 22:41:34	212890	45.77	0.54
09/26/18 22:41:44	212900	45.75	0.53
09/26/18 22:41:54	212910	45.77	0.54
09/26/18 22:42:04	212920	45.76	0.53
09/26/18 22:42:14	212930	45.81	0.54
09/26/18 22:42:24	212940	45.82	0.54
09/26/18 22:42:34	212950	45.79	0.53
09/26/18 22:42:44	212960	45.79	0.53
09/26/18 22:42:54	212970	45.83	0.48
09/26/18 22:43:04	212980	45.82	0.48
09/26/18 22:43:14	212990	45.83	0.48
09/26/18 22:43:24	213000	45.83	0.49

DRIFT AND BIAS CHECK		
Strat Test Pre and Post QA/QC Check	O2	NOx
Initial Zero	0.06	0.21
Final Zero	0.09	0.11
Avg. Zero	0.08	0.16
Initial UpScale	11.83	5.87
Final UpScale	12.15	5.48
Avg. UpScale	11.99	5.68
Sys Resp (Zero)	-0.01	0.02
Sys Resp (Upscale)	12.03	5.80
Upscale Cal Gas	11.98	5.53
Initial Zero Bias	0.33%	1.68%
Final Zero Bias	0.48%	0.80%
Zero Drift	0.14%	0.88%
Initial Upscale Bias	-0.95%	0.62%
Final Upscale Bias	0.57%	-2.83%
Upscale Drift	1.52%	3.45%
Alternative Specification Abs Diff	Initial Zero	0.07
	Final Zero	0.10
	Initial Upscale	0.20
	Final Upscale	0.12
Calibration Span	21.00	11.32
3% of Range (drift)	0.63	0.34
5% of Range (bias)	1.05	0.57

Response Time (min)	0.8	1.8
Sys. Response (min)	1.8	

INJECTIONS

Date/Time mm/dd/yy hh:mm:ss	Z	O ₂ %	s Z	NOx ppm	s
09/24/18 14:16:54		13.32		2.76	
09/24/18 14:17:04		13.11		2.80	
09/24/18 14:17:14		7.89		2.81	
09/24/18 14:17:24		1.83		2.78	
09/24/18 14:17:34	x	0.44		2.63	
09/24/18 14:17:44		0.23		2.78	
09/24/18 14:17:54		0.19		4.10	
09/24/18 14:18:04		0.17		5.22	
09/24/18 14:18:14		0.15		5.42	
09/24/18 14:18:24		0.14		5.57	
09/24/18 14:18:34		0.12		5.59	x
09/24/18 14:23:04		0.06		5.90	
09/24/18 14:23:14		0.06		5.86	x
09/24/18 14:23:24		1.51		5.86	
09/24/18 14:23:34		5.07		5.81	
09/24/18 14:23:44		9.77		5.74	
09/24/18 14:23:54		11.44	x	5.51	
09/24/18 14:24:04		11.73		4.77	
09/24/18 14:24:14		11.79		2.60	
09/24/18 14:24:24		11.81		1.00	
09/24/18 14:24:34		11.81		0.79	
09/24/18 14:24:44		11.82		0.57	
09/24/18 14:24:54		11.83	x	0.43	
09/24/18 14:25:04		11.83		0.36	

DRIFT AND BIAS CHECK						
100% W/Db Load, Run - 1	O ₂	NOx	CO	THC	CO ₂	
Raw Average	12.01	2.44	0.61	1.63	4.91	
Corrected Average	11.93	2.43	0.42	1.81	4.89	
Initial Zero	0.09	0.00	0.07	0.01	-0.02	
Final Zero	0.09	0.01	0.33	0.11	0.03	
Avg. Zero	0.09	0.01	0.20	0.06	0.01	
Initial UpScale	12.07	5.58	5.74	2.94	8.99	
Final UpScale	12.04	5.51	5.79	2.98	8.92	
Avg. UpScale	12.06	5.55	5.77	2.96	8.96	
Sys Resp (Zero)	0.09	0.00	0.07	0.01	-0.02	
Sys Resp (Upscale)	12.07	5.58	5.74	2.94	8.99	
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92	
Initial Zero Bias	0.00%	0.00%	0.00%	0.00%	0.00%	
Final Zero Bias	0.00%	0.09%	2.33%	1.00%	0.27%	
Zero Drift	0.00%	0.09%	2.33%	1.00%	0.27%	
Initial Upscale Bias	0.00%	0.00%	0.00%	0.00%	0.00%	
Final Upscale Bias	-0.14%	-0.62%	0.45%	0.40%	-0.37%	
Upscale Drift	0.14%	0.62%	0.45%	0.40%	0.37%	
Alternative Specification Abs Diff	Initial Zero	0.00	0.00	0.00	--	0.00
	Final Zero	0.00	0.01	0.26	--	0.05
	Initial Upscale	0.00	0.00	0.00	--	0.00
	Final Upscale	0.03	0.07	0.05	--	0.07
Calibration Span	21.00	11.32	11.18	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.34	0.34	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.57	0.56	0.50	0.94	

DRIFT AND BIAS CHECK						
100% W/Db Load, Run - 2	O ₂	NOx	CO	THC	CO ₂	
Raw Average	11.99	2.49	0.59	2.26	4.90	
Corrected Average	11.95	2.50	0.27	2.54	4.92	
Initial Zero	0.09	0.01	0.33	0.11	0.03	
Final Zero	0.08	0.01	0.35	0.28	-0.03	
Avg. Zero	0.09	0.01	0.34	0.20	0.00	
Initial UpScale	12.04	5.51	5.79	2.98	8.92	
Final UpScale	11.99	5.48	5.80	2.72	8.86	
Avg. UpScale	12.02	5.50	5.80	2.85	8.89	
Sys Resp (Zero)	0.09	0.00	0.07	0.01	-0.02	
Sys Resp (Upscale)	12.07	5.58	5.74	2.94	8.99	
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92	
Initial Zero Bias	0.00%	0.09%	2.33%	1.00%	0.27%	
Final Zero Bias	-0.05%	0.09%	2.50%	2.70%	-0.05%	
Zero Drift	0.05%	0.00%	0.18%	1.70%	0.32%	
Initial Upscale Bias	-0.14%	-0.62%	0.45%	0.40%	-0.37%	
Final Upscale Bias	-0.38%	-0.88%	0.54%	-2.20%	-0.70%	
Upscale Drift	0.24%	0.27%	0.09%	2.60%	0.32%	
Alternative Specification Abs Diff	Initial Zero	0.00	0.01	0.26	--	0.05
	Final Zero	0.01	0.01	0.28	--	0.01
	Initial Upscale	0.03	0.07	0.05	--	0.07
	Final Upscale	0.08	0.10	0.06	--	0.13
Calibration Span	21.00	11.32	11.18	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.34	0.34	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.57	0.56	0.50	0.94	

DRIFT AND BIAS CHECK						
100% W/Db Load, Run - 3	O ₂	NOx	CO	THC	CO ₂	
Raw Average	11.96	2.50	0.57	1.57	4.89	
Corrected Average	11.96	2.52	0.25	1.77	4.95	
Initial Zero	0.08	0.01	0.35	0.28	-0.03	
Final Zero	0.05	-0.03	0.32	0.12	-0.04	
Avg. Zero	0.07	-0.01	0.34	0.20	-0.04	
Initial UpScale	11.99	5.48	5.80	2.72	8.86	
Final UpScale	11.96	5.51	5.81	2.89	8.80	
Avg. UpScale	11.98	5.50	5.81	2.81	8.83	
Sys Resp (Zero)	0.09	0.00	0.07	0.01	-0.02	
Sys Resp (Upscale)	12.07	5.58	5.74	2.94	8.99	
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92	
Initial Zero Bias	-0.05%	0.09%	2.50%	2.70%	-0.05%	
Final Zero Bias	-0.19%	-0.27%	2.24%	1.10%	-0.11%	
Zero Drift	0.14%	0.35%	0.27%	1.60%	0.05%	
Initial Upscale Bias	-0.38%	-0.88%	0.54%	-2.20%	-0.70%	
Final Upscale Bias	-0.52%	-0.62%	0.63%	-0.50%	-1.02%	
Upscale Drift	0.14%	0.27%	0.09%	1.70%	0.32%	
Alternative Specification Abs Diff	Initial Zero	0.01	0.01	0.28	--	0.01
	Final Zero	0.04	0.03	0.25	--	0.02
	Initial Upscale	0.08	0.10	0.06	--	0.13
	Final Upscale	0.11	0.07	0.07	--	0.19
Calibration Span	21.00	11.32	11.18	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.34	0.34	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.57	0.56	0.50	0.94	

DRIFT AND BIAS CHECK						
Base Load, Run - 1	O ₂	NOx	CO	THC	CO ₂	
Raw Average	13.42	2.03	0.61	2.19	4.06	
Corrected Average	13.44	2.05	0.27	2.41	4.13	
Initial Zero	0.05	-0.03	0.32	0.12	-0.04	
Final Zero	0.09	-0.04	0.38	0.02	-0.04	
Avg. Zero	0.07	-0.04	0.35	0.07	-0.04	
Initial UpScale	11.96	5.51	5.81	2.89	8.80	
Final UpScale	11.97	5.58	5.87	3.00	8.82	
Avg. UpScale	11.97	5.55	5.84	2.95	8.81	
Sys Resp (Zero)	0.02	-0.11	0.08	-0.01	-0.05	
Sys Resp (Upscale)	12.07	5.58	5.74	2.94	8.99	
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92	
Initial Zero Bias	0.14%	0.71%	2.15%	1.30%	0.05%	
Final Zero Bias	0.33%	0.62%	2.68%	0.30%	0.05%	
Zero Drift	0.19%	0.09%	0.54%	1.00%	0.00%	
Initial Upscale Bias	-0.52%	-0.62%	0.63%	-0.50%	-1.02%	
Final Upscale Bias	-0.48%	0.00%	1.16%	0.60%	-0.91%	
Upscale Drift	0.05%	0.62%	0.54%	1.10%	0.11%	
Alternative Specification Abs Diff	Initial Zero	0.03	0.08	0.24	--	0.01
	Final Zero	0.07	0.07	0.30	--	0.01
	Initial Upscale	0.11	0.07	0.07	--	0.19
	Final Upscale	0.10	0.00	0.13	--	0.17
Calibration Span	21.00	11.32	11.18	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.34	0.34	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.57	0.56	0.50	0.94	

DRIFT AND BIAS CHECK						
Base Load, Run - 2	O ₂	NOx	CO	THC	CO ₂	
Raw Average	13.40	2.02	0.61	1.33	4.05	
Corrected Average	13.44	2.00	0.27	1.46	4.13	
Initial Zero	0.09	-0.04	0.38	0.02	-0.04	
Final Zero	0.10	0.11	0.32	-0.11	-0.03	
Avg. Zero	0.10	0.04	0.35	-0.05	-0.04	
Initial UpScale	11.97	5.58	5.87	3.00	8.82	
Final UpScale	11.94	5.48	5.80	3.09	8.78	
Avg. UpScale	11.96	5.53	5.84	3.05	8.80	
Sys Resp (Zero)	0.09	0.00	0.07	0.01	-0.02	
Sys Resp (Upscale)	12.07	5.58	5.74	2.94	8.99	
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92	
Initial Zero Bias	0.00%	-0.35%	2.77%	0.10%	-0.11%	
Final Zero Bias	0.05%	0.97%	2.24%	-1.20%	-0.05%	
Zero Drift	0.05%	1.33%	0.54%	1.30%	0.05%	
Initial Upscale Bias	-0.48%	0.00%	1.16%	0.60%	-0.91%	
Final Upscale Bias	-0.62%	-0.88%	0.54%	1.50%	-1.12%	
Upscale Drift	0.14%	0.88%	0.63%	0.90%	0.21%	
Alternative Specification Abs Diff	Initial Zero	0.00	0.04	0.31	--	0.02
	Final Zero	0.01	0.11	0.25	--	0.01
	Initial Upscale	0.10	0.00	0.13	--	0.17
	Final Upscale	0.13	0.10	0.06	--	0.21
Calibration Span	21.00	11.32	11.18	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.34	0.34	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.57	0.56	0.50	0.94	

DRIFT AND BIAS CHECK						
Base Load, Run - 3	O ₂	NOx	CO	THC	CO ₂	
Raw Average	13.39	2.04	0.58	2.50	4.05	
Corrected Average	13.45	1.99	0.26	2.76	4.14	
Initial Zero	0.10	0.11	0.32	-0.11	-0.03	
Final Zero	0.12	0.06	0.34	0.18	-0.03	
Avg. Zero	0.11	0.09	0.33	0.04	-0.03	
Initial UpScale	11.94	5.48	5.80	3.09	8.78	
Final UpScale	11.94	5.56	5.83	3.06	8.78	
Avg. UpScale	11.94	5.52	5.82	3.08	8.78	
Sys Resp (Zero)	0.09	0.00	0.07	0.01	-0.02	
Sys Resp (Upscale)	12.07	5.58	5.74	2.94	8.99	
Upscale Cal Gas	11.98	5.53	5.73	3.08	8.92	
Initial Zero Bias	0.05%	0.97%	2.24%	-1.20%	-0.05%	
Final Zero Bias	0.14%	0.53%	2.42%	1.70%	-0.05%	
Zero Drift	0.10%	0.44%	0.18%	2.90%	0.00%	
Initial Upscale Bias	-0.62%	-0.88%	0.54%	1.50%	-1.12%	
Final Upscale Bias	-0.62%	-0.18%	0.81%	1.20%	-1.12%	
Upscale Drift	0.00%	0.71%	0.27%	0.30%	0.00%	
Alternative Specification Abs Diff	Initial Zero	0.01	0.11	0.25	--	0.01
	Final Zero	0.03	0.06	0.27	--	0.01
	Initial Upscale	0.13	0.10	0.06	--	0.21
	Final Upscale	0.13	0.02	0.09	--	0.21
Calibration Span	21.00	11.32	11.18	10.00	18.70	
3% of Cal. Span (drift)	0.63	0.34	0.34	0.30	0.56	
5% of Cal. Span (bias)	1.05	0.57	0.56	0.50	0.94	



AIR HYGIENE

MULTI LOAD TEST - FIELD DATA SHEET

Company:	CPV Valley, LLC
Location:	CPV Valley Energy Center
Date:	Monday, September 24, 2018
Unit Make and Model:	Siemens SGT6-8000H
Unit Number:	CTG-2
Serial Number:	
Data Recorded By:	PKM
Truck(s):	165
Trailer(s):	215

CYLINDER SERIAL NUMBERS		O ₂	NOx	CO	CO ₂	THC
Low		EB0078112	CC719163	CC719163	EB0078112	CC719163
Mid		CC719163	EB0078112	EB0078112	CC719163	EB0072959
High		EB00101677	EB0052316	EB0052316	EB00101677	EB0100138

NO ₂ CONVERSION	
NO ₂ Gas (ppm)	49.1
NO Reading (ppm)	
Cylinder Num	EB0051214

Stack Dia. = _____
 Measured By: _____
 Measured W/ith: _____

RUN INFORMATION	Max Load					Low Load				
	% #1	% #2	% #3	% #4	% #5	% #1	% #2	% #3	% #4	% #5
Time Start (hh:mm:ss)										
Time Stop (hh:mm:ss)										
Rated MegaWatts (MW or hp)										
Actual MegaWatts (MW or hp)										
Barometric Pressure (In. Hg)										
Ambient Temperature (°F)										
Relative Humidity (%)										
Fuel Flow (lb/min)										
Fuel Flow (SCFH) ¹ =(lb/min)*21.7										
Specific Humidity (gr/lb)										
Specific Humidity (lb H ₂ O/lb air)=(gr/lb)/7000										
RSD (psl)										
RCD (mm Hg)=(psi*14.24)*51.71493										
NOx Water Injection (gpm)										

CALIBRATION	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0	-0.01	0	0.02	0	-0.02	0	-0.11	0	-0.03		
Low Gas			5.53	5.80	5.73	5.86	3.08	2.91				
Mid Gas	11.98	12.03	11.32	11.56	11.18	11.11	5.05	4.75	8.92	9.03		
High Gas	21	21.04					8.61	8.54	18.7	18.94		

BIAS	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Low Load Run #1												
Load 1 Run #1 / Load 1 Run #2	0.09	12.15	0.11	5.48	0.36	5.77						
Load 1 Run #2 / Load 1 Run #3												
Load 1 Run #3 / Load 1 Run #4												
Load 1 Run #4 / Load 1 Run #5												
Load 1 Run #5 / END												
Initial / Load 2 Run #1												
Load 2 Run #1 / Load 2 Run #2												
Load 2 Run #2 / Load 2 Run #3												
Load 2 Run #3 / Load 2 Run #4												
Load 2 Run #4 / Load 2 Run #5												
Load 2 Run #5 / Final												

Bias Gas Actual Conc.

11.98

5.53

5.73

3.08

8.92

Signature _____



AIR HYGIENE

MULTI LOAD TEST - FIELD DATA SHEET

Company:	CPV Valley, LLC
Location:	CPV Valley Energy Center
Date:	Thursday, September 25, 2018
Project Code:	site-18-middletown.ny-start#1
Unit Make and Model:	Siemens SGT6-8000H
Unit Number:	CTG-2
Serial Number:	
Data Recorded By:	PKM
Tested With AHI Unit(s):	Truck(s): 165 Trailer(s): 215

CYLINDER SERIAL NUMBERS		O ₂	NO _x	CO	CO ₂	THC
Low	EB0078112	CC719163	CC719163	CC719163	EB0078112	CC719163
Mid	CC719163	EB0078112	EB0078112	EB0078112	CC719163	EB0072999
High	EB00101677	EB0052316	EB0052316	EB0052316	EB00101677	EB0100138

NO ₂ CONVERSION	
NO ₂ Gas (ppm)	NO _x Reading (ppm)
NO Reading (ppm)	Cylinder Num
	EB0051214

Stack Dia. = _____
 Measured By: _____
 Measured With: _____

RUN INFORMATION	← BASE LOAD →					Low Load				
	% #1	% #2	% #3	% #4	% #5	% #1	% #2	% #3	% #4	% #5
Time Start (hh:mm:ss)	9:25:24	11:24:24	12:57:24	15:40:24	17:15:24	18:44:24				
Time Stop (hh:mm:ss)	10:24:24	12:23:24	13:56:24	16:39:24	18:14:24	19:43:24				
Rated MegaWatts (MW or hp)										
Actual MegaWatts (MW or hp)	29.78	29.78	29.75	29.10	29.68	29.66				
Barometric Pressure (in. Hg)	52	53	54	58	58	58				
Ambient Temperature (°F)	97	97	97	96	98	98				
Relative Humidity (%)										
Fuel Flow (lb/min)										
Fuel Flow (SCF/hr)=(lb/min)*2.17										
Specific Humidity (gr/lb)										
Specific Humidity (lb H ₂ O/lb air)=(gr/lb)/7000										
PGD (psi)										
PGD (mm Hg)=(psi*14.24)+51.71483										
Box Water Injection (gpm)										

CALIBRATION	O ₂		NO _x		CO		THC		CO ₂		SO ₂	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0	0.09	0	0.00	0	0.07	0	0.01	0	-0.02		
Low Gas	11.98	12.07	5.53	5.58	5.74	5.74	3.08	2.94	8.92	8.99		
Mid Gas	21	21.01	11.32	11.38	11.15	11.15	5.05	5.07	18.7	18.83		
High Gas							8.81	8.63				

BIAS	O ₂		NO _x		CO		THC		CO ₂		SO ₂	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Low Load Run #1	0.09	12.07	0.00	5.58	0.07	5.74	0.01	2.94	-0.02	8.99		
Load 1 Run #1 / Load 1 Run #2	0.09	12.04	0.01	5.51	0.33	5.79	0.11	2.98	0.03	8.92		
Load 1 Run #2 / Load 1 Run #3	0.08	11.99	0.01	5.48	0.35	5.80	0.28	2.72	-0.03	8.86		
Load 1 Run #3 / Load 1 Run #4	0.05	11.96	-0.03	5.51	0.32	5.81	0.12	2.89	-0.04	8.80		
Load 1 Run #4 / Load 1 Run #5	0.09	11.97	-0.04	5.58	0.38	5.87	0.02	3.00	-0.04	8.82		
Load 1 Run #5 / END	0.10	11.94	0.11	5.48	0.32	5.80	-0.11	3.09	-0.03	8.78		
Initial / Load 2 Run #1	0.12	11.94	0.06	5.56	0.34	5.83	0.36	3.06	-0.03	8.78		
Load 2 Run #1 / Load 2 Run #2												
Load 2 Run #2 / Load 2 Run #3												
Load 2 Run #3 / Load 2 Run #4												
Load 2 Run #4 / Load 2 Run #5												
Load 2 Run #5 / Final												

Bias Gas Actual Conc. 11.98 5.53 5.73 3.08 8.92

Signature: *Patrick A. [unclear]*



AIR HYGIENE

MULTI LOAD TEST - FIELD DATA SHEET

Company:	CPV Valley, LLC
Location:	CPV Valley Energy Center
Date:	Wednesday, November 20, 2014
Project Code:	slc-18-middlestown.ny-start#1
Unit Make and Model:	Siemens SGT6-800DH
Unit Number:	CTG-2
Serial Number:	
Data Recorded By:	PKM
Trailer(s):	165
Trailer(s):	215

CYLINDER SERIAL NUMBERS	Low	O ₂	NOx	CO	CO ₂	THC
	Mid	EB0078112	CC719163	CC719163	EB0078112	CC719163
	High	CC719163	EB0078112	EB0078112	CC719163	EB0072999
		EB00101677	EB0052316	EB0052316	EB00101677	EB0100138

Stack Dia. = _____
 Measured By: _____
 Measured With: _____

NO ₂ CONVERSION	
NO ₂ Gas (ppm)	49.1
NOx Reading (ppm)	
Cylinder Num	EB0051214

RUN INFORMATION	Max Load					Low Load				
	% #1	% #2	% #3	% #4	% #5	% #1	% #2	% #3	% #4	% #5
Time Start (hh:mm:ss)	23:41:24	00:57:24	02:13:24							
Time Stop (hh:mm:ss)	00:40:24	01:56:24	03:12:24							
Rated MegaWatts (MW or hp)										
Actual MegaWatts (MW or hp)										
Barometric Pressure (in. Hg)	29.49	29.53	29.54							
Ambient Temperature (°F)	60	60	58							
Relative Humidity (%)	83	79	76							
Fuel Flow (lb/min)										
Fuel Flow (SCF/hr)=(lb/min)*21.7										
Specific Humidity (gr/lb)										
Specific Humidity (lb H ₂ O/lb air)=(gr/lb)/7000										
NO ₂ (ppm)										
NO _x (ppm)										
NO _x (mm Hg)=(psi*14.24)*51.71493										
NO _x Water Injection (gpm)										

CALIBRATION	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0	0.02	0	-0.11	0	0.08	0	-0.01	0	-0.05		
Low Gas			5.53	5.56	5.73	5.97	3.08	3.18	3.08	3.18		
Mid Gas	11.98	12.01	11.32	11.51	11.18	11.07	5.05	5.02	8.92	8.92		
High Gas	21	21.01					8.61	8.75	18.7	18.73		

BIAS	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Low Load Run #1												
Load 1 Run #1 / Load 1 Run #2	0.02	12.01	-0.11	5.56	0.08	5.97	-0.01	3.18	-0.05	8.92		
Load 1 Run #2 / Load 1 Run #3	0.11	11.91	0.12	5.53	0.42	6.08	-0.12	3.08	-0.04	8.81		
Load 1 Run #3 / Load 1 Run #4	0.09	11.92	0.07	5.47	0.50	6.05	-0.05	3.12	-0.05	8.79		
Load 1 Run #4 / Load 1 Run #5	0.10	11.92	0.01	5.43	0.51	6.05	0.10	3.22	-0.05	8.84		
Load 1 Run #5 / END												
Initial / Load 2 Run #1												
Load 2 Run #1 / Load 2 Run #2												
Load 2 Run #2 / Load 2 Run #3												
Load 2 Run #3 / Load 2 Run #4												
Load 2 Run #4 / Load 2 Run #5												
Load 2 Run #5 / Final												

QUALITY ASSURANCE AND QUALITY CONTROL DATA

**Unit #CTG-1
Equipment Certifications and Calibrations**

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0024

Filename: \\AHI-FILES\SVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0024 Calibration 5-7-18.xls}Original (5 point)

Make: Apex
 Model #: XC-522
 Serial #: 1308035

Date: 05/07/18
 Barometric Pressure: 29.25 (in. Hg)
 Theoretical Critical Vacuum: 13.80 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
0.32	17.00	78.000	83.170	5.170	73.0	73.0
0.63	12.00	83.170	88.410	5.240	74.0	74.0
1.10	10.00	88.410	94.350	5.940	75.0	75.0
2.00	10.00	94.350	102.120	7.770	76.0	76.0
3.60	10.00	102.120	112.690	10.570	77.0	77.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
73.0	73.0	140	0.2353	16.0	71.2	71.4	71.3
75.0	75.0	148	0.3368	16.0	71.3	71.4	71.4
76.0	76.0	155	0.4555	16.0	71.4	71.6	71.5
77.0	77.0	163	0.5955	16.0	71.6	71.7	71.7
77.0	77.0	173	0.8121	16.0	71.6	71.7	71.7

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
5.009	141.85	5.076	143.8	5.227
5.066	143.48	5.128	145.2	5.281
5.739	162.53	5.779	163.7	5.953
7.510	212.69	7.554	213.9	7.784
10.248	290.22	10.302	291.8	10.615

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
0.005	1.013	1.955	49.66	0.086
0.004	1.012	1.874	47.59	0.005
-0.002	1.007	1.786	45.36	-0.083
-0.003	1.006	1.897	48.17	0.028
-0.003	1.005	1.834	46.58	-0.035
AVERAGE:	1.009	1.869	47.47	PASSED

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: _____

Craig McCarty

DATE: 05/07/18 05/07/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0024

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0024 Calibration 5-7-18.xls]Original (5 point)

Make: Apex	Date: 05/07/18
Model #: XC-522	Barometric Pressure: 29.25 (in. Hg)
Serial #: 1308035	Temperature (ASTM cal): 70.90 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	100.00	0.00	602.00	0.33	1203.00	0.25
Probe	99.00	0.50	600.00	0.00	1201.00	0.08
Filter	100.00	0.00	600.00	0.00	1200.00	0.00
Dryer	100.00	0.00	602.00	0.33	1203.00	0.25
Aux.	101.00	0.50	602.00	0.33	1203.00	0.25

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	70.90 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	71.0	0.10	yes
DGM Out	71.0	0.10	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty

DATE: 05/07/18 05/07/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0024 Calibration 5-7-18.xls}Original (5 point)

Barometric Pressure: 29.25

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	70.90	<i>Craig McCarty</i>	05/07/18	05/07/18
	Read	71.00			
	±°F	0.10			
Probe	Ref	70.90	<i>Craig McCarty</i>	05/07/18	05/07/18
	Read	71.00			
	±°F	0.10			
Filter	Ref	70.90	<i>Craig McCarty</i>	05/07/18	05/07/18
	Read	71.00			
	±°F	0.10			
Cond.	Ref	70.90	<i>Craig McCarty</i>	05/07/18	05/07/18
	Read	71.00			
	±°F	0.10			
CPM	Ref	70.90	<i>Craig McCarty</i>	05/07/18	05/07/18
	Read	71.00			
	±°F	0.10			
Exit	Ref	70.90	<i>Craig McCarty</i>	05/07/18	05/07/18
	Read	71.00			
	±°F	0.10			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0024

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0024 Calibration 5-7-18.xls]10-10-18 (3 point)

Make: Apex	Date: 10/10/18
Model #: XC-522	Barometric Pressure: 29.10 (in. Hg)
Serial #: 1308035	Theoretical Critical Vacuum: 13.73 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
1.90	10.00	94.110	101.700	7.590	70.0	70.0
1.90	10.00	101.700	109.290	7.590	71.0	71.0
1.90	10.00	109.290	116.880	7.590	73.0	73.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
71.0	71.0	163	0.5955	16.0	71.2	71.3	71.3
73.0	73.0	163	0.5955	16.0	71.3	71.2	71.3
74.0	74.0	163	0.5955	16.0	71.2	71.3	71.3

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
7.380	208.99	7.518	212.9	7.781
7.359	208.40	7.518	212.9	7.781
7.338	207.81	7.518	212.9	7.781

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
-0.003	1.019	1.830	46.49	0.005
0.000	1.022	1.825	46.36	0.000
0.003	1.025	1.820	46.23	-0.005
AVERAGE:	1.022	1.825	46.36	PASSED

LAST 5-PT:	1.009	1.869	PASSED	5-PT Date:
% DIFF:	1.3%	2.4%		05/07/18

40 CFR - CHAPTER I - PART 60

Appendix A, Method 5

10.3.2 Calibration After Use

After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single, intermediate orifice setting (based on the previous field test)...Calculate the average value of the DGM calibration factor. If the value has changed by more than 5 percent, recalibrate the meter over the full range of orifice settings, as detailed in Section 10.3.1.

10.3.3 Acceptable Variation in Calibration

If the DGM coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for the test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: Craig McCarty

DATE: 10/10/18 10/10/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0024

Filename: \\AHI-FILES\VR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0024 Calibration 5-7-18.xls]10-10-18 (3 point)

Make: Apex	Date: 10/10/18
Model #: XC-522	Barometric Pressure: 29.10 (in. Hg)
Serial #: 1308035	Temperature (ASTM cal): 71.30 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	602.00	0.33	1204.00	0.33
Probe	101.00	0.50	602.00	0.33	1204.00	0.33
Filter	101.00	0.50	602.00	0.33	1204.00	0.33
Dryer	101.00	0.50	602.00	0.33	1204.00	0.33
Aux.	101.00	0.50	602.00	0.33	1204.00	0.33

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	71.30 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	71.0	0.30	yes
DGM Out	71.0	0.30	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 10/10/18 10/10/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0024 Calibration 5-7-18.xls]10-10-18 (3 point)

Barometric Pressure: 29.10

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	71.30	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.30			
Probe	Ref	71.30	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	72.00			
	±°F	0.70			
Filter	Ref	71.30	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.30			
Cond.	Ref	71.30	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.30			
CPM	Ref	71.30	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.30			
Exit	Ref	71.30	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.30			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0028

Filename: \\AHI-FILES\SVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0028 Calibration 11-27-17.xls}Original (5 point)

Make: apex
 Model #: 522
 Serial #: 1705007

Date: 11/27/17
 Barometric Pressure: 29.26 (in. Hg)
 Theoretical Critical Vacuum: 13.80 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
0.31	17.00	175.600	180.970	5.370	74.0	74.0
0.63	12.00	180.970	186.430	5.460	74.0	74.0
1.10	10.00	186.430	192.620	6.190	74.0	74.0
1.90	10.00	192.620	200.780	8.160	74.0	74.0
3.50	10.00	200.780	211.880	11.100	75.0	75.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
74.0	75.0	140	0.2345	16.0	69.6	69.7	69.7
74.0	74.0	148	0.3355	16.0	69.6	69.6	69.6
74.0	74.0	155	0.4539	16.0	69.6	69.4	69.5
75.0	75.0	163	0.5911	16.0	69.5	69.4	69.5
76.0	76.0	173	0.8106	16.0	69.4	69.1	69.3

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
5.192	147.04	5.068	143.5	5.201
5.286	149.69	5.119	145.0	5.252
6.000	169.91	5.772	163.5	5.921
7.917	224.22	7.517	212.9	7.710
10.793	305.66	10.310	292.0	10.572

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
0.014	0.976	1.895	48.14	0.058
0.006	0.968	1.883	47.83	0.046
0.000	0.962	1.796	45.62	-0.041
-0.013	0.949	1.827	46.41	-0.010
-0.007	0.955	1.786	45.36	-0.052
AVERAGE:	0.962	1.838	46.67	PASSED

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: _____

Craig McCarty

DATE: 11/27/17 11/27/17

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0028

Filename: \\AHI-FILES\VR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0028 Calibration 11-27-17.xls}Original (5 point)

Make: apex Date: 11/27/17
 Model #: 522 Barometric Pressure: 29.25 (in. Hg)
 Serial #: 1705007 Temperature (ASTM cal): 68.00 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	601.00	0.17	1201.00	0.08
Probe	101.00	0.50	601.00	0.17	1201.00	0.08
Filter	101.00	0.50	601.00	0.17	1201.00	0.08
Dryer	101.00	0.50	601.00	0.17	1201.00	0.08
Aux.	101.00	0.50	601.00	0.17	1201.00	0.08

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	68.00 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	68.0	0.00	yes
DGM Out	68.0	0.00	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty

DATE: 11/27/17 11/27/17

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\Public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0028 Calibration 11-27-17.xls]Original (5 point)

Barometric Pressure: 29.26

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	68.60	<i>Craig McCarty</i>	11/27/17	11/27/17
	Read	68.00			
	±°F	0.60			
Probe	Ref	68.60	<i>Craig McCarty</i>	11/27/17	11/27/17
	Read	69.00			
	±°F	0.40			
Filter	Ref	68.60	<i>Craig McCarty</i>	11/27/17	11/27/17
	Read	69.00			
	±°F	0.40			
Cond.	Ref	68.60	<i>Craig McCarty</i>	11/27/17	11/27/17
	Read	68.00			
	±°F	0.60			
CPM	Ref	68.60	<i>Craig McCarty</i>	11/27/17	11/27/17
	Read	68.00			
	±°F	0.60			
Exit	Ref	68.60	<i>Craig McCarty</i>	11/27/17	11/27/17
	Read	68.00			
	±°F	0.60			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0028 Calibration 11-27-17.xls}10-9-18 (3 point)

Make: apex	Date: 10/09/18
Model #: 522	Barometric Pressure: 28.88 (in. Hg)
Serial #: 1705007	Theoretical Critical Vacuum: 13.62 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
1.90	10.00	292.400	300.610	8.210	73.0	73.0
1.90	10.00	300.610	308.820	8.210	75.0	75.0
1.90	10.00	308.820	317.090	8.270	78.0	78.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
75.0	75.0	163	0.5955	16.0	71.0	71.0	71.0
77.0	77.0	163	0.5955	16.0	71.0	70.8	70.9
79.0	79.0	163	0.5955	16.0	70.8	71.0	70.9

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
7.870	222.89	7.463	211.4	7.779
7.841	222.06	7.464	211.4	7.778
7.862	222.64	7.464	211.4	7.778

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
-0.002	0.948	1.831	46.51	0.008
0.002	0.952	1.824	46.33	0.000
0.000	0.949	1.816	46.11	-0.008
AVERAGE:	0.950	1.824	46.32	PASSED

LAST 5-PT:	0.962	1.838	PASSED	5-PT Date:
% DIFF:	1.3%	0.8%		11/27/17

40 CFR - CHAPTER I - PART 60

Appendix A, Method 5

10.3.2 Calibration After Use

After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single, intermediate orifice setting (based on the previous field test)...Calculate the average value of the DGM calibration factor. If the value has changed by more than 5 percent, recalibrate the meter over the full range of orifice settings, as detailed in Section 10.3.1.

10.3.3 Acceptable Variation in Calibration

If the DGM coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for the test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: Craig McCarty

DATE: 10/09/18 10/09/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0028

Filename: \\AHI-FILES\VR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0028 Calibration 11-27-17.xls}10-9-18 (3 point)

Make: apex Date: 10/09/18
 Model #: 522 Barometric Pressure: 28.88 (in. Hg)
 Serial #: 1705007 Temperature (ASTM cal): 71.00 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	100.00	0.00	600.00	0.00	1200.00	0.00
Probe	100.00	0.00	600.00	0.00	1200.00	0.00
Filter	100.00	0.00	600.00	0.00	1200.00	0.00
Dryer	100.00	0.00	600.00	0.00	1200.00	0.00
Aux.	100.00	0.00	600.00	0.00	1200.00	0.00

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	71.00 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	71.0	0.00	yes
DGM Out	71.0	0.00	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 10/09/18 10/09/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-d-0028

Filename: \\AHI-FILES\VR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0028 Calibration 11-27-17.xls]10-9-18 (3 point)

Barometric Pressure: 28.88

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	70.70	<i>Craig M. Carthy</i>	<u>10/09/18</u>	10/09/18
	Read	71.00			
	±°F	0.30			
Probe	Ref	70.80	<i>Craig M. Carthy</i>	<u>10/09/18</u>	10/09/18
	Read	71.00			
	±°F	0.20			
Filter	Ref	70.70	<i>Craig M. Carthy</i>	<u>10/09/18</u>	10/09/18
	Read	70.00			
	±°F	0.70			
Cond.	Ref	70.80	<i>Craig M. Carthy</i>	<u>10/09/18</u>	10/09/18
	Read	71.00			
	±°F	0.20			
CPM	Ref	70.70	<i>Craig M. Carthy</i>	<u>10/09/18</u>	10/09/18
	Read	71.00			
	±°F	0.30			
Exit	Ref	70.70	<i>Craig M. Carthy</i>	<u>10/09/18</u>	10/09/18
	Read	71.00			
	±°F	0.30			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).



Wind Tunnel Pitot Calibration

S-type Pitot ID: **A4187** Date: **2-Mar-15**
 Standard Pitot ID: **001** Personnel: **KMR MF**
 Cp(std): **0.99** Cp(actual): **0.724**
 Part Number: P_{bar}(in Hg): **29.71**
 Test Velocity (fps): **50** T(°F): **55**
 Wind Tunnel Location: **Calera, AL** Tunnel Size: **20" x 40"**
 Customer: **Air Hygiene**

A-SIDE	ΔP_{std} (In. H ₂ O)	ΔP_s (In. H ₂ O)	Cp(s)	Deviation*
	0.563	1.053	0.723	0.002
	0.561	1.048	0.724	-0.001
	0.561	1.050	0.724	0.000
	AVERAGE		0.724	0.001
			Std deviation	0.002

NOTES:

1. Pitot calibrated with an Environmental Supply Co. PM10 cyclone.
2. C_p is only valid when used with PM10 cyclone.
3. C_p is only valid with 1" spacing from PM10 cyclone.

$$Cp(s) = Cp(std) \sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

*Deviation = {Cp(s) - AVG Cp(s)} {must be <0.010}

Standard deviation of the deviations must be less than 0.02 for both sides.

Pitot tube S/N A4187 was calibrated in accordance with the CFR 40, Part 60 Appendix A, Method 2, Section 10.


Signature

3/2/15
Date

S-TYPE PITOT TUBE CALIBRATION SHEET
Reference USEPA Reference Method 2 (40CFR60, App. A, Meth. 2)

PITOT SERIAL# A5702
 PITOT TYPE: S
 STD. PITOT TYPE: HEMISPHERICAL
 Cp(std): 0.990
 PROBE SERIAL# N/A

CALIBRATION DATE: 17-Nov-14
 BAROMETRIC PRESSURE: 29.40 in Hg
 STATIC PRESSURE: -0.6 in H₂O
 BLOCKAGE %: <2%
 CORRECTION FACTOR: 1.00

SIDE "A" CALIBRATION				
RUN NO.	ΔP_{std} in H ₂ O	ΔP_s in H ₂ O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.565	0.814	0.825	0.000
2	0.564	0.809	0.827	0.002
3	0.561	0.810	0.824	-0.001

"A" AVERAGE	0.825	0.0014 <small>(must be ≤ 0.01)</small>
--------------------	-------	---

SIDE "B" CALIBRATION				
RUN NO.	ΔP_{std} in H ₂ O	ΔP_s in H ₂ O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.561	0.804	0.827	-0.001
2	0.564	0.804	0.829	0.001
3	0.561	0.804	0.827	-0.001



"B" AVERAGE	0.828	0.0013 <small>(must be ≤ 0.01)</small>
--------------------	-------	---

ACCEPTANCE CRITERIA

AVERAGE -0.0026 AVG. Cp (A) - AVG. Cp (B) must be ≤ 0.01

If the Average and both Deviation Averages "A" & "B" are ≤ 0.01 , then the OVERALL AVERAGE below may be used.
 * If NOT, use the "A" Average OR "B" Average.

OVERALL AVERAGE 0.8264




I certify that the above pitot tube was tested in accordance with the US EPA Method 2 standards.
 See the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 2, Item 4.

Print Name: BO PRITCHARD

Date 11/17/2014

Signature: 

Type S Pitot Tube Inspection Form



PITOT TUBE/PROBE # 5702

Parameter	Value	Allowable Range	Check
Assembly Level?	yes	Yes	OK
Ports Damaged?	no	No	OK
$\alpha 1$	0	$-10^\circ < \alpha 1 < +10^\circ$	OK
$\alpha 2$	1	$-10^\circ < \alpha 2 < +10^\circ$	OK
$\beta 1$	0	$-5^\circ < \beta 1 < +5^\circ$	OK
$\beta 2$	1	$-5^\circ < \beta 2 < +5^\circ$	OK
γ	1		
θ	0		
$Z = A \tan \gamma$	0.000	$Z \leq .125''$	OK
$W = A \tan \theta$	0.000	$W \leq .031''$	OK
D_t	0.375	.188" to .375"	OK
$A/2D_t$	1.105333	$1.05 \leq P_A/D_t \leq 1.5$	OK
A	0.829	$2.1D_t \leq A \leq 3D_t$	OK

Certification

I certify that pitot tube/probe number 5702 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube certification factor of 0.84. See 40 CFR Pt. 60, App. A, EPA Method 2.

Certified by: Bob Plummer 11-12-14
Personnel (Signature/Date)

Certificate of Calibration

S-Type Pitot Tube Calibration

See the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 2, Item 4.

Pitot Information

Pitot Type: S
 Pitot Serial #: 8162
 Probe Serial #: WT-CAL-PROBE

Calibration Conditions


Bar. Pressure (in Hg): 30.00
 Elevation (ft): 407
 Adj. Bar. Pressure (in Hg): 29.59
 Static Pressure (in H2O): -0.6
 Blockage %: < 2
 Correction Factor: 1.00

Reference Pitot Information

Std. Pitot Type: Ellipsoidal
 Cp(std): 0.990
 Serial #: APEX-RP1

Side "A" Calibration			
Run No.	ΔP_{std} in H2O	ΔP_s in H2O	Cp(s)
1	0.558	0.817	0.818
2	0.557	0.810	0.821
3	0.557	0.812	0.820

"A" Average: 0.820
 (must be ≤ 0.01)



$$C_{p(s)} = C_{p(std)} \frac{\Delta P_{std}}{\Delta P_s}$$

$$\text{Deviation} = C_{p(s)} - C_p(A)$$

$$\text{Avg Dev} = \sigma(A) = \frac{\sum_1^3 [C_{p(s)} - C_p(A)]}{3}$$

Method 2 Section 10.1.4.3 For a probe assembly constructed such that its pitot tube is always used in the same orientation, only one side of the pitot tube need be calibrated (the side which will face the flow). The pitot tube must still meet the alignment specifications of Figure 2-2 or 2-3, however, and must have an average deviation (σ) value of 0.01 or less (see section 10.1.4.4).

Technician: Chris Harris

Signature: Chris Harris

Date: 5/18/2018

I certify that the above pitot tube was tested in accordance with the US EPA Method 2 standards.

QUALITY ASSURANCE AND QUALITY CONTROL DATA

**Unit #CTG-2
Equipment Certifications and Calibrations**

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0025

Filename: \\AHI-FILES\SVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0025 Calibration 6-6-18.xls}Original (5 point)

Make: apex
Model #: XC-522D
Serial #: 1604005

Date: 06/06/18
Barometric Pressure: 29.23 (in. Hg)
Theoretical Critical Vacuum: 13.79 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
0.31	17.00	0.001	5.141	5.140	72.0	72.0
0.61	12.00	5.141	10.330	5.189	72.0	72.0
1.10	10.00	10.330	16.222	5.892	74.0	74.0
1.90	10.00	16.222	23.904	7.682	77.0	77.0
3.50	10.00	23.904	34.397	10.493	78.0	78.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
72.0	72.0	140	0.2353	16.0	71.8	71.8	71.8
74.0	74.0	148	0.3368	16.0	71.8	72.1	72.0
76.0	76.0	155	0.4555	16.0	72.1	72.5	72.3
78.0	78.0	163	0.5955	16.0	72.5	73.3	72.9
80.0	80.0	173	0.8121	16.0	73.3	73.4	73.4

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
4.986	141.19	5.070	143.6	5.229
5.027	142.38	5.122	145.1	5.284
5.694	161.26	5.771	163.4	5.958
7.404	209.69	7.540	213.5	7.793
10.126	286.77	10.279	291.1	10.632

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
0.000	1.017	1.901	48.28	0.080
0.002	1.019	1.823	46.29	0.002
-0.003	1.013	1.791	45.50	-0.029
0.002	1.018	1.804	45.82	-0.016
-0.001	1.015	1.783	45.30	-0.037
AVERAGE:	1.017	1.820	46.24	PASSED

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: _____

Craig McCarty

DATE: 06/06/18 06/06/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0025

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0025 Calibration 6-6-18.xls]Original (5 point)

Make: apex Date: 06/06/18
 Model #: XC-522D Barometric Pressure: 29.23 (in. Hg)
 Serial #: 1604005 Temperature (ASTM cal): 72.00 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	100.00	0.00	601.00	0.17	1202.00	0.17
Probe	100.00	0.00	601.00	0.17	1202.00	0.17
Filter	100.00	0.00	601.00	0.17	1202.00	0.17
Dryer	100.00	0.00	601.00	0.17	1202.00	0.17
Aux.	100.00	0.00	601.00	0.17	1202.00	0.17

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	72.00 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	72.0	0.00	yes
DGM Out	72.0	0.00	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty

DATE: 06/06/18 06/06/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0025 Calibration 6-6-18.xls}Original (5 point)

Barometric Pressure: 29.21

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	72.00	<i>Craig McCarty</i>	06/06/18	06/06/18
	Read	72.00			
	±°F	0.00			
Probe	Ref	72.00	<i>Craig McCarty</i>	06/06/18	06/06/18
	Read	71.00			
	±°F	1.00			
Filter	Ref	72.00	<i>Craig McCarty</i>	06/06/18	06/06/18
	Read	72.00			
	±°F	0.00			
Cond.	Ref	72.00	<i>Craig McCarty</i>	06/06/18	06/06/18
	Read	71.00			
	±°F	1.00			
CPM	Ref	72.00	<i>Craig McCarty</i>	06/06/18	06/06/18
	Read	71.00			
	±°F	1.00			
Exit	Ref	72.00	<i>Craig McCarty</i>	06/06/18	06/06/18
	Read	72.00			
	±°F	0.00			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0025

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\SAMP-CP-0025 Calibration 6-6-18.xls\10-5-18 (3 point)

Make: apex	Date: 10/05/18
Model #: XC-522D	Barometric Pressure: 29.12 (in. Hg)
Serial #: 1604005	Theoretical Critical Vacuum: 13.74 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
1.90	10.00	0.001	7.610	7.609	75.0	75.0
1.90	10.00	7.610	15.210	7.600	75.0	75.0
1.90	10.00	15.210	22.829	7.619	76.0	76.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
75.0	75.0	163	0.5955	16.0	71.0	71.2	71.1
76.0	76.0	163	0.5955	16.0	71.2	71.4	71.3
77.0	77.0	163	0.5955	16.0	71.4	71.5	71.5

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
7.341	207.89	7.525	213.1	7.780
7.325	207.45	7.523	213.1	7.781
7.330	207.58	7.522	213.0	7.782

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
-0.001	1.025	1.813	46.05	0.002
0.001	1.027	1.812	46.03	0.001
0.000	1.026	1.809	45.95	-0.002
AVERAGE:	1.026	1.811	46.01	PASSED

LAST 5-PT:	1.017	1.820	PASSED	5-PT Date:
% DIFF:	0.9%	0.5%		06/06/18

40 CFR - CHAPTER I - PART 60

Appendix A, Method 5

10.3.2 Calibration After Use

After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single, intermediate orifice setting (based on the previous field test)...Calculate the average value of the DGM calibration factor. If the value has changed by more than 5 percent, recalibrate the meter over the full range of orifice settings, as detailed in Section 10.3.1.

10.3.3 Acceptable Variation in Calibration

If the DGM coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for the test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: Craig McCarty

DATE: 10/05/18 10/05/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0025

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0025 Calibration 6-6-18.xls]10-5-18 (3 point)

Make: apex	Date: 10/05/18
Model #: XC-522D	Barometric Pressure: 29.12 (in. Hg)
Serial #: 1604005	Temperature (ASTM cal): 71.30 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	602.00	0.33	1203.00	0.25
Probe	101.00	0.50	602.00	0.33	1203.00	0.25
Filter	101.00	0.50	602.00	0.33	1203.00	0.25
Dryer	101.00	0.50	602.00	0.33	1203.00	0.25
Aux.	101.00	0.50	602.00	0.33	1203.00	0.25

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	71.30 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	72.0	0.70	yes
DGM Out	72.0	0.70	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 10/05/18 10/05/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0025 Calibration 6-6-18.xls]10-5-18 (3 point)

Barometric Pressure: 29.12

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	71.50	<i>Craig M. Carthy</i>	10/05/18	10/05/18
	Read	72.00			
	±°F	0.50			
Probe	Ref	71.50	<i>Craig M. Carthy</i>	10/05/18	10/05/18
	Read	73.00			
	±°F	1.50			
Filter	Ref	71.50	<i>Craig M. Carthy</i>	10/05/18	10/05/18
	Read	72.00			
	±°F	0.50			
Cond.	Ref	71.50	<i>Craig M. Carthy</i>	10/05/18	10/05/18
	Read	72.00			
	±°F	0.50			
CPM	Ref	71.50	<i>Craig M. Carthy</i>	10/05/18	10/05/18
	Read	72.00			
	±°F	0.50			
Exit	Ref	71.50	<i>Craig M. Carthy</i>	10/05/18	10/05/18
	Read	72.00			
	±°F	0.50			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0029

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0029 Calibration 8-9-18.xls}Original (5 point)

Make: apex
 Model #: 522
 Serial #: 1706009

Date: 08/09/18
 Barometric Pressure: 29.19 (in. Hg)
 Theoretical Critical Vacuum: 13.77 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
0.31	17.00	862.100	867.330	5.230	73.0	73.0
0.63	12.00	867.330	872.630	5.300	75.0	75.0
1.10	10.00	872.630	878.640	6.010	77.0	77.0
1.90	10.00	878.640	886.490	7.850	78.0	78.0
3.50	10.00	886.490	897.290	10.800	80.0	80.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
75.0	75.0	140	0.2353	16.0	70.9	71.3	71.1
77.0	77.0	148	0.3368	16.0	71.3	71.4	71.4
78.0	78.0	155	0.4555	16.0	71.4	71.5	71.5
80.0	80.0	163	0.5955	16.0	71.6	71.8	71.7
82.0	82.0	173	0.8121	16.0	71.8	71.9	71.9

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
5.047	142.93	5.067	143.5	5.226
5.100	144.42	5.118	144.9	5.281
5.773	163.50	5.768	163.3	5.953
7.535	213.39	7.538	213.5	7.784
10.370	293.67	10.279	291.1	10.617

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
0.004	1.004	1.894	48.10	0.070
0.004	1.004	1.872	47.56	0.048
-0.001	0.999	1.783	45.28	-0.041
0.001	1.000	1.797	45.65	-0.027
-0.008	0.991	1.774	45.06	-0.050
AVERAGE:	1.000	1.824	46.33	PASSED

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: _____

Craig McCarty

DATE: 08/09/18 08/09/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0029

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0029 Calibration 8-9-18.xls]Original (5 point)

Make: apex
 Model #: 522
 Serial #: 1706009

Date: 08/09/18
 Barometric Pressure: 29.19 (in. Hg)
 Temperature (ASTM cal): 70.30 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	100.00	0.00	601.00	0.17	1203.00	0.25
Probe	100.00	0.00	601.00	0.17	1203.00	0.25
Filter	100.00	0.00	601.00	0.17	1203.00	0.25
Dryer	100.00	0.00	601.00	0.17	1203.00	0.25
Aux.	100.00	0.00	601.00	0.17	1203.00	0.25

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	70.30 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	70.0	0.30	yes
DGM Out	70.0	0.30	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty

DATE: 08/09/18 08/09/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0029 Calibration 8-9-18.xls}Original (5 point)

Barometric Pressure: 29.19

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	70.30	<i>Craig McCarty</i>	<u>08/09/18</u>	08/09/18
	Read	71.00			
	±°F	0.70			
Probe	Ref	70.30	<i>Craig McCarty</i>	<u>08/09/18</u>	08/09/18
	Read	71.00			
	±°F	0.70			
Filter	Ref	70.30	<i>Craig McCarty</i>	<u>08/09/18</u>	08/09/18
	Read	71.00			
	±°F	0.70			
Cond.	Ref	70.30	<i>Craig McCarty</i>	<u>08/09/18</u>	08/09/18
	Read	71.00			
	±°F	0.70			
CPM	Ref	70.30	<i>Craig McCarty</i>	<u>08/09/18</u>	08/09/18
	Read	71.00			
	±°F	0.70			
Exit	Ref	70.30	<i>Craig McCarty</i>	<u>08/09/18</u>	08/09/18
	Read	71.00			
	±°F	0.70			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0029

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0029 Calibration 8-9-18.xls]10-10-18 (3 point)

Make: apex
Model #: 522
Serial #: 1706009

Date: 10/10/18
Barometric Pressure: 29.06 (in. Hg)
Theoretical Critical Vacuum: 13.71 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
1.90	10.00	648.900	656.730	7.830	71.0	71.0
1.90	10.00	656.730	664.570	7.840	72.0	72.0
1.90	10.00	664.570	672.420	7.850	75.0	75.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
72.0	72.0	163	0.5955	16.0	70.8	70.9	70.9
75.0	75.0	163	0.5955	16.0	70.9	71.0	71.0
76.0	76.0	163	0.5955	16.0	71.0	71.2	71.1

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
7.588	214.90	7.511	212.7	7.778
7.569	214.36	7.510	212.7	7.779
7.551	213.84	7.509	212.7	7.780

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
-0.002	0.990	1.828	46.43	0.006
0.000	0.992	1.821	46.26	0.000
0.002	0.994	1.815	46.10	-0.006
AVERAGE:	0.992	1.821	46.27	PASSED
LAST 5-PT:	1.000	1.824	PASSED	5-PT Date:
% DIFF:	0.8%	0.1%		08/09/18

40 CFR - CHAPTER I - PART 60

Appendix A, Method 5

10.3.2 Calibration After Use

After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single, intermediate orifice setting (based on the previous field test)...Calculate the average value of the DGM calibration factor. If the value has changed by more than 5 percent, recalibrate the meter over the full range of orifice settings, as detailed in Section 10.3.1.

10.3.3 Acceptable Variation in Calibration

If the DGM coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for the test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: Craig McCarty

DATE: 10/10/18 10/10/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0029

Filename: \\AHI-FILES\VR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0029 Calibration 8-9-18.xls]10-10-18 (3 point)

Make: apex	Date: 10/10/18
Model #: 522	Barometric Pressure: 29.06 (in. Hg)
Serial #: 1706009	Temperature (ASTM cal): 70.80 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	100.00	0.00	601.00	0.17	1203.00	0.25
Probe	100.00	0.00	601.00	0.17	1203.00	0.25
Filter	100.00	0.00	601.00	0.17	1203.00	0.25
Dryer	100.00	0.00	601.00	0.17	1203.00	0.25
Aux.	100.00	0.00	601.00	0.17	1203.00	0.25

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	70.80 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	70.0	0.80	yes
DGM Out	70.0	0.80	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 10/10/18 10/10/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Assett ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\Public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0029 Calibration 8-9-18.xls]10-10-18 (3 point)

Barometric Pressure: 29.06

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	70.80	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.20			
Probe	Ref	70.80	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.20			
Filter	Ref	70.80	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.20			
Cond.	Ref	70.80	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.20			
CPM	Ref	70.80	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.20			
Exit	Ref	70.80	<i>Craig M. Carthy</i>	10/10/18	10/10/18
	Read	71.00			
	±°F	0.20			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0030 Calibration 7-9-18.xls}Original (5 point)

Make: apex
 Model #: 522
 Serial #: 1706010

Date: 07/09/18
 Barometric Pressure: 29.36 (in. Hg)
 Theoretical Critical Vacuum: 13.85 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
0.31	17.00	523.220	528.570	5.350	79.0	79.0
0.63	12.00	528.570	533.970	5.400	79.0	79.0
1.10	10.00	533.970	540.100	6.130	80.0	80.0
1.90	10.00	540.100	548.090	7.990	81.0	81.0
3.50	10.00	548.090	559.080	10.990	82.0	82.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
79.0	79.0	140	0.2353	16.0	74.1	74.1	74.1
80.0	80.0	148	0.3368	16.0	74.1	74.2	74.2
81.0	81.0	155	0.4555	16.0	74.2	74.3	74.3
82.0	82.0	163	0.5955	16.0	74.3	74.4	74.4
84.0	84.0	173	0.8121	16.0	74.4	74.5	74.5

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
5.145	145.70	5.082	143.9	5.241
5.192	147.04	5.134	145.4	5.295
5.890	166.80	5.786	163.9	5.968
7.678	217.45	7.564	214.2	7.804
10.574	299.46	10.314	292.1	10.643

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
0.004	0.988	1.876	47.64	0.064
0.005	0.989	1.859	47.22	0.047
-0.002	0.982	1.772	45.00	-0.040
0.001	0.985	1.788	45.40	-0.025
-0.009	0.975	1.766	44.86	-0.046
AVERAGE:	0.984	1.812	46.03	PASSED

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: _____

Craig McCarty

DATE: 07/09/18 07/09/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0030 Calibration 7-9-18.xls]Original (5 point)

Make: apex	Date: 07/09/18
Model #: 522	Barometric Pressure: 29.36 (in. Hg)
Serial #: 1706010	Temperature (ASTM cal): 74.30 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	100.00	0.00	602.00	0.33	1205.00	0.42
Probe	100.00	0.00	602.00	0.33	1205.00	0.42
Filter	100.00	0.00	602.00	0.33	1205.00	0.42
Dryer	100.00	0.00	602.00	0.33	1205.00	0.42
Aux.	100.00	0.00	602.00	0.33	1205.00	0.42

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	74.30 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	74.0	0.30	yes
DGM Out	74.0	0.30	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty

DATE: 07/09/18 07/09/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0086

Hotbox: samp-bh-0012

Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0030 Calibration 7-9-18.xls}Original (5 point)

Barometric Pressure: 29.36

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	74.20	<i>Craig McCarty</i>	07/09/18	07/09/18
	Read	74.00			
	±°F	0.20			
Probe	Ref	74.20	<i>Craig McCarty</i>	07/09/18	07/09/18
	Read	74.00			
	±°F	0.20			
Filter	Ref	74.20	<i>Craig McCarty</i>	07/09/18	07/09/18
	Read	74.00			
	±°F	0.20			
Cond.	Ref	74.20	<i>Craig McCarty</i>	07/09/18	07/09/18
	Read	74.00			
	±°F	0.20			
CPM	Ref	74.20	<i>Craig McCarty</i>	07/09/18	07/09/18
	Read	74.00			
	±°F	0.20			
Exit	Ref	74.20	<i>Craig McCarty</i>	07/09/18	07/09/18
	Read	74.00			
	±°F	0.20			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

METERING SYSTEM DRY GAS METER CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0032

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current[SAMP-CP-0032 Calibration 6-26-18.xls]Original (5 point)

Make: apex
 Model #: 522
 Serial #: 1804004

Date: 06/26/18
 Barometric Pressure: 29.13 (in. Hg)
 Theoretical Critical Vacuum: 13.74 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
0.31	17.00	27.050	32.310	5.260	73.0	73.0
0.62	12.00	32.310	37.620	5.310	74.0	74.0
1.10	10.00	37.620	43.650	6.030	76.0	76.0
1.90	10.00	43.650	51.540	7.890	79.0	79.0
3.50	10.00	51.540	62.360	10.820	80.0	80.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
74.0	74.0	140	0.2353	16.0	71.5	71.6	71.6
75.0	75.0	148	0.3368	16.0	71.6	71.8	71.7
78.0	78.0	155	0.4555	16.0	71.8	72.4	72.1
80.0	80.0	163	0.5955	16.0	72.4	72.4	72.4
82.0	82.0	173	0.8121	16.0	72.4	72.4	72.4

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
5.070	143.59	5.054	143.1	5.228
5.113	144.80	5.106	144.6	5.283
5.786	163.86	5.752	162.9	5.956
7.551	213.84	7.518	212.9	7.789
10.368	293.62	10.253	290.4	10.623

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
0.002	0.997	1.901	48.28	0.076
0.004	0.999	1.853	47.06	0.028
-0.001	0.994	1.790	45.47	-0.035
0.001	0.996	1.802	45.76	-0.023
-0.006	0.989	1.780	45.20	-0.045
AVERAGE:	0.995	1.825	46.36	PASSED

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: _____

Craig McCarty

DATE: 06/26/18 06/26/18

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0032

Filename: \\AHI-FILES\VR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0032 Calibration 6-26-18.xls]Original (5 point)

Make: apex Date: 06/26/18
 Model #: 522 Barometric Pressure: (in. Hg)
 Serial #: 1804004 Temperature (ASTM cal): (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	100.00	0.00	600.00	0.00	1200.00	0.00
Probe	100.00	0.00	601.00	0.17	1201.00	0.08
Filter	101.00	0.50	600.00	0.00	1201.00	0.08
Dryer	100.00	0.00	600.00	0.00	1200.00	0.00
Aux.	100.00	0.00	600.00	0.00	1200.00	0.00

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
 Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	72.00 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	72.0	0.00	yes
DGM Out	72.0	0.00	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 06/26/18 06/26/18

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
 Appendix A, Method 5
 10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID(s): Probe: samp-hp-0086 Hotbox: samp-bh-0012 Gooseneck: samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\IM-5 Consoles\Calibration Sheet v4.1\Current\{SAMP-CP-0032 Calibration 6-26-18.xls}Original (5 point)

Barometric Pressure: 29.14

Thermo-couples	Temps		Signature	Date	
		(°F)			
Stack	Ref	72.00	<i>Craig McCarty</i>	06/26/18	06/26/18
	Read	72.00			
	±°F	0.00			
Probe	Ref	72.00	<i>Craig McCarty</i>	06/26/18	06/26/18
	Read	73.00			
	±°F	1.00			
Filter	Ref	72.00	<i>Craig McCarty</i>	06/26/18	06/26/18
	Read	72.00			
	±°F	0.00			
Cond.	Ref	72.00	<i>Craig McCarty</i>	06/26/18	06/26/18
	Read	72.00			
	±°F	0.00			
CPM	Ref	72.00	<i>Craig McCarty</i>	06/26/18	06/26/18
	Read	72.00			
	±°F	0.00			
Exit	Ref	72.00	<i>Craig McCarty</i>	06/26/18	06/26/18
	Read	72.00			
	±°F	0.00			

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).



Wind Tunnel Pitot Calibration

S-type Pitot ID: **A4187** Date: **2-Mar-15**
 Standard Pitot ID: **001** Personnel: **KMR MF**
 Cp(std): **0.99** Cp(actual): **0.724**
 Part Number: P_{bar}(in Hg): **29.71**
 Test Velocity (fps): **50** T(°F): **55**
 Wind Tunnel Location: **Calera, AL** Tunnel Size: **20" x 40"**
 Customer: **Air Hygiene**

A-SIDE	ΔP_{std} (In. H ₂ O)	ΔP_s (In. H ₂ O)	Cp(s)	Deviation*
	0.563	1.053	0.723	0.002
	0.561	1.048	0.724	-0.001
	0.561	1.050	0.724	0.000
	AVERAGE		0.724	0.001
			Std deviation	0.002

NOTES:

1. Pitot calibrated with an Environmental Supply Co. PM10 cyclone.
2. C_p is only valid when used with PM10 cyclone.
3. C_p is only valid with 1" spacing from PM10 cyclone.

$$Cp(s) = Cp(std) \sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

*Deviation = {Cp(s) - AVG Cp(s)} {must be <0.010}

Standard deviation of the deviations must be less than 0.02 for both sides.

Pitot tube S/N A4187 was calibrated in accordance with the CFR 40, Part 60 Appendix A, Method 2, Section 10.


Signature

3/2/15
Date



Wind Tunnel Pitot Calibration

S-type Pitot ID: **A5273** Date: **2-Mar-15**
 Standard Pitot ID: **001** Personnel: **KMR MF**
 Cp(std): **0.99** Cp(actual): **0.742**
 Part Number: P_{bar}(in Hg): **29.71**
 Test Velocity (fps): **50** T(°F): **55**
 Wind Tunnel Location: **Calera, AL** Tunnel Size: **20" x 40"**
 Customer: **Air Hygiene**

A-SIDE	ΔP_{std} (in. H ₂ O)	ΔP_p (in. H ₂ O)	Cp(s)	Deviation*
	0.5596	0.9948	0.743	0.002
	0.5608	0.9981	0.742	-0.001
	0.5615	0.9984	0.742	0.000
	AVERAGE		0.742	0.001
Std deviation			0.002	

- NOTES:**
1. Pitot calibrated with an Environmental Supply Co. PM10 cyclone.
 2. C_p is only valid when used with PM10 cyclone.
 3. C_p is only valid with 1" spacing from PM10 cyclone.

$$Cp(s) = Cp(std) \sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

*Deviation = {Cp(s) - AVG Cp(s)} {must be <0.010}

Standard deviation of the deviations must be less than 0.02 for both sides.

Pitot tube S/N A5273 was calibrated in accordance with the CFR 40, Part 60 Appendix A, Method 2, Section 10.



 Signature

3/2/15
 Date

Certificate of Calibration

S-Type Pitot Tube Calibration

See the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 2, Item 4.

Pitot Information

Pitot Type: S
 Pitot Serial #: 8169
 Probe Serial #: WT-CAL-PROBE

Calibration Conditions


Bar. Pressure (in Hg): 30.00
 Elevation (ft): 407
 Adj. Bar. Pressure (in Hg): 29.59
 Static Pressure (in H2O): -0.6
 Blockage %: < 2
 Correction Factor: 1.00

Reference Pitot Information

Std. Pitot Type: Ellipsoidal
 Cp(std): 0.990
 Serial #: APEX-RP1

Side "A" Calibration				
Run No.	ΔP_{std} in H2O	ΔP_s in H2O	Cp(s)	Deviation Cp(s) - avg.Cp(s)
1	0.558	0.776	0.840	0.001
2	0.556	0.776	0.838	-0.001
3	0.557	0.777	0.838	0.000

"A" Average: 0.839
 (must be ≤ 0.01)



$$C_{p(s)} = C_{p(std)} \frac{\Delta p_{std}}{\Delta p_s}$$

$$\text{Deviation} = C_{p(s)} - C_p(A)$$

$$\text{Avg Dev} = \sigma(A) = \frac{\sum_{i=1}^3 [C_{p(s)} - C_p(A)]}{3}$$


Method 2 Section 10.1.4.3 For a probe assembly constructed such that its pitot tube is always used in the same orientation, only one side of the pitot tube need be calibrated (the side which will face the flow). The pitot tube must still meet the alignment specifications of Figure 2-2 or 2-3, however, and must have an average deviation (σ) value of 0.01 or less (see section 10.1.4.4).

Technician: Chris Harris

Signature: *Chris Harris*

Date: 5/18/2018

I certify that the above pitot tube was tested in accordance with the US EPA Method 2 standards.



Reference pilot is lowered in from the top of the wind tunnel and removed during testing.

P:\Archives-documentation\Justin - Master CAD Files\P-#\{PROBEST}\Method 5 Probe\

8 7 6 5 4 3 2 1

DATE	DESCRIPTION	BY	CHKD	DATE
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018
04/17/2018	ISSUED FOR FABRICATION	JM	CM	04/17/2018



SIZE: DWG. NO. B
 M5 Probe in Tunnel
 SCALE: 1:3 WEIGHT: SHEET 1 OF 1



Wind Tunnel Pitot Calibration

S-type Pitot ID: **P-980** Date: **2-Nov-15**
 Standard Pitot ID: **001** Personnel: **KMR**
 Cp(std): **0.99** Cp(actual): **0.772**
 Part Number: _____ P_{bar}(in Hg): **29.31**
 Test Velocity (fps): **50** T(°F): **67**
 Wind Tunnel Location: **Calera, AL** Tunnel Size: **20" x 40"**
 Customer: **Air Hygiene**

A-SIDE	ΔP_{std} (in. H ₂ O)	ΔP_s (in. H ₂ O)	Cp(s)	Deviation*
	0.563	0.925	0.772	0.002
	0.563	0.925	0.772	-0.001
	0.563	0.926	0.772	0.000
	AVERAGE	0.772	0.001	
		Std deviation	0.002	

- NOTES:**
1. Pitot calibrated with an Apex Instruments PM10 cyclone.
 2. C_p is only valid when used with PM10 cyclone.
 3. C_p is only valid with 1" spacing from PM10 cyclone.

$$Cp(s) = Cp(std) \sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

*Deviation = {Cp(s) - AVG Cp(s)} {must be <0.010}

Standard deviation of the deviations must be less than 0.02 for both sides.

Pitot tube S/N P-980 was calibrated in accordance with the CFR 40, Part 60 Appendix A, Method 2, Section 10.



 Signature

11/2/15

 Date

QUALITY ASSURANCE AND QUALITY CONTROL DATA

**Common
Equipment Certifications and Calibrations**

WEATHER STATION CALIBRATION SHEET
Temperature, Barometric Pressure, and Relative Humidity Periodic Calibration
Air Hygiene Asset ID: samp-we-0032

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\Weather Stations\2018\[SAMP-WE-0032_AHU.xlsm]112013
 Make: Kestrel ISO 17025 Weather Station ID SAMP-WE-0033
 Model #: 4000 ISO 17025 S/N A026334
 Serial #: 724648 ISO 17025 Cal Due 8/22/2018

ASTM Temp (deg F) ($\pm 1.5^\circ$)	Thermo. (deg F)	\pm deg F	ASTM Barometer (in. Hg) (± 0.1 in Hg)	Barometric (in. Hg)	\pm in. Hg	Time
69.40	70.60	1.20	29.19	29.19	0.00	08:20
<i>Sean Barnes</i>						<u>05/10/18</u>
<i>(signature)</i>						<i>(date)</i>

ASTM Temp (deg F) ($\pm 1.5^\circ$)	Thermo. (deg F)	\pm deg F	ASTM Barometer (in. Hg) (± 0.1 in Hg)	Barometric (in. Hg)	\pm in. Hg	Time
69.60	70.60	1.00	29.17	29.17	0.00	08:44
<i>Sean Barnes</i>						<u>05/10/18</u>
<i>(signature)</i>						<i>(date)</i>

ASTM Temp (deg F) ($\pm 1.5^\circ$)	Thermo. (deg F)	\pm deg F	ASTM Barometer (in. Hg) (± 0.1 in Hg)	Barometric (in. Hg)	\pm in. Hg	Time
69.60	70.40	0.80	29.16	29.17	0.01	09:00
<i>Sean Barnes</i>						<u>05/10/18</u>
<i>(signature)</i>						<i>(date)</i>

ASTM Temp (deg F) ($\pm 1.5^\circ$)	Thermo. (deg F)	\pm deg F	ASTM Barometer (in. Hg) (± 0.1 in Hg)	Barometric (in. Hg)	\pm in. Hg	Time
69.60	70.60	1.00	29.22	29.25	0.03	11:06
<i>Sean Barnes</i>						<u>05/10/18</u>
<i>(signature)</i>						<i>(date)</i>

Note: Verified against ISO 17025 Traceable Barometer and Thermometer (SAMP-WE-0033).

WEATHER STATION CALIBRATION SHEET
Temperature, Barometric Pressure, and Relative Humidity Periodic Calibration
Air Hygiene Asset ID: samp-we-0041

Filename: \\AHI-FILES\SVR\public\Shared\QAQC\Calibrations\Weather Stations\2017\[Weather Station Calibration_samp-we-0041_215.xlsm]112013
 Make: Kestrel ISO 17025 Weather Station ID SAMP-WE-0033
 Model #: 2500 ISO 17025 S/N A026334
 Serial #: 2195814 ISO 17025 Cal Due 8/22/2018

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
68.10	69.10	1.00	29.31	29.32	0.01	13:18
<i>Sean Barnes</i>						<i>10/27/17</i>
<i>(signature)</i>						<i>(date)</i>

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
68.10	68.60	0.50	29.31	29.33	0.02	13:35
<i>Sean Barnes</i>						<i>10/27/17</i>
<i>(signature)</i>						<i>(date)</i>

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
68.10	68.10	0.00	29.30	29.31	0.01	13:53
<i>Sean Barnes</i>						<i>10/27/17</i>
<i>(signature)</i>						<i>(date)</i>

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
68.50	69.10	0.60	29.28	29.32	0.04	14:30
<i>Sean Barnes</i>						<i>10/27/17</i>
<i>(signature)</i>						<i>(date)</i>

Note: Verified against ISO 17025 Traceable Barometer and Thermometer (SAMP-WE-0033).

QUALITY ASSURANCE AND QUALITY CONTROL DATA

**Unit #CTG-1
Laboratory Analysis
PM**

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	1-Base-PM-1
Sample Leakage Evident	NO	Estimated Leak Volume	
		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		1	Start Time	09:52
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.6000	--	--	0.6000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.3	70	0.3461	0.9539	
Cyclone Wash 2.5<PM<10			1.5	61	0.3016	1.1984	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.0	64	0.3164	0.6836	
Inorganic Impinger Contents			3.0	310.9328	1.2857	1.7143	
Organic Impinger Contents			2.6	100.3009	0.7143	1.8857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	1-Base-PM-2
Sample Leakage Evident	NO	Estimated Leak Volume	
		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		2	Start Time	15:02
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.1	47	0.2324	0.8676	
Cyclone Wash 2.5<PM<10			0.6	56	0.2769	0.3232	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.9	47	0.2324	0.6676	
Inorganic Impinger Contents			1.4	230.6921	1.2857	0.1143	
Organic Impinger Contents			1.4	79.2377	0.7143	0.6857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	1-Base-PM-3	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		3	Start Time	15:36
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.8000	--	--	0.8000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.5	63	0.3115	0.1885	
Cyclone Wash 2.5<PM<10			0.5000	60	0.2966	0.2034	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.9	44	0.2175	0.6825	
Inorganic Impinger Contents			2.1	280.8425	1.2857	0.8143	
Organic Impinger Contents			1.1	83.2497	0.7143	0.3857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run		1-100 w/DB-PM-1
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		1	Start Time	23:32
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.7	58	0.2867	0.4133	
Cyclone Wash 2.5<PM<10			0.5000	57	0.2818	0.2182	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.2	37	0.1829	1.0171	
Inorganic Impinger Contents			3.9	270.8124	1.2857	2.6143	
Organic Impinger Contents			1.6	89.2678	0.7143	0.8857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	1-100 w/DB-PM-2
Sample Leakage Evident	NO	Estimated Leak Volume	
		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		2	Start Time	04:11
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			1.0000	--	--	1.0000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.5	58	0.2867	0.2133	
Cyclone Wash 2.5<PM<10			0.5	64	0.3164	0.1836	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.7	58	0.2867	0.4133	
Inorganic Impinger Contents			1.2	300.9027	1.2857	0.0000	
Organic Impinger Contents			1.1	110.3310	0.7143	0.3857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run		1-100 w/DB-PM-3
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		3	Start Time	09:20
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.9000	--	--	0.9000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.5000	83	0.4103	0.0897	
Cyclone Wash 2.5<PM<10			0.5	70	0.3461	0.1539	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.5000	60	0.2966	0.2034	
Inorganic Impinger Contents			2.4	381.1434	1.2857	1.1143	
Organic Impinger Contents			1.0	87.2618	0.7143	0.2857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-1 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	1-100 w/DB-PM-FB		
Sample Leakage Evident	NO	Estimated Leak Volume		0.00	(mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Gravimetric Concentrations			
Sample Portion	Final	Tare	Gain
	(g)	(g)	(mg)
Inorganic Impinger Contents	0.0018	0.0000	1.2857
Organic Impinger Contents	0.0010	0.0000	0.7143

max 2 mg total blank
adjustment, proportioned

Actual Gain
(mg)
1.8000
1.0000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

**Unit #CTG-2
Laboratory Analysis
PM**

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Analytical Data		Run	2-Base-PM-1	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		1	Start Time	19:14
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.9000	70.0000	0.3461	0.5539	
Cyclone Wash 2.5<PM<10			0.5000	73.0000	0.3609	0.1391	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.6000	76.0000	0.3757	0.2243	
Inorganic Impinger Contents			3.1000	360.0000	1.3103	1.7897	
Organic Impinger Contents			1.2000	91.0000	0.6897	0.5103	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Analytical Data		Run	2-Base-PM-2	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		2	Start Time	23:30
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.8000	64.0000	0.3164	0.4836	
Cyclone Wash 2.5<PM<10			0.5000	65.0000	0.3213	0.1787	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.5	46.0000	0.2274	0.2726	
Inorganic Impinger Contents			2.3000	370.0000	1.3103	0.9897	
Organic Impinger Contents			1.1000	88.0000	0.6897	0.4103	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Analytical Data		Run	2-Base-PM-3	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0005	340.0000	0.0015	--
DI Water Blank Weight of Solids	0.0005	370.0000	0.0014	--
Hexane Blank Weight of Solids	0.0082	250.0000	0.0328	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		3	Start Time	04:17
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.5000	66.0000	0.0971	0.4029	
Cyclone Wash 2.5<PM<10			0.5000	69.0000	0.1015	0.3985	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.5000	67.0000	0.0985	0.4015	
Inorganic Impinger Contents			2.2000	320.0000	1.3103	0.8897	
Organic Impinger Contents			1.0000	95.0000	0.6897	0.3103	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#4

Analytical Data		Run	2-Base-PM-FB	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Gravimetric Concentrations					Actual Gain
Sample Portion	Final	Tare	Gain	max 2 mg total blank adjustment, proportioned	(mg)
	(g)	(g)	(mg)		
Inorganic Impinger Contents	0.0019	0.0000	1.3103		1.9000
Organic Impinger Contents	0.0010	0.0000	0.6897		1.0000

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run		2-100 w/DB-PM-1	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		1	Start Time	23:36
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			1.5000	--	--	1.5000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.1	72	0.3560	0.7441	
Cyclone Wash 2.5<PM<10			0.5000	53	0.2620	0.2380	
Cyclone Exit to Front Half of Filter Wash (<2.5)			2.3	39	0.1928	2.1072	
Inorganic Impinger Contents			2.2	361.0832	1.2857	0.9143	
Organic Impinger Contents			1.3	70.2106	0.7143	0.5857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	2-100 w/DB-PM-2
Sample Leakage Evident	NO	Estimated Leak Volume	
		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		2	Start Time	05:03
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.8000	--	--	0.8000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.6	68	0.3362	0.2638	
Cyclone Wash 2.5<PM<10			0.5000	78	0.3856	0.1144	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.5	65	0.3213	0.1787	
Inorganic Impinger Contents			10	260.7823	1.2857	8.7143	
Organic Impinger Contents			17	100.3009	0.7143	16.2857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run		2-100 w/DB-PM-3	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		3	Start Time	10:20
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			1.0000	--	--	1.0000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.8	84	0.4153	0.3847	
Cyclone Wash 2.5<PM<10			0.8	71	0.3510	0.4490	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.3	62	0.3065	0.9935	
Inorganic Impinger Contents			7.0	410	1.2857	5.7143	
Organic Impinger Contents			7.4	91	0.7143	6.6857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	2-100 w/DB-PM-FB	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Gravimetric Concentrations					Actual Gain
Sample Portion	Final	Tare	Gain	max 2 mg total blank adjustment, proportioned	(mg)
	(g)	(g)	(mg)		
Inorganic Impinger Contents	0.0018	0.0000	1.2857		1.8000
Organic Impinger Contents	0.0010	0.0000	0.7143		1.0000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

**Laboratory Analysis
Maxxam**

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2018/10/03

Report #: R5426001

Version: 2 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B8P3474

Received: 2018/09/26, 20:30

Sample Matrix: Stack Sampling Train
Samples Received: 76

Analyses	Quantity	Date	Date	Laboratory Method	Reference
		Extracted	Analyzed		
Extractable Condensables (M202)	12	2018/09/27	2018/10/02	BRL SOP-00118	EPA 202 m
Non Extractable Condensables (M202)	12	2018/09/27	2018/10/02	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
Ammonium in H2SO4 Impingers (CTM-027)	26	2018/09/27	2018/09/27	BRL SOP-00107	EPA CTM-027 m
>10um Particulates in Rinse	12	2018/09/27	2018/10/03	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	12	2018/09/27	2018/10/03	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	12	N/A	2018/09/28	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	12	2018/09/27	2018/10/03	BRL SOP-00109	EPA M201A
Sulphuric Acid Mist by IC	12	2018/09/27	2018/09/27	BRL SOP-00105	EPA CTM013/13A/13B m
Sulphuric Acid Mist by IC	1	2018/10/01	N/A	BRL SOP-00105	EPA CTM013/13A/13B m
Sulphur Dioxide (CTM-013B)	12	2018/09/27	2018/09/27	BRL SOP-00105	EPA CTM-013B m
Sulphur Dioxide (CTM-013B)	1	2018/10/01	N/A	BRL SOP-00105	EPA CTM-013B m
Final Volume of Acetone Probe Rinse	12	N/A	2018/10/03	BRL SOP-00109	
Volume of Sulfuric Acid Impinger	26	N/A	2018/09/27		
Volume of Hydrogen Peroxide Impinger	13	N/A	2018/10/01		
Final Volume of Impinger	13	N/A	2018/10/01		
Weight of Solvent from Impingers	12	N/A	2018/09/27		
Weight of Water from Impingers	12	N/A	2018/09/27		

Remarks:

Maxxam Analytics' laboratories are accredited to ISO/IEC 17025:2005 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Maxxam are based upon recognized Provincial, Federal or US method compendia such as CCME, MDDELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Maxxam's profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Maxxam in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Maxxam Analytics' liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Maxxam has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Maxxam, unless otherwise agreed in writing. Maxxam is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2018/10/03
Report #: R5426001
Version: 2 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B8P3474

Received: 2018/09/26, 20:30
agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by Maxxam, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

Clayton Johnson, Project Manager - Air Toxics, Source Evaluation

Email: CJohnson@maxxam.ca

Phone# (905)817-5769

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

Maxxam ID		HWD060	HWD095			
Sampling Date		2018/09/24	2018/09/24			
	UNITS	M201A- UNIT 1 BASE-R1	M201A- UNIT 1 BASE-R2	RDL	MDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	1.3	1.1	0.5	0.1	5755422
< 2.5 Particulate Weight in Acetone Rinse	mg	1.0	0.9	0.5	0.5	5755420
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.5	0.6	0.5	0.5	5755421
< 2.5 Particulate Weight on Filter	mg	0.60	0.30	0.30	0.30	5757073
Acetone Rinse Volume (10)	ml	70	47	1	N/A	5755423
Acetone Rinse Volume (2.5 - 10)	ml	61	56	1	N/A	5755423
Acetone Rinse Volume (2.5)	ml	64	47	1	N/A	5755423
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable						

Maxxam ID		HWD096	HWD097			
Sampling Date		2018/09/25	2018/09/24			
	UNITS	M201A- UNIT 1 BASE-R3	M201A- UNIT 1 W/DB-R1	RDL	MDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	0.5	0.7	0.5	0.1	5755422
< 2.5 Particulate Weight in Acetone Rinse	mg	0.9	1.2	0.5	0.5	5755420
2.5 - 10 Particulate Weight in Acetone Rinse	mg	<0.5	<0.5	0.5	0.5	5755421
< 2.5 Particulate Weight on Filter	mg	0.80	<0.30	0.30	0.30	5757073
Acetone Rinse Volume (10)	ml	63	58	1	N/A	5755423
Acetone Rinse Volume (2.5 - 10)	ml	60	57	1	N/A	5755423
Acetone Rinse Volume (2.5)	ml	44	37	1	N/A	5755423
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable						

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

Maxxam ID		HWD098	HWD099			
Sampling Date		2018/09/24	2018/09/25			
	UNITS	M201A- UNIT 1 W/DB-R2	M201A- UNIT 1 W/DB-R3	RDL	MDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	0.5	<0.5	0.5	0.1	5755422
< 2.5 Particulate Weight in Acetone Rinse	mg	0.7	<0.5	0.5	0.5	5755420
2.5 - 10 Particulate Weight in Acetone Rinse	mg	0.5	0.5	0.5	0.5	5755421
< 2.5 Particulate Weight on Filter	mg	1.00	0.90	0.30	0.30	5757073
Acetone Rinse Volume (10)	ml	58	83	1	N/A	5755423
Acetone Rinse Volume (2.5 - 10)	ml	64	70	1	N/A	5755423
Acetone Rinse Volume (2.5)	ml	58	60	1	N/A	5755423
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable						

Maxxam ID		HWD100	HWD101			
Sampling Date		2018/09/24	2018/09/24			
	UNITS	M201A- UNIT 2 BASE-R1	M201A- UNIT 2 BASE-R2	RDL	MDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	1.3	0.6	0.5	0.1	5755422
< 2.5 Particulate Weight in Acetone Rinse	mg	0.7	0.8	0.5	0.5	5755420
2.5 - 10 Particulate Weight in Acetone Rinse	mg	0.8	0.6	0.5	0.5	5755421
< 2.5 Particulate Weight on Filter	mg	<0.30	<0.30	0.30	0.30	5757073
Acetone Rinse Volume (10)	ml	71	45	1	N/A	5755423
Acetone Rinse Volume (2.5 - 10)	ml	68	50	1	N/A	5755423
Acetone Rinse Volume (2.5)	ml	65	48	1	N/A	5755423
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable						

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

Maxxam ID		HWD102	HWD103			
Sampling Date		2018/09/25	2018/09/24			
	UNITS	M201A- UNIT 2 BASE-R3	M201A- UNIT 2 W/DB-R1	RDL	MDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	1.2	1.1	0.5	0.1	5755422
< 2.5 Particulate Weight in Acetone Rinse	mg	1.0	2.3	0.5	0.5	5755420
2.5 - 10 Particulate Weight in Acetone Rinse	mg	<0.5	<0.5	0.5	0.5	5755421
< 2.5 Particulate Weight on Filter	mg	<0.30	1.50	0.30	0.30	5757073
Acetone Rinse Volume (10)	ml	60	72	1	N/A	5755423
Acetone Rinse Volume (2.5 - 10)	ml	72	53	1	N/A	5755423
Acetone Rinse Volume (2.5)	ml	48	39	1	N/A	5755423
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable						

Maxxam ID		HWD104	HWD105			
Sampling Date		2018/09/24	2018/09/25			
	UNITS	M201A- UNIT 2 W/DB-R2	M201A- UNIT 2 W/DB-R3	RDL	MDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	0.6	0.8	0.5	0.1	5755422
< 2.5 Particulate Weight in Acetone Rinse	mg	0.5	1.3	0.5	0.5	5755420
2.5 - 10 Particulate Weight in Acetone Rinse	mg	<0.5	0.8	0.5	0.5	5755421
< 2.5 Particulate Weight on Filter	mg	0.80	1.00	0.30	0.30	5757073
Acetone Rinse Volume (10)	ml	68	84	1	N/A	5755423
Acetone Rinse Volume (2.5 - 10)	ml	78	71	1	N/A	5755423
Acetone Rinse Volume (2.5)	ml	65	62	1	N/A	5755423
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable						

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

Maxxam ID		HWC952	HWC953	HWC954			
Sampling Date		2018/09/24	2018/09/24	2018/09/25			
	UNITS	M202- UNIT 1 BASE-R1	M202- UNIT 1 BASE-R2	M202- UNIT 1 BASE-R3	RDL	MDL	QC Batch
Weight	g	310	230	280	0.1	0.1	5754784
Weight of Solvent	g	100	79	83	0.1	N/A	5754782
Miscellaneous Parameters							
Inorganic Condensibles	mg	3.0	1.4	2.1	0.5	0.1	5754787
Organic Condensibles	mg	2.6	1.4	1.1	1.0	0.20	5754779
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable							

Maxxam ID		HWC955	HWC956	HWC957			
Sampling Date		2018/09/24	2018/09/24	2018/09/25			
	UNITS	M202- UNIT 1 W/DB-R1	M202- UNIT 1 W/DB-R2	M202- UNIT 1 W/DB-R3	RDL	MDL	QC Batch
Weight	g	270	300	380	0.1	0.1	5754784
Weight of Solvent	g	89	110	87	0.1	N/A	5754782
Miscellaneous Parameters							
Inorganic Condensibles	mg	3.9	1.2	2.4	0.5	0.1	5754787
Organic Condensibles	mg	1.6	1.1	1.0	1.0	0.20	5754779
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable							

Maxxam ID		HWC958	HWD055	HWD056			
Sampling Date		2018/09/24	2018/09/24	2018/09/25			
	UNITS	M202- UNIT 2 BASE-R1	M202- UNIT 2 BASE-R2	M202- UNIT 2 BASE-R3	RDL	MDL	QC Batch
Weight	g	300	350	280	0.1	0.1	5754784
Weight of Solvent	g	100	79	91	0.1	N/A	5754782
Miscellaneous Parameters							
Inorganic Condensibles	mg	61	2.0	16	0.5	0.1	5754787
Organic Condensibles	mg	88	1.9	13	1.0	0.20	5754779
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable							

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

Maxxam ID		HWD057	HWD058	HWD059			
Sampling Date		2018/09/24	2018/09/24	2018/09/25			
	UNITS	M202- UNIT 2 W/DB-R1	M202- UNIT 2 W/DB-R2	M202- UNIT 2 W/DB-R3	RDL	MDL	QC Batch
Weight	g	360	260	410	0.1	0.1	5754784
Weight of Solvent	g	70	100	91	0.1	N/A	5754782
Miscellaneous Parameters							
Inorganic Condensibles	mg	2.2	10	7.0	0.5	0.1	5754787
Organic Condensibles	mg	1.3	17	7.4	1.0	0.20	5754779
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable							

EPA CTM 027 AMMONIA (STACK SAMPLING TRAIN)

Maxxam ID		HWD114			HWD115			HWD116			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT1 BASE- R1 FH	RDL	MDL	CTM027- UNIT1 BASE- R1 BH	RDL	MDL	CTM027- UNIT1 BASE- R2 FH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	211	1	1	239	1	1	179	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	4400	250	48	49	13	2.5	4600	250	48	5756997

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Maxxam ID		HWD116			HWD117			HWD118			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT1 BASE- R2 FH Lab-Dup	RDL	MDL	CTM027- UNIT1 BASE- R2 BH	RDL	MDL	CTM027- UNIT1 BASE- R3 FH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	N/A	1	1	215	1	1	195	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	4600	250	48	57	13	2.5	4900	250	48	5756997

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

Maxxam ID		HWD119			HWD120			HWD121			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT1 BASE- R3 BH	RDL	MDL	CTM027- UNIT1 W/DB- R1 FH	RDL	MDL	CTM027- UNIT1 W/DB- R1 BH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	218	1	1	247	1	1	223	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	47	13	2.5	4400	250	48	59	13	2.5	5756997

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

EPA CTM 027 AMMONIA (STACK SAMPLING TRAIN)

Maxxam ID		HWD122			HWD123			HWD124			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT1 W/DB- R2 FH	RDL	MDL	CTM027- UNIT1 W/DB- R2 BH	RDL	MDL	CTM027- UNIT1 W/DB- R3 FH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	243	1	1	215	1	1	233	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	4100	250	48	230	13	2.5	4000	250	48	5756997

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Maxxam ID		HWD125			HWD126			HWD127			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT1 W/DB- R3 BH	RDL	MDL	CTM027- UNIT2 BASE- R1 FH	RDL	MDL	CTM027- UNIT2 BASE- R1 BH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	228	1	1	215	1	1	281	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	47	13	2.5	4500	250	48	77	14	2.7	5756997

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Maxxam ID		HWD128			HWD129			HWD130			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT2 BASE- R2 FH	RDL	MDL	CTM027- UNIT2 BASE- R2 BH	RDL	MDL	CTM027- UNIT2 BASE- R3 FH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	164	1	1	274	1	1	215	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	4900	250	48	42	14	2.7	5100	250	48	5756997

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

EPA CTM 027 AMMONIA (STACK SAMPLING TRAIN)

Maxxam ID		HWD131			HWD132			HWD133			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT2 BASE- R3 BH	RDL	MDL	CTM027- UNIT2 W/DB- R1 FH	RDL	MDL	CTM027- UNIT2 W/DB- R1 BH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	217	1	1	168	1	1	263	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	<13	13	2.5	1400	25	4.8	36	13	2.5	5756997

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Maxxam ID		HWD134			HWD135			HWD136			
Sampling Date		2018/09/25			2018/09/25			2018/09/25			
	UNITS	CTM027- UNIT2 W/DB- R2 FH	RDL	MDL	CTM027- UNIT2 W/DB- R2 BH	RDL	MDL	CTM027- UNIT2 W/DB- R3 FH	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	220	1	1	219	1	1	223	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	5700	63	12	30	13	2.5	5300	130	25	5757006

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Maxxam ID		HWD136			HWD137			HWY651			
Sampling Date		2018/09/25			2018/09/25			2018/09/07			
	UNITS	CTM027- UNIT2 W/DB- R3 FH Lab-Dup	RDL	MDL	CTM027- UNIT2 W/DB- R3 BH	RDL	MDL	CTM027 - DI BLANK	RDL	MDL	QC Batch

Sulfuric Acid Volume	ml	N/A	1	1	288	1	1	241	1	1	5756985
----------------------	----	-----	---	---	-----	---	---	-----	---	---	---------

Inorganics											
Ammonium (NH4)	ug	5300	130	25	33	14	2.7	<13	13	2.5	5757006

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

EPA CTM 027 AMMONIA (STACK SAMPLING TRAIN)

Maxxam ID		HWY652			
Sampling Date		2018/09/07			
	UNITS	CTM027 - H2SO4 BLANK	RDL	MDL	QC Batch
Sulfuric Acid Volume	ml	267	1	1	5756985
Inorganics					
Ammonium (NH4)	ug	<13	13	2.5	5757006
RDL = Reportable Detection Limit QC Batch = Quality Control Batch					

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

Maxxam ID		HWD138	HWD139			HWD140			
Sampling Date		2018/09/24	2018/09/24			2018/09/25			
	UNITS	CTM13- UNIT1 BASE- R1 CW	CTM13- UNIT1 BASE- R1 IC	RDL	MDL	CTM13- UNIT1 BASE- R2 CW	RDL	MDL	QC Batch
Hydrogen Peroxide Volume	ml	N/A	204	1	1	N/A	1	1	5760404
Impinger Volume	ml	107	N/A	1	1	85	1	1	5760373
Miscellaneous Parameters									
Sulphur dioxide	mg	N/A	<0.068	0.068	N/A	N/A	0.068	N/A	5755885
Sulphuric Acid Mist	mg	<0.011	N/A	0.011	0.011	<0.009	0.009	0.009	5755858
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable									

Maxxam ID		HWD140	HWD141	HWD141					
Sampling Date		2018/09/25	2018/09/25	2018/09/25					
	UNITS	CTM13- UNIT1 BASE- R2 CW Lab-Dup	CTM13- UNIT1 BASE- R2 IC	CTM13- UNIT1 BASE- R2 IC Lab-Dup	RDL	MDL	QC Batch		
Hydrogen Peroxide Volume	ml	N/A	204	N/A	1	1	5760404		
Miscellaneous Parameters									
Sulphur dioxide	mg	N/A	<0.068	<0.068	0.068	N/A	5755885		
Sulphuric Acid Mist	mg	<0.009	N/A	N/A	0.009	0.009	5755858		
RDL = Reportable Detection Limit QC Batch = Quality Control Batch Lab-Dup = Laboratory Initiated Duplicate N/A = Not Applicable									

Maxxam ID		HWD142		HWD143		HWD144			
Sampling Date		2018/09/25		2018/09/25		2018/09/24			
	UNITS	CTM13- UNIT1 BASE- R3 CW	RDL	CTM13- UNIT1 BASE- R3 IC	MDL	CTM13- UNIT1 W/DB- R1 CW	RDL	MDL	QC Batch
Hydrogen Peroxide Volume	ml	N/A	1	223	1	N/A	1	1	5760404
Impinger Volume	ml	90	1	N/A	1	124	1	1	5760373
Miscellaneous Parameters									
Sulphur dioxide	mg	N/A	0.068	0.097	N/A	N/A	0.074	N/A	5755885
Sulphuric Acid Mist	mg	<0.009	0.009	N/A	0.009	<0.013	0.013	0.013	5755858
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable									

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

Maxxam ID		HWD145		HWD146		HWD147			
Sampling Date		2018/09/24		2018/09/25		2018/09/25			
	UNITS	CTM13- UNIT1 W/DB- R1 IC	MDL	CTM13- UNIT1 W/DB- R2 CW	RDL	CTM13- UNIT1 W/DB- R2 IC	RDL	MDL	QC Batch
Hydrogen Peroxide Volume	ml	324	1	N/A	1	224	1	1	5760404
Impinger Volume	ml	N/A	1	106	1	N/A	1	1	5760373
Miscellaneous Parameters									
Sulphur dioxide	mg	<0.11	N/A	N/A	0.11	<0.075	0.075	N/A	5755885
Sulphuric Acid Mist	mg	N/A	0.013	<0.011	0.011	N/A	0.01	0.011	5755858
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable									

Maxxam ID		HWD148		HWD149		HWD150			
Sampling Date		2018/09/25		2018/09/25		2018/09/24			
	UNITS	CTM13- UNIT1 W/DB- R3 CW	RDL	CTM13- UNIT1 W/DB- R3 IC	MDL	CTM13- UNIT2 BASE- R1 CW	RDL	MDL	QC Batch
Hydrogen Peroxide Volume	ml	N/A	1	282	1	N/A	1	1	5760404
Impinger Volume	ml	100	1	N/A	1	121	1	1	5760373
Miscellaneous Parameters									
Sulphur dioxide	mg	N/A	0.075	<0.094	N/A	N/A	0.094	N/A	5755885
Sulphuric Acid Mist	mg	<0.01	0.01	N/A	0.01	<0.012	0.012	0.012	5755858
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable									

Maxxam ID		HWD151				HWD152			
Sampling Date		2018/09/24				2018/09/25			
	UNITS	CTM13- UNIT2 BASE- R1 IC	RDL	MDL		CTM13- UNIT2 BASE- R2 CW	RDL	MDL	QC Batch
Hydrogen Peroxide Volume	ml	281	1	1		N/A	1	1	5760404
Impinger Volume	ml	N/A	1	1		100	1	1	5760373
Miscellaneous Parameters									
Sulphur dioxide	mg	<0.094	0.094	N/A		N/A	0.094	N/A	5755885
Sulphuric Acid Mist	mg	N/A	0.012	0.012		<0.01	0.01	0.01	5755858
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable									

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

Maxxam ID		HWD153			HWD154					
Sampling Date		2018/09/25			2018/09/25					
	UNITS	CTM13- UNIT2 BASE- R2 IC	MDL	CTM13- UNIT2 BASE- R3 CW	RDL	MDL	QC Batch			
Hydrogen Peroxide Volume	ml	277	1	N/A	1	1	5760404			
Impinger Volume	ml	N/A	1	121	1	1	5760373			
Miscellaneous Parameters										
Sulphur dioxide	mg	<0.092	N/A	N/A	0.092	N/A	5755885			
Sulphuric Acid Mist	mg	N/A	0.01	0.014	0.012	0.012	5755858			
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable										

Maxxam ID		HWD155			HWD156			HWD157		
Sampling Date		2018/09/25			2018/09/24			2018/09/24		
	UNITS	CTM13- UNIT2 BASE- R3 IC	MDL	CTM13- UNIT2 W/DB- R1 CW	RDL	CTM13- UNIT2 W/DB- R1 IC	RDL	MDL	QC Batch	
Hydrogen Peroxide Volume	ml	250	1	N/A	1	342	1	1	5760404	
Impinger Volume	ml	N/A	1	76	1	N/A	1	1	5760373	
Miscellaneous Parameters										
Sulphur dioxide	mg	0.084	N/A	N/A	0.083	<0.11	0.11	N/A	5755885	
Sulphuric Acid Mist	mg	N/A	0.012	<0.008	0.008	N/A	0.011	0.008	5755858	
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable										

Maxxam ID		HWD158			HWD159			HWD160		
Sampling Date		2018/09/25			2018/09/25			2018/09/25		
	UNITS	CTM13- UNIT2 W/DB- R2 CW	RDL	CTM13- UNIT2 W/DB- R2 IC	MDL	CTM13- UNIT2 W/DB- R3 CW	RDL	MDL	QC Batch	
Hydrogen Peroxide Volume	ml	N/A	1	298	1	N/A	1	1	5760404	
Impinger Volume	ml	105	1	N/A	1	114	1	1	5760373	
Miscellaneous Parameters										
Sulphur dioxide	mg	N/A	0.11	0.11	N/A	N/A	0.099	N/A	5755885	
Sulphuric Acid Mist	mg	<0.011	0.011	N/A	0.011	<0.012	0.012	0.012	5755858	
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable										

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

Maxxam ID		HWD161		HWY653		HWY654			
Sampling Date		2018/09/25		2018/09/07		2018/09/07			
	UNITS	CTM13- UNIT2 W/DB- R3 IC	MDL	CTM13 - DI BLANK	RDL	CTM13 - H2O2 BLANK	RDL	MDL	QC Batch
Hydrogen Peroxide Volume	ml	295	1	N/A	1	267	1	1	5760404
Impinger Volume	ml	N/A	1	170	1	N/A	1	1	5760373
Miscellaneous Parameters									
Sulphur dioxide	mg	<0.098	N/A	N/A	0.098	<0.089	0.089	N/A	5755885
Sulphuric Acid Mist	mg	N/A	0.012	<0.017	0.017	N/A	N/A	0.017	5755858
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable									

TEST SUMMARY

Maxxam ID: HWC952
Sample ID: M202- UNIT 1 BASE- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWC953
Sample ID: M202- UNIT 1 BASE- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWC954
Sample ID: M202- UNIT 1 BASE- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWC955
Sample ID: M202- UNIT 1 W/DB- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWC956
Sample ID: M202- UNIT 1 W/DB- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

TEST SUMMARY

Maxxam ID: HWC957
Sample ID: M202- UNIT 1 W/DB- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWC958
Sample ID: M202- UNIT 2 BASE- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWD055
Sample ID: M202- UNIT 2 BASE- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWD056
Sample ID: M202- UNIT 2 BASE- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWD057
Sample ID: M202- UNIT 2 W/DB- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

TEST SUMMARY

Maxxam ID: HWD058
Sample ID: M202- UNIT 2 W/DB- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensables (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWD059
Sample ID: M202- UNIT 2 W/DB- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5754779	2018/09/27	2018/10/02	Muhammad M Rahman
Non Extractable Condensables (M202)	BAL	5754787	2018/09/27	2018/10/02	Muhammad M Rahman
Weight of Solvent from Impingers		5754782	N/A	2018/09/27	Muhammad M Rahman
Weight of Water from Impingers		5754784	N/A	2018/09/27	Muhammad M Rahman

Maxxam ID: HWD060
Sample ID: M201A- UNIT 1 BASE- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD095
Sample ID: M201A- UNIT 1 BASE- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD096
Sample ID: M201A- UNIT 1 BASE- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

TEST SUMMARY

Maxxam ID: HWD097
Sample ID: M201A- UNIT 1 W/DB- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD098
Sample ID: M201A- UNIT 1 W/DB- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD099
Sample ID: M201A- UNIT 1 W/DB- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD100
Sample ID: M201A- UNIT 2 BASE- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD101
Sample ID: M201A- UNIT 2 BASE- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore

TEST SUMMARY

Maxxam ID: HWD101
Sample ID: M201A- UNIT 2 BASE- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD102
Sample ID: M201A- UNIT 2 BASE- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD103
Sample ID: M201A- UNIT 2 W/DB- R1
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD104
Sample ID: M201A- UNIT 2 W/DB- R2
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

Maxxam ID: HWD105
Sample ID: M201A- UNIT 2 W/DB- R3
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5755422	2018/09/27	2018/10/03	Farag Farag
2.5-10um Particulates in Rinse	BAL	5755421	2018/09/27	2018/10/03	Farag Farag
2.5 um Particulates on Filter	BAL	5757073	N/A	2018/09/28	Brenda Moore
<2.5um Particulates in Rinse	BAL	5755420	2018/09/27	2018/10/03	Farag Farag
Final Volume of Acetone Probe Rinse		5755423	N/A	2018/10/03	Farag Farag

TEST SUMMARY

Maxxam ID: HWD114
Sample ID: CTM027- UNIT1 BASE- R1 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD115
Sample ID: CTM027- UNIT1 BASE- R1 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD116
Sample ID: CTM027- UNIT1 BASE- R2 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD116 Dup
Sample ID: CTM027- UNIT1 BASE- R2 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern

Maxxam ID: HWD117
Sample ID: CTM027- UNIT1 BASE- R2 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD118
Sample ID: CTM027- UNIT1 BASE- R3 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

TEST SUMMARY

Maxxam ID: HWD119
Sample ID: CTM027- UNIT1 BASE- R3 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD120
Sample ID: CTM027- UNIT1 W/DB- R1 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD121
Sample ID: CTM027- UNIT1 W/DB- R1 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD122
Sample ID: CTM027- UNIT1 W/DB- R2 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD123
Sample ID: CTM027- UNIT1 W/DB- R2 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD124
Sample ID: CTM027- UNIT1 W/DB- R3 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

TEST SUMMARY

Maxxam ID: HWD125
Sample ID: CTM027- UNIT1 W/DB- R3 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD126
Sample ID: CTM027- UNIT2 BASE- R1 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD127
Sample ID: CTM027- UNIT2 BASE- R1 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD128
Sample ID: CTM027- UNIT2 BASE- R2 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD129
Sample ID: CTM027- UNIT2 BASE- R2 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD130
Sample ID: CTM027- UNIT2 BASE- R3 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

TEST SUMMARY

Maxxam ID: HWD131
Sample ID: CTM027- UNIT2 BASE- R3 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD132
Sample ID: CTM027- UNIT2 W/DB- R1 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD133
Sample ID: CTM027- UNIT2 W/DB- R1 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5756997	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD134
Sample ID: CTM027- UNIT2 W/DB- R2 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5757006	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD135
Sample ID: CTM027- UNIT2 W/DB- R2 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5757006	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD136
Sample ID: CTM027- UNIT2 W/DB- R3 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5757006	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

TEST SUMMARY

Maxxam ID: HWD136 Dup
Sample ID: CTM027- UNIT2 W/DB- R3 FH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5757006	2018/09/27	2018/09/27	Ann-Marie Stern

Maxxam ID: HWD137
Sample ID: CTM027- UNIT2 W/DB- R3 BH
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5757006	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWD138
Sample ID: CTM13- UNIT1 BASE- R1 CW
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD139
Sample ID: CTM13- UNIT1 BASE- R1 IC
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD140
Sample ID: CTM13- UNIT1 BASE- R2 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD140 Dup
Sample ID: CTM13- UNIT1 BASE- R2 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le

Maxxam ID: HWD141
Sample ID: CTM13- UNIT1 BASE- R2 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le

TEST SUMMARY

Maxxam ID: HWD141
Sample ID: CTM13- UNIT1 BASE- R2 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD141 Dup
Sample ID: CTM13- UNIT1 BASE- R2 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le

Maxxam ID: HWD142
Sample ID: CTM13- UNIT1 BASE- R3 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD143
Sample ID: CTM13- UNIT1 BASE- R3 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD144
Sample ID: CTM13- UNIT1 W/DB- R1 CW
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD145
Sample ID: CTM13- UNIT1 W/DB- R1 IC
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD146
Sample ID: CTM13- UNIT1 W/DB- R2 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le

TEST SUMMARY

Maxxam ID: HWD146
Sample ID: CTM13- UNIT1 W/DB- R2 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD147
Sample ID: CTM13- UNIT1 W/DB- R2 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD148
Sample ID: CTM13- UNIT1 W/DB- R3 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD149
Sample ID: CTM13- UNIT1 W/DB- R3 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD150
Sample ID: CTM13- UNIT2 BASE- R1 CW
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD151
Sample ID: CTM13- UNIT2 BASE- R1 IC
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

TEST SUMMARY

Maxxam ID: HWD152
Sample ID: CTM13- UNIT2 BASE- R2 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD153
Sample ID: CTM13- UNIT2 BASE- R2 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD154
Sample ID: CTM13- UNIT2 BASE- R3 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD155
Sample ID: CTM13- UNIT2 BASE- R3 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD156
Sample ID: CTM13- UNIT2 W/DB- R1 CW
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD157
Sample ID: CTM13- UNIT2 W/DB- R1 IC
Matrix: Stack Sampling Train

Collected: 2018/09/24
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

TEST SUMMARY

Maxxam ID: HWD158
Sample ID: CTM13- UNIT2 W/DB- R2 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD159
Sample ID: CTM13- UNIT2 W/DB- R2 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD160
Sample ID: CTM13- UNIT2 W/DB- R3 CW
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/09/27	2018/09/27	Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWD161
Sample ID: CTM13- UNIT2 W/DB- R3 IC
Matrix: Stack Sampling Train

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/09/27	2018/09/27	Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

Maxxam ID: HWY651
Sample ID: CTM027 - DI BLANK
Matrix: Stack Sampling Train

Collected: 2018/09/07
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5757006	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

Maxxam ID: HWY652
Sample ID: CTM027 - H2SO4 BLANK
Matrix: Stack Sampling Train

Collected: 2018/09/07
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Ammonium in H2SO4 Impingers (CTM-027)	IC/SPEC	5757006	2018/09/27	2018/09/27	Ann-Marie Stern
Volume of Sulfuric Acid Impinger		5756985	N/A	2018/09/27	Walt Wang

TEST SUMMARY

Maxxam ID: HWY653
Sample ID: CTM13 - DI BLANK
Matrix: Stack Sampling Train

Collected: 2018/09/07
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by IC	IC/SPEC	5755858	2018/10/01		Lang Le
Final Volume of Impinger		5760373	N/A	2018/10/01	Walt Wang

Maxxam ID: HWY654
Sample ID: CTM13 - H2O2 BLANK
Matrix: Stack Sampling Train

Collected: 2018/09/07
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphur Dioxide (CTM-013B)	IC/SPEC	5755885	2018/10/01		Lang Le
Volume of Hydrogen Peroxide Impinger		5760404	N/A	2018/10/01	Walt Wang

GENERAL COMMENTS

Sample HWC952 [M202- UNIT 1 BASE- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWC953 [M202- UNIT 1 BASE- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWC954 [M202- UNIT 1 BASE- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWC955 [M202- UNIT 1 W/DB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWC956 [M202- UNIT 1 W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWC957 [M202- UNIT 1 W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWC958 [M202- UNIT 2 BASE- R1] : ORGANIC EXTRACTION : Visual oily extract residue found in vial.
INORGANIC EXTRACTION : Blackish oily residue found in Teflon dish.

Sample HWD055 [M202- UNIT 2 BASE- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWD056 [M202- UNIT 2 BASE- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Blackish oily residue found in Teflon dish.

Sample HWD057 [M202- UNIT 2 W/DB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample HWD058 [M202- UNIT 2 W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Brownish residue found in Teflon dish.

Sample HWD059 [M202- UNIT 2 W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Brownish residue found in Teflon dish.

Sample HWD060 [M201A- UNIT 1 BASE- R1] : DE Edge of the filter frayed
LFT Loose filter material

Sample HWD097 [M201A- UNIT 1 W/DB- R1] : Negative weight observed

Sample HWD100 [M201A- UNIT 2 BASE- R1] : Negative weight observed

DE Edge of the filter frayed
LFT Loose filter material

Sample HWD101 [M201A- UNIT 2 BASE- R2] : Negative weight observed

Sample HWY651 [CTM027 - DI BLANK] : blank results reported from worksheet #5723151
, job#B8N3906 as per client request

Sample HWY652 [CTM027 - H2SO4 BLANK] : blank results reported from worksheet #5723151, job#B8N3906 as per client request

Sample HWY653 [CTM13 - DI BLANK] : Blank Sample was previously analyzed on 2018-09-11 (see ws #5722951)

Sample HWY654 [CTM13 - H2O2 BLANK] : Blank sample was previously analyzed on 2018-09-11 (see ws#5722965)

Results relate only to the items tested.

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
5754779	MOR	Spiked Blank	Organic Condensibles	2018/10/02		96	%	70 - 130
5754779	MOR	Method Blank	Organic Condensibles	2018/10/02	<1.0		mg	
5754787	MOR	Method Blank	Inorganic Condensibles	2018/10/02	<0.5		mg	
5755420	FF	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2018/10/03	<0.5		mg	
5755421	FF	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2018/10/03	<0.5		mg	
5755422	FF	Method Blank	> 10 Particulate Weight in Acetone Rinse	2018/10/03	<0.5		mg	
5755858	LLE	Matrix Spike(HWD140)	Sulphuric Acid Mist	2018/09/27		97	%	80 - 120
5755858	LLE	Spiked Blank	Sulphuric Acid Mist	2018/09/27		100	%	90 - 110
5755858	LLE	Method Blank	Sulphuric Acid Mist	2018/09/27	<0.01		mg	
5755858	LLE	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2018/09/27	NC		%	20
5755885	LLE	Matrix Spike(HWD141)	Sulphur dioxide	2018/09/27		100	%	80 - 120
5755885	LLE	Spiked Blank	Sulphur dioxide	2018/09/27		102	%	90 - 110
5755885	LLE	Method Blank	Sulphur dioxide	2018/09/27	<0.013		mg	
5755885	LLE	RPD - Sample/Sample Dup	Sulphur dioxide	2018/09/27	NC		%	20
5756997	A_S	Matrix Spike(HWD116)	Ammonium (NH4)	2018/09/27		98	%	75 - 125
5756997	A_S	Spiked Blank	Ammonium (NH4)	2018/09/27		99	%	90 - 110
5756997	A_S	Method Blank	Ammonium (NH4)	2018/09/27	<13		ug	
5756997	A_S	RPD - Sample/Sample Dup	Ammonium (NH4)	2018/09/27	0.31		%	20
5757006	A_S	Matrix Spike(HWD136)	Ammonium (NH4)	2018/09/27		104	%	75 - 125
5757006	A_S	Spiked Blank	Ammonium (NH4)	2018/09/27		100	%	90 - 110
5757006	A_S	Method Blank	Ammonium (NH4)	2018/09/27	<13		ug	
5757006	A_S	RPD - Sample/Sample Dup	Ammonium (NH4)	2018/09/27	0.0075		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Brenda Moore

Brenda Moore, Team Lead

Frank Mo

Frank Mo, B.Sc., Inorganic Lab. Manager

Walt Wang

Walt Wang, Supervisor, Inorganics

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Your Project #: SIE-18-MIDDLETOWN.NY-START#1
Your C.O.C. #: na

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2018/09/27
Report #: R5417818
Version: 1 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B8P3503

Received: 2018/09/26, 20:30

Sample Matrix: Tedlar Bag
Samples Received: 3

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Reference
Light Hydrocarbons	3	N/A	2018/09/27	CAM SOP-00204	GC/FID

Remarks:

Maxxam Analytics' laboratories are accredited to ISO/IEC 17025:2005 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Maxxam are based upon recognized Provincial, Federal or US method compendia such as CCME, MDDELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Maxxam's profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Maxxam in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Maxxam Analytics' liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Maxxam has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Maxxam, unless otherwise agreed in writing. Maxxam is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by Maxxam, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

Clayton Johnson, Project Manager - Air Toxics, Source Evaluation

Email: CJohnson@maxxam.ca

Phone# (905)817-5769

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Total Cover Pages : 1

Page 1 of 6

RESULTS OF ANALYSES OF TEDLAR BAG

Maxxam ID		HWD195	HWD195	HWD196	HWD197			
Sampling Date		2018/09/25	2018/09/25	2018/09/25	2018/09/25			
COC Number		na	na	na	na			
	UNITS	U2-R1	U2-R1 Lab-Dup	U2-R2	U2-R3	RDL	MDL	QC Batch
Gas								
Ethane	ppm	<0.1	<0.1	<0.1	<0.1	0.1	0.02	5755395
Methane	ppm	<2	<2	<2	<2	2	0.4	5755395
RDL = Reportable Detection Limit QC Batch = Quality Control Batch Lab-Dup = Laboratory Initiated Duplicate								

TEST SUMMARY

Maxxam ID: HWD195
Sample ID: U2-R1
Matrix: Tedlar Bag

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Light Hydrocarbons	GC/FID	5755395	N/A	2018/09/27	Iqbal Hasan

Maxxam ID: HWD195 Dup
Sample ID: U2-R1
Matrix: Tedlar Bag

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Light Hydrocarbons	GC/FID	5755395	N/A	2018/09/27	Iqbal Hasan

Maxxam ID: HWD196
Sample ID: U2-R2
Matrix: Tedlar Bag

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Light Hydrocarbons	GC/FID	5755395	N/A	2018/09/27	Iqbal Hasan

Maxxam ID: HWD197
Sample ID: U2-R3
Matrix: Tedlar Bag

Collected: 2018/09/25
Shipped:
Received: 2018/09/26

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Light Hydrocarbons	GC/FID	5755395	N/A	2018/09/27	Iqbal Hasan

GENERAL COMMENTS

Results relate only to the items tested.

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
5755395	IH0	Method Blank	Ethane		<0.1		ppm	
			Methane		<2		ppm	
5755395	IH0	RPD - Sample/Sample Dup	Ethane	2018/09/27	NC		%	30
			Methane	2018/09/27	NC		%	30

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Tom Mitchell, B.Sc, Supervisor, Compressed Gases

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2018/10/18

Report #: R5447062

Version: 2 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B8R1187

Received: 2018/10/12, 23:55

Sample Matrix: Stack Sampling Train
Samples Received: 10

Analyses	Quantity	Date	Date	Laboratory Method	Reference
		Extracted	Analyzed		
Extractable Condensables (M202)	5	2018/10/15	2018/10/17	BRL SOP-00118	EPA 202 m
Non Extractable Condensables (M202)	5	2018/10/15	2018/10/16	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
>10um Particulates in Rinse	3	2018/10/15	2018/10/18	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	3	2018/10/15	2018/10/18	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	3	N/A	2018/10/16	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	3	2018/10/15	2018/10/18	BRL SOP-00109	EPA M201A
Particulates/Acetone Rinse (M5/315/M201)	1	2018/10/15	2018/10/18	BRL SOP-00109	EPA 5/315 m
Final Volume of Acetone Probe Rinse	4	N/A	2018/10/18	BRL SOP-00109	
Weight of Solvent from Impingers	5	N/A	2018/10/15		
Weight of Water from Impingers	5	N/A	2018/10/15		

Remarks:

Maxxam Analytics' laboratories are accredited to ISO/IEC 17025:2005 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Maxxam are based upon recognized Provincial, Federal or US method compendia such as CCME, MDDELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Maxxam's profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Maxxam in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Maxxam Analytics' liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Maxxam has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Maxxam, unless otherwise agreed in writing. Maxxam is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by Maxxam, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2018/10/18
Report #: R5447062
Version: 2 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B8R1187
Received: 2018/10/12, 23:55

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: CJohnson@maxxam.ca
Phone# (905)817-5769

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

Maxxam ID		IAC047	IAC048	IAC049			
Sampling Date		2018/10/10	2018/10/10	2018/10/11			
	UNITS	M201A- UNIT 2- R1	M201A- UNIT 2- R2	M201A- UNIT 2- R3	RDL	MDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	0.9	0.8	0.5	0.5	0.1	5783286
< 2.5 Particulate Weight in Acetone Rinse	mg	0.6	<0.5	<0.5	0.5	0.5	5783283
2.5 - 10 Particulate Weight in Acetone Rinse	mg	<0.5	<0.5	<0.5	0.5	0.5	5783285
< 2.5 Particulate Weight on Filter	mg	<0.30	0.30	<0.30	0.30	0.30	5786521
Acetone Rinse Volume (10)	ml	70	64	66	1	N/A	5783287
Acetone Rinse Volume (2.5 - 10)	ml	73	65	69	1	N/A	5783287
Acetone Rinse Volume (2.5)	ml	76	46	67	1	N/A	5783287
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable							

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

Maxxam ID		IAC037	IAC038	IAC039	IAC040			
Sampling Date					2018/10/10			
	UNITS	M202- DI WATER BLANK	M202- HEXANE BLANK	M202- UNIT 2- FB	M202- UNIT 2- R1	RDL	MDL	QC Batch
Weight	g	370	N/A	280	360	0.1	0.1	5783592
Weight of Solvent	g	N/A	250	66	91	0.1	N/A	5783588
Miscellaneous Parameters								
Inorganic Condensibles	mg	<0.5	N/A	1.9	3.1	0.5	0.1	5783596
Organic Condensibles	mg	N/A	8.2	<1.0	1.2	1.0	0.20	5783580
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable								

Maxxam ID		IAC041	IAC042			
Sampling Date		2018/10/10	2018/10/11			
	UNITS	M202- UNIT 2- R2	M202- UNIT 2- R3	RDL	MDL	QC Batch
Weight	g	370	320	0.1	0.1	5783592
Weight of Solvent	g	88	95	0.1	N/A	5783588
Miscellaneous Parameters						
Inorganic Condensibles	mg	2.3	2.2	0.5	0.1	5783596
Organic Condensibles	mg	1.1	<1.0	1.0	0.20	5783580
RDL = Reportable Detection Limit QC Batch = Quality Control Batch N/A = Not Applicable						

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

Maxxam ID		IAC046			
Sampling Date					
	UNITS	M201A- ACETONE BLANK	RDL	MDL	QC Batch
Acetone Rinse Particulate Weight in Acetone Rinse	mg	<0.5	0.5	0.1	5783282
Acetone Rinse Volume	ml	340	1	1	5783287
RDL = Reportable Detection Limit QC Batch = Quality Control Batch					

TEST SUMMARY

Maxxam ID: IAC037
Sample ID: M202- DI WATER BLANK
Matrix: Stack Sampling Train

Collected:
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	5783596	2018/10/15	2018/10/16	Muhammad M Rahman
Weight of Water from Impingers		5783592	N/A	2018/10/15	Muhammad M Rahman

Maxxam ID: IAC038
Sample ID: M202- HEXANE BLANK
Matrix: Stack Sampling Train

Collected:
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5783580	2018/10/15	2018/10/17	Muhammad M Rahman
Weight of Solvent from Impingers		5783588	N/A	2018/10/15	Muhammad M Rahman

Maxxam ID: IAC039
Sample ID: M202- UNIT 2- FB
Matrix: Stack Sampling Train

Collected:
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5783580	2018/10/15	2018/10/17	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5783596	2018/10/15	2018/10/16	Muhammad M Rahman
Weight of Solvent from Impingers		5783588	N/A	2018/10/15	Muhammad M Rahman
Weight of Water from Impingers		5783592	N/A	2018/10/15	Muhammad M Rahman

Maxxam ID: IAC040
Sample ID: M202- UNIT 2- R1
Matrix: Stack Sampling Train

Collected: 2018/10/10
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5783580	2018/10/15	2018/10/17	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5783596	2018/10/15	2018/10/16	Muhammad M Rahman
Weight of Solvent from Impingers		5783588	N/A	2018/10/15	Muhammad M Rahman
Weight of Water from Impingers		5783592	N/A	2018/10/15	Muhammad M Rahman

Maxxam ID: IAC041
Sample ID: M202- UNIT 2- R2
Matrix: Stack Sampling Train

Collected: 2018/10/10
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5783580	2018/10/15	2018/10/17	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	5783596	2018/10/15	2018/10/16	Muhammad M Rahman
Weight of Solvent from Impingers		5783588	N/A	2018/10/15	Muhammad M Rahman
Weight of Water from Impingers		5783592	N/A	2018/10/15	Muhammad M Rahman

Maxxam ID: IAC042
Sample ID: M202- UNIT 2- R3
Matrix: Stack Sampling Train

Collected: 2018/10/11
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	5783580	2018/10/15	2018/10/17	Muhammad M Rahman

TEST SUMMARY

Maxxam ID: IAC042
Sample ID: M202- UNIT 2- R3
Matrix: Stack Sampling Train

Collected: 2018/10/11
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	5783596	2018/10/15	2018/10/16	Muhammad M Rahman
Weight of Solvent from Impingers		5783588	N/A	2018/10/15	Muhammad M Rahman
Weight of Water from Impingers		5783592	N/A	2018/10/15	Muhammad M Rahman

Maxxam ID: IAC046
Sample ID: M201A- ACETONE BLANK
Matrix: Stack Sampling Train

Collected:
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Particulates/Acetone Rinse (M5/315/M201)	BAL	5783282	2018/10/15	2018/10/18	Farag Farag
Final Volume of Acetone Probe Rinse		5783287	N/A	2018/10/18	Farag Farag

Maxxam ID: IAC047
Sample ID: M201A- UNIT 2- R1
Matrix: Stack Sampling Train

Collected: 2018/10/10
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5783286	2018/10/15	2018/10/18	Farag Farag
2.5-10um Particulates in Rinse	BAL	5783285	2018/10/15	2018/10/18	Farag Farag
2.5 um Particulates on Filter	BAL	5786521	N/A	2018/10/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	5783283	2018/10/15	2018/10/18	Farag Farag
Final Volume of Acetone Probe Rinse		5783287	N/A	2018/10/18	Farag Farag

Maxxam ID: IAC048
Sample ID: M201A- UNIT 2- R2
Matrix: Stack Sampling Train

Collected: 2018/10/10
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5783286	2018/10/15	2018/10/18	Farag Farag
2.5-10um Particulates in Rinse	BAL	5783285	2018/10/15	2018/10/18	Farag Farag
2.5 um Particulates on Filter	BAL	5786521	N/A	2018/10/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	5783283	2018/10/15	2018/10/18	Farag Farag
Final Volume of Acetone Probe Rinse		5783287	N/A	2018/10/18	Farag Farag

Maxxam ID: IAC049
Sample ID: M201A- UNIT 2- R3
Matrix: Stack Sampling Train

Collected: 2018/10/11
Shipped:
Received: 2018/10/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	5783286	2018/10/15	2018/10/18	Farag Farag
2.5-10um Particulates in Rinse	BAL	5783285	2018/10/15	2018/10/18	Farag Farag
2.5 um Particulates on Filter	BAL	5786521	N/A	2018/10/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	5783283	2018/10/15	2018/10/18	Farag Farag
Final Volume of Acetone Probe Rinse		5783287	N/A	2018/10/18	Farag Farag

GENERAL COMMENTS

Sample IAC037 [M202- DI WATER BLANK] : INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample IAC038 [M202- HEXANE BLANK] : ORGANIC EXTRACTION : Oily material found in vial.

Sample IAC039 [M202- UNIT 2- FB] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample IAC040 [M202- UNIT 2- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample IAC041 [M202- UNIT 2- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample IAC042 [M202- UNIT 2- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Results relate only to the items tested.

QUALITY ASSURANCE REPORT


QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
5783282	FF	Method Blank	Acetone Rinse Particulate Weight in Acetone Ri	2018/10/18	<0.5		mg	
5783283	FF	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2018/10/18	<0.5		mg	
5783285	FF	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2018/10/18	<0.5		mg	
5783286	FF	Method Blank	> 10 Particulate Weight in Acetone Rinse	2018/10/18	<0.5		mg	
5783580	MOR	Spiked Blank	Organic Condensibles	2018/10/17		96	%	70 - 130
5783580	MOR	Method Blank	Organic Condensibles	2018/10/17	<1.0		mg	
5783596	MOR	Method Blank	Inorganic Condensibles	2018/10/18	<0.5		mg	

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Brenda Moore, Team Lead



Frank Mo, B.Sc., Inorganic Lab. Manager

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

ASR 1187

Requested Standard Analysis - 5-10 business days after receipt at lab

Contact Information (deliver results to)
 Name: Michael Stockwell
 Phone: (616) 307-8865
 Email:

Air Hygiene International, Inc.
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
 (888) 461-8778
 www.airhygiene.com

SAMPLE DESCRIPTION AND LABELING RECORD

Project Number: sie-18-middletown.ny-start#4 Laboratory Analysis Requested

Person Taking Samples: MS Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	--	--
2-Base-PM-1-F	Unit 2-Base-PM - Run 1 - Filter	10/10/18	N/A	X			
2-Base-PM-1-C2	Unit 2-Base-PM - Run 1 - Nozzle Wash PM>10	10/10/18		X			
2-Base-PM-1-C3	Unit 2-Base-PM - Run 1 - Cyclone Wash 2.5<PM<10	10/10/18		X			
2-Base-PM-1-C4	Unit 2-Base-PM - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	10/10/18	N/A	X			
2-Base-PM-1-C5	Unit 2-Base-PM - Run 1 - Inorganic Impinger Contents	10/10/18			X		
2-Base-PM-1-C6	Unit 2-Base-PM - Run 1 - Organic Impinger Contents	10/10/18			X		
2-Base-PM-1-CPM	Unit 2-Base-PM - Run 1 - CPM Filter	10/10/18	N/A		X		
2-Base-PM-2-F	Unit 2-Base-PM - Run 2 - Filter	10/10/18	N/A	X			
2-Base-PM-2-C2	Unit 2-Base-PM - Run 2 - Nozzle Wash PM>10	10/10/18		X			
2-Base-PM-2-C3	Unit 2-Base-PM - Run 2 - Cyclone Wash 2.5<PM<10	10/10/18		X			
2-Base-PM-2-C4	Unit 2-Base-PM - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	10/10/18	N/A	X			
2-Base-PM-2-C5	Unit 2-Base-PM - Run 2 - Inorganic Impinger Contents	10/10/18			X		
2-Base-PM-2-C6	Unit 2-Base-PM - Run 2 - Organic Impinger Contents	10/10/18			X		
2-Base-PM-2-CPM	Unit 2-Base-PM - Run 2 - CPM Filter	10/10/18	N/A		X		
2-Base-PM-3-F	Unit 2-Base-PM - Run 3 - Filter	10/11/18	N/A	X			
2-Base-PM-3-C2	Unit 2-Base-PM - Run 3 - Nozzle Wash PM>10	10/11/18		X			
2-Base-PM-3-C3	Unit 2-Base-PM - Run 3 - Cyclone Wash 2.5<PM<10	10/11/18		X			
2-Base-PM-3-C4	Unit 2-Base-PM - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	10/11/18	N/A	X			
2-Base-PM-3-C5	Unit 2-Base-PM - Run 3 - Inorganic Impinger Contents	10/11/18			X		
2-Base-PM-3-C6	Unit 2-Base-PM - Run 3 - Organic Impinger Contents	10/11/18			X		
2-Base-PM-3-CPM	Unit 2-Base-PM - Run 3 - CPM Filter	10/11/18	N/A		X		
2-Base-PM-FB-C3	Unit 2-Base-PM - Run FB - Cyclone Wash 2.5<PM<10 CPM Filter	FB		X			
2-Base-PM-FB-C4	Unit 2-Base-PM - Run FB - Organic Impinger Contents	FB	N/A	X			
2-Base-PM-FB-C5	Unit 2-Base-PM - Run FB - Inorganic Impinger Contents	FB			X		
2-Base-PM-B1-Acetone	Unit 2-Base-PM - Blank - Acetone		200		X		
2-Base-PM-B2-DI Water	Unit 2-Base-PM - Blank - DI Water		200	X			
2-Base-PM-B3-Hexane	Unit 2-Base-PM - Blank - Hexane		200		X		

Signature: *[Signature]* Date: 10/11/18 Time: 10:00
 Signature: *[Signature]* Date: 2018/10/12 Time: 23:55

sie-18-middletown.ny-start#1-U2

SD&L

APPENDIX E
FUEL ANALYSIS RECORDS

Client: CPV Valley, LLC
 Location: CPV Valley Energy Center
 Date: September 24, 2018
 Project #: sie-18-middletown.ny-start#1

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular ¹ Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross ^{1,3} Heating Value (Btu/ft ³)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net ^{1,3} Heating Value (Btu/ft ³)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH ₄	97.684	16.0430	15.67	95.71	994.85	971.80	895.75	875.01
Ethane	C ₂ H ₆	1.835	30.0700	0.55	3.37	1,743.15	31.99	1,594.41	29.26
Propane	C ₃ H ₈	0.047	44.0970	0.02	0.13	2,478.35	1.16	2,280.17	1.07
iso-Butane	iC ₄ H ₁₀	0.000	58.1230	0.00	0.00	3,203.11	0.00	2,955.38	0.00
n-Butane	nC ₄ H ₁₀	0.000	58.1230	0.00	0.00	3,213.35	0.00	2,965.62	0.00
Iso-Pentane	iC ₅ H ₁₂	0.000	72.1500	0.00	0.00	3,940.87	0.00	3,643.50	0.00
n-Pentane	nC ₅ H ₁₂	0.000	72.1500	0.00	0.00	3,948.75	0.00	3,648.32	0.00
Hexanes	C ₆ H ₁₄	0.000	86.1770	0.00	0.00	4,684.54	0.00	4,337.82	0.00
Heptanes	C ₇ H ₁₆	0.000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C ₈ H ₁₈	0.000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO ₂	0.052	44.0100	0.02	0.14	0.00	0.00	0.00	0.00
Nitrogen	N ₂	0.382	28.0134	0.11	0.65	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H ₂ S	0.000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O ₂	0.000	31.9988	0.00	0.00	0.00	0.00	0.00	0.00
Helium	He	0.000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H ₂	0.000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		100.000		16.37	100.00	dry	1,004.96	dry	905.34
						wet^{2,5}	981.79	wet^{2,5}	884.46

Characteristics of Fuel Gas	
Molecular Weight of gas =	16.374 lb/lb-mole
Btu per lb. of gas ⁴ =	23,643.747 gross (HHV)
Btu per lb. of gas ⁴ =	21,300.020 net (LHV)
Density of fuel gas ² =	0.0425 lb/cu. ft
Wt % VOC in fuel gas =	0.13 %
Specific Gravity ¹ =	0.5653

Component	Wt%
carbon	74.49
oxygen	0.10
hydrogen	24.76
nitrogen	0.65
helium	0.00
sulfur	0.00
Total	100.00

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,633.27
 (Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

$$F\text{-Factor} = 1,000,000 * ((3.64 * \%H) + (1.53 * \%C) + (0.57 * \%S) + (0.14 * \%N) - (0.46 * \%O)) / GCV$$

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

¹ ASTM D 3588

² Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

³ Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

⁴ Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

⁵ GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: CPV Valley, LLC
 Location: CPV Valley Energy Center
 Date: September 25, 2018
 Project #: sie-18-middleton.ny-start#1

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular ¹ Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross ^{1,3} Heating Value (Btu/ft ³)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net ^{1,3} Heating Value (Btu/ft ³)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH ₄	97.795	16.0430	15.69	95.92	994.85	972.91	895.75	876.00
Ethane	C ₂ H ₆	1.828	30.0700	0.55	3.36	1,743.15	31.86	1,594.41	29.15
Propane	C ₃ H ₈	0.044	44.0970	0.02	0.12	2,478.35	1.09	2,280.17	1.00
iso-Butane	iC ₄ H ₁₀	0.000	58.1230	0.00	0.00	3,203.11	0.00	2,955.38	0.00
n-Butane	nC ₄ H ₁₀	0.000	58.1230	0.00	0.00	3,213.35	0.00	2,965.62	0.00
Iso-Pentane	iC ₅ H ₁₂	0.000	72.1500	0.00	0.00	3,940.87	0.00	3,643.50	0.00
n-Pentane	nC ₅ H ₁₂	0.000	72.1500	0.00	0.00	3,948.75	0.00	3,648.32	0.00
Hexanes	C ₆ H ₁₄	0.000	86.1770	0.00	0.00	4,684.54	0.00	4,337.82	0.00
Heptanes	C ₇ H ₁₆	0.000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C ₈ H ₁₈	0.000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO ₂	0.034	44.0100	0.01	0.09	0.00	0.00	0.00	0.00
Nitrogen	N ₂	0.299	28.0134	0.08	0.51	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H ₂ S	0.000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O ₂	0.000	31.9988	0.00	0.00	0.00	0.00	0.00	0.00
Helium	He	0.000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H ₂	0.000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		100.000		16.36	100.00	dry	1,005.86	dry	906.15
						wet^{2,5}	982.67	wet^{2,5}	885.26

Characteristics of Fuel Gas	
Molecular Weight of gas =	16.357 lb/lb-mole
Btu per lb. of gas ⁴ =	23,689.403 gross (HHV)
Btu per lb. of gas ⁴ =	21,341.065 net (LHV)
Density of fuel gas ² =	0.0425 lb/cu. ft
Wt % VOC in fuel gas =	0.12 %
Specific Gravity ¹ =	0.5648

Component	Wt%
carbon	74.62
oxygen	0.07
hydrogen	24.80
nitrogen	0.51
helium	0.00
sulfur	0.00
Total	100.00

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,632.22
 (Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

$$F\text{-Factor} = 1,000,000 * ((3.64 * \%H) + (1.53 * \%C) + (0.57 * \%S) + (0.14 * \%N) - (0.46 * \%O)) / GCV$$

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

¹ ASTM D 3588

² Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

³ Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

⁴ Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

⁵ GPA Reference Bulletin 181-86, revised 1986, reprinted 1995



Certificate of Analysis
 Number: 1030-18100260-001A

Houston Laboratories
 8820 Interchange Drive
 Houston, TX 77054
 Phone 713-660-0901

Air Hygiene International, Inc.
 1600 West Tacoma Street
 Broken Arrow, OK 74012

Oct. 05, 2018

Station Name: SMR Feed Line
 Station Number: sie-18-middletown.ny-start#1
 Cylinder No: 1030-06464
 Analyzed: 10/04/2018 05:02:00 by JD

Sampled By: PM
 Sample Of: Gas Spot
 Sample Date: 09/24/2018
 Sample Conditions:
 Method: GPA-2261M

Analytical Data

Components	Mol. %	Wt. %	GPM at 14.696 psia		
Nitrogen	0.382	0.654		GPM TOTAL C2+	0.503
Methane	97.684	95.709		GPM TOTAL C3+	0.013
Carbon Dioxide	0.052	0.140		GPM TOTAL iC5+	0.000
Ethane	1.835	3.370	0.490		
Propane	0.047	0.127	0.013		
Iso-butane	NIL	NIL	NIL		
n-Butane	NIL	NIL	NIL		
Iso-pentane	NIL	NIL	NIL		
n-Pentane	NIL	NIL	NIL		
Hexanes Plus	NIL	NIL	NIL		
	100.000	100.000	0.503		

Calculated Physical Properties

Relative Density Real Gas	0.5663
Calculated Molecular Weight	16.37
Compressibility Factor	0.9979

GPA 2172 Calculation:

Calculated Gross BTU per ft³ @ 14.696 psia & 60°F

Real Gas Dry BTU	1022
Water Sat. Gas Base BTU	1005

Comments: Gross Dry BTU at 29.92 "Hg and 68 °F = 1005 per cubic foot (ASTM D1826). Gross Saturated BTU at 29.92 "Hg and 68 °F = 982 per cubic foot (ASTM D1826).

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP, GPA guidelines for quality assurance, unless otherwise stated.



Certificate of Analysis
 Number: 1030-18100260-001A

Houston Laboratories
 8820 Interchange Drive
 Houston, TX 77054
 Phone 713-660-0901

Air Hygiene International, Inc.
 1600 West Tacoma Street
 Broken Arrow, OK 74012

Oct. 05, 2018

Station Name: SMR Feed Line
 Station Number: sie-18-middletown.ny-start#1
 Cylinder No: 1030-06464
 Analyzed: 10/04/2018 by TB

Sampled By: PM
 Sample Of: Gas Spot
 Sample Date: 09/24/2018
 Sample Conditions:
 Method: ASTM D-5504

Sulfur Analysis

SULFIDES	ppmw	MERCAPTANS	ppmw	DISULFIDES	ppmw
Hydrogen	ND	Methyl	ND	Carbon	ND
Carbonyl	ND	Ethyl	ND	Dimethyl	ND
Dimethyl	ND	Isopropyl	ND	Methyl Ethyl	ND
Methyl Ethyl	ND	n-Propyl	ND	Diethyl	ND
Diethyl	ND	Isobutyl	ND	Di-iso-Propyl	0.5
Di-iso-Propyl	ND	sec-Butyl	ND	Di-n-Propyl	0.5
Di-n-Propyl	ND	tert-Butyl	1.4	Di-iso-Butyl	ND
Di-iso-Butyl	ND	n-Butyl	ND	Di-sec-Butyl	ND
Di-sec-Butyl	ND	Isoamyl	ND	Di-tert-Butyl	ND
Di-tert-Butyl	ND	pri-Amyl	ND	Di-n-Butyl	ND
Di-n-Butyl	ND	n-Amyl	ND		
OTHER	ppmw	OTHER	ppmw	OTHER	ppmw
Misc. Sulfurs	ND	Thiophene	ND	Thiophane	ND
Sulfur Dioxide	ND				

Comments: Additional 0.2 ppmw Sulfur detected as unidentified compounds
 Detection limit = 0.1 ppmw
 Total Sulfur detected = 0.034 grains/100 std. cubic ft. at 68 °F.
 ND = Not Detected

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP, GPA guidelines for quality assurance, unless otherwise stated.



Certificate of Analysis
 Number: 1030-18100260-002A

Houston Laboratories
 8820 Interchange Drive
 Houston, TX 77054
 Phone 713-660-0901

Air Hygiene International, Inc.
 1600 West Tacoma Street
 Broken Arrow, OK 74012

Oct. 05, 2018

Station Name: SMR Feed Line
 Station Number: sie-18-middletown.ny-start#1
 Cylinder No: 1030-01476
 Analyzed: 10/04/2018 05:20:00 by JD

Sampled By: PM
 Sample Of: Gas Spot
 Sample Date: 09/25/2018
 Sample Conditions:
 Method: GPA-2261M

Analytical Data

Components	Mol. %	Wt. %	GPM at 14.696 psia		
Nitrogen	0.299	0.512		GPM TOTAL C2+	0.501
Methane	97.795	95.918		GPM TOTAL C3+	0.012
Carbon Dioxide	0.034	0.091		GPM TOTAL iC5+	0.000
Ethane	1.828	3.360	0.489		
Propane	0.044	0.119	0.012		
Iso-butane	NIL	NIL	NIL		
n-Butane	NIL	NIL	NIL		
Iso-pentane	NIL	NIL	NIL		
n-Pentane	NIL	NIL	NIL		
Hexanes Plus	NIL	NIL	NIL		
	100.000	100.000	0.501		

Calculated Physical Properties

Relative Density Real Gas	0.5657
Calculated Molecular Weight	16.36
Compressibility Factor	0.9979

GPA 2172 Calculation:

Calculated Gross BTU per ft³ @ 14.696 psia & 60°F

Real Gas Dry BTU	1023
Water Sat. Gas Base BTU	1006

Comments: Gross Dry BTU at 29.92 "Hg and 68 °F = 1006 per cubic foot (ASTM D1826). Gross Saturated BTU at 29.92 "Hg and 68 °F = 983 per cubic foot (ASTM D1826).

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP, GPA guidelines for quality assurance, unless otherwise stated.



Certificate of Analysis
 Number: 1030-18100260-002A

Houston Laboratories
 8820 Interchange Drive
 Houston, TX 77054
 Phone 713-660-0901

Air Hygiene International, Inc.
 1600 West Tacoma Street
 Broken Arrow, OK 74012

Oct. 05, 2018

Station Name: SMR Feed Line
 Station Number: sie-18-middletown.ny-start#1
 Cylinder No: 1030-01476
 Analyzed: 10/04/2018 by TB

Sampled By: PM
 Sample Of: Gas Spot
 Sample Date: 09/25/2018
 Sample Conditions:
 Method: ASTM D-5504

Sulfur Analysis

SULFIDES	ppmw	MERCAPTANS	ppmw	DISULFIDES	ppmw
Hydrogen	ND	Methyl	ND	Carbon	ND
Carbonyl	ND	Ethyl	ND	Dimethyl	ND
Dimethyl	ND	Isopropyl	ND	Methyl Ethyl	ND
Methyl Ethyl	ND	n-Propyl	ND	Diethyl	ND
Diethyl	ND	Isobutyl	ND	Di-iso-Propyl	0.2
Di-iso-Propyl	ND	sec-Butyl	ND	Di-n-Propyl	2.9
Di-n-Propyl	ND	tert-Butyl	ND	Di-iso-Butyl	ND
Di-iso-Butyl	ND	n-Butyl	ND	Di-sec-Butyl	ND
Di-sec-Butyl	ND	Isoamyl	ND	Di-tert-Butyl	ND
Di-tert-Butyl	ND	pri-Amyl	ND	Di-n-Butyl	ND
Di-n-Butyl	ND	n-Amyl	ND		
OTHER	ppmw	OTHER	ppmw	OTHER	ppmw
Misc. Sulfurs	ND	Thiophene	ND	Thiophane	ND
Sulfur Dioxide	ND				

Comments: Detection limit = 0.1 ppmw
 Total Sulfur detected = 0.039 grains/100 std. cubic ft. at 68 °F.
 ND = Not Detected

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP, GPA guidelines for quality assurance, unless otherwise stated.

please do 48hr analysis



Air Hygiene International, Inc.
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
 (888) 461-8778
 www.airhygiene.com

**SAMPLE DESCRIPTION AND
 CHAIN OF CUSTODY RECORD**

Project Number:		sie-18-middletown.ny-start#1		Laboratory Analysis Requested:			
Person Taking Samples:		Pat McGovern, Jr.		ASTM 5504, ASTM D 1945			
Sample Number	Location	Date	Volume	Analysis Method			
				5504	1945		
1030-06464	SMR feed line	9/24/2018		X	X		
1030-04658	SMR feed line (BACKUP)	9/24/2018		X	X		
1030-01476	SMR feed line	9/25/2018		X	X		
1030-05208	SMR feed line (BACKUP)	9/25/2018		X	X		
1030-04658 & 1030-05208 are BACKUP ONLY							
Only Analyze Backup if necessary							
<i>[Signature]</i> Relinquished by: (Signature)		10/21/18 Date:	14:17 Time:	<i>[Signature]</i> Received by: (Signature)		10/3 Date:	14:07 Time:
		Date:	Time:	Received by: (Signature)		Date:	Time:

Chain of Custody

APPENDIX F
STRATIFICATION TEST DATA

STRATIFICATION TEST DATA

**Unit #CTG-1
Stratification Results**

Source Information	
Company	CPV Valley, LLC
Plant Name	CPV Valley Energy Center
Equipment	Siemens SCC6-5000F, Unit #CTG-1
Location	Middletown, New York

Test Information	
Date	09/24/18
Project #	sie-18-middletown.ny-start#1
Unit Number	CTG-1
Load	Base
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing) <input type="radio"/> Velocity Traverse (Flow and Flow RATA Test) <input type="radio"/> Stratification Traverse (Compliance Test) <input type="checkbox"/> RM 20 <input checked="" type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input checked="" type="checkbox"/> Part 75	Circular Stack

sie-18-middletown.ny-start#1-CTG1-Strat

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	CPV Valley, LLC	Date	09/24/18
Plant Name	CPV Valley Energy Center	Project #	sie-18-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, Unit #CTG-1	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	235.25	in.
Distance to Near Wall of Stack	(L _{nw})	7.25	in.
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A _s)	283.53	ft ²



Distance from Disturbances to Port			
Distance Upstream	(A)	1200.00	in.
Diameters Upstream	(A _D)	5.26	diameters
Distance Downstream	(B)	1095.00	in.
Diameters Downstream	(B _D)	4.80	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B _D) Stream	Up (A _D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria Points	
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>= 2.00	8 or 12 ²	8 or 12 ²	Minimum Number of Traverse Points	
Upstream Spec		12	12	RATA Stratification	
Downstream Spec		24	16	Criteria Points	
Traverse Pts Required		24	16	Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
					12 points

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.
² 8 for Circular Stacks 12 to 24 inches
 12 for Circular Stacks over 24 inches

Number of Traverse Points Used				
4	Ports by	3	Pts / port	Stratification Traverse
12	Pts Used	12	Required	(RATA)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	10	17 2/8
2	14.6%	33 2/8	40 4/8
3	29.6%	67 4/8	74 6/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	CPV Valley, LLC	Date	09/24/18
Plant Name	CPV Valley Energy Center	Project #	sie-18-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, Unit #CTG-1	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	228.00	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	283.53	ft ²	Run Start	16:03:46	Run End	16:55:46


Traverse Point	Time Per Point	Point Start Time	Point Stop Time (Reading)	O ₂	Percent Difference	NO _x	Percent Difference
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	4.00	16:03:46	16:07:46	13.55	0.11%	2.57	7.32%
D-2	4.00	16:07:46	16:11:46	13.51	0.16%	2.51	4.64%
D-1	4.00	16:11:46	16:15:46	13.52	0.12%	2.44	1.89%
C-3	4.00	16:15:46	16:19:46	13.54	0.05%	2.45	2.25%
C-2	4.00	16:19:46	16:23:46	13.54	0.05%	2.53	5.54%
C-1	4.00	16:23:46	16:27:46	13.53	0.01%	2.47	3.21%
B-3	4.00	16:27:46	16:31:46	13.53	0.04%	2.44	1.98%
B-2	4.00	16:31:46	16:35:46	13.54	0.01%	2.42	1.18%
B-1	4.00	16:35:46	16:39:46	13.54	0.03%	2.25	6.04%
A-3	4.00	16:43:46	16:47:46	13.55	0.10%	2.25	6.04%
A-2	4.00	16:47:46	16:51:46	13.52	0.11%	2.20	8.21%
A-1	4.00	16:51:46	16:55:46	13.55	0.09%	2.21	7.71%
Average				13.54		2.39	

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	CPV Valley, LLC	Date	09/24/18
Plant Name	CPV Valley Energy Center	Project #	sie-18-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, Unit #CTG-1	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	228.00	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	283.53	ft ²	Run Start	16:03:46	Run End	16:55:46

40 CFR 75 Criteria					
Stratification Results					
Maximum Percent Difference	8.21 % for NO _x	Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
Maximum Pollutant Conc. Diff.	0.20 ppm for NO _x				
Maximum Diluent Conc. Diff.	0.02 % for O ₂				
Stack Diameter	228.00 in.		%	in.	in.
Stratification Conclusions					
		1	>17.27%	>39.37	>46.62
Maximum % Diff.	Percent Diff. ≤10% Passed 6.5.6.3(a) Criteria	2			
Maximum Conc. Diff.	Conc. Diff. ≤ 0.3% Passed 6.5.6.3(b) Criteria	3			
Stack Diameter	D > 93.6 in.				
Passed Strat. Test Under 6.5.6.3(b) Criteria					
Test Type		<input type="checkbox"/> Moisture, for MW <input type="checkbox"/> Use 6.5.6.3(a) points? <input type="checkbox"/> Moisture, for wet-to-dry <input type="checkbox"/> 6.5.6(b)(2) alt. points could apply <input checked="" type="checkbox"/> Gas			



STRATIFICATION TEST DATA

**Unit #CTG-2
Stratification Results**

Source Information	
Company	CPV Valley, LLC
Plant Name	CPV Valley Energy Center
Equipment	Siemens SCC6-5000F, Unit #CTG-2
Location	Middletown, New York

Test Information	
Date	09/24/18
Project #	sie-18-middletown.ny-start#1
Unit Number	CTG-2
Load	100% w/DB
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing) <input type="radio"/> Velocity Traverse (Flow and Flow RATA Test) <input type="radio"/> Stratification Traverse (Compliance Test) <input type="checkbox"/> RM 20 <input checked="" type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input checked="" type="checkbox"/> Part 75	Circular Stack

STRATIFICATION TRAVERSE (RATA) RESULTS

Company	CPV Valley, LLC	Date	09/24/18
Plant Name	CPV Valley Energy Center	Project #	sie-18-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, Unit #CTG-2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	228.00	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	283.53	ft ²	Run Start	16:45:24	Run End	17:38:24


Traverse Point	Time Per Point	Point Start Time	Point Stop Time (Reading)	O ₂	Percent Difference	NOx	Percent Difference
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	4.00	16:45:24	16:49:24	13.59	0.27%	2.34	2.27%
D-2	4.00	16:49:24	16:53:24	13.65	0.18%	2.40	0.42%
D-1	4.00	16:53:24	16:57:24	13.66	0.24%	2.44	1.78%
C-3	5.00	16:57:24	17:02:24	13.64	0.12%	2.60	8.68%
C-2	4.00	17:02:24	17:06:24	13.61	0.10%	2.53	5.54%
C-1	4.00	17:06:24	17:10:24	13.62	0.08%	2.42	1.07%
B-3	5.00	17:10:24	17:15:24	13.60	0.22%	2.39	0.32%
B-2	4.00	17:15:24	17:19:24	13.59	0.27%	2.43	1.69%
B-1	4.00	17:19:24	17:23:24	13.63	0.02%	2.39	0.03%
A-3	7.00	17:23:24	17:30:24	13.64	0.10%	2.24	6.51%
A-2	4.00	17:30:24	17:34:24	13.64	0.05%	2.31	3.35%
A-1	4.00	17:34:24	17:38:24	13.66	0.26%	2.23	6.70%
Average				13.63		2.39	

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	CPV Valley, LLC	Date	09/24/18
Plant Name	CPV Valley Energy Center	Project #	sie-18-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, Unit #CTG-2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	228.00	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	283.53	ft ²	Run Start	16:45:24	Run End	17:38:24

40 CFR 75 Criteria						
Stratification Results						
Maximum Percent Difference	8.68 % for NO _x	Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length	
Maximum Pollutant Conc. Diff.	0.21 ppm for NO _x					
Maximum Diluent Conc. Diff.	0.04 % for O ₂					
Stack Diameter	228.00 in.		%	in.	in.	
Stratification Conclusions						
		1	>17.27%	>39.37	>46.62	
Maximum % Diff.	Percent Diff. ≤10% Passed 6.5.6.3(a) Criteria	2				
Maximum Conc. Diff.	Conc. Diff. ≤ 0.3% Passed 6.5.6.3(b) Criteria	3				
Stack Diameter	D > 93.6 in.					
Passed Strat. Test Under 6.5.6.3(b) Criteria						
Test Type		<input type="checkbox"/> Moisture, for MW <input type="checkbox"/> Moisture, for wet-to-dry <input checked="" type="checkbox"/> Gas			<input type="checkbox"/> Use 6.5.6.3(a) points? <input type="checkbox"/> 6.5.6(b)(2) alt. points could apply	



APPENDIX G

SEPTEMBER 25-27
PM TEST DATA
CTG-2 BASE LOAD
[EXCEEDED PERMIT LIMITS]

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Historical Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Run Start Time	09:52	15:12	15:39		hh:mm	
Run Stop Time	14:08	19:25	19:51		hh:mm	
Test Date	09/24/18	09/24/18	09/25/18		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	1.000	1.000	1.000			
Pitot Tube Coefficient	0.7420	0.7420	0.7420			
Average Nozzle Diameter	0.140	0.141	0.140		in	
Stack Test Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Initial Meter Volume	886.110	962.300	342.830		ft ³	
Final Meter Volume	962.005	1048.720	427.220		ft ³	
Total Meter Volume	75.895	86.420	84.390	82.235	ft ³	
Total Sampling Time	241.50	241.75	241.25	241.50	min	
Average Meter Temperature	79.50	79.92	78.25	79.22	°F	
Average Stack Temperature	218.00	216.50	203.33	212.61	°F	
Barometric Pressure	29.97	29.96	29.69	29.87	in Hg	
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89	in H ₂ O	
Absolute Stack Pressure	29.90	29.89	29.62	29.81	in Hg	
Average Orifice Pressure Drop	0.39	0.43	0.43	0.42	in H ₂ O	
Absolute Meter Pressure	30.10	30.09	29.82	30.01	in Hg	
Avg Square Root Pitot Pressure	1.16	1.19	1.18	1.18	√(in H ₂ O)	
Moisture Content Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Impinger Water Weight Gain	134.00	249.40	199.10	194.17	g	
Silica Gel Weight Gain	23.20	33.30	31.60	29.37	g	
Total Water Volume Collected	157.48	283.21	231.12	223.94	ml	
Standard Water Vapor Volume	7.41	13.33	10.88	10.54	scf	
Standard Meter Volume	74.5	84.7	82.2	80.5	dscf	
Standard Metric Meter Volume	2.1	2.4	2.3	2.3	dscm	
Calculated Stack Moisture	9.05	13.60	11.68	11.44	%	
Saturated Stack Moisture	100.00	100.00	84.75	94.92	%	
Reported Stack Moisture Content	9.05	13.60	11.68	11.44	%	
Gas Analysis Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Carbon Dioxide Content	4.0	4.0	4.0	4.0	%	
Oxygen Content	13.4	13.4	13.4	13.4	%	
Carbon Monoxide Content	0.6	0.6	0.6	0.6	ppm	
Nitrogen Content	82.6	82.6	82.6	82.6	%	
Stack Dry Molecular Weight	29.18	29.18	29.18	29.18	lb/lb-mole	
Stack Wet Molecular Weight	28.16	27.66	27.87	27.90	lb/lb-mole	
Calculated Fuel Factor	1.875	1.875	1.875	1.875		
Fuel F-Factor	8632.80	8632.80	8632.80	8632.80	dscf/MMBtu	
Percent Excess Air	159.4	159.4	159.4	159.4	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Volumetric Flow Rate Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Average Stack Gas Velocity	66.07	68.01	67.24	67.11	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft ²	
Actual Stack Flow Rate	1,124,032	1,157,038	1,143,870	1,141,647	acfm	
Wet Standard Stack Flow Rate	52,494	54,137	54,090	53,574	wkscfh	
Dry Standard Stack Flow Rate	47,742,394	46,777,098	47,771,465	47,430,319	dscfh	
Percent of Isokinetic Rate	104.1	118.3	116.8	113.0	%	
Emission Rate Data	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Total PM ₁₀ /PM _{2.5} Mass	148.14	3.12	28.21	59.82	mg	--
Total PM ₁₀ /PM _{2.5} Concentration	1.99E-03	3.68E-05	3.43E-04	7.90E-04	g/dscf	--
	3.07E-02	5.68E-04	5.29E-03	1.22E-02	gr/dscf	--
Total PM ₁₀ /PM _{2.5} Emission Rate	94.97	1.72	16.39	37.69	kg/hr	--
	209.37	3.79	36.12	83.10	lb/hr	--
	917.06	16.61	158.23	363.97	tpy	--
	0.1055	0.0020	0.0182	0.0419	lb/MMBtu	0.0073
Filterable PM ₁₀ Mass	0.46	0.35	0.14	0.32	mg	--
Filterable PM ₁₀ Concentration	6.23E-06	4.16E-06	1.75E-06	4.05E-06	g/dscf	--
	9.61E-05	6.43E-05	2.70E-05	6.25E-05	gr/dscf	--
Filterable PM ₁₀ Emission Rate	0.30	0.19	0.08	0.19	kg/hr	--
	0.66	0.43	0.18	0.42	lb/hr	--
	2.87	1.88	0.81	1.85	tpy	--
	0.0003	0.0002	0.0001	0.0002	lb/MMBtu	--
Filterable PM _{2.5} Mass	0.68	0.86	1.06	0.87	mg	--
Filterable PM _{2.5} Concentration	9.11E-06	1.02E-05	1.29E-05	1.07E-05	g/dscf	--
	1.41E-04	1.57E-04	1.99E-04	1.66E-04	gr/dscf	--
Filterable PM _{2.5} Emission Rate	0.44	0.48	0.62	0.51	kg/hr	--
	0.96	1.05	1.36	1.12	lb/hr	--
	4.20	4.60	5.96	4.92	tpy	--
	0.0005	0.0005	0.0007	0.0006	lb/MMBtu	--
Condensable PM _{2.5} Mass	147.00	1.90	27.00	58.63	mg	--
Condensable PM _{2.5} Concentration	1.97E-03	2.24E-05	3.28E-04	7.75E-04	g/dscf	--
	3.05E-02	3.46E-04	5.07E-03	1.20E-02	gr/dscf	--
Condensable PM _{2.5} Emission Rate	94.24	1.05	15.68	36.99	kg/hr	--
	207.76	2.31	34.58	81.55	lb/hr	--
	909.98	10.13	151.46	357.19	tpy	--
	0.1047	0.0012	0.0174	0.0411	lb/MMBtu	--
RM 201A Quality Control	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	Average	Units	Limits
Cyclone Flow Rate	0.44	0.52	0.49	0.48	ft ³ /min	
Stack Viscosity	208.13	203.55	202.21	204.63	μP	
Cunningham Correction Factor	1.08	1.09	1.10	1.09		
Recalculated D50-1 for CIV	2.93	2.32	2.45	2.57		
Recalculated Cunninham	1.07	1.08	1.08	1.08		
Lower Limit Cut Diameter, CI (NRE<3162), D50LL	2.91	2.32	2.43	2.55		

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Fuel Type	Gas, Natural

Test Information			
Project #		sie-18-middletown.ny-start#1	
Operator		PM / BL	
Date for Preliminary Run	(mm/dd/yy)	09/24/18	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		CTG-2	
Base Run Number		2-Base-PM	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		1	2	3	
Test Date	(mm/dd/yy)	09/24/18	09/24/18	09/25/18	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8632.80	8632.80	8632.80	dscf/MMBtu
Meter Box Number	from ACS	SAMP-CP-0029	SAMP-CP-0029	SAMP-CP-0029	
Meter Calibration Factor	(Y)	1.000	1.000	1.000	
Orifice Meter Coefficient	($\Delta H_{@}$)	1.824	1.824	1.824	in H ₂ O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	5273/10	5273/10	5273/10	
Pitot Tube Coefficient	(C _p)	0.7420	0.7420	0.7420	
Nozzle Number	from ACS	2	2	2	must match cyc nozz tab (e.g. 3, 4, etc.)
Nozzle Diameter	(D _n)	0.140	0.141	0.140	in
Probe Number	from ACS	SAMP-HP-0140	SAMP-HP-0140	SAMP-HP-0140	
Probe Length		108.0	108.0	108.0	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	5143	5143	5143	
Impinger Case Number	from ACS	SAMP-CC-0001	SAMP-CC-0022	SAMP-CC-0001	


Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Pat McGovern, Jr.
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

Created with Isocalc-AHI v20180830


METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	CPV Valley Energy Center	Date	09/24/18
Sampling Location	CTG-2 Stack	Stack Type	Circular
Operator	PM / BL	Ports Available	4
Project #	sie-18-middletown.ny-start#1	Ports Used	4
Stack Size	Large (>24 inch diameter)	Port ID (inches)	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	235.25	in
Distance to Near Wall of Stack	(L _{nw})	7.25	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A _s)	283.53	ft ²



Distance from Port to Disturbances			
Distance Upstream	(A)	1200.00	in
Diameters Upstream	(A _D)	5.26	diameters
Distance Downstream	(B)	1095.00	in
Diameters Downstream	(B _D)	4.80	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		24	16
Traverse Pts Required		24	16

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

² 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

- Method 1 Trav
- 12 Point PM Trav
- Velocity

Number of Traverse Points Used			
4	Ports by	3	Across
12	Pts Used	12	Required

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
	Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.044	10	17 2/8
2	0.146	33 2/8	40 4/8
3	0.296	67 4/8	74 6/8
4			
5			
6			
7			
8			
9			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	2-Base-PM-4	2-Base-PM-5	2-Base-PM-6	
Carbon Dioxide Content	4.0	4.0	4.0	4.0				%
Oxygen Content	13.3	13.4	13.4	13.4				%
Stack Moisture Content	9.0	9.1	13.6	11.7				%
Nitrogen plus CO Content	82.7	82.6	82.6	82.6				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H₂O)	Min.	1.61	Max.	2.10
---	------	------	------	------

Stack and Equipment Information	Prelim	2-Base-PM-1	2-Base-PM-2	2-Base-PM-3	2-Base-PM-4	2-Base-PM-5	2-Base-PM-6	
Barometric Pressure	29.82	29.97	29.96	29.69				in Hg
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89				in H ₂ O
Absolute Stack Pressure	29.75	29.90	29.89	29.62				in Hg
Average Stack Temp	210	218	217	203				0.00
Average Stack Temp	670	678	677	663				°R
Average Meter Temp	85	80	80	78				0.00
Orifice Meter Coefficient	1.824	1.824	1.824	1.824				in H ₂ O
Pitot Coefficient	0.742	0.742	0.742	0.742				
Stack Dry Molecular Weight	29.17	29.18	29.18	29.18				lb/lb mole
Stack Wet Molecular Weight	28.17	28.16	27.66	27.87				lb/lb mole
Stack Viscosity	206.33	208.13	203.55	202.21				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.09							
Cunningham Correction Factor, for a 2.5 µm particle		1.08	1.08	1.08				
Prelim Cut Dia., Cyclone I, D _{50LL} , N _{re} <3162	10.19	2.91	2.32	2.43				µm
Middle Zone Dia., Cyclone I, D _{50T} , N _{re} <3162	10.59							µm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic), N _{re} <3162	0.51							dscfm
Reynolds Number, Cyc I & IV, N _{re} <3162	2644.72	2246.43	2697.86	2604.42				
Dia. of 50% Prob. (D ₅₀) Cyc IV (N _{re} <3162)	2.40	2.91	2.33	2.45				µm
Sampling Rate, Cyc IV, N _{re} <3,162	0.51							dscfm
Reynolds Number, Cyc IV, N _{re} <3162	2644.68	2246.43	2697.86	2604.42				
Prelim Cut Dia., Cyclone I, D _{50LL} ≥3162	10.61							µm
Middle Zone Dia., Cyclone I, D _{50T} ≥3162	10.81							µm
Sampling Rate (PM ₁₀ & PM _{2.5} Cyclic)≥3162	0.49							dscfm
Reynolds Number, Cyc I & IV, N _{re} ≥3162	2572.33							
Dia. of 50% Prob. (D ₅₀) CIV (N _{re} ≥3162)	2.30							µm
Sampling Rate, Cyc IV, N _{re} ≥3,162	4.91							dscfm
Reynolds Number ≥ 3162	25723.49							
Cyclone Flow Rate	0.51	0.44	0.52	0.49				ft ³ /min
Recalculated D ₅₀₋₁ for C _{IV}		2.93	2.32	2.45				
Recalculated Cunningham		1.07	1.08	1.08				
Z		1.01	1.00	1.01				
Isokinetics		104.05	118.31	116.77				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.140	0.141	0.140				in

Orifice Head and Nozzle Selection Calculation

Nozzle No.	1	2	3	4	5	6	7	8	9	10	11
Nozzle diameter, D _n , in.	0.125	0.140	0.156	0.172	0.188	0.200	0.216	0.234	0.253	0.274	0.296
Nozzle velocity, v _n , ft/sec	98.81	78.77	63.20	52.19	43.68	38.60	33.09	28.20	24.12	20.56	17.62
R _{min}	0.76	0.75	0.73	0.70	0.66	0.63	0.57	0.50	0.50	0.50	0.50
v _{min} , ft/sec	75.46	58.94	45.92	36.50	29.00	24.33	18.94	14.10	12.06	10.28	8.81
R _{max}	1.23	1.24	1.25	1.26	1.28	1.30	1.32	1.35	1.39	1.43	1.49
v _{max} , ft/sec	121.08	97.31	78.92	65.98	56.05	50.14	43.78	38.16	33.52	29.51	26.21
Δp _{min} , in. H ₂ O @ t _s -50°F	1.91	1.17	0.71	0.45	0.28	0.20	0.12	0.07	0.05	0.04	0.03
Δp _{min} , in. H ₂ O @ t _s	1.77	1.08	0.66	0.41	0.26	0.18	0.11	0.06	0.05	0.03	0.02
Δp _{max} , in. H ₂ O @ t _s	4.56	2.94	1.94	1.35	0.98	0.78	0.60	0.45	0.35	0.27	0.21
Δp _{min} , in. H ₂ O @ t _s +50°F	4.24	2.74	1.80	1.26	0.91	0.73	0.55	0.42	0.32	0.25	0.20
ΔH, in. H ₂ O @ t _s +50°F						0.380					
ΔH, in. H ₂ O @ t _s						0.439					
ΔH, in. H ₂ O @ t _s -50°F						0.512					

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18		
Sampling Location	CTG-2 Stack	Operator	PM / BL		
Project #	sie-18-middletown.ny-start#1	# of Ports Used	1 (gas probe)		
Fuel Type	Gas, Natural	Min. Fuel Factor	1.600	Max. Fuel Factor	1.836

Gas Analysis Data								
Run Number	2-Base-PM-1		Date	09/24/18	Run Start Time	09:52	Run Stop Time	14:08
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:16	4.0	13.4	0.6	82.6	29.18	1.875	159.4	NO

Gas Analysis Data								
Run Number	2-Base-PM-2		Date	09/24/18	Run Start Time	15:12	Run Stop Time	19:25
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:13	4.0	13.4	0.6	82.6	29.18	1.875	159.4	NO

Gas Analysis Data								
Run Number	2-Base-PM-3		Date	09/25/18	Run Start Time	15:39	Run Stop Time	19:51
Sample Analysis Time	CO ₂ Conc.	O ₂ Conc.	CO Conc.	N ₂ Conc.	Dry Molecular Weight	Calculated Fuel Factor	Excess Air	Fuel Factor in Range
	(%CO ₂)	(%O ₂)	(ppmCO)	(%N ₂)	(M _d)	(F _o) _{avg}	(%EA) _{avg}	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:12	4.0	13.4	0.6	82.6	29.18	1.875	159.4	NO

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	CPV Valley Energy Center	Preliminary Run Date	09/24/18
Sampling Location	CTG-2 Stack	Operator	PM / BL
Project #	sie-18-middletown.ny-start#1	Ports Used	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0032	Standard	Result	Difference	Pass/Fail
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	09/24/18	500	499.9	-0.1	Pass
Test Day 2	09/25/18	500	500.0	0.0	Pass

Moisture Content Data								
Run Number	2-Base-PM-1		Date	09/24/18	Start Time	09:52	Stop Time	14:08
Meter Box Number	SAMP-CP-0029		Meter Cal Factor			(Y)	1.000	
Total Meter Volume	(V _m)	75.895	dcf	Barometric Pressure	(P _b)	29.97	in Hg	
Average Stack Temp	(t _s) _{avg}	218	°F	Stack Static Pressure	(P _{static})	-0.89	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	80	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.39	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	Dry		Dry	DI Water	Sil Gel			
Final Value	(V _f),(W _f)	490.80	598.80	767.10	897.80			
Initial Value	(V _i),(W _i)	362.10	596.80	763.80	874.60			
Net Value	(V _n),(W _n)	128.7	2.0	3.3	23.2			
Results								
Total Weight	(W _t)	157.20	g	Water Vol Weighed	(V _{wsg(std)})	7.412	scf	
Std Meter Volume	(V _{m(std)})	74.473	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.00	%	
Calc Moisture Content	(B _{ws(calc)})	9.05	%	Final Moisture Content	(B _{ws})	9.05	%	

Moisture Content Data								
Run Number	2-Base-PM-2		Date	09/24/18	Start Time	15:12	Stop Time	19:25
Meter Box Number	SAMP-CP-0029		Meter Cal Factor			(Y)	1.000	
Total Meter Volume	(V _m)	86.420	dcf	Barometric Pressure	(P _b)	29.96	in Hg	
Average Stack Temp	(t _s) _{avg}	217	°F	Stack Static Pressure	(P _{static})	-0.89	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	80	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	Dry		Dry	DI Water	Sil Gel			
Final Value	(V _f),(W _f)	579.00	604.20	755.50	956.20			
Initial Value	(V _i),(W _i)	357.10	593.20	739.00	922.90			
Net Value	(V _n),(W _n)	221.9	11.0	16.5	33.3			
Results								
Total Weight	(W _t)	282.70	g	Water Vol Weighed	(V _{wsg(std)})	13.329	scf	
Std Meter Volume	(V _{m(std)})	84.715	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.00	%	
Calc Moisture Content	(B _{ws(calc)})	13.60	%	Final Moisture Content	(B _{ws})	13.60	%	

Moisture Content Data								
Run Number	2-Base-PM-3		Date	09/25/18	Start Time	15:39	Stop Time	19:51
Meter Box Number	SAMP-CP-0029		Meter Cal Factor			(Y)	1.000	
Total Meter Volume	(V _m)	84.390	dcf	Barometric Pressure	(P _b)	29.69	in Hg	
Average Stack Temp	(t _s) _{avg}	203	°F	Stack Static Pressure	(P _{static})	-0.89	in H ₂ O	
Average Meter Temp	(t _m) _{avg}	78	°F	Avg Orifice Pressure	(ΔH) _{avg}	0.43	in H ₂ O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	(g)	(g)	(g)	(g)				
Contents	Dry		Dry	DI Water	Sil Gel			
Final Value	(V _f),(W _f)	523.40	602.60	784.80	929.90			
Initial Value	(V _i),(W _i)	357.40	597.20	757.10	898.30			
Net Value	(V _n),(W _n)	166.0	5.4	27.7	31.6			
Results								
Total Weight	(W _t)	230.70	g	Water Vol Weighed	(V _{wsg(std)})	10.878	scf	
Std Meter Volume	(V _{m(std)})	82.234	dscf	Sat. Moisture Content	(B _{ws(svp)})	84.75	%	
Calc Moisture Content	(B _{ws(calc)})	11.68	%	Final Moisture Content	(B _{ws})	11.68	%	

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	PM / BL
Run Number	2-Base-PM-1

Filter #	000015
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C_p)	0.7420	5273/10	
Average Stack Temp (t_s)	218.0		°F
Average Meter Temp (t_m)	79.5		
Orifice Meter Coefficient (ΔH_{or})	1.824		in H ₂ O
Square Root ΔP ($\Delta P_{avg}^{1/2}$)	1.16		in H ₂ O
Stack Moisture Content (B_{ws})	9.05		%
Stack Dry Molecular Weight (M_d)	29.18		lb/lb-mole
Estimated Orifice Flow Rate (Q_m)	0.75		acfm
ΔP to ΔH Isokinetic Factor (K)	0.22		

Leak Checks					
Train	Pre	0.001	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
PASS	Pitot	Pre (+)	5.6	in H ₂ O for	15.0 sec
	Pre (-)	5.1	in H ₂ O for	15.0 sec	
	Post (+)	5.8	in H ₂ O for	15.0 sec	
	Post (-)	5.5	in H ₂ O for	15.0 sec	

Sampling Equipment			
Meter Box Number	SAMP-CP-0029		
Meter Cal Factor (Y)	1.000		
Nozzle Number	2		
Average Nozzle Diameter (D_{na})	0.1400		in
Suggested Nozzle Diameter (D_m)	0.2175		in
Probe Number	SAMP-HP-0140		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	5143		
Impinger Case Number	SAMP-CC-0001		

Nozzle Measurements				ID: 2
Pre	0.140	0.140	0.140	PASS
Post	0.140	0.140	0.140	PASS

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0032	

Run Time		
Start	09:52	End 14:08

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	362.1	596.8	763.8	874.6				
Post	490.8	598.8	767.1	897.8				

Pressures		
Barometric Pressure (P_b)	29.97	in Hg
Stack Static Pressure (P_{static})	-0.89	in H ₂ O
Absolute Stack Pressure (P_s)	29.90	in Hg
Absolute Meter Pressure (P_m)	30.10	in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0029	SAMP-CP-0029	SAMP-CP-0029			SAMP-HP-0140	SAMP-HP-0140	5143	SAMP-CC-0001	1035	6692	SAMP-CP-0029		SAMP-CP-0029						
	Traverse Point #	Sampling Time (min)	Timer Time (hh:mm:ss)	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _{m,Std})	Cumul. Percent IsoKinetic (I)
A-1	0.0	00:00:00	886.110	1.40	0.439	0.39	211	225	253	63	50	79	75	75	3.0	1.18	66.99	6.283	112.1	83.147
A-2	18.3	00:18:15	892.460	1.50	0.439	0.39	211	237	256	53	45	69	78	78	3.0	1.22	69.34	12.330	106.2	79.938
A-3	37.3	00:37:15	898.605	1.50	0.439	0.39	213	257	253	55	48	70	80	80	3.0	1.22	69.45	18.556	105.2	79.668
B-1	56.3	00:56:15	904.956	1.20	0.439	0.39	218	259	253	58	44	68	82	82	3.0	1.10	62.35	25.597	109.7	80.545
B-2	76.8	01:16:45	912.165	1.20	0.439	0.39	219	255	272	56	48	68	83	83	3.0	1.10	62.39	31.691	108.8	78.698
B-3	97.3	01:37:15	918.415	1.20	0.439	0.39	220	267	263	56	54	68	82	82	3.0	1.10	62.44	37.687	108.0	77.294
C-1	117.8	01:57:45	924.554	1.30	0.439	0.39	221	231	263	57	55	68	79	79	3.0	1.14	65.03	44.858	109.7	78.359
C-2	138.3	02:18:15	931.855	1.30	0.439	0.39	221	229	273	59	66	68	79	79	3.0	1.14	65.03	51.419	109.6	78.221
C-3	158.8	02:38:45	938.535	1.40	0.439	0.39	218	232	262	63	70	71	79	79	3.0	1.18	67.34	57.862	108.5	77.631
D-1	180.0	03:00:00	945.095	1.40	0.439	0.39	221	234	259	64	72	68	79	79	3.0	1.18	67.49	63.593	107.0	76.597
D-2	200.5	03:20:30	950.930	1.40	0.439	0.39	222	226	272	66	73	69	79	79	3.0	1.18	67.54	69.176	105.5	75.593
D-3	221.0	03:41:00	956.615	1.40	0.439	0.39	221	230	264	67	74	71	79	79	3.0	1.18	67.49	74.470	104.1	74.470
Last Pt	241.5	04:01:30	962.005																	
Final Val	241.5	04:01:30	962.005												Max Vac	3.0	Final Values	74.470	104.1	
Average Values				1.35		0.39	218	240	262	60	58	70	80	80			1.16	66.07		

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/24/18
Operator	PM / BL
Run Number	2-Base-PM-2

Filter #	000020
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.7420	5273/10	
Average Stack Temp (t _s)	216.5		°F
Average Meter Temp (t _m)	79.9		
Orifice Meter Coefficient (ΔH@)	1.824		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.19		in H ₂ O
Stack Moisture Content (B _{ws})	13.60		%
Stack Dry Molecular Weight (M _d)	29.18		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.31		acfm
ΔP to ΔH Isokinetic Factor (K)	0.21		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	15.0	in Hg
Pitot	Pre (+)	3.6	in H ₂ O for	15.0	sec
	Pre (-)	3.3	in H ₂ O for	15.0	sec
	Post (+)	5.0	in H ₂ O for	15.0	sec
	Post (-)	5.4	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0029		
Meter Cal Factor	(Y)	1.000	
Nozzle Number	2		
Average Nozzle Diameter (D _{na})	0.1407		in
Suggested Nozzle Diameter (D _m)	0.1379		in
Probe Number	SAMP-HP-0140		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	5143		
Impinger Case Number	SAMP-CC-0022		

Nozzle Measurements					ID: 2
Pre	0.141	0.140	0.141	PASS	
Post	0.141	0.140	0.141	PASS	

Barometer ID	
SAMP-WE-0014	
Scale ID	
SAMP-SC-0032	

Run Time		
Start	15:12	End 19:25

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	357.1	593.2	739.0	922.9				
Post	579.0	604.2	755.5	956.2				

Pressures			
Barometric Pressure (P _b)	29.96		in Hg
Stack Static Pressure (P _{static})	-0.89		in H ₂ O
Absolute Stack Pressure (P _s)	29.89		in Hg
Absolute Meter Pressure (P _m)	30.09		in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0029	SAMP-CP-0029	SAMP-CP-0029		SAMP-HP-0140	SAMP-HP-0140	5143	SAMP-CC-0022	1035	6692	SAMP-CP-0029	SAMP-CP-0029								
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	962.300	1.40	0.439	0.43	223	253	251	65	56	70	74	74	4.0	1.18	68.22	6.145	114.3	81.400
A-2	18.3	00:18:15	968.500	1.50	0.439	0.43	221	240	248	65	59	71	75	75	4.0	1.22	70.51	12.625	112.9	81.934
A-3	37.3	00:37:15	975.050	1.40	0.439	0.43	218	248	259	65	61	70	77	77	4.0	1.18	67.97	19.209	116.0	83.670
B-1	55.5	00:55:30	981.730	1.20	0.439	0.43	218	242	249	65	68	70	78	78	4.0	1.10	62.93	26.360	119.1	83.851
B-2	76.0	01:16:00	989.000	1.20	0.439	0.43	218	252	261	65	78	70	79	79	4.0	1.10	62.93	33.008	119.0	82.692
B-3	96.5	01:36:30	995.770	1.20	0.439	0.43	217	265	261	65	80	70	81	81	4.0	1.10	62.88	40.257	120.8	83.182
C-1	117.0	01:57:00	1003.180	1.50	0.439	0.43	214	261	254	56	85	70	81	81	4.0	1.22	70.15	47.321	119.5	83.199
C-2	137.5	02:17:30	1010.400	1.50	0.439	0.43	214	261	259	55	70	70	82	82	4.0	1.22	70.15	54.547	118.9	83.460
C-3	158.0	02:38:00	1017.800	1.50	0.439	0.43	214	266	267	57	70	70	83	83	4.0	1.22	70.15	61.867	118.6	83.789
D-1	178.5	02:58:30	1025.310	1.40	0.439	0.43	214	262	253	60	75	71	83	83	4.0	1.18	67.77	69.206	118.8	84.074
D-2	199.0	03:19:00	1032.840	1.60	0.439	0.43	215	264	259	59	80	70	83	83	4.0	1.26	72.50	77.033	118.3	84.362
D-3	220.8	03:40:45	1040.870	1.50	0.439	0.43	212	264	257	60	81	75	83	83	4.0	1.22	70.04	84.685	118.3	84.685
Last Pt	241.8	04:01:45	1048.720																	
Final Val	241.8	04:01:45	1048.720												Max Vac	4.0	Final Values	84.685	118.3	
Average Values				1.41		0.43	217	257	257	61	72	71	80	80		1.19	68.01			

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Date	09/25/18
Operator	PM / BL
Run Number	2-Base-PM-3

Filter #	18081505
	--

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID (C _p)	0.7420	5273/10	
Average Stack Temp (t _s)	203.3		°F
Average Meter Temp (t _m)	78.3		
Orifice Meter Coefficient (ΔH@)	1.824		in H ₂ O
Square Root ΔP (ΔP ^{1/2} _{avg})	1.18		in H ₂ O
Stack Moisture Content (B _{ws})	11.68		%
Stack Dry Molecular Weight (M _d)	29.18		lb/lb-mole
Estimated Orifice Flow Rate (Q _m)	0.35		acfm
ΔP to ΔH Isokinetic Factor (K)	0.22		

Leak Checks					
Train	Pre	0.000	ft ³ /min@	15.0	in Hg
PASS	Post	0.000	ft ³ /min@	17.0	in Hg
Pitot	Pre (+)	5.1	in H ₂ O for	15.0	sec
	Pre (-)	5.2	in H ₂ O for	15.0	sec
	Post (+)	5.6	in H ₂ O for	15.0	sec
	Post (-)	5.2	in H ₂ O for	15.0	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0029		
Meter Cal Factor	(Y)	1.000	
Nozzle Number	2		
Average Nozzle Diameter (D _{na})	0.1400		in
Suggested Nozzle Diameter (D _m)	0.1466		in
Probe Number	SAMP-HP-0140		in
Probe Length	108		in
Liner Material	glass		
Sample Case / Oven Number	5143		
Impinger Case Number	SAMP-CC-0001		

Nozzle Measurements				ID: 2
Pre	0.140	0.140	0.140	PASS
Post	0.140	0.140	0.140	PASS

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0032

Run Time		
Start	15:39	End 19:51

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	357.4	597.2	757.1	898.3				
Post	523.4	602.6	784.8	929.9				

Pressures		
Barometric Pressure (P _b)	29.69	in Hg
Stack Static Pressure (P _{static})	-0.89	in H ₂ O
Absolute Stack Pressure (P _s)	29.62	in Hg
Absolute Meter Pressure (P _m)	29.82	in Hg

Wash Volumes					ml
					ml

Identification Nos.	SAMP-CP-0029	SAMP-CP-0029	SAMP-CP-0029		SAMP-HP-0140	SAMP-HP-0140	5143	SAMP-CC-0001	1035	6692	SAMP-CP-0029	SAMP-CP-0029								
Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (≤85°F)	CPM Filter Temp (76.5±8.5°F)	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumul. Meter Volume (V _m) _{std}	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H ₂ O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	342.830	1.30	0.439	0.43	203	264	260	56	55	66	75	75	5.0	1.14	64.81	5.069	96.0	67.002
A-2	18.3	00:18:15	348.000	1.30	0.439	0.43	205	266	259	60	71	71	76	76	5.0	1.14	64.91	11.869	114.9	78.452
A-3	36.5	00:36:30	354.950	1.40	0.439	0.43	202	266	258	61	71	72	77	77	5.0	1.18	67.21	18.492	115.3	80.380
B-1	55.5	00:55:30	361.730	1.30	0.439	0.43	202	269	262	62	78	70	78	78	5.0	1.14	64.76	26.018	118.6	82.590
B-2	76.0	01:16:00	369.450	1.40	0.439	0.43	203	267	263	60	75	72	78	78	5.0	1.18	67.26	32.823	116.1	81.424
B-3	97.3	01:37:15	376.430	1.40	0.439	0.43	204	268	261	57	66	68	78	78	5.0	1.18	67.31	41.402	120.0	84.289
C-1	118.5	01:58:30	385.230	1.50	0.439	0.43	203	268	263	62	68	69	79	79	5.0	1.22	69.62	48.768	119.3	84.643
C-2	139.0	02:19:00	392.800	1.50	0.439	0.43	205	267	261	58	69	69	79	79	5.0	1.22	69.72	56.465	119.5	85.406
C-3	159.5	02:39:30	400.710	1.60	0.439	0.43	205	261	268	60	80	68	79	79	5.0	1.26	72.01	64.396	119.3	86.070
D-1	180.5	03:00:30	408.860	1.40	0.439	0.43	200	273	261	61	82	69	80	80	5.0	1.18	67.11	71.895	119.6	86.291
D-2	201.0	03:21:00	416.580	1.40	0.439	0.43	204	270	266	60	84	72	80	80	5.0	1.18	67.31	79.024	119.2	86.070
D-3	221.5	03:41:30	423.920	1.30	0.439	0.43	204	222	256	63	85	73	80	80	5.0	1.14	64.86	82.229	116.8	82.229
Last Pt	241.3	04:01:15	427.220																	
Final Val	241.3	04:01:15	427.220												Max Vac	5.0	Final Values	82.229	116.8	
Average Values				1.40		0.43	203	263	262	60	74	70	78	78		1.18	67.24			

Notes:

Probe temp out of specification due to:

CPM filter temp out of specification due to:

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	2-Base-PM-1	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		1	Start Time	09:52
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.3	71	0.3510	0.9490	
Cyclone Wash 2.5<PM<10			0.8	68	0.3362	0.4638	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.7	65	0.3213	0.3787	
Inorganic Impinger Contents			61	300.9027	1.2857	59.7143	
Organic Impinger Contents			88	100.3009	0.7143	87.2857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	2-Base-PM-2	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		2	Start Time	15:12
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			0.6	45	0.2225	0.3775	
Cyclone Wash 2.5<PM<10			0.6	50	0.2472	0.3528	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.8	48	0.2373	0.5627	
Inorganic Impinger Contents			2.0	351.0532	1.2857	0.7143	
Organic Impinger Contents			1.9	79.2377	0.7143	1.1857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	2-Base-PM-3	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Filter	Maxxam		
Nozzle Wash PM>10	Maxxam		
Cyclone Wash 2.5<PM<10	Maxxam		
Cyclone Exit to Front Half of Filter Wash (<2.5)	Maxxam		
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Blank and Titration Concentrations				
Blank Type	Weight	Volume	Concentration	Mass
	(g)	(ml)	(mg/ml)	(mg)
Acetone Blank Weight of Solids	0.0010	202.2756	0.0049	--
DI Water Blank Weight of Solids	0.0005	230.6921	0.0022	--
Hexane Blank Weight of Solids	0.0010	257.9666	0.0039	--
0.1N NH ₄ OH Correction	--		--	0.0000

Gravimetric Concentrations			Run		3	Start Time	15:39
Sample Portion	Final	Tare	Gain	Volume	Blank Adjustment	Adjusted Gain	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.2	60	0.2966	0.9034	
Cyclone Wash 2.5<PM<10			0.5000	72	0.3560	0.1441	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.0	48	0.2373	0.7627	
Inorganic Impinger Contents			16	280.8425	1.2857	14.7143	
Organic Impinger Contents			13	91.2738	0.7143	12.2857	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	CPV Valley Energy Center
Sampling Location	CTG-2 Stack
Project #	sie-18-middletown.ny-start#1

Analytical Data		Run	2-Base-PM-FB	
Sample Leakage Evident	NO	Estimated Leak Volume		0.00 (mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	Maxxam		
Organic Impinger Contents	Maxxam		

Gravimetric Concentrations					Actual Gain
Sample Portion	Final	Tare	Gain	max 2 mg total blank adjustment, proportioned	(mg)
	(g)	(g)	(mg)		
Inorganic Impinger Contents	0.0018	0.0000	1.2857		1.8000
Organic Impinger Contents	0.0010	0.0000	0.7143		1.0000

**this page intentionally left blank
end of report**

ATTACHMENT 4

Continuous Emissions Monitoring Plan



Valley Energy Center
3330 Route 6
Middletown, NY 10940

June 12, 2017

Regional Air Pollution Control Engineer
NYSDEC – Region 3
21 South Putt Corners Road
New Paltz, NY 12561
Certified Mail: 7016 0600 0000 8503 7094

Division of Air Resources
NYSDEC - Bureau of Quality Assurance
625 Broadway
Albany, New York 12233-3258
Certified Mail: 7016 0600 0000 8503 7087

USEPA Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code 6204M
Washington, DC 20460
Certified Mail: 7016 0600 0000 8503 7070

USEPA Region II
Air Compliance Branch
290 Broadway
New York, NY 10007-1866
Certified Mail: 7016 0600 0000 8503 7063

Re: CPV Valley Energy Center
ORIS Code – 56940
NYSDEC Title V Permit ID: 3-3356-00136/00001
CEMS Plan

Dear Sir / Madam:

In accordance with 6 CRR-NY 227-2.6 (b), CPV Valley Energy Center is submitting the attached CEMS Plan for the new Combined Cycle Combustion Turbines Unit No. 1 (“CTG1”) and 2 (“CTG2”). Previously the facility submitted the Hardcopy Monitoring Plan on March 31, 2017 to the Department in accordance with 40 CFR §75.53 and 40 CFR §75.62(a)(2). CPV Valley Energy Center believed the Hardcopy Monitoring Plan fulfilled the specific requirements identified in 6 CRR-NY 227-2.6 (b) for the CEMS Plan.

If there are any questions regarding this submittal, please contact Benjamin Stanley at (845) 649-8300.

Sincerely,

Benjamin Stanley

CC:
Jack Breen - CPV
Chris Allgeier – CPV
Jonathan Moore

CEMS PLAN
6 CRR-NY 227-2.6 (b)

Continuous Emissions Monitoring System (CEMS)

40 CFR 75 Monitoring Plan Submittal Package

Document Date: March 2017

Revision No.: 0

CEMTEK Project No.: 50478

Siemens Document No.: CN50478_MONPLAN

Siemens Document Control No.: UNID498367531 rev04

Prepared for:

CPV Valley Energy Center

CTG Units 1 and 2

Middletown, NY

Facility ORISPL ID: 56940

Prepared by:

CEMTEK Environmental, Inc.

3041 S. Orange Ave

Santa Ana, CA 92707-4247

Phone: 714-437-7100

Fax: 714-437-7177

www.cemteks.com



Contents

1	Facility Information	1
2	CEMS Overview	1
2.1	CEMS Analyzers	2
2.1.1	TAPI 200M NO _x /O ₂ Analyzer	2
2.1.2	TAPI 200M NO _x /NH ₃ Analyzer	3
2.1.3	TAPI T300M CO/CO ₂ Analyzer	3
2.2	Data Acquisition System	4
2.3	Appendix D Reporting System	5
2.3.1	Fuel Flow Monitoring	5
2.3.2	SO ₂ /CO ₂ Monitoring	6
2.3.3	Fuel Sampling	6
3	NO _x Analyzer Range and MER Determination	6
4	F-Factor Determination	7
5	Certification Summary	7
5.1	7-Day Calibration Error Test – Part 75	8
5.2	7-Day Calibration Drift Test – Part 60	9
5.3	Linearity Error Check – Part 75	10
5.4	Cycle/Response Time Check – Part 75	11
5.5	CO Response Time Check – Part 60	11
5.6	Relative Accuracy Test Audit	12
	Appendix A Monitoring Plan Records	13
	Appendix B CEMS Drawings	14
	Appendix C Stack Drawings	15
	Appendix D Fuel Flowmeter Locations	16

1 Facility Information

The Valley Energy Center facility is located in Wawayanda, NY and consists of one combined cycle power plant operating on dual-fuel (natural gas and fuel oil) with duct burning.

The Facility consists of: two (2) Siemens SGT6-5000F(4) gas turbines with Dry Low NO_x (DLN) Combustion Systems, operating in 2x1 combined cycle configuration, firing natural gas and ultra-low sulfur diesel (ULSD) fuel oil; two (2) 3-drum HRSG's equipped with SCR systems for NO_x control and oxidation catalysts for CO and VOC control; and one (1) Siemens SST6-5000 steam turbine generator (STG).

2 CEMS Overview

The Acid Rain Program (40 CFR 75 and related Parts) requires monitoring and reporting of NO_x emission rate in lb/mmBtu, which is calculated using a NO_x and O₂ CEMS.

The Acid Rain Program also requires monitoring and reporting of heat input, SO₂, and CO₂. This is accomplished by following the alternate procedures in 40 CFR 75 Appendixes D and G. Appendix D defines how heat input is calculated from certified fuel flow meters. The heat input and fuel factors are then used to calculate the mass emissions of SO₂.

Each CEMS is a dry extractive system, which monitors NO_x, NH₃, CO, and O₂. Programmable Logic Controllers (PLCs) allows each system to automatically operate and perform daily, unattended calibrations. Complete system operation and sequencing is automatic. Operator attention is necessary for periodic system verification of accuracy, manual calibrations, and normal maintenance.

Each CTG CEMS is divided into two primary subassemblies. The Stack subassembly consists of a dual-bench NO_x/O₂ analyzer, a dual bench CO/CO₂ analyzer, and associated sample-conditioning system components. The NH₃ subassembly consists of a NO_x analyzer referenced as the NO_x/NH₃ analyzer and associated sample-conditioning system components. The NH₃ subassembly works with the Stack subassembly to calculate ammonia slip.

2.1 CEMS Analyzers

The following table provides information on the monitors that were subject to this test program.

CTG CEMS Unit 1

Analyzer	Manufacturer/Model	Range(s)	Serial Number
NO _x	Teledyne API T200M	0-10 ppm/0-100 ppm	645
O ₂		0-25%	
NO _x /NH ₃	Teledyne API T200M	0-10 ppm/0-100 ppm	644
CO	Teledyne API T300M	0-10 ppm/0-5000 ppm	355
CO ₂		0-10%	

CTG CEMS Unit 2

Analyzer	Manufacturer/Model	Range(s)	Serial Number
NO _x	Teledyne API T200M	0-10 ppm/0-100 ppm	646
O ₂		0-25%	
NO _x /NH ₃	Teledyne API T200M	0-10 ppm/0-100 ppm	643
CO	Teledyne API T300M	0-10 ppm/0-5000 ppm	354
CO ₂		0-10%	

The CO₂ analyzers and the NO_x/NH₃ analyzers are used for process monitoring and control.

2.1.1 TAPI 200M NO_x/O₂ Analyzer

The Model T200M uses the chemiluminescence measurement principal. The T200M is a microprocessor controlled instrument that measures the concentration of nitric oxide (NO), total nitrogen oxides (NO_x, the sum of NO and NO₂) and nitrogen dioxide (NO₂) in a sample gas drawn through the instrument. Sample and calibration gases are supplied at ambient atmospheric pressure in order to establish a constant flow through the reaction cell where the sample gas is exposed to ozone (O₃), initiating a chemical reaction that gives off light (chemiluminescence). The instrument measures the amount of chemiluminescence to determine the amount of NO in the sample gas. A catalytic-reactive converter converts any NO₂ in the sample gas to NO, which is then (including the NO in the sample gas) reported as NO_x. NO₂ is calculated as the difference between NO_x and NO.

The analyzer includes an oxygen sensor which utilizes the fact that oxygen is attracted into a strong magnetic field to obtain fast, accurate oxygen measurements.

The sensors core is made up of two nitrogen filled glass spheres, which are mounted on a rotating suspension within a magnetic field. A mirror is mounted centrally on the suspension and light is shone onto the mirror, which reflects the light onto a pair of photocells that then generate a signal.

Oxygen from the sample stream is attracted into the magnetic field displacing the nitrogen filled spheres and causing the suspended mirror to rotate. This changes the amount of light reflected onto the photocells and therefore the output levels of the photocells. A feedback loop increases the amount of current fed into the wire winding in order to move the mirror back into its original position. The more O₂ present, the more the mirror moves and the more current is fed into the wire winding by the feedback control loop. A sensor measures the amount of current generated by the feedback control loop which is directly proportional to the concentration of oxygen within the sample gas mixture.

2.1.2 TAPI 200M NO_x/NH₃ Analyzer

Ammonia slip is measured at the stack through use of the two TAPI 200M NO_x analyzers. An NH₃ converter is located at the probe interface box. Stack sample gas from the probe is split into two transport paths. One path transports sample gas to the primary sample conditioning system and outlet analyzers. The second path transports sample gas to the NH₃ converter (NH₃ to NO). After passing through the converter the sample is transported to the secondary sample conditioning system and the secondary NO_x/NH₃ analyzer. Ammonia slip is calculated as the difference between converted and unconverted NO_x ppm.

2.1.3 TAPI T300M CO/CO₂ Analyzer

The T300M is a Gas Filter Correlation carbon monoxide analyzer. The microprocessor-controlled analyzer determines the concentration of carbon monoxide (CO) in a sample gas drawn through the instrument. It uses a method based on the Beer-Lambert law, an empirical relationship that relates the absorption of light to the properties of the material through which the light is traveling over a defined distance. In this case the light is infrared (IR) traveling through a sample chamber filled with a gas bearing a varying concentration of CO.

The analyzer passes the IR beam through a spinning wheel made up of two separate chambers: one containing a high concentration of CO known as the reference, and the other containing a neutral gas known as the measure. The concentration of CO in the sample chamber is computed by taking the ratio of the instantaneous measure and the reference values and then compensating the ratio for the sample temperature and pressure.

The GMM221 CO₂ transmitter, included with the CO analyzer is silicon based. Its operation is based on the NDIR Single-Beam Dual Wavelength principle. The module consists of a component board, cable and a CO₂ probe.

2.2 Data Acquisition System

The CEMS system includes an Allen Bradley Control Logix Programmable Logic Controller (PLC). The PLC consists of a series of input and output modules. PLCs are designed for industrial applications and are more tolerant of humidity, temperature, and vibration than a desktop computer would be. The Allen Bradley Control Logix Programmable Logic Controller communicates information from the analyzers and sensors to the DAHS and/or the plant's Distributed Control System (DCS). For ease of connection and added protection, the PLC is mounted in the instrument rack inside of the shelter.

The Programmable Logic Controller (PLC) has a range of functions in a typical system. The PLC is programmed to automatically perform a system calibration at predetermined intervals. It can also receive a manual input to perform calibrations on an as-needed basis. Analog -to-digital converters take 4-20 mA signals received directly from the analyzers and convert those signals into digital values that are then scaled into the appropriate engineering units. There are also digital input points, used to monitor conditions such as *process-on, in calibration, or analyzer fault*. Signals from the analyzers and DCS are processed and then forwarded to the DAHS server, either in the form of raw data or averages, depending on the source.

The PLC has an RJ-45 jack, allowing it to be networked with the DAHS using cat5e patch cable. The PLC is typically connected to an Ethernet switch on the same network as the DAHS server. Some analyzers will also be patched into the local switch. This configuration allows the PLC to communicate with more than one device on a local area network, and allows the DAHS to accept data from multiple PLCs. In this type of situation, there will also be a client computer, or a dedicated OIT, located with each PLC to function as a local interface.

The PLC will run in a stand-alone mode (that is not connected to the DAHS or DCS), if necessary. It will continue to calibrate all analyzers in cases where the DAHS is temporarily offline. In addition, the controller has battery backup (non-volatile) memory. Data for each channel can be stored in memory on a "first in first out" (FIFO) basis until the memory is full. This helps prevent data loss if the DAHS goes offline. The amount of time the DAHS can be offline before the PLC memory is full (and subsequently over-written with new data) varies by system. Typically the PLC memory will hold approximately seven days of data. When the DAHS returns to service, available data from the controller can be retrieved and stored by the DAHS.

The PLC automatically performs a system calibration at predetermined intervals to ensure accurate measurements.

The Data Acquisition and Handling System (DAHS) provides automated data monitoring and management capabilities to the CEMS. The DAHS server is located in the plant's control room with remote work stations located in each CEMS shelter.

The hardware for the DAHS includes a Dell desktop computer with an Intel Core 2 Duo 3.2 GHz CPU, 4 GB RAM, 500 GB hard disk, 16xDVD +/- RW drive, USB enhanced keyboard and optical mouse, 19" flat panel LCD monitor, 2 Ethernet interface cards, and Windows 7 operating system. Removable hard drives are included for data backup and archiving. The DAHS is backed up to a disk on a monthly basis for data archiving.

The software by VIM technologies is specifically designed for CEMS and regulatory compliance. The DAHS provides an interface to the PLC, collects and stores data, performs calculations, and generates reports specific to each customer's regulatory requirements. There is a user manual for the VIM software in pdf format located on the hard drive of the DAHS server.

The DAHS server receives data from the PLC over a switched Ethernet and fiber optic network. Data is written and stored to hard disk on the DAHS server. Depending on the data, the DAHS will process values received from the PLC into averages or rolling averages, as necessary. In addition to gas measurements from the analyzers, a number of process-operating parameters are monitored by the PLC and logged by the DAHS. These include calibration control, alarms, analyzer status, and process status.

2.3 Appendix D Reporting System

The alternate monitoring methodology found in Part 75, Appendix D requires continuous monitoring of fuel flow rate and periodic sampling of the fuel characteristics, such as sulfur content, gross calorific value (GCV), and density. The measured fuel flow rates are used with the results from the fuel sampling and analysis to determine the SO₂ mass emissions rate and the unit heat input rate.

2.3.1 Fuel Flow Monitoring

The Acid Rain Program requires monitoring and reporting of heat input, SO₂ and CO₂. This is accomplished by following the alternate procedures in Part 75 Appendixes D and G. Part 75 Appendixes D and F define how heat input is calculated from fuel flow meters. The heat input and fuel factors are then used to calculate the mass emissions of SO₂ and CO₂. The appropriate gas heating value (GCV) is manually entered into the DAHS. The appropriate quarterly average gas heating value (GCV) is manually entered into the DAHS.

Fuel flow is monitored by certified fuel flowmeters in order to report heat input to the unit in accordance with Part 75, Appendix D. For each hour when the unit is combusting fuel, the facility is required to measure and record the flow of fuel combusted by the unit with an in-line fuel flowmeter and automatically record the data.

Signals from each flowmeter are sent to the CEM's DAHS via the PLC control unit for required recording and emission reporting. Data is reduced to hourly averages.

The fuel flowmeters are certified, in accordance with Part 75, Appendix D, section 2.1.5.1. Manufacturer, model number and serial number of each fuel flowmeter and accompanying converter are noted in the facility's Part 75 monitoring plan records located in Appendix A.

Documentation is provided in the appendix section of this document demonstrating that the natural gas supply qualified as pipeline quality natural gas per the definition located in 40 CFR72, section 72.2.

2.3.2 SO₂/CO₂ Monitoring

When natural gas (NNG) is burned SO₂ is calculated using fuel analysis values for sulfur content and GCV, and the calculated heat input result. These values can be adjusted in the DAHS based on quarterly fuel analysis reports, as required by Permit Condition 22.2.

SO₂ from fuel oil is calculated from oil flow rate, mass of oil, and %sulfur content of the fuel (from fuel analysis). Analytical content and related required constants can be entered and adjusted in the DAHS as needed.

CO₂ is calculated using the heat input and the dry carbon fuel factors (F factors) for natural gas and oil. The factors can be adjusted in the DAHS.

2.3.3 Fuel Sampling

Fuel sampling for SO₂ and GCV content for natural gas will be done in accordance with methods outlined by Permit Condition 22.2 and 40 CFR 75 Appendix D section 2.3 and Table D-5.

Oil fuel sampling for SO₂ and GCV content will be performed in accordance with Permit Condition 22.2 and 40 CFR 75 Appendix D section 2.2 and Table D-4.

3 NO_x Analyzer Range and MER Determination

The maximum NO_x expected concentration (MEC) value and maximum NO_x potential concentration (MPC) value were chosen based on manufacturer's guarantee levels and on air permit limits (cross reference specification from 40 CFR 75 §75.53(e)(2)(i)).

MPC = 100 ppm NO_x (manufacturer's expected concentrations)

MEC = 6 ppm NO_x (from facility's permit limit, oil-fueled based)

Low range: MEC x (1.0 up to 1.25), rounded up to nearest 10 = 10 ppm

High range: MPC x (1.0 up to 1.25), rounded up to nearest 10 = 100 ppm

In addition, a NO_x maximum emission rate (MER) was calculated per the following equation. The MER is used as a maximum cap value for missing data substitution.

$$E = K \times Cd \times Fd \times (20.9 / (20.9 - \%O_2d)) = 1.144 \text{ lb/mmBtu}$$

E = Pollutant emissions, lb/mmBtu

K = 1.194×10^{-7} (lb/dscf)/ppm NO_x

Cd = Hourly average NO_x concentration, ppm dry. The NO_x MPC value of 100 ppm was utilized as the Cd value in the equation

%O₂ = Oxygen concentration, % volume. The allowed default of 19% O₂ for turbines was utilized in the equation.

Fd = Fuel-based factor representing a ratio of the volume of dry flue gases generated to the caloric value of the fuel combusted. A default factor of 8710 for natural gas (as the primary fuel source) was utilized in the equation.

4 F-Factor Determination

An F factor for dual fuels (oil and natural gas) is determined using EPA Part 75, Appendix F, Equation F-8 (cross reference specification from 40 CFR 75 §75.53(e)(2)(i)).

$$Fd = (X_{oil} * 9190) + (X_{gas} * 8710)$$

Fd = Fuel factor from oil and gas
 9190 = Fc factor for oil, O₂ basis, dscf/10⁶ Btu
 8710 = Fc factor for natural gas, O₂ basis, dscf/10⁶ Btu
 X = Fraction of total heat input derived from each fuel type (oil and gas)

$$X, \text{ natural gas} = (HHV_{gas} * \text{natural gas flow}) / \text{Total heat input}$$

$$X, \text{ oil} = (HHV_{oil} * \text{oil fuel flow}) / \text{Total heat input}$$

HHV = Higher heating value, natural gas or oil, Btu/scf

Natural gas fuel flow, kscfh

Oil fuel flow, lb/hr

Total heat input is derived from EPA Part 75, Appendix D, Equation D-15A.

5 Certification Summary

Certification testing of the CEMS will be done in accordance with 40 CFR 75, Appendix A and 40 CFR 60, Appendix B Performance Specifications as required by the applicable regulations and air permit requirements (cross reference specification from 40 CFR 75 §75.53(e)(2)(i)). The source tester contracted to perform the Relative Accuracy Test Audit will provide a RATA test protocol under separate cover for Agency review.

A hard copy of all test results will be made available and forwarded to the EPA Regional Office and State Agency after completion of all testing.

The DAHS formulae listed in the Monitoring Plan record fields will be testing during or immediately after completion of the primary certification program. The DAHS uses standardized missing data substitution procedure. A statement from the DAHS supplier certifying that the missing data substitution routines meets Part 75 specifications will be provided with the certification report.

After certification, facility technicians will maintain and operate the CEMS in accordance with the Quality Control/Quality Assurance procedures outlined in the CEMS Quality Assurance Plan (QAP) developed for the CEMS components.

The final certification report will contain a summary of all test results, description of the tests performed, and supporting documentation including:

- DAHS report printouts
- Spreadsheet calculation cross-checks
- Calibration gas certificates
- Technician's field notes, as applicable

The certification report will also include copies of the DAHS Verification printouts and fuel flowmeter accuracy test results.

A QA_Cert EDR will be prepared shortly after finalization of the certification report for submittal to the EPA's ECMPS/Client Tool host server.

5.1 7-Day Calibration Error Test – Part 75

An on-site calibration error test (7-day drift test) will be performed for each O₂ and NO_x monitoring system in accordance with 40 CFR 75, Appendix A, Section 6.3. The tests are performed while the unit was combusting fuel at stabilized stack temperature and pressure conditions.

The calibration error test consists of measuring the calibration error of each monitor scale once each day for seven (7) consecutive unit operating (process on line) days. The calibration error tests are conducted at two EPA Traceability Protocol calibration gas concentrations: zero-level (0-20%) and high-level (80-100%) as specified in 40 CFR 75, Appendix A, Section 6.3.1. Alternately, a mid-level calibration gas (50-60% of span) may be used in place of the high-level gas as the mid-level gas is more representative of actual stack gas concentrations.

During calibration, the system controller flows calibration gases to the probe. The analyzers are challenged once with each of the two calibration gases. Each gas flows for approximately 10 minutes. The monitor response is recorded by the DAHS.

Any required routine manual adjustments to the monitor settings are not made until after taking measurements at both zero and high concentration levels for that day (reference Part 75, Appendix A, section 6.3.1). A failed calibration or taking an analyzer out-of-service during the drift period will result in a re-start of the drift period once the analyzer is placed back into service.

The DAHS compares the actual analyzer reading with the expected value of the calibration gas. The calibration error for the NO_x monitor is computed by the DAHS from the test results for each concentration level as follows:

Daily Drift for Pollutants 40 CFR 75, Appendix A Equation A-5	
$CE = \frac{ R - A }{S} \times 100$	<p>CE = Calibration error as a percentage of instrument span</p> <p>R = Zero or high-level calibration gas value in ppm</p> <p>A = Actual monitor response to calibration gas in ppm</p> <p>S = Span of the instrument</p>

The calibration error for diluent (O₂) monitors is computed by the DAHS from the test results for each concentration level as follows:

Daily Drift for Diluents 40 CFR 75, Appendix A, Equation A-5	
$CE = R - A $	<p>CE = Calibration error as a percentage of O₂</p> <p>R = Zero or high-level calibration gas value in percent (%).</p> <p>A = Actual monitor response to calibration gas in percent (%)</p>

In accordance with 40 CFR 75, Appendix A, Section 3.1, results of the 7-day calibration error test is acceptable if the daily calibration error does not exceed: 2.5% for NO_x and 0.5% for O₂. Alternatively, if the pollutant monitor's span value is equal to or less than 200 ppm, then calibration error shall not exceed 5.0 ppm difference.

5.2 7-Day Calibration Drift Test – Part 60

Calibrations are performed on each CO analyzer automatically at approximately 24-hour intervals by the DAHS for seven consecutive unit operating (process on-line) days. The calibration drift tests are conducted at two calibration gas concentrations: zero-level (0-20%) and high-level (50-100%) as specified in 40 CFR 60 Appendix B Performance Specifications. The low and high span (zero and span gas) readings for each analyzer are taken from the DAHS at the completion of the calibration routine. (40 CFR 60, Appendix B, PS-2, Section 4.1).

The 24-hour calibration drifts are calculated and reported by the following method (40 CFR 60, Appendix B, PS-2). For pollutant analyzers, the raw zero reading is subtracted from the zero gas bottle value, the difference is then divided by the analyzer's span and the resultant value is multiplied by 100 to give the percent calibration drift. The preceding procedure is repeated with the span gas to give the span drift.

Daily Drift for CO 40 CFR 60, Appendix B, PS-2 and PS-4	
$CD = \frac{R - A}{S} \times 100$	<p>CD = Calibration error as a percentage of instrument span</p> <p>R = Zero or high level calibration gas value in ppm</p> <p>A = Actual monitor response to calibration gas in ppm</p> <p>S = Span of the instrument</p>

The 24-hour calibration drift must not exceed ±5% for CO (6 out of 7 days).

5.3 Linearity Error Check – Part 75

An on-site linearity check test will be conducted in accordance with the 40 CFR 75, Appendix A, for each O₂ and NO_x monitoring system. The test is performed while the unit is combusting primary fuel at stabilized stack temperature and pressure conditions. The test is performed on both ranges of dual-ranged analyzers. If a NO_x analyzer range is ≤30 ppm that range is exempt from the linearity requirement.

EPA Protocol certified calibration gases are used to conduct the linearity checks of the analyzers. Three points (concentrations) of calibration gases, low (20-30%), mid (50-60%) and high (80-100%) are introduced at the probe (40 CFR 75, Appendix A, Section 5.2). Each monitor is challenged three times with the appropriate reference gas, without using the same gas twice in succession. The monitors’ response for each concentration is recorded by the DAHS. The average of the three responses is used to calculate the linearity error (40 CFR 75, Appendix A, Section 6.2). A copy of the DAHS linearity report will be included in the certification report.

Linearity error is calculated using the following equation.

Linearity Error Equation A-4, 40 CFR 75, Appendix A	
$LE = \frac{ R - A }{R} \times 100$	<p>LE = Percent Linearity Error</p> <p>R = Calibration gas reference value</p> <p>A = Average of monitor response</p>

Linearity Check: Alternate Criteria 40 CFR 75, Appendix A, Section 3	
$LE = R - A $	LE = Percent linearity error R = Calibration gas reference value A = Average of monitor response

Linearity checks are acceptable for monitor certification if none of the test results exceed the applicable performance specification of 40 CFR 75, Appendix A, Section 3.2. The results of the NO_x and O₂ shall be less than 5.0% as calculated by the above equation or the alternative criteria of ≤0.5% O₂ or ≤5 ppm difference for NO_x.

5.4 Cycle/Response Time Check – Part 75

The cycle time test measures the monitor's reaction time to a change in gas concentration (40 CFR 75, Appendix A, Section 6.4). The system measures stack concentrations until a stable response is observed (normal sampling mode). The stable stack response value is recorded. A low-level (zero) calibration gas will be injected at the probe sample interface. Gas injection at the probe continues until a stable monitor response is reached. Next the monitor is switched back to monitor stack gas until a stable reading is achieved and the time recorded. A span-level (80-100% of span) calibration gas is then injected at the probe until a stable response is reached. The amount of time required for the system to respond to 95% of the final stable calibration gas response value is noted from the DAHS 1-minute data report. The time is recorded for the upscale test and the downscale test for each analyzer. The response time for NO_x and O₂ will be ≤15 minutes.

The test is performed on both ranges of dual-ranged analyzers.

5.5 CO Response Time Check – Part 60

An on-site response time test for the CO monitoring system is performed in accordance with Performance Specification 4A, section 8.3. The response time test measures the monitor's reaction time to a change in gas concentration.

The daily zero and span calibration gases are utilized for response time testing. A zero-level calibration gas is direct injected into the analyzer. Gas injection continues until a stable monitor response is reached. A high span gas is then introduced to the analyzer until a stable value is observed. The upscale response time required is the amount of time to reach 95% of the final stable end value. The zero gas is re-introduced to the analyzer until a stable reading is reached. The downscale response time required is the amount of time to reach 95% of the final stable end value.

The response times for 3 repetitions of upscale and downscale runs are recorded. An average of the 3 upscale and 3 downscale runs is determined. The response time of the longer (slower) of the two means must be ≤1.5 minutes.

The DAHS cannot generate reports for less than 1-minute averages making it difficult to “find” the step change point for a 90 second pass/fail criteria. The technician performing the test will use a stopwatch type device and will note monitor response values in 10-second intervals for each test run. Monitor values are taken directly from the monitor display panel.

5.6 Relative Accuracy Test Audit

A Relative Accuracy Test Audit (RATA) will be performed on-site for each O₂ and NO_x monitoring system in accordance with 40 CFR 75, Appendix A, Section 6.5. A full RATA test protocol, written by the source tester contracted to perform the test, will be provided as a separate document.

Appendix A Monitoring Plan Records

The attached file of monitoring plan records was configured and downloaded from the EPA's ECMPs/Client Tool software program.

Coding note on the gas fuel flowmeters:

GAS component ID represents the turbine natural gas fuel flowmeter

GAB component ID represents the natural gas duct burner fuel flowmeter



ECMPS Client Tool

Version 1.0 2016 Q4

Monitoring Plan Printout Report

January 24, 2017 01:34 PM

Facility Name: CPV Valley Energy Center

Facility Details

Facility ID (ORISPL): 56940
 Monitoring Plan Location IDs: 0001
 State: NY
 County: Orange
 Latitude: 41.4130
 Longitude: 74.4350

Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
0001	Q - Quarterly	2017 QTR 3	

Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Cross Area Exit	Cross Area Flow	Material Code	Shape Code	Begin Date	End Date
0001		464	275	284		OTHER	ROUND	08/18/2017	

Unit Operation Information

Unit Identifier	Non-Load Based Ind	Commence Commercial Operation Date	Commence Operation Date	Boiler/Turbine Type			Max Heat Input		
				Code	Begin Date	End Date	Value (mmBtu)	Begin Date	End Date
0001	0	01/01/2018	01/01/2018	CC	01/01/2018		2734.0	01/01/2018	

Unit Type Codes: CC - Combined cycle

Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
0001	ARP	P2	01/01/2018	
	CSNOX	A	01/01/2018	
	CSNOXOS	A	01/01/2018	
	CSOSG2	A	01/01/2018	
	CSSO2G1	A	01/01/2018	

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:34 PM

Unit Fuel

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
0001	DSL	S				01/01/2018	
	NNG	P				01/01/2018	

Fuel Type Codes: NNG - Natural Gas
DSL - Diesel Oil

Fuel Indicator Codes: S - Secondary
P - Primary

Unit Controls

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
0001	NOX	SCR	Y				

Control Equipment Descriptions: SCR - Selective Catalytic Reduction

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
0001	CO2	AD	SPTS		08/18/2017 00	
	HI	AD	SPTS		08/18/2017 00	
	NOXR	CEM	SPTS		08/18/2017 00	
	OP	EXP			08/18/2017 00	
	SO2	AD	SPTS		08/18/2017 00	

Parameter Codes: SO2 - SO2 Hourly Mass Rate (lb/hr)
OP - Opacity
NOXR - NOx Emission Rate (lb/mmBtu)
HI - Heat Input Rate (mmBtu/hr)
CO2 - CO2 Hourly Mass Rate (ton/hr)

Methodology Codes: EXP - Exempt
CEM - Continuous Emission Monitor
AD - Appendix D

Substitute Data Codes: SPTS - Standard Part 75 for Missing Data

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:34 PM

Monitoring System / Analytical Components

Unit/Stack /Pipe Identifier	System					Component									
	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	BAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour	Hg Converter Indicator
0001	GAS	GAS	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIE S	CEMLINK6		08/18/2017 00		
						GAB	GFFM	ORF		FLUIDIC TECHNOLOGIE S	FAB3110	FAB3110-1A	08/18/2017 00		
						GAS	GFFM	ORF		GTE	3044SS PADDLE	3033514	08/18/2017 00		
	NOX	NOX	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIE S	CEMLINK6		08/18/2017 00		
						NOX	NOX	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						O2D	O2	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						PRB	PRB	EXT		UNIVERSAL	270SF	TBD	08/18/2017 00		
	OIL	OILM	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIE S	CEMLINK6		08/18/2017 00		
						OIL	OFFM	TUR		FTI	FT-40C4U3-LEA-3	160405M51314	08/18/2017 00		

System Types Descriptions:

GAS - Gas Fuel Flow
 NOX - NOx Emission Rate
 OILM - Mass of Oil Fuel Flow

System Designations Descriptions:

P - Primary

Sample Acquisition Method (SAM):

TUR - Turbine
 ORF - Orifice
 EXT - Dry Extractive

Component Types Descriptions:

DAHS - Data Acquisition and Handling System
 GFFM - Gas Fuel Flowmeter
 NOX - NOx Concentration
 O2 - O2 Concentration
 PRB - Probe
 OFFM - Oil Fuel Flowmeter

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:34 PM

Monitoring System Fuel Flow

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
0001	GAS	NNG	28000.0	HSCF	URV	08/18/2017 00	
	OIL	DSL	120000.0	LBHR	URV	08/18/2017 00	

System Fuel Codes Descriptions: NNG - Natural Gas
DSL - Diesel Oil

Units of Measure Descriptions: LBHR - Pounds / Hour
HSCF - Hundred Standard Cubic Feet / Hour

Source Codes Descriptions: URV - Upper Range Value

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dual Range Indicator	Begin Date/Hour	End Date/Hour
0001	NOX	NOX	Auto Ranging	Y	08/18/2017 00	
	O2	O2D	High Range		08/18/2017 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Emissions Formulas

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
0001	NOXR	100	F-5	$NOx_lb/mmBtu = S\#(NOX-NOX) * (1.194 * 10^{**7}) * F\#(107) * (20.9 / (20.9 - S\#(O2D-NOX)))$	08/18/2017 00	
	HI	101	F-20	$HI_gas = (F\#(112) * GCV_gas) / 10^{**6}$	08/18/2017 00	
	SO2	102	D-5	$M_SO2_gas = F\#(111) * F\#(101)$	08/18/2017 00	
	CO2	103	G-4	$W_CO2_gas = (1040 * F\#(101) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	HI	104	D-8	$HI_oil = S\#(OIL-OIL)_oilrate * (GCV_oil / 10^{**6})$	08/18/2017 00	
	SO2	105	D-2	$M_SO2_oil = 2.0 * S\#(OIL-OIL)_oilrate * (\%S_oil / 100)$	08/18/2017 00	
	CO2	106	G-4	$W_CO2_oil = (1420 * F\#(104) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	FD	107	F-8	$Fd = (X_oil * 9190) + (X_gas * 8710)$	08/18/2017 00	
	HI	108	D-15A	$HI_total = (F\#(101) * T_gas + F\#(104) * T_oil) / T_unit$	08/18/2017 00	
	CO2	109	G-4A	$CO2_total = (F\#(103) * T_gas + F\#(106) * T_oil) / T_unit$	08/18/2017 00	
	SO2	110	D-12	$SO2_total = (F\#(102) * T_gas + F\#(105) * T_oil) / T_unit$	08/18/2017 00	
	SO2R	111	D-1H	$ER_SO2_gas = (2.0 / 7000) * (10^{**6}) * S_NNG/GCV_NNG$	08/18/2017 00	
FGAS	112	N-GAS	$N_gas = S\#(GAS-GAS) + S\#(GAB-GAS)$	08/18/2017 00		

- Parameter Codes Descriptions:**
- NOXR - NOx Emission Rate (lb/mmBtu)
 - HI - Heat Input Rate (mmBtu/hr)
 - SO2 - SO2 Hourly Mass Rate (lb/hr)
 - CO2 - CO2 Hourly Mass Rate (ton/hr)
 - FD - F-Factor Dry-basis
 - SO2R - SO2 Hourly Emission Rate (lb/mmBtu)
 - FGAS - Gas Hourly Flow Rate (hscf)
- Formula Codes Descriptions:**
- N-GAS - FGAS (net gas flow rate)
 - G-4A - CO2 (from CO2 rate for multiple fuels)
 - G-4 - CO2 (from HI, Fc)
 - F-8 - FD/FC/FW (from multiple fuels)
 - F-5 - NOXR/SO2R (from NOX or SO2 dry, O2 dry, Fd)
 - F-20 - HI (same as D-6)
 - D-8 - HI (from oil flow rate, GCV)
 - D-5 - SO2 (from gas SO2 emission rate, HI)
 - D-2 - SO2 (from OILM, oil sulfur content)
 - D-1H - SO2R (from gas sulfur content, GCV)
 - D-15A - HI (from HI rate for multiple fuels)
 - D-12 - SO2 (from SO2 rate for multiple fuels)

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:34 PM

Span Values

Unit/Stack/Pipe Identifier	Comp Type	Scale	Method	MPC/MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)	Flow Span Value (SCFH)	Begin Date/Hour	End Date/Hour
0001	NOX	H	ME	100.0	6.0	100.000	100.000	PPM	9.5				08/18/2017 00	
	NOX	L	PL		6.0	10.000	10.000	PPM	9.5				08/18/2017 00	
	O2	H				25.000	25.000	PCT					08/18/2017 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Span Method Codes Descriptions: PL - Permit Limit for NOX MEC
ME - Manufacturer's Estimate for NOX MPC

Units of Measure Descriptions: PPM - Parts per Million
PCT - Percentage

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
0001	400	MW	400	100	High	Mid	Yes	12/31/2017	12/31/2017 00	

Units of Measure Descriptions: MW - Megawatt

Monitoring Defaults

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
0001	NORX	1.1440	LBMMBTU	MD	NFS	A	DEF	08/18/2017 00	
	O2X	19.0000	PCT	DC	NFS	A	DEF	08/18/2017 00	

Parameter Codes Descriptions: O2X - Maximum O2 Concentration (pct)
NORX - Maximum NOx Emission Rate (lb/mmBtu)

Units of Measure Descriptions: PCT - Percentage
LBMMBTU - Pounds / mmBtu

Purpose Codes Descriptions: MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default
DC - Diluent Cap

Fuel Type Codes Descriptions: NFS - Non-Fuel Specific

Operating Conditions Descriptions: A - Any Hour

Source Codes Descriptions: DEF - Default Value from Part 75

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:34 PM



ECMPS Client Tool

Version 1.0 2016 Q4

Monitoring Plan Printout Report

January 24, 2017 01:35 PM

Facility Name: CPV Valley Energy Center

Facility Details

Facility ID (ORISPL): 56940
 Monitoring Plan Location IDs: 0002
 State: NY
 County: Orange
 Latitude: 41.4130
 Longitude: 74.4350

Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
0002	Q - Quarterly	2017 QTR 3	

Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Cross Area Exit	Cross Area Flow	Material Code	Shape Code	Begin Date	End Date
0002		464	275	284		OTHER	ROUND	08/18/2017	

Unit Operation Information

Unit Identifier	Non-Load Based Ind	Commence Commercial Operation Date	Commence Operation Date	Boiler/Turbine Type			Max Heat Input		
				Code	Begin Date	End Date	Value (mmBtu)	Begin Date	End Date
0002	0	01/01/2018	01/01/2018	CC	01/01/2018		2734.0	01/01/2018	

Unit Type Codes: CC - Combined cycle

Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
0002	ARP	P2	01/01/2018	
	CSNOX	A	01/01/2018	
	CSNOXOS	A	01/01/2018	
	CSOSG2	A	01/01/2018	
	CSSO2G1	A	01/01/2018	

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:35 PM

Unit Fuel

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
0002	DSL	S				01/01/2018	
	NNG	P				01/01/2018	

Fuel Type Codes: NNG - Natural Gas
DSL - Diesel Oil

Fuel Indicator Codes: S - Secondary
P - Primary

Unit Controls

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
0002	NOX	SCR	Y				

Control Equipment Descriptions: SCR - Selective Catalytic Reduction

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
0002	CO2	AD	SPTS		08/18/2017 00	
	HI	AD	SPTS		08/18/2017 00	
	NOXR	CEM	SPTS		08/18/2017 00	
	OP	EXP			08/18/2017 00	
	SO2	AD	SPTS		08/18/2017 00	

Parameter Codes: SO2 - SO2 Hourly Mass Rate (lb/hr)
OP - Opacity
NOXR - NOx Emission Rate (lb/mmBtu)
HI - Heat Input Rate (mmBtu/hr)
CO2 - CO2 Hourly Mass Rate (ton/hr)

Methodology Codes: EXP - Exempt
CEM - Continuous Emission Monitor
AD - Appendix D

Substitute Data Codes: SPTS - Standard Part 75 for Missing Data

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:35 PM

Monitoring System / Analytical Components

Unit/Stack /Pipe Identifier	System					Component									
	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	BAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour	Hg Converter Indicator
0002	GAS	GAS	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIE S	CEMLINK6		08/18/2017 00		
						GAB	GFFM	ORF		FLUIDIC TECHNOLOGIE S	FAB3110	FAB3110-1B	08/18/2017 00		
						GAS	GFFM	ORF		GTE	3044SS PADDLE	3033515	08/18/2017 00		
	NOX	NOX	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIE S	CEMLINK6		08/18/2017 00		
						NOX	NOX	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						O2D	O2	EXT	D	TAPI	T200M	TBD	08/18/2017 00		
						PRB	PRB	EXT		UNIVERSAL	270SF	TBD	08/18/2017 00		
	OIL	OILM	P	08/18/2017 00		DAS	DAHS			VIM TECHNOLOGIE S	CEMLINK6		08/18/2017 00		
						OIL	OFFM	TUR		FTI	FT-40C4U3-LEA-3	160405M51315	08/18/2017 00		

System Types Descriptions:

GAS - Gas Fuel Flow
 NOX - NOx Emission Rate
 OILM - Mass of Oil Fuel Flow

System Designations Descriptions:

P - Primary

Sample Acquisition Method (SAM):

TUR - Turbine
 ORF - Orifice
 EXT - Dry Extractive

Component Types Descriptions:

DAHS - Data Acquisition and Handling System
 GFFM - Gas Fuel Flowmeter
 NOX - NOx Concentration
 O2 - O2 Concentration
 PRB - Probe
 OFFM - Oil Fuel Flowmeter

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:35 PM

Monitoring System Fuel Flow

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
0002	GAS	NNG	28000.0	HSCF	URV	08/18/2017 00	
	OIL	DSL	120000.0	LBHR	URV	08/18/2017 00	

System Fuel Codes Descriptions: NNG - Natural Gas
DSL - Diesel Oil

Units of Measure Descriptions: LBHR - Pounds / Hour
HSCF - Hundred Standard Cubic Feet / Hour

Source Codes Descriptions: URV - Upper Range Value

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dual Range Indicator	Begin Date/Hour	End Date/Hour
0002	NOX	NOX	Auto Ranging	Y	08/18/2017 00	
	O2	O2D	High Range		08/18/2017 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:35 PM

Emissions Formulas

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
0002	NOXR	100	F-5	$NOx_lb/mmBtu = S\#(NOX-NOX) * (1.194 * 10^{**7}) * F\#(107) * (20.9 / (20.9 - S\#(O2D-NOX)))$	08/18/2017 00	
	HI	101	F-20	$HI_gas = (F\#(112) * GCV_gas) / 10^{**6}$	08/18/2017 00	
	SO2	102	D-5	$M_SO2_gas = F\#(111) * F\#(101)$	08/18/2017 00	
	CO2	103	G-4	$W_CO2_gas = (1040 * F\#(101) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	HI	104	D-8	$HI_oil = S\#(OIL-OIL)_oilrate * (GCV_oil) / 10^{**6}$	08/18/2017 00	
	SO2	105	D-2	$M_SO2_oil = 2.0 * S\#(OIL-OIL)_oilrate * (\%S_oil) / 100$	08/18/2017 00	
	CO2	106	G-4	$W_CO2_oil = (1420 * F\#(104) * 1/385 * 44.0) / 2000$	08/18/2017 00	
	FD	107	F-8	$Fd = (X_oil * 9190) + (X_gas * 8710)$	08/18/2017 00	
	HI	108	D-15A	$HI_total = F\#(101) * T_gas + F\#(104) * T_oil / T_unit$	08/18/2017 00	
	CO2	109	G-4A	$CO2_total = (F\#(103) * T_gas + F\#(106) * T_oil) / T_unit$	08/18/2017 00	
	SO2	110	D-12	$SO2_total = (\#(102) * T_gas + F\#(105) * T_oil) / T_unit$	08/18/2017 00	
	SO2R	111	D-1H	$ER_SO2_gas = (2.0 / 7000) * (10^{**6}) * S_NNG/GCV_NNG$	08/18/2017 00	
FGAS	112	N-GAS	$N_gas = S\#(GAS-GAS) + S\#(GAB-GAS)$	08/18/2017 00		

- Parameter Codes Descriptions:**
- NOXR - NOx Emission Rate (lb/mmBtu)
 - HI - Heat Input Rate (mmBtu/hr)
 - SO2 - SO2 Hourly Mass Rate (lb/hr)
 - CO2 - CO2 Hourly Mass Rate (ton/hr)
 - FD - F-Factor Dry-basis
 - SO2R - SO2 Hourly Emission Rate (lb/mmBtu)
 - FGAS - Gas Hourly Flow Rate (hscf)
- Formula Codes Descriptions:**
- N-GAS - FGAS (net gas flow rate)
 - G-4A - CO2 (from CO2 rate for multiple fuels)
 - G-4 - CO2 (from HI, Fc)
 - F-8 - FD/FC/FW (from multiple fuels)
 - F-5 - NOXR/SO2R (from NOX or SO2 dry, O2 dry, Fd)
 - F-20 - HI (same as D-6)
 - D-8 - HI (from oil flow rate, GCV)
 - D-5 - SO2 (from gas SO2 emission rate, HI)
 - D-2 - SO2 (from OILM, oil sulfur content)
 - D-1H - SO2R (from gas sulfur content, GCV)
 - D-15A - HI (from HI rate for multiple fuels)
 - D-12 - SO2 (from SO2 rate for multiple fuels)

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:35 PM

Span Values

Unit/Stack/Pipe Identifier	Comp Type	Scale	Method	MPC/MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)	Flow Span Value (SCFH)	Begin Date/Hour	End Date/Hour
0002	NOX	H	ME	100.0	6.0	100.000	100.000	PPM	9.5				08/18/2017 00	
	NOX	L	PL		6.0	10.000	10.000	PPM	9.5				08/18/2017 00	
	O2	H				25.000	26.000	PCT					08/18/2017 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Span Method Codes Descriptions: PL - Permit Limit for NOX MEC
ME - Manufacturer's Estimate for NOX MPC

Units of Measure Descriptions: PPM - Parts per Million
PCT - Percentage

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
0002	400	MW	400	100	High	Mid	Yes	12/31/2017	12/31/2017 00	

Units of Measure Descriptions: MW - Megawatt

Monitoring Defaults

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
0002	NORX	1.1440	LBMMBTU	MD	NFS	A	DEF	08/18/2017 00	
	O2X	19.0000	PCT	DC	NFS	A	DEF	08/18/2017 00	

Parameter Codes Descriptions: O2X - Maximum O2 Concentration (pct)
NORX - Maximum NOx Emission Rate (lb/mmBtu)

Units of Measure Descriptions: PCT - Percentage
LBMMBTU - Pounds / mmBtu

Purpose Codes Descriptions: MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default
DC - Diluent Cap

Fuel Type Codes Descriptions: NFS - Non-Fuel Specific

Operating Conditions Descriptions: A - Any Hour

Source Codes Descriptions: DEF - Default Value from Part 75

Facility Name: CPV Valley Energy Center

Facility ID (ORISPL): 56940

Monitoring Plan Printout Report

January 24, 2017 01:35 PM

Appendix B CEMS Drawings

The following CEMS Engineering drawings are attached.

Sample system flow diagram(s)
Drawing number 50478A02


The sample system flow diagram(s) illustrates major CEMS components in the gas sample flow path (cross reference 40 CFR 75 §75.53(e)(2)(iv)).

System block diagram (data flow)
Drawing number 50478A07

The system block diagram is an overview on CEMS sampling pathways and data pathways (cross reference 40 CFR 75 §75.53(e)(2)(iii)).

Major components are identified on the sample system flow diagram(s) by tag names. The following is an identification key for the tags.

AMx	Instrument air manifold
ASx	Ammonia scrubber
BPRx	Back pressure regulator
CGMx	Calibration gas manifold
DMAx	Drain manifold
DPx	Peristaltic drain pump
FRx	Filter regulator
FSx	Flow switch
Fx	Sample system particulate filter
GCx	Sample gas cooler
HVx	Hand valves
MSx	Moisture sensor
PGx	Pressure gauge
PSx	Pressure switch/pressure transducer
REGx	Calibration gas regulator
RMx	Rotameter (flow meters)
SPx	Sample pump
SVx	Solenoid valves
TVx	Trim valve
VGx	Vacuum gauge



TYPICAL FOR UNITS 1 & 2

1. ALL TUBING SHALL BE 1/4" O.D. TEFLON.
NOTES: UNLESS OTHERWISE SPECIFIED.

HEATED LINE - - - - -
INSTRUMENT AIR - - - - -

CEMTEK Environmental, Inc.
3041 S. Orange Ave., Santa Ana, CA. 92707
Phone: 714-437-7100. CEMS Parts: 888-400-0200

BOTH THIS DRAWING AND THE INFORMATION IN IT ARE PROPRIETARY, ARE THE PROPERTY OF CEMTEK ENVIRONMENTAL, INC. AND MAY NOT BE USED FOR THE DESIGN, PRODUCTION, INSTALLATION OR OPERATION OF APPARATUS OR PROCESSES EXCEPT UNDER CONTRACT WITH IT.

CEMTEK ENVIRONMENTAL, INC.


NO.	REVISION	DATE	APPR. NO.	REVISION	DATE	APPR.
A	CUSTOMER COMMENTS	09/15/15	PT			
B	AS BUILT	12/13/16	PT			

ELECTRICAL SPECIFICATION			
INS	SIZE	LUGS	MISC
CONTROL WIRE	PVC 18 AWG MIN	NONE	-
SIGNAL WIRE	TEFLON 18 AWG MIN	NONE	-
POWER WIRE	THHN 14 AWG MIN	NONE	-

SIEMENS ENERGY
CPV VALLEY ENERGY CENTER
WAWAYANDA, NY
CONTINUOUS EMISSIONS MONITORING SYSTEM
P.O. NO. 4500715162
CEMTEK PROJECT NO. CN50478

STACK SAMPLE SYSTEM FLOW			
PROJECT:	SCALE:	SHT: 1 OF 1	
SIEMENS-CPV VALLEY	N/A		
DWN: M. SUSOEFF	DATE: 07/16/15		
CKD: P. TRAN	DATE: 07/16/15		
APP: D. OQUENDO	DATE: 07/16/15	50478A02	

Z:\CAD_Projects\50478 Siemens CPV Valley CEMS\50478A\2016-12-13 AS BUILT\50478A02-01.dwg PRINTED ON: 1/26/2017 9:24 AM BY MSUSOEFF



NOTES: UNLESS OTHERWISE SPECIFIED.

POWER LINE - - - - -
 INSTRUMENT AIR - - - - -
 HEAT TRACED - - - - -
 PIPING - - - - -
 ETHERNET CABLE - - - - -
 LOW VOLTAGE SIGNALS - - - - -
 FIBER OPTIC CABLE - - - - -

UNIT 1

CEMTEK
 Environmental, Inc.
 3041 S. Orange Ave., Santa Ana, CA. 92707
 Phone: 714-437-7100. CEMS Parts: 888-400-0200

BOTH THIS DRAWING AND THE INFORMATION IN IT ARE PROPRIETARY, ARE THE PROPERTY OF CEMTEK ENVIRONMENTAL, INC. AND MAY NOT BE USED FOR THE DESIGN, PRODUCTION, INSTALLATION OR OPERATION OF APPARATUS OR PROCESSES EXCEPT UNDER CONTRACT WITH IT.

CEMTEK ENVIRONMENTAL, INC.

NO.	REVISION	DATE	APPR.	NO.	REVISION	DATE	APPR.
A	CUSTOMER COMMENTS	09/15/15	PT				
B	CUSTOMER COMMENTS 3	09/14/16	PT				
C	AS BUILT	12/13/16	PT				

ELECTRICAL SPECIFICATION			
INS	SIZE	LUGS	MISC
CONTROL WIRE	PVC 18 AWG MIN	NONE	-
SIGNAL WIRE	TEFLON 18 AWG MIN	NONE	-
POWER WIRE	THHN 14 AWG MIN	NONE	-

SIEMENS ENERGY
 CPV VALLEY ENERGY CENTER
 WAWAYANDA, NY
 CONTINUOUS EMISSIONS MONITORING SYSTEM
 P.O. NO. 4500715162
 CEMTEK PROJECT NO. CN50478

PROJECT: SIEMENS-CPV VALLEY		SCALE: N/A SHT: 1 OF 2	
DWN:	M. SUSOEFF	DATE	07/16/15
CKD:	P. TRAN	DATE	07/16/15
APP:	D. OQUENDO	DATE	07/16/15

50478A07

Z:\CAD_Projects\50478 Siemens CPV Valley CEMS\50478A\2016-12-13 AS BUILT\50478A07-01.dwg PRINTED ON: 1/26/2017 9:25 AM BY MSUSOEFF

Appendix C Stack Drawings

Dimensioned stack drawings are attached depicting location of the CEMS probe and EPA test ports (cross reference 40 CFR 75 §75.53(e)(2)(ii) and (iv)).



Engineering Design Report

Stack Arrangement

Prepared For:

Project Name: Valley Energy Center Project

Location: Wawayanda, NY

CMI Customer: Siemens Energy, Inc., Orlando, FL


Customer Name: CPV Valley, LLC

This report is the property of CMI and is exclusively provided for use on this order. This report is not to be reproduced or shared with other parties without CMI written permission. This report shall be returned upon request. Use of data herein shall in no way alter or expand CMI liability under the contract.

		UNID No.:	<u>497460516</u>
Prepared By:	<u>K. Taylor</u>	Document No.:	<u>2068-001.01-SGA</u>
Reviewed By:	<u>K. Taylor</u>	Contract No.:	<u>2068</u>
Approved By:	<u>K. Taylor</u>	Revision No.:	<u>2</u>

DRAWING INDEX

Drawing File No.	Drawing Name	Drawing Revision
Q42-GA-01	Stack General Assembly	0
G42-GA-02	Stack Elevations and Sections	0
Q42-GA-03	Stack Sections and Details	1
Q42-GA-04	Stack Sections and Details	0
Q42-GA-05	Stack Sections	0



STACK GENERAL ASSEMBLY
(SCALE: N.T.S.)

NOTE:
STACK HAS BEEN DESIGNED
FOR 2" OF 8pcf INSULATION
UP TO EL. 100'-0"

NOTE:
PERSONNEL PROTECTION
NOT SHOWN FOR CLARITY

CODE	LOAD TABLE	
	WIND	SEISMIC
	ASCE 7-05 ASME-ST5	IBC
SPEED/CLASS	100 MPH	0.273-0.066/D
EXP/GROUP	C	III
IMPORTANCE	1.15	1.25
BASE SHEAR	185 KIPS	35 KIPS
BASE MOMENT		
	27,000 KIP-FT	6,000 KIP-FT
LIVE LOAD	140 KIPS	
APPROX. DEAD LOAD	615 KIPS	
PLAT/LADDERS	47 KIPS	

NOZZLE TABLE	
F _x	-3,983 LBF
F _y	-6,820 LBF
F _z	2,420 LBF
M _x	30,332 FT-LBF
M _y	-41,711 FT-LBF
M _z	-33,566 FT-LBF

CERTIFIED FOR CONSTRUCTION

THIS DRAWING FOR APPROVAL ONLY.
DETAILED CONSTRUCTION DRAWINGS TO
BE SUBMITTED AFTER APPROVAL OF
GENERAL ARRANGMENT

NO.	DATE	REVISION	BY	CHECKED	APPROVED BY	DATE
△	01/10/16	CERTIFIED FOR CONSTRUCTION	J.R.	C.R.		
△	01/04/16	GENERAL REVISION	CMY	J.R.		
△	07/23/15	ISSUED FOR REVIEW	CMY	J.R.		

- MATERIALS**
- ALL PLATES, BARS AND STRUCTURAL SHAPES SHALL CONFORM TO CHINESE CARBON STEEL Q235B UNLESS NOTED OTHERWISE.
 - PLATFORMS AND LADDERS TO BE CONSTRUCTED OF CHINESE CARBON STEEL Q235B.
 - ALL REINFORCING TO BE CHINESE CARBON STEEL Q235B.
 - NO METRIC BOLTS ARE PERMITTED. ALL BOLTS SHALL BE IMPERIAL SIZE AND ASTM A325 OR A490 U.N.O.
- TOLERANCES**
- STACK SHALL BE FABRICATED SUCH THAT IT CAN BE ERECTED PLUMB AT THE VERTICAL CENTERLINE TO WITHIN 1" [25] PER 50' [15240] OF STACK HEIGHT.
 - DIAMETER OUT-OF-ROUNDNESS SHALL BE LIMITED TO 1% OF THE STACK DIAMETER.
 - LOCAL DENTS IN THE PLATE WALL SHALL HAVE A DEPTH LESS THAN ONE HALF THE NOMINAL PLATE THICKNESS.
 - VERTICAL SEAMS SHALL BE STAGGERED 90° (20' MINIMUM).
 - PEAKING OF JOINTS AS MEASURED BY A TEMPLATE CUT TO THE PRESCRIBED RADIUS AND HAVING A MINIMUM CHORD LENGTH OF 18" [457] SHALL NOT EXCEED 1/4" [6].
 - TEST PORT FLANGES SHALL BE PERPENDICULAR TO THE CENTERLINE TO WITHIN 1/4" [12] AND LOCATED WITHIN 7/8" [12] OF LOCATION SHOWN.
 - MAXIMUM MISALIGNMENT OF PLATE SHALL NOT EXCEED 25% OF NOMINAL THICKNESS OR 1/8" [3], WHICHEVER IS LESS.

- FABRICATION**
- ALL WORK SHALL BE FABRICATED IN ACCORDANCE WITH THE AISC "SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS", 13TH EDITION.
 - ALL WELDING IS TO BE PERFORMED USING A.W.S. PROCEDURES (CODE D1.1). ALL WELDING SHALL BE BY A.W.S. CERTIFIED WELDERS USING E-70XX ELECTRODES. ALL FULL PENETRATION WELDS ARE TO BE INSPECTED PER ASME STS-1 2011, PART 8.4.1 (C). WELD INSPECTION SHALL BE RADIOGRAPHY.
 - ALL WELDING SHALL BE PERFORMED IN ACCORDANCE WITH WRITTEN WELDING PROCEDURE SPECIFICATIONS. EXCEPT AS OTHERWISE SPECIFIED, WELDING SHALL BE PERFORMED USING ONLY THOSE JOINT DETAILS AND WELDING PROCEDURES WHICH ARE QUALIFIED OR PRE-QUALIFIED IN ACCORDANCE WITH REFERENCED AWS OR ASME.
 - ALL BUTT WELDS SHALL BE PRE-QUALIFIED, FULL PENETRATION WELDS AND SHALL DEVELOP THE PENETRATION BUTT GROOVE WELDS.
 - ALL EXTERIOR WELDS SHALL BE SEAL WELDS.
 - ALL WELDING ELECTRODES AND FLUX SHALL CONFORM TO THE AWS CODE AND BE EQUIVALENT TO THE BASE METAL IN STRENGTH.
 - DEFECTIVE AREAS SHALL BE REPAIRED IN SUCH A MANNER AS NOT TO GOUGE, GROOVE OR REDUCE THE BASE METAL THICKNESS.
 - ALL EXTERNAL WELDS SHALL BE CONTINUOUS, STITCH WELDING IS NOT PERMITTED.
 - REMOVE ALL WELD RUN-OUT TABS.
 - HANDRAILS ARE TO BE TWO RAIL DESIGN.

- MATERIAL CERTIFICATIONS**
- MATERIAL TEST REPORTS FOR ALL MATERIAL UTILIZED ARE TO BE REQUESTED WHEN MATERIAL IS ORDERED. TEST REPORTS SHALL BE SUBMITTED TO IES, INC. UPON RECEIPT.
 - MSDS SHEETS FOR ALL TOUCH-UP PAINTS, THINNERS AND ANY OTHER HAZARDOUS MATERIAL IS TO BE INCLUDED WITH THE SHIPMENT OF THE ITEMS.

- PERSONNEL PROTECTION**
- PERSONNEL PROTECTION TO BE SHIPPED LOOSE FOR FIELD INSTALLATION.
 - PERSONNEL PROTECTION TO BE FABRICATED FROM 1/2" - 16 GALVANIZED FLATTENED EXPANDED METAL.
 - PERSONNEL PROTECTION SHALL HAVE ITS EDGES BANDED IN THE SHOP TO CREATE A SMOOTH EDGE.
 - CONNECTION CLIPS TO BE GALVANIZED Q235B CARBON STEEL.
 - PERSONNEL PROTECTION TO BE PROVIDED AT EACH PLATFORM, LADDER AND FROM GRADE UP TO 8'-0" [2.5m] HEIGHT. LADDER LOCATION TO PROVIDE 7/8" [200] MIN. TOE CLEARANCE FROM PERSONNEL PROTECTION.
 - TWO RAIL HANDRAIL DESIGN PER OSHA 29 CFR 1910 & CMI STD. DWG. #007.

- SURFACE PREPARATION**
- ALL SHARP PROJECTIONS SHALL BE GROUND SMOOTH.
 - ALL WELD FLUX AND SPATTER SHALL BE REMOVED BY POWER TOOL CLEANING.
 - PROTECT FLANGED AND THREADED CONNECTIONS WITH WOODEN OR PLASTIC COVERS FOR SANDBLAST, PAINTING AND SHIPMENT.
 - SANDBLAST PER SSPC-SP-10 EXTERNALLY AND INTERNALLY.
 - PLATFORMS & LADDERS TO BE HOT-DIPPED GALVANIZED PER ASTM A-123.
 - ALL FIELD WELD JOINTS SHALL HAVE INTERNAL AND EXTERNAL COATINGS HALTED 4" [100] FROM WELD JOINT, COATED WITH A WELDABLE PRIMER SUCH AS CAROWELD 11WB AND COVERED WITH A NO RESIDUE STRONG ADHESIVE TAPE. THE TAPE SHALL REMAIN ON FOR SHIPPING.
 - CORROSION ALLOWANCE = 0.0625" [1.6].
 - ALL NUTS, BOLTS, WASHERS, STUDS AND FASTENERS TO BE MECHANICALLY GALVANIZED. SUPPLIER SHALL PROVIDE 10% EXTRA SHIPPED LOOSE TO THE FIELD.

- COATING**
- EXTERNAL COATING: PREP SSPC-SP-10/NACE NO. 2 - NEAR WHITE BLAST CLEANING.
 - EXTERNAL SURFACES (WITH INSULATION) SHOP APPLY PRIMER: P1-INORGANIC ZINC ETHYL SILICATE OR P3-WELDABLE INORGANIC ZINC SILICATE PER SIEMENS APPENDIX 13; COATINGS: 20% EXTRA COATING BY SUPPLIER (SHIPPED LOOSE).
 - INTERNAL COATING: PREP SSPC-SP-10/NACE NO. 2 - NEAR WHITE BLAST CLEANING.
 - INTERNAL SURFACES SHOP APPLY PRIMER: P1-INORGANIC ZINC ETHYL SILICATE, AMERON-DIMECOTEE (HS), INTERNATIONAL-INTERZING 22 (HS), SHERWIN WILLIAMS-ZINC CLAD II (HS), CARBOLINE-CARBOZINC 11 (HS OR VOC) PER SIEMENS APPENDIX 13; COATINGS: 20% EXTRA COATING BY SUPPLIER (SHIPPED LOOSE).
 - PLATFORMS, LADDERS, HANDRAILS, GRATING AND PERSONNEL PROTECTION TO SHALL BE HOT-DIPPED GALVANIZED PER ASTM A385.

- SHIPPING**
- PIECES ARE TO BE LOADED SUCH THAT NO COMPONENT IS COMPROMISED, INCLUDING THE PAINT SYSTEM.
 - POINT LOADS ON SHELL PLATES ARE TO BE AVOIDED. 15PM-15 TIMBERS USED FOR SHIPPING SHALL BE PLACED SPANNING A MINIMUM OF TWO STIFFENERS.
 - ANY TEMPORARY SHIPPING BRACES WHICH ARE WELDED TO THE STACK SHALL BE PAINTED YELLOW. ERECTOR SHALL REMOVE TEMPORARY BRACES PRIOR TO ERECTION.
 - BOLTS, NUTS, WASHERS, GASKETS AND ANY OTHER SHIPPED LOOSE ITEMS SHALL BE PACKED IN CONTAINERS. A PACKING LIST SHALL BE ATTACHED TO CONTAINER IDENTIFYING ALL ITEMS CONTAINED INSIDE.

- FIT-UP**
- MODERATE AMOUNTS OF STRAIGHTENING, SHIMMING, REAMING, CUTTING AND GRINDING ARE REQUIRED FOR NORMAL ERECTION PROCEDURES FOR PROPER FIT UP.
 - MISFITS WHICH CANNOT BE CORRECTED BY THESE MEANS ARE TO BE REPORTED TO CMI ENERGY IMMEDIATELY.
 - THE ERECTOR SHALL PROVIDE INFORMATION TO CORRECT THE FIT UP AND SHALL WORK WITH CMI ENERGY TO DETERMINE THE MOST ECONOMIC SOLUTION TO CORRECT THE FIT UP PROBLEM.
- ERECTOR**
- THE STACK WILL ARRIVE IN 90° PANELS.
 - STACK PANELS SHALL BE LIFTED TO THE VERTICAL POSITION WITH NECESSARY MEANS TO NOT DAMAGE ANY COMPONENTS, INCLUDING THE PAINT SYSTEM.
 - STACK PANELS TO BE WELDED VERTICALLY TOGETHER AND THEN LIFTED AS ONE CAN SECTION WITH THE PROVIDED LIFTING TRUNIONS.
 - A TAILING CRANE SHOULD BE ATTACHED TO THE BASE CHAIR OR TAILING LUGS DURING THE LIFT.
 - ALL ANCHOR BOLTS ARE TIGHTENED USING THE AISC "TURN-OFF-THE-NUT" METHOD.

MATCH MARK ALL FIELD JOINTS.

ies INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC.
Stacks, Ducts, Dampers & Silencers
SALES: (770) 645-1421 ENGINEERING: (334) 321-7039

PROJECT: **VALLEY ENERGY CENTER PROJECT**

CITY: **WAWAYANDA** STATE: **NEW YORK**

CLIENT: **CMI ENERGY**

CLIENT DRAWING NO.:


DESCRIPTION: **2068 STACK GENERAL ASSEMBLY**

IES DRAWING NO. **Q42-GA-01** SHEET **1** OF **5**

DRIVEN BY: **C. YOUNG** DATE: **07/20/15**

CHECKED BY: **J. REID** DATE: **07/23/15**

APPROVED BY:



STACK ELEVATION LOOKING SOUTH
(SCALE: 3/32" = 1'-0")

STACK ELEVATION LOOKING WEST
(SCALE: 3/32" = 1'-0")

CERTIFIED FOR CONSTRUCTION

THIS DRAWING FOR APPROVAL ONLY.
DETAILED CONSTRUCTION DRAWINGS TO
BE SUBMITTED AFTER APPROVAL OF
GENERAL ARRANGMENT









NO.	DATE	REVISION	BY	CHECKED
1	01/10/16	CERTIFIED FOR CONSTRUCTION	J.R.	C.R.
2	01/04/16	GENERAL REVISION	CMY	J.R.
3	07/23/15	ISSUED FOR REVIEW	CMY	J.R.

DESIGN DRAWING NO.	Q42-GA-02	SHEET	2 OF 5
DRAWN BY	C. YOUNG	DATE	07/20/15
CHECKED BY	J. REID	DATE	07/23/15
APPROVED BY		DATE	

ies INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC.
Stacks, Ducts, Dampers & Silencers
SALES: (770) 645-1421 ENGINEERING: (334) 321-7039

PROJECT: VALLEY ENERGY CENTER PROJECT
CITY: WAWAYANDA STATE: NEW YORK
CLIENT: CMI ENERGY
CLIENT DRAWING NO.:
DESCRIPTION: 2068 STACK ELEVATIONS & SECTIONS

THIS DRAWING, INCLUDING ALL INFORMATION CONTAINED THEREIN, IS THE EXCLUSIVE PROPERTY OF INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC. IF IT IS DISCLOSED WITHOUT THE UNDERSTANDING IT WILL BE RETURNED IN CONFIDENCE AND WILL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART FOR ANY PURPOSES OTHER THAN THAT FOR WHICH DISCLOSED. THIS DRAWING IS TO BE RETURNED ON DEMAND TO INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC.



CERTIFIED FOR CONSTRUCTION

THIS DRAWING FOR APPROVAL ONLY.
DETAILED CONSTRUCTION DRAWINGS TO
BE SUBMITTED AFTER APPROVAL OF
GENERAL ARRANGMENT

NO.	DATE	REVISION	BY	CHECKED
△	02/11/16	REVISED AS NOTED	J.R.	C.R.
△	01/10/16	CERTIFIED FOR CONSTRUCTION	J.R.	C.R.
△	01/04/16	GENERAL REVISION	CMY	J.R.
△	07/23/15	ISSUED FOR REVIEW	CMY	J.R.

Industrial Environmental Systems, Inc.
Stacks, Ducts, Dampers & Silencers

SALES: (770) 645-1421 ENGINEERING: (334) 321-7039

PROJECT: VALLEY ENERGY CENTER PROJECT

CITY: WAWAYANDA STATE: NEW YORK

CLIENT: CMI ENERGY

CLIENT DRAWING NO.:








DESCRIPTION: 2068 STACK SECTIONS & DETAILS

IES DRAWING NO. Q42-GA-03 SHEET 3 OF 5

DRAWN BY: C. YOUNG DATE: 07/20/15
CHECKED BY: J. REID DATE: 07/23/15

APPROVED BY: DATE:

THIS DRAWING, INCLUDING ALL INFORMATION CONTAINED THEREIN, IS THE EXCLUSIVE PROPERTY OF INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC. IF IT IS DISCLOSED WITH THE UNDERSTANDING IT WILL BE RETURNED IN CONFIDENCE AND WILL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART FOR ANY PURPOSES OTHER THAN THAT FOR WHICH DISCLOSED, THIS DRAWING IS TO BE RETURNED ON DEMAND TO INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC.



- NOTE:** ALL PORTS TO BE CONSTRUCTED FROM 304 STAINLESS STEEL
- NOTE:** LUG AND CLIP DETAILS TO BE DESIGNED PER GE SPEC B29
- (A) (4) EPA TEST PORTS EQUALLY SPACED 90° APART
 6" SCH. 40 PIPE w/150# R.F. FLANGE, w/BLIND FLANGE, w/CHAIN.
 MOUNT (1) 100x100x6 L-BRACKET 14" ABOVE EACH PORT
 MOUNT (1) 8MM EYE BOLT 36" ABOVE EACH L-BRACKET
 PROJECTION = 6" [152] FROM STACK O.D.
 ● EL. 175'-1 1/2" [53379]
 - (B) (2) CEM PORTS 180° APART. 4" SCH. 40 PIPE
 w/150# R.F. FLANGE, w/BLIND FLANGE, w/CHAIN.
 PROJECTION = 6" [152] FROM STACK O.D.
 ● EL. 175'-1 1/2" [53379]
 - (C) (2) OPACITY PORTS 180° APART. 6" SCH. 10 PIPE.
 PROJECTION = 8" [215] FROM STACK I.D.
 ● EL. 174'-3 1/2" [53226]
 - (D) (2) TEMPERATURE TEST PORTS
 1 1/2" SCH. 40 PIPE w/150# R.F. FLANGE w/BLIND FLANGE, w/CHAIN.
 PROJECTION = 6" [152] FROM STACK O.D.
 ● EL. 175'-1 1/2" [53379]

CERTIFIED FOR CONSTRUCTION

THIS DRAWING FOR APPROVAL ONLY.
 DETAILED CONSTRUCTION DRAWINGS TO
 BE SUBMITTED AFTER APPROVAL OF
 GENERAL ARRANGMENT

NO.	DATE	REVISION	BY	CHECKED
01/10/16		CERTIFIED FOR CONSTRUCTION	J.R.	C.R.
01/04/16		GENERAL REVISION	CMY	J.R.
07/23/15		ISSUED FOR REVIEW	CMY	J.R.

ies INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC.
 Stacks, Ducts, Dampers & Silencers
 SALES: (770) 645-1421 ENGINEERING: (334) 321-7039

PROJECT
 VALLEY ENERGY CENTER PROJECT

CITY WAWAYANDA **STATE** NEW YORK

CLIENT CMI ENERGY





CLIENT DRAWING NO.

DESCRIPTION
 2068 STACK SECTIONS & DETAILS

IES DRAWING NO. Q42-GA-04 **SHEET** 4 OF 5

DRAWN BY C. YOUNG **DATE** 07/20/15
CHECKED BY J. REID **DATE** 07/23/15

THIS DRAWING, INCLUDING ALL INFORMATION CONTAINED THEREIN, IS THE EXCLUSIVE PROPERTY OF INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC. IF IT IS DISCLOSED TO ANY OTHER PARTY WITHOUT THE WRITTEN CONSENT OF INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC., THE USER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES. THIS DRAWING IS TO BE RETURNED TO INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC. UPON COMPLETION OF THE PROJECT.





CERTIFIED FOR CONSTRUCTION


THIS DRAWING FOR APPROVAL ONLY.
DETAILED CONSTRUCTION DRAWINGS TO
BE SUBMITTED AFTER APPROVAL OF
GENERAL ARRANGMENT

ies INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC. Stacks, Ducts, Dampers & Silencers				
SALES: (770) 645-1421	ENGINEERING: (334) 321-7039			
PROJECT	CPV VALLEY #2068			
CITY	NEW YORK			
STATE	NEW YORK			
CLIENT	CMI ENERGY			
CLIENT DRAWING NO.				
DESCRIPTION	STACK SECTIONS			
IES DRAWING NO.	Q42-GA-05			
SHEET	5 OF 5			
DATE	01/10/16			
REVISION	CERTIFIED FOR CONSTRUCTION			
DATE	01/04/16			
REVISION	GENERAL REVISION			
DATE	07/23/15			
REVISION	ISSUED FOR REVIEW			
NO.	DATE	REVISION	BY	CHECKED
			J.R.	C.R.
			CMY	J.R.
			CMY	J.R.

THIS DRAWING, INCLUDING ALL INFORMATION CONTAINED THEREIN, IS THE EXCLUSIVE PROPERTY OF INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC. IF IT IS DISCLOSED WITHOUT THE UNDERSTANDING IT WILL BE RETURNED IN CONFIDENCE AND WILL NOT BE REPRODUCED, COPIED, REPRODUCED, OR IN ANY MANNER USED FOR ANY PURPOSES OTHER THAN THAT FOR WHICH DISCLOSED. THIS DRAWING IS TO BE RETURNED ON DEMAND TO INDUSTRIAL ENVIRONMENTAL SYSTEMS, INC.



PLAN VIEW
GAS FLOW →




Revision	Description	Drawing Status	Checker	Approved	Date	Rev.
FINAL	KETTLE BOILER BY OTHERS (SHOWN PHANTOM)	MDS	JRS	KJT	04/25/16	8
FINAL		MDS	JRS	KJT	03/24/16	7
FINAL		MDS	JRS	KJT	11/02/15	6
FINAL		MDS	JRS	KJT	10/09/15	5
FOR REVIEW, REVISED COORDINATE SYSTEM, MOVED SCR LAYDOWN AREA, BLOWDOWN TANK, AND SCR SKID		MDS	JRS	KJT	09/24/15	4

SIEMENS		Revision Status		DRAWING FORMAT IS IMPERIAL	
8		THIRD ANGLE PREDICTION		DRAWING UNITS: MM FE - IN	
497456892		XX NTS		DIM TOLERANCE: 2.0MM 1/16"	
2068-099-G10102		Date		DEC. TOLERANCE: 0.254 0.01	
497456892		Date		GENERAL ARRANGEMENT TOP VIEW	
2068-099-G10102		Date		Sheet 1 of 1	

Appendix D Fuel Flowmeter Locations

The attached P&ID drawings detail location of the certified fuel flowmeters and fuel analysis tap points (cross reference 40 CFR 75 §75.53(f)(1)(ii)(A)).



- NOTES:**
- ORIFICE PLATE REQUIRES 12 STRAIGHT PIPE DIAMETERS BETWEEN STRAIGHTENER AND ORIFICE PLATE AND 18 STRAIGHT PIPE DIAMETERS FROM ORIFICE PLATE TO FITTING UPSTREAM STRAIGHTENER. ORIFICE PLATE REQUIRES 4 STRAIGHT PIPE DIAMETERS DOWNSTREAM ORIFICE PLATE.
 - PROVIDE TEMPORARY SPOOL FOR AIR BLOW
 - LOCATE TAP 4 STRAIGHT PIPE DIAMETER MIN FROM FLANGE
 - LOCATE TAP 10 STRAIGHT PIPE DIAMETER MIN FROM FLANGE
 - FLOW ORIFICE REQUIRES STRAIGHT RUN OF 30 STRAIGHT PIPE DIAMETER MIN UPSTREAM AND 7 STRAIGHT PIPE DIAMETER MIN DOWNSTREAM
 - LOCATE TAPS 10 STRAIGHT PIPE DIAMETERS DOWNSTREAM FROM VALVES.

IT IS A VIOLATION OF SECTION 7209-2 OF THE NEW YORK STATE EDUCATION LAW FOR ANY PERSON TO ALTER ANY DOCUMENT THAT BEARS THE SEAL OF A PROFESSIONAL ENGINEER, UNLESS THE PERSON IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER.

FOR CONSTRUCTION

COPYRIGHT © 2015 BY BURNS & MCDONNELL CONSULTANTS, INC.

no.	date	by	ckd	description
3	03/01/17	BAN	CRF	REVISED AS SHOWN
2	10/07/16	RMS	BAN	REVISED AS SHOWN
1	06/30/16	RMS	DSH	ISSUED FOR CONSTRUCTION
0	01/15/16	RMS	DSH	ISSUED FOR BELOW GRADE ROUTING

no.	date	by	ckd	description


BURNS & MCDONNELL

9400 WARD PARKWAY
KANSAS CITY, MO 64114
816-333-9400
FIRM LICENSE NO. 0011996

designed: R. SUTHERLIN
detailed: R. CHANDLER

CPV Valley Energy Center
ORANGE COUNTY, NEW YORK

Piping & Instrumentation Diagram	
FUEL GAS	
project	contract
84595	
drawing	rev.
MMOFGS-001	3
sheet	of sheets
file 84595MMOFGS001.pid	



- NOTES:**
- REFER TO SIEMENS DRAWING 499244497
 - METER SECTION REQUIRES ADDITIONAL PIPE STRAIGHT RUN OF 20 PIPE DIAMETERS UPSTREAM. REFER TO SIEMENS DRAWING DP2IT-00000113
 - REFER TO SIEMENS DRAWING TCVC55D2680
 - REFER TO SIEMENS DRAWING TCVC55D2681
 - REFER TO SIEMENS DRAWING S16-11602-2-1
 - REFER TO SIEMENS DRAWING 70B7119-V
 - REFER TO SIEMENS DRAWING 2068-000-G30801
 - REFER TO SIEMENS DRAWING US1177-MB-MFB030-011200 PAGE 21 & 70B6674
 - REFER TO SIEMENS DRAWING US1177-MB-MFB030-011200 PAGE 22
 - PROVIDE SPOOL FOR AIR BLOW
 - PROVIDE SPOOL FOR AIR BLOW
 - COMMON TEMPORARY HOSE FOR NITROGEN PURGE CONNECTION. HOSE SHALL BE DISCONNECTED DURING NORMAL OPERATION.
 - REFER TO SIEMENS DRAWING US1177-MB-MFB030-011200 PAGE 49

IT IS A VIOLATION OF SECTION 7209-2 OF THE NEW YORK STATE EDUCATION LAW FOR ANY PERSON TO ALTER ANY DOCUMENT THAT BEARS THE SEAL OF A PROFESSIONAL ENGINEER, UNLESS THE PERSON IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER.

FOR CONSTRUCTION

Copyright © 2015 BY BURNS & MCDONNELL CONSULTANTS, INC.
 Scale For Microfining
 Millimeters
 Inches

no.	date	by	ckd	description	no.	date	by	ckd	description
1	10/07/16	RMS	BAN	REVISED AS SHOWN					
0	06/30/16	RMS	DSH	ISSUED FOR CONSTRUCTION-WORKING					

BURNS & MCDONNELL
 9400 WARD PARKWAY
 KANSAS CITY, MO 64114
 816-333-9400
 FIRM LICENSE NO. 0011996


designed: R. SUTHERLIN
 detailed: R. CHANDLER

VALLEY ENERGY CENTER
 CPV VALLEY LLC
 CPV Valley Energy Center
 ORANGE COUNTY, NEW YORK

Piping & Instrumentation Diagram
FUEL GAS

project	contract
84595	
drawing	rev.
MM1FGS-001	1
sheet	of sheets
file 84595MM1FGS001.pid	

- NOTES:
- PIPE SIZE SHOWN IS CARRIER PIPE SIZE. SEE PIPE SPEC 00CSJ01 FOR CONTAINMENT PIPE SIZE. CONTAINMENT PIPE LINE NUMBER INCLUDES SUFFIX J.
 - INSTRUMENT IS CONNECTED TO STRAINER.
 - MINIMUM STRAIGHT PIPE RUN DISTANCE UPSTREAM OF FLOW ELEMENT IS 10 FT AND DOWNSTREAM IS 4 FT.
 - ALLOW OPERATIONS TO RECIRCULATE STAGNANT OIL FROM GAS TURBINE.
 - VERAC TANK GAUGING SYSTEM SUPPLIED WITH TANK.
 - NOT USED.
 - LEAK SENSORS CONNECT TO CASING INSPECTION PORTS.
 - SEE TANK DATASHEET 48 56 60, 0FOL-TNK-0001 FOR DETAIL.
 - ROUTE OUTSIDE CONTAINMENT WALL. PROVIDE FFFE CONNECTION. HOSE CONNECTION BY 5.8360.



IT IS A VIOLATION OF SECTION 7209-2 OF THE NEW YORK STATE EDUCATION LAW FOR ANY PERSON TO ALTER ANY DOCUMENT THAT BEARS THE SEAL OF A PROFESSIONAL ENGINEER, UNLESS THE PERSON IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER.

FOR CONSTRUCTION

Scale For Microfitting
Millimeters
Inches

no.	date	by	ckd	description
3	03/01/17	BEB	BAN	REVISED AS SHOWN
2	10/07/16	BEB	BAN	REVISED AS SHOWN
1	06/30/16	BEB	BAN	ISSUED FOR CONSTRUCTION
0	01/15/16	BEB	DSH	ISSUED FOR BELOW GRADE ROUTING

no.	date	by	ckd	description

BURNS & MCDONNELL

9400 WARD PARKWAY
KANSAS CITY, MO 64114
816-333-9400
FIRM LICENSE NO. 0011996


designed: B. BOWMAN
detailed: B. BOWMAN

CPV Valley Energy Center
ORANGE COUNTY, NEW YORK

Piping & Instrumentation Diagram
FUEL OIL

project	contract
84595	
drawing	rev.
MM0FOL-001	3
sheet	of sheets
file 84595MM0FOL001.pid	

COPYRIGHT © 2015 BY BURNS & MCDONNELL CONSULTANTS, INC.



- NOTES:**
1. REFER TO SIEMENS DRAWING 499244497
 2. METER SECTION REQUIRES ADDITIONAL PIPE STRAIGHT RUN OF 20 PIPE DIAMETERS UPSTREAM. REFER TO SIEMENS DRAWING DP2IT-00000113
 3. REFER TO SIEMENS DRAWING TCVGC55D2680
 4. REFER TO SIEMENS DRAWING TCVGC55D2681
 5. REFER TO SIEMENS DRAWING S16-11602-2-1
 6. REFER TO SIEMENS DRAWING 70B7119-V
 7. REFER TO SIEMENS DRAWING 2068-000-G30801
 8. REFER TO SIEMENS DRAWING US1177-MB-MFB030-011200 PAGE 21 & 70B6674
 9. REFER TO SIEMENS DRAWING US1177-MB-MFB030-011200 PAGE 22
 10. PROVIDE SPOOL FOR AIR BLOW
 11. PROVIDE SPOOL FOR AIR BLOW
 12. COMMON TEMPORARY HOSE FOR NITROGEN PURGE CONNECTION
 13. REFER TO SIEMENS DRAWING US1177-MB-MFB030-011200 PAGE 49

IT IS A VIOLATION OF SECTION 7209-2 OF THE NEW YORK STATE EDUCATION LAW FOR ANY PERSON TO ALTER ANY DOCUMENT THAT BEARS THE SEAL OF A PROFESSIONAL ENGINEER, UNLESS THE PERSON IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER.

FOR CONSTRUCTION

COPYRIGHT © 2015 BY BURNS & MCDONNELL CONSULTANTS, INC.

no.	date	by	ckd	description
1	10/07/16	RMS	BAN	REVISED AS SHOWN
0	06/30/16	RMS	DSH	ISSUED FOR CONSTRUCTION-WORKING

BURNS & MCDONNELL


9400 WARD PARKWAY
KANSAS CITY, MO 64114
816-333-9400
FIRM LICENSE NO. 0011996

designed: R. SUTHERLIN
detailed: R. CHANDLER

CPV Valley Energy Center
ORANGE COUNTY, NEW YORK

Piping & Instrumentation Diagram
FUEL GAS

project	contract
84595	
drawing	rev.
MM2FGS-001	1
sheet	of sheets
file 84595MM2FGS001.pid	



NOTES:
 1. PIPE SIZE SHOWN IS CARRIER PIPE SIZE. SEE PIPE SPEC 00CSJ01 FOR CONTAINMENT PIPE SIZE. CONTAINMENT PIPE LINE NUMBER INCLUDES SUFFIX J.
 2. INSTRUMENT CONNECTED TO STRAINER.
 3. LEAK SENSORS CONNECT TO CASING INSPECTION PORT.

IT IS A VIOLATION OF SECTION 7209-2 OF THE NEW YORK STATE EDUCATION LAW FOR ANY PERSON TO ALTER ANY DOCUMENT THAT BEARS THE SEAL OF A PROFESSIONAL ENGINEER, UNLESS THE PERSON IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER.

FOR CONSTRUCTION

COPYRIGHT © 2015 BY BURNS & MCDONNELL CONSULTANTS, INC.

no.	date	by	ckd	description	no.	date	by	ckd	description
2	10/07/16	BEB	BAN	REVISED AS SHOWN					
1	06/30/16	BEB	BAN	ISSUED FOR CONSTRUCTION					
0	01/15/16	BEB	DSH	ISSUED FOR BELOW GRADE ROUTING					

BURNS & MCDONNELL
 9400 WARD PARKWAY
 KANSAS CITY, MO 64114
 816-333-9400
 FIRM LICENSE NO. 0011996

designed: **B. BOWMAN**
 detailed: **B. BOWMAN**

VALLEY ENERGY CENTER
 CPV VALLEY LLC
 CPV Valley Energy Center
 ORANGE COUNTY, NEW YORK

Piping & Instrumentation Diagram
FUEL OIL

project	contract
84595	
drawing	rev.
MMOFOL-002	2
sheet	of sheets
file 84595MMOFOL002.pid	

7016 0600 0000 8503 7063

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

NEW YORK, NY 10007

Certified Mail Fee	\$3.35
Extra Services & Fees (check box, add fee as appropriate)	\$2.75
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00
<input type="checkbox"/> Return Receipt (electronic)	\$0.00
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00
<input type="checkbox"/> Adult Signature Required	\$0.00
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00

Postage	\$1.82
Total Postage and Fees	\$7.92

0060 05
Postmark Here
06/14/2017

Sent To
USEPA REGION II AIR COMP BRANCH
290 BROADWAY
NEW YORK, NY 10007-1866

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7016 0600 0000 8503 7070

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

WASHINGTON, DC 20460

Certified Mail Fee	\$3.35
Extra Services & Fees (check box, add fee as appropriate)	\$2.75
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00
<input type="checkbox"/> Return Receipt (electronic)	\$0.00
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00
<input type="checkbox"/> Adult Signature Required	\$0.00
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00

Postage	\$2.03
Total Postage and Fees	\$8.13

0060 05
Postmark Here
06/14/2017

Sent To
USEPA CLEAN AIR MARKETS DIVISION
1700 PENNSYLVANIA AVE, NW
WASHINGTON, DC 20460

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7016 0600 0000 8503 7094

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

NEW PALTZ, NY 12561

Certified Mail Fee	\$3.35
Extra Services & Fees (check box, add fee as appropriate)	\$2.75
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00
<input type="checkbox"/> Return Receipt (electronic)	\$0.00
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00
<input type="checkbox"/> Adult Signature Required	\$0.00
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00

Postage	\$2.03
Total Postage and Fees	\$8.13

0060 05
Postmark Here
06/14/2017

Sent To
REGIONAL AIR POLLUTION CONTROL ENGR. NYS DEC REGION 3
21 SOUTH PUTT COMERS RD
NEW PALTZ, NY 12561

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7016 0600 0000 8503 7087

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

ALBANY, NY 12233

Certified Mail Fee	\$3.35
Extra Services & Fees (check box, add fee as appropriate)	\$2.75
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00
<input type="checkbox"/> Return Receipt (electronic)	\$0.00
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00
<input type="checkbox"/> Adult Signature Required	\$0.00
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00

Postage	\$1.82
Total Postage and Fees	\$7.92

0060 05
Postmark Here
06/14/2017

Sent To
Division of Air Resources NYSDEC - Bureau of QA
625 BROADWAY
ALBANY, NEW YORK 12233-3258


PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

USFPA REGION II
 AIR COMPLIANCE BRANCH
 200 BROADWAY
 NEW YORK, NY 10007-1866



9590 9402 2493 6306 1515 43

PS Form 3811, July 2015 PSN 7530-02-000-9053

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

DIVISION OF AIR RESOURCES
 NYSDC - BUREAU OF QA
 325 BROADWAY
 ALBANY, NY 12233-3258



9590 9402 2493 6306 1515 29

PS Form 3811, July 2015 PSN 7530-02-000-9053

COMPLETE THIS SECTION ON DELIVERY

A. Signature *Chris Maloney* Agent
 B. Received by (Printed Name) *Chris Maloney* Addressee
 C. Date of Delivery *6-14-17*
 D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
- Adult Signature
 - Adult Signature Restricted Delivery
 - Certified Mail®
 - Certified Mail Restricted Delivery
 - Collect on Delivery
 - Collect on Delivery Restricted Delivery
 - Mail Restricted Delivery
 - Priority Mail Express®
 - Registered Mail™
 - Registered Mail Restricted Delivery
 - Signature Confirmation™
 - Signature Confirmation™ Restricted Delivery

Domestic Return Receipt

COMPLETE THIS SECTION ON DELIVERY

A. Signature *[Signature]* Agent
 B. Received by (Printed Name) *[Name]* Addressee
 C. Date of Delivery *[Date]*
 D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
- Adult Signature
 - Adult Signature Restricted Delivery
 - Certified Mail®
 - Certified Mail Restricted Delivery
 - Collect on Delivery
 - Collect on Delivery Restricted Delivery
 - Mail Restricted Delivery
 - Priority Mail Express®
 - Registered Mail™
 - Registered Mail Restricted Delivery
 - Signature Confirmation™
 - Signature Confirmation™ Restricted Delivery


Domestic Return Receipt

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

REGIONAL AIR POLLUTION CONTROL
 BUREAU
 NYSDC - REGION #3
 SOUTH AUST CORNER RD
 SUW PARK, NY 13581



9590 9402 2493 6306 1515 12

PS Form 3811, July 2015 PSN 7530-02-000-9053

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

ASERPA ELEMENTARY MARKETS DIV
 200 DENNIS-LAVANIA AVE NW
 WDC CODE 6204M
 WASHINGTON, DC 20460



9590 9402 2493 6306 1515 36

PS Form 3811, July 2015 PSN 7530-02-000-9053

COMPLETE THIS SECTION ON DELIVERY

A. Signature *[Signature]* Agent
 B. Received by (Printed Name) *[Name]* Addressee
 C. Date of Delivery *[Date]*
 D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
- Adult Signature
 - Adult Signature Restricted Delivery
 - Certified Mail®
 - Certified Mail Restricted Delivery
 - Collect on Delivery
 - Collect on Delivery Restricted Delivery
 - Mail Restricted Delivery
 - Priority Mail Express®
 - Registered Mail™
 - Registered Mail Restricted Delivery
 - Signature Confirmation™
 - Signature Confirmation™ Restricted Delivery

Domestic Return Receipt

COMPLETE THIS SECTION ON DELIVERY

A. Signature *[Signature]* Agent
 B. Received by (Printed Name) *[Name]* Addressee
 C. Date of Delivery *[Date]*
 D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
- Adult Signature
 - Adult Signature Restricted Delivery
 - Certified Mail®
 - Certified Mail Restricted Delivery
 - Collect on Delivery
 - Collect on Delivery Restricted Delivery
 - Mail Restricted Delivery
 - Priority Mail Express®
 - Registered Mail™
 - Registered Mail Restricted Delivery
 - Signature Confirmation™
 - Signature Confirmation™ Restricted Delivery

Domestic Return Receipt

Continuous Emissions Monitoring System (CEMS)

40 CFR 75 and 40 CFR 60 Certification Test Report

Report Date: June 2018

Revision: A

CEMTEK Project No.: 50478A

Siemens UNID No.: 498368484

Prepared for:

CPV Valley Energy Center

CTG Unit 2 Stack CEMS

Middletown, NY

Prepared by:

CEMTEK KVB-Enertec

3041 S. Orange Ave

Santa Ana, CA 92707-4247

Phone: 714-437-7100

Fax: 714-437-7177

www.cemteks.com



Contents

1	Introduction	1
1.1	Facility Description.....	1
1.2	CEMS Overview	1
1.2.1	CEMS Analyzers.....	2
1.2.2	Data Acquisition System	2
2	Summary of Results	3
2.1	Results Summary Tables	3
3	Test Procedures	6
3.1	7-Day Calibration Error Test – NO _x , O ₂	6
3.2	7-Day Calibration Drift Test CO and CO ₂ Monitors	7
3.3	Linearity Error Check – NO _x , O ₂	8
3.4	CO Analyzer Cylinder Gas Audit	9
3.5	Cycle/Response Time Check – NO _x , O ₂	9
3.6	CO Analyzer Response Time Check.....	10
4	Test Data and Supporting Documentation	11
4.1	7-Day Calibration Drift Data.....	11
4.2	Linearity and CGA Data	12
4.3	Cycle/Response Time Data	13
4.4	Calibration Gas Certificates.....	14
5	Relative Accuracy Test Audit.....	15
	Table 1: NO _x Analyzer Test Results Summary.....	3
	Table 2: O ₂ Analyzer Test Results Summary	4
	Table 3: CO Analyzer Test Results Summary.....	4
	Table 4: CO ₂ Analyzer Test Results Summary	5

1 Introduction

This document is intended to satisfy the CEMS certification requirements of the USEPA as required by the Code of Federal Regulations, Title 40, Part 75 (40 CFR 75 or Part 75), Appendix A and 40 CFR 60 (Part 60) Appendix B Performance Specifications. This document summarizes the test program and test results.

Data from the various tests performed under this program provides resources for evaluating the acceptability of the operation of the facility's continuous emissions monitoring system (CEMS).

Tests were performed by personnel from CEMTEK Environmental Inc. with assistance from facility technicians.

The performance tests completed in this certification test program include:

- Part 75 Linearity Check – NO_x, O₂
- Part 75/Part 60 Cycle/Response Time Check – NO_x, O₂, CO
- Part 75/Part 60 Calibration Drift Check (7-day drift test) – NO_x, O₂, CO, CO₂
- Part 60 CGA – CO
- Relative Accuracy Test Audit (RATA)

1.1 Facility Description

The Valley Energy Center facility is located in Wawayanda, NY and consists of one combined cycle power plant operating on dual-fuel (natural gas and fuel oil) with duct burning.

The Facility consists of: two (2) Siemens SGT6-5000F (4) gas turbines with Dry Low NO_x (DLN) Combustion Systems, operating in 2x1 combined cycle configuration, firing natural gas and ultra-low sulfur diesel (ULSD) fuel oil; two (2) 3-drum HRSG's equipped with SCR systems for NO_x control and oxidation catalysts for CO and VOC control; and one (1) Siemens SST6-5000 steam turbine generator (STG).

This report summarizes test results for Unit 2.

1.2 CEMS Overview

The CEMS measures concentrations of carbon monoxide (CO), oxides of nitrogen (NO_x), and oxygen (O₂) from the turbine exhaust stack. All measurements are done on a real time basis. Contact closures are provided for alarms and system status.

All flue gas pollutant and diluent measurements are made on a dry basis. Effluent gas from the sampling location is filtered and transported through heated sample lines to the sample conditioning system in the main analyzer equipment rack. The sample conditioning system again filters the effluent gas. A sample gas cooler removes moisture. The dry, particulate-free effluent gas sample is supplied to each analyzer within the equipment rack. The analog outputs of each analyzer and certain plant signal inputs are transmitted to a system controller located with the analyzer components.

The system operates automatically so operator attention is necessary only for manual verification and accuracy and normal maintenance. Automatic zero and span calibrations are performed on the CEMS monitors every 24 hours. Certified EPA Protocol calibration gases are injected at a valve box in the back of the probe.

1.2.1 CEMS Analyzers

The following table summarizes the analyzer components of the CEMS.

CTG CEMS Unit 2

Analyzer	Manufacturer/Model	Range(s)	Serial Number
NO _x	Teledyne API T200M	0-10 ppm/0-100 ppm	646
O ₂		0-25%	
CO	Teledyne API T300M	0-10 ppm/0-3000 ppm	354
CO ₂		0-10%	

1.2.2 Data Acquisition System

The CEMS Data Acquisition and Reporting is controlled by the DAHS. The DAHS is a PC-based, multi-user, multi-tasking system. The DAHS provides automated data monitoring and management capabilities to the CEMS. The DAHS is utilized for operator interface, data storage, report generation, and data display.

The PLC transmits data from the analyzers to the DAHS. The DAHS polls the PLC for data to generate and store one (1) minute averages. The DAHS will indicate any occurrence of specification limit exceedances or CEM operational problems. In the DAHS, necessary reports are generated in the required format for submittal to the applicable regulatory agencies. These reports may be produced in either hard copy or electronic format and can be made available to state and local agencies.

All required reporting parameters follow the equations in 40 CFR Part 75 Appendices D, F, and G and facility operating permit as applicable.

2 Summary of Results

The results of all tests performed are summarized in the following tables. Procedural test descriptions are located in Section 3. DAHS printouts and supporting documentation for all tests are located within Section 4 of this document.

2.1 Results Summary Tables

Table 1: NO_x Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
Part 75 RATA	7.01% lb/mmBtu by RM	≤10% semi-annual, ≤7.5% annual (by RM) or alternately ≤0.02 lb/mmBtu difference semi-annual, ≤0.015 lb/mmBtu difference annual (40 CFR 75, Appendix A and B)	5/11/18
Part 75 BAF	1.052	d > cc , the monitoring system has failed to meet bias test criteria, data to be adjusted to calculated BAF. If passed, BAF = 1.000	
Part 60 RATA	5.0% ppm @15% O ₂ 4.6% ppm 5.4% lb/hr	≤20% or ≤10% applicable standard (40 CFR 60, Appendix B, PS-2)	
Low Range Results			
Linearity Check	Low = 3.58% Mid = 4.13% High = 2.07%	≤5% of reference or ≤5 ppm absolute difference (40 CFR 75, Appendix A)	5/11/18
Cycle Time	Zero run = 2 min Span run = 3 min	≤15 minutes (40 CFR 75, Appendix A)	5/8/18
7-Day Drift, Highest Reading	zero = 0.00% span = 1.80%	≤2.5% of span or for ranges ≤200 ppm, then ≤5 ppm absolute difference (40 CFR 75, Appendix A)	4/24/18 thru 5/2/18
High Range Results			
Linearity Check	Low = 3.39% Mid = 2.12% High = 1.86%	≤5% of reference or ≤5 ppm absolute difference (40 CFR 75, Appendix A)	5/10/18
Cycle Time	Zero run = 3 min Span run = 3 min	≤15 minutes (40 CFR 75, Appendix A)	5/8/18
7-Day Drift, Highest Reading	zero = 0.10% span = 0.85%	≤2.5% of span or for ranges ≤200 ppm, then ≤5 ppm absolute difference (40 CFR 75, Appendix A)	4/24/18 thru 5/2/18

Table 2: O₂ Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
Part 75 RATA	0.5% by RM	≤10% semi-annual, ≤7.5% annual (by RM) or alternately ≤1.0% difference semi-annual, ≤0.7% difference annual (40 CFR 75, Appendix A and B)	5/11/18
Linearity Check	Low = 2.52% Mid = 0.14% High = 0.05%	≤5% of reference or ≤0.5% difference (40 CFR 75, Appendix A)	5/11/18
Cycle Time	Zero run = 2 min Span run = 1 min	≤15 minutes (40 CFR 75, Appendix A)	5/8/18
7-Day Drift, Highest Reading	zero = 0.00% span = 0.01%	≤0.5% difference (40 CFR 75, Appendix A)	4/25/18 thru 5/3/18

Table 3: CO Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
Part 60 RATA	0.6 ppm diff @ 15% O ₂ 0.6 ppm diff 0.6 lb/hr diff	≤10% by RM or ≤5% of applicable standard or difference + CC ≤5 ppm (40 CFR 60, Appendix B, PS-4/4A)	5/11/18
Low Range Results			
Response Time	2 min 40 sec	≤240 seconds (4 minutes) (40 CFR 60, PS-4A eCFR)	5/8/18
7-Day Drift, Highest Reading	zero = 2.00% span = 3.60%	≤5.0% of full span 6 out of 7 days (40 CFR 60, Appendix B, PS-4)	4/24/18 thru 5/2/18
CGA	Low = -11.36% Mid = -4.59%	≤15.0% of reference value or ≤5.0 ppm difference (40 CFR 60 Appendix F Procedure 1)	5/11/18
High Range Results			
Response Time	2 min 40 sec	≤240 seconds (4 minutes) (40 CFR 60, PS-4A eCFR)	5/8/18
7-Day Drift, Highest Reading	zero = 0.06% span = 0.68%	≤5.0% of full span 6 out of 7 days (40 CFR 60, Appendix B, PS-4)	4/24/18 thru 5/2/18
CGA	Low = 3.04% Mid = 1.71%	≤15.0% of reference value or ≤5.0 ppm difference (40 CFR 60 Appendix F Procedure 1)	5/11/18

Table 4: CO₂ Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
7-Day Drift, Highest Reading	zero = 0.00% span = 0.30%	≤0.5% difference (40 CFR 60, Appendix B, PS-3)	4/24/18 thru 5/2/18

3 Test Procedures

The test procedures used in this certification program were done in accordance with the methods outlined in 40 CFR 75 Appendix A and 40 CFR 60 Appendix B Performance Specifications. The following provides a brief overview on individual test procedures.

Test description for the RATA portion of the test program is attached as Section 5.

3.1 7-Day Calibration Error Test – NO_x, O₂

An on-site calibration error test (7-day drift test) was performed for each NO_x and O₂ monitoring system in accordance with 40 CFR 75, Appendix A, Section 6.3. The tests were performed while the unit was combusting fuel at stabilized stack temperature and pressure conditions.

The calibration error test consists of measuring the calibration error of each monitor scale once each day for seven (7) consecutive unit operating (process on line) days. The calibration error tests were conducted at two EPA Traceability Protocol 1 calibration gas concentrations: zero-level (0-20%) and high-level (80-100%) as specified in 40 CFR 75, Appendix A, Section 6.3.1.

In accordance with 40 CFR 75, Appendix A, Section 3.1, results of the 7-day calibration error test are acceptable if the daily calibration error does not exceed: 2.5% for NO_x and 0.5% for O₂. Alternatively, if the pollutant monitor's span value is equal to or less than 200 ppm, then calibration error shall not exceed 5.0 ppm difference.

Calibrations were performed automatically at approximately 24-hour intervals by the system controller during the drift test period. The readings for each analyzer were taken from the DAHS at the completion of the calibration routine. Copies of the DAHS reports are included with this test report. Manual or automatic adjustments were not made to the monitors until after the zero and high drift responses had been taken for that day during the 7-day test.

The percent calibration error is determined using the following equation:

Daily Drift for Pollutants 40 CFR 75, Appendix A Equation A-5	
$CE = \frac{ R - A }{S} \times 100$	<p>CE = Calibration error as a percentage of instrument span</p> <p>R = Zero or high-level calibration gas value in ppm</p> <p>A = Actual monitor response to calibration gas in ppm</p> <p>S = Span of the instrument</p>

The calibration error for diluent (O₂) monitors is computed by the DAHS from the test results for each concentration level as follows:

Daily Drift for Diluents 40 CFR 75, Appendix A, Equation A-5	
$CE = R - A $	<p>CE = Calibration error as a percentage of O₂</p> <p>R = Zero or high-level calibration gas value in percent (%).</p> <p>A = Actual monitor response to calibration gas in percent (%)</p>

3.2 7-Day Calibration Drift Test CO and CO₂ Monitors

The CO₂ analyzer is used for process monitoring and control (non-compliance). A 7-day calibration drift check was performed as a demonstration of analyzer accuracy with results reported in this report.

Calibrations were performed on the CO and CO₂ analyzer(s) automatically at approximately 24-hour intervals by the DAHS for seven consecutive unit operating (process on-line) days. The calibration drift tests were conducted at two calibration gas concentrations: zero-level (0-20%) and high-level (50-100%) as specified in 40 CFR 60 Appendix B Performance Specifications. The low and high span (zero and span gas) readings for each analyzer were taken from the DAHS at the completion of the calibration routine (40 CFR 60, Appendix B, PS-2, Section 4.1).

The 24-hour calibration drifts were calculated and reported by the following method (40 CFR 60, Appendix B, PS-2). For CO analyzers, the raw zero reading is subtracted from the zero-gas bottle value, the difference is then divided by the analyzer’s span and the resultant value is multiplied by 100 to give the percent calibration drift. The preceding procedure is repeated with the span gas to give the span drift.

Daily Drift for CO 40 CFR 60, Appendix B, PS-2 and PS-4	
$CD = \frac{R - A}{S} \times 100$	<p>CD = Calibration error as a percentage of instrument span</p> <p>R = Zero or high-level calibration gas value in ppm</p> <p>A = Actual monitor response to calibration gas in ppm</p> <p>S = Span of the instrument</p>

The calibration error for the CO₂ monitor is computed by the DAHS from the test results for each concentration level as follows:

Daily Drift for Diluents 40 CFR 60, Appendix B, PS-3 for CO₂	
CD = R – A	CD = Calibration drift as a percentage of CO ₂ R = Zero or high level calibration gas value in percent (%) A = Actual monitor response to calibration gas in percent (%)

The 24-hour calibration drift must not exceed ±5% for CO (6 out of 7 days) and ±0.5% difference for CO₂.

3.3 Linearity Error Check – NO_x, O₂

An on-site linearity check test was conducted in accordance with the 40 CFR 75, Appendix A, for each NO_x and O₂ monitoring system. The test was performed while the unit was combusting primary fuel at stabilized stack temperature and pressure conditions.

EPA Protocol certified calibration gases were used to conduct the linearity checks of the analyzers. Three points (concentrations) of calibration gases, low (20-30%), mid (50-60%) and high (80-100%) were introduced at the probe (40 CFR 75, Appendix A, Section 5.2). Each monitor was challenged three times with the appropriate reference gas, without using the same gas twice in succession. The monitors’ response for each concentration was recorded. The average of the three responses will be used to calculate the linearity error (40 CFR 75, Appendix A, Section 6.2).

Linearity error was calculated using the following equation.

Linearity Error Equation A-4, 40 CFR 75, Appendix A	
$LE = \frac{ R - A }{R} \times 100$	LE = Percent Linearity Error R = Calibration gas reference value A = Average of monitor response

Linearity Check: Alternate Criteria 40 CFR 75, Appendix A, Section 3	
LE = R – A 	LE = Percent linearity error R = Calibration gas reference value A = Average of monitor response

Linearity checks are acceptable for monitor certification if none of the test results exceed the applicable performance specification of 40 CFR 75, Appendix A, Section 3.2. The results of the NO_x and O₂ shall be less than 5.0% as calculated by the above equation or the alternative criteria of ≤0.5% O₂ or ≤5 ppm difference for NO_x.

Note: If the NO_x span value is ≤30 ppm, that range of the analyzer is exempt from the linearity test requirements per 40 CFR 75, Appendix A, Section 6.2.

3.4 CO Analyzer Cylinder Gas Audit

Although not required for certification compliance (per Part 60 PS-4A) a Cylinder Gas Audit (CGA) was performed on the CO analyzer utilizing procedures from 40 CFR 60 Appendix F Procedure 1. The CGA was conducted as a demonstration check with results included in the CO analyzer summary table.

Separate calibration gas cylinders are used for the two required concentration levels during the audit. Three non-consecutive runs at each concentration level are performed. The calibration gases are introduced at the probe interface box and transported through the CEMS sampling system (normal sampling flow path).

The accuracy values for each concentration should not exceed 15% as calculated in the following equation or 5 ppm difference:

Cylinder Gas Audit Accuracy 40 CFR 60, Appendix F, Section 6.3	
$A = \frac{C_m - C_a}{C_a} \times 100$	<p>A = Percent accuracy of the CEM</p> <p>C_m = The average monitor response to the specific audit gas (high or low) in units of concentration</p> <p>C_a = Certified value of audit gas (value according to EPA Protocol certification) in units of concentration</p>

3.5 Cycle/Response Time Check – NO_x, O₂

The cycle time test measures the monitor's reaction time to a change in gas concentration (40 CFR 75, Appendix A, Section 6.4). The system measured stack concentrations until a stable response was observed. The stable stack value was recorded. A low-level (zero) calibration gas was injected at the probe sample interface. Gas injection at the probe continued until a stable monitor response was reached. Next the monitor was switched back to monitor stack gas until a stable reading was achieved and the time recorded. A span-level (80-100% of span) calibration gas was then injected at the probe until a stable response was reached. The amount of time required for the system to respond to 95% of the final stable calibration gas response value was recorded. The time was recorded for the upscale test and the downscale test for each analyzer. The response time for NO_x and O₂ will be ≤15 minutes.

The two cycle times for the upscale and downscale tests were compared. The longer of these two times was recorded as the cycle time for the analyzer.

For monitors with dual ranges, the test results from the range giving the longer cycle time was reported.

3.6 CO Analyzer Response Time Check

An on-site response time test for the CO monitoring system was performed in accordance with Performance Specification 4A, section 8.3 (as specified in recent eCFR posting). The response time test measures the monitor's reaction time to a change in gas concentration. A zero-level calibration gas was injected at the probe interface valve box such that the entire sampling system is included in the test. Gas injection continued until a stable monitor response was reached. A high span gas was then introduced to probe valve box until a stable value was observed. The upscale response time required is the amount of time to reach 95% of the final stable end value. The zero gas was re-introduced until a stable reading was reached. The downscale response time required is the amount of time to reach 95% of the final stable end value. The response times for 3 repetitions of upscale and downscale runs were recorded. An average of the 3 upscale and 3 downscale runs was determined. The response time of the longer (slower) of the two means must be ≤ 240 seconds (4 minutes).

The daily zero and span calibration gases were utilized for response time testing.

4 Test Data and Supporting Documentation

This section contains DAHS printouts and supporting documentation for tests performed in this certification test program.

4.1 7-Day Calibration Drift Data

The following pages contain DAHS printouts and supporting documentation for the drift tests performed on the gas analyzers and flow monitors. All test results are in accordance with the methods outlined in 40 CFR 75 Appendix A and 40 CFR 60 Appendix B Performance Specifications (as applicable).

7-Day Calibration Error (Drift) - NOx Low Range

40 CFR 75

Manufacturer: TAPI
 Model: T200M
 Serial Number: 646
 Measurement Span (ppm): 10

Span Gas Option
 High 80-100%

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	8.68	86.80	OK	CC280797	12/06/20	OK

Zero Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Zero Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	24-Apr-18	9:53	0.00	0.00	0.00	PASS	0.00	PASS
2	25-Apr-18	11:33	0.00	0.00	0.00	PASS	0.00	PASS
3	28-Apr-18	15:08	0.00	0.00	0.00	PASS	0.00	PASS
4	29-Apr-18	14:57	0.00	0.00	0.00	PASS	0.00	PASS
5	30-Apr-18	1:29	0.00	0.00	0.00	PASS	0.00	PASS
6	1-May-18	18:09	0.00	0.00	0.00	PASS	0.00	PASS
7	2-May-18	12:09	0.00	0.00	0.00	PASS	0.00	PASS

Highest Zero Difference 0.00 Highest Zero Drift 0.00

Span Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Span Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	24-Apr-18	9:56	8.68	8.70	0.02	PASS	0.20	PASS
2	25-Apr-18	11:36	8.68	8.60	0.08	PASS	0.80	PASS
3	28-Apr-18	15:11	8.68	8.60	0.08	PASS	0.80	PASS
4	29-Apr-18	15:00	8.68	8.50	0.18	PASS	1.80	PASS
5	30-Apr-18	1:32	8.68	8.50	0.18	PASS	1.80	PASS
6	1-May-18	18:12	8.68	8.50	0.18	PASS	1.80	PASS
7	2-May-18	12:12	8.68	8.50	0.18	PASS	1.80	PASS

Highest Span Difference 0.18 Highest Span Drift 1.80

Notes:

Allowed calibration gas ranges (40 CFR 75)
 0-20% of span
 80-100% of span

Alternately a 40-60% of span may be used.
 Change the Span Gas Option cell if a mid-level gas is used.

Pass/Fail Criteria: 2.5% of span each day of drift period
 or if the span is 200 ppm or less, then 5 ppm difference
 (40 CFR 75, Appendix A, Section 3.1)

*Only use alternate criteria when span is less than 200 ppm

Equation (40 CFR 75, Appendix A, Eq. A-5):

$CE = (|R - A| / R) \times 100$
 or alternate for span ranges less than or equal to 200 ppm
 $CE = |R - A|$

CE = Calibration Error, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

7-Day Calibration Error (Drift) - NOx High Range

40 CFR 75

Manufacturer: TAPI
 Model: T200M
 Serial Number: 646
 Measurement Span (ppm): 100

Span Gas Option
 High 80-100%

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	88.75	88.75	OK	CC477949	09/25/25	OK

Zero Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Zero Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	24-Apr-18	9:53	0.00	0.10	0.10	PASS	0.10	PASS
2	25-Apr-18	11:33	0.00	0.00	0.00	PASS	0.00	PASS
3	28-Apr-18	15:08	0.00	0.00	0.00	PASS	0.00	PASS
4	29-Apr-18	14:57	0.00	0.00	0.00	PASS	0.00	PASS
5	30-Apr-18	1:29	0.00	0.00	0.00	PASS	0.00	PASS
6	1-May-18	18:09	0.00	0.00	0.00	PASS	0.00	PASS
7	2-May-18	12:09	0.00	0.00	0.00	PASS	0.00	PASS

Highest Zero Difference 0.10 Highest Zero Drift 0.10

Span Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Span Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	24-Apr-18	9:59	88.75	89.10	0.35	PASS	0.35	PASS
2	25-Apr-18	11:39	88.75	89.40	0.65	PASS	0.65	PASS
3	28-Apr-18	15:14	88.75	88.50	0.25	PASS	0.25	PASS
4	29-Apr-18	15:03	88.75	88.20	0.55	PASS	0.55	PASS
5	30-Apr-18	1:35	88.75	88.10	0.65	PASS	0.65	PASS
6	1-May-18	18:15	88.75	88.10	0.65	PASS	0.65	PASS
7	2-May-18	12:15	88.75	87.90	0.85	PASS	0.85	PASS

Highest Span Difference 0.85 Highest Span Drift 0.85

Notes:

Allowed calibration gas ranges (40 CFR 75)
 0-20% of span
 80-100% of span

Alternately a 40-60% of span may be used.
 Change the Span Gas Option cell if a mid-level gas is used.

Pass/Fail Criteria: 2.5% of span each day of drift period
 or if the span is 200 ppm or less, then 5 ppm difference
 (40 CFR 75, Appendix A, Section 3.1)

*Only use alternate criteria when span is less than 200 ppm

Equation (40 CFR 75, Appendix A, Eq. A-5):

$CE = (|R - A| / R) \times 100$
 or alternate for span ranges less than or equal to 200 ppm
 $CE = |R - A|$

CE = Calibration Error, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

7-Day Calibration Error (Drift) - CO Low Range

Manufacturer: **TAPI**
 Model: **T300M**
 Serial Number: **354**
 Measurement Span (ppm): 10

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	8.94	89.40	OK	CC280797	12/06/20	OK

Day	Date	Cal Time	Zero Reading			Primary Criteria (%span)
			Cal Gas (R)	Response (A)	Zero Calibration Error ((R-A)/S) x 100	
1	24-Apr-18	9:53	0.00	0.00	0.00	PASS
2	25-Apr-18	11:33	0.00	-0.10	1.00	PASS
3	28-Apr-18	15:08	0.00	0.10	1.00	PASS
4	29-Apr-18	14:57	0.00	0.00	0.00	PASS
5	30-Apr-18	1:29	0.00	0.20	2.00	PASS
6	1-May-18	18:09	0.00	0.10	1.00	PASS
7	2-May-18	12:09	0.00	0.10	1.00	PASS

Highest Zero Drift 2.00

Day	Date	Cal Time	Span Reading			Primary Criteria (%span)
			Cal Gas (R)	Response (A)	Span Calibration Error ((R-A)/S) x 100	
1	24-Apr-18	9:56	8.94	8.90	0.40	PASS
2	25-Apr-18	11:36	8.94	9.10	1.60	PASS
3	28-Apr-18	15:11	8.94	9.30	3.60	PASS
4	29-Apr-18	15:00	8.94	9.10	1.60	PASS
5	30-Apr-18	1:32	8.94	9.00	0.60	PASS
6	1-May-18	18:12	8.94	8.90	0.40	PASS
7	2-May-18	12:12	8.94	8.80	1.40	PASS

Highest Span Drift 3.60

Notes:

Allowed calibration gas ranges (40 CFR 60)
 0-20% of span
 50-100% of span

Pass/Fail Criteria: 5.0% of span for 6 out of 7 days

Equation (40 CFR 60, Appendix B, PS-4):

CD = (R - A / S) x 100
 CD = Calibration Drift, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

Siemens
 CPV Valley Energy Center
 CTG 2
 Middletown, NY

Project # CN50478

Result: **PASS**

7-Day Calibration Error (Drift) - CO High Range

Manufacturer: **TAPI**
 Model: **T300M**
 Serial Number: **354**
 Measurement Span (ppm): **3000**

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	2591.00	86.37	OK	EB0095371	09/19/25	OK

Day	Date	Cal Time	Zero Reading			Primary Criteria (%span)
			Cal Gas (R)	Response (A)	Zero Calibration Error ((R-A)/S) x 100	
1	24-Apr-18	9:53	0.00	0.80	0.03	PASS
2	25-Apr-18	11:33	0.00	-0.90	0.03	PASS
3	28-Apr-18	15:08	0.00	-1.90	0.06	PASS
4	29-Apr-18	14:57	0.00	-0.40	0.01	PASS
5	30-Apr-18	1:29	0.00	-0.60	0.02	PASS
6	1-May-18	18:09	0.00	-0.80	0.03	PASS
7	2-May-18	12:09	0.00	-0.90	0.03	PASS

Highest Zero Drift **0.06**

Day	Date	Cal Time	Span Reading			Primary Criteria (%span)
			Cal Gas (R)	Response (A)	Span Calibration Error ((R-A)/S) x 100	
1	24-Apr-18	10:02	2591.00	2578.10	0.43	PASS
2	25-Apr-18	11:42	2591.00	2601.40	0.35	PASS
3	28-Apr-18	15:17	2591.00	2604.40	0.45	PASS
4	29-Apr-18	15:06	2591.00	2611.30	0.68	PASS
5	30-Apr-18	1:38	2591.00	2608.90	0.60	PASS
6	1-May-18	18:18	2591.00	2599.90	0.30	PASS
7	2-May-18	12:18	2591.00	2598.00	0.23	PASS

Highest Span Drift **0.68**

Notes:

Allowed calibration gas ranges (40 CFR 60)
 0-20% of span
 50-100% of span

Pass/Fail Criteria: 5.0% of span for 6 out of 7 days

Equation (40 CFR 60, Appendix B, PS-4):

CD = (R - A / S) x 100
 CD = Calibration Drift, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

7-Day Calibration Error (Drift) - O2

40 CFR 75, Appendix A, Section 3.1

Manufacturer: **TAPI**
 Model: **T200M**
 Serial Number: **646**
 Analyzer Range (%): 25

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	20.89	83.56	OK	EB0095371	09/19/25	OK

Zero Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift R-A	Criteria (% diff)
1	25-Apr-18	11:33	0.00	0.00	0.00	PASS
2	28-Apr-18	15:08	0.00	0.00	0.00	PASS
3	29-Apr-18	14:57	0.00	0.00	0.00	PASS
4	30-Apr-18	1:29	0.00	0.00	0.00	PASS
5	1-May-18	18:09	0.00	0.00	0.00	PASS
6	2-May-18	12:09	0.00	0.00	0.00	PASS
7	3-May-18	14:08	0.00	0.00	0.00	PASS

Highest Zero Drift 0.00

Span Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift R-A	Criteria (% diff)
1	25-Apr-18	11:42	20.89	20.90	0.01	PASS
2	28-Apr-18	15:17	20.89	20.90	0.01	PASS
3	29-Apr-18	15:06	20.89	20.90	0.01	PASS
4	30-Apr-18	1:38	20.89	20.90	0.01	PASS
5	1-May-18	18:18	20.89	20.90	0.01	PASS
6	2-May-18	12:18	20.89	20.90	0.01	PASS
7	3-May-18	14:17	20.89	20.90	0.01	PASS

Highest Span Drift 0.01

Notes:

Allowed calibration gas ranges (40 CFR 75)
 0-20% of span
 80-100% of span

Pass/Fail Criteria: 0.5% difference for each day of the drift period
 (40 CFR 75, Appendix A, Section 3.1)

Equation (40 CFR 75, Appendix A, Section 3.1):

$$CE = |R - A|$$

CE = Calibration Error, %
 R = Calibration Gas Reference Value, %O2
 A = Monitor Response, %O2

Siemens
 CPV Valley Energy Center
 CTG 2
 Middletown, NY

Project # CN50478

Result: Pass

7-Day Calibration Error (Drift) - CO2

40 CFR 60, PS-3

Manufacturer: **TAPI**
 Model: **T300M**
 Serial Number: **354**
 Analyzer Range (%): 10

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	8.90	89.00	OK	EB0095371	09/19/25	OK

Zero Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift R-A	Criteria (% diff)
1	24-Apr-18	9:53	0.00	0.00	0.00	PASS
2	25-Apr-18	11:33	0.00	0.00	0.00	PASS
3	28-Apr-18	15:08	0.00	0.00	0.00	PASS
4	29-Apr-18	14:57	0.00	0.00	0.00	PASS
5	30-Apr-18	1:29	0.00	0.00	0.00	PASS
6	1-May-18	18:09	0.00	0.00	0.00	PASS
7	2-May-18	12:09	0.00	0.00	0.00	PASS

Highest Zero Drift 0.00

Span Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift (CD) R-A	Criteria (% diff)
1	24-Apr-18	10:02	8.90	8.70	0.20	PASS
2	25-Apr-18	11:42	8.90	8.60	0.30	PASS
3	28-Apr-18	15:17	8.90	8.70	0.20	PASS
4	29-Apr-18	15:06	8.90	8.70	0.20	PASS
5	30-Apr-18	1:38	8.90	8.70	0.20	PASS
6	1-May-18	18:18	8.90	8.70	0.20	PASS
7	2-May-18	12:18	8.90	8.70	0.20	PASS

Highest Span Drift 0.30

Notes:

Allowed calibration gas ranges (40 CFR 60, PS-3)
 0-20% of span
 50-100% of span

Pass/Fail Criteria: 0.5% difference for each day of the drift period

Equation (40 CFR 60, Appendix B):

$CD = R - A$

CD = Calibration Drift, %

R = Calibration Gas Value, %CO2

A = Monitor Response, %CO2

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
① 04/24/2018 09:53	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
② 04/24/2018 09:56	CTG2 NOx Low P75	Upscale	8.70	8.70	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
③ 04/25/2018 11:33	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
④ 04/25/2018 11:36	CTG2 NOx Low P75	Upscale	8.70	8.60	1.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑤ 04/28/2018 15:08	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑥ 04/28/2018 15:11	CTG2 NOx Low P75	Upscale	8.70	8.60	1.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑦ 04/29/2018 14:57	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑧ 04/29/2018 15:00	CTG2 NOx Low P75	Upscale	8.70	8.50	2.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑨ 04/30/2018 01:29	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑩ 04/30/2018 01:32	CTG2 NOx Low P75	Upscale	8.70	8.50	2.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑪ 04/30/2018 05:36	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑫ 04/30/2018 05:39	CTG2 NOx Low P75	Upscale	8.70	8.50	2.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑬ 05/01/2018 18:09	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑭ 05/01/2018 18:12	CTG2 NOx Low P75	Upscale	8.70	8.50	2.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑮ 05/02/2018 12:09	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑯ 05/02/2018 12:12	CTG2 NOx Low P75	Upscale	8.70	8.50	2.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑰ 05/03/2018 14:08	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑱ 05/03/2018 14:11	CTG2 NOx Low P75	Upscale	8.70	8.50	2.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20
⑲ 05/07/2018 17:15	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass	ON	ON	ON	CC2807 97	12/06/20

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
05/07/2018 17:18	CTG2 NOx Low P75	Upscale	8.70	8.50	2.00	2.50	10.00		0	Pass			ON	CC2807 97	12/06/20
05/08/2018 15:32	CTG2 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00		0	Pass			ON		
05/08/2018 15:35	CTG2 NOx Low P75	Upscale	8.70	8.70	0.00	2.50	10.00		0	Pass			ON	CC2807 97	12/06/20

Calibration Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

7 certified NOx from cal gas cert

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/24/2018 09:53	CTG2 NOx High P75	Zero	0.00	0.10	-0.10	2.50	100.00	①	0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/24/2018 09:59	CTG2 NOx High P75	Upscale	88.60 88.75	89.10	-0.50	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/25/2018 11:33	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00	②	0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/25/2018 11:39	CTG2 NOx High P75	Upscale	88.60	89.40	-0.80	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/28/2018 15:08	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00	③	0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/28/2018 15:14	CTG2 NOx High P75	Upscale	88.60	88.50	0.10	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/29/2018 14:57	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00	④	0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/29/2018 15:03	CTG2 NOx High P75	Upscale	88.60	88.20	0.40	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/30/2018 01:29	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00	⑤	0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/30/2018 01:35	CTG2 NOx High P75	Upscale	88.60	88.10	0.50	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/30/2018 05:36	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
04/30/2018 05:42	CTG2 NOx High P75	Upscale	88.60	88.30	0.30	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
05/01/2018 18:09	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00	⑥	0	Pass	ON	ON	ON	CC4779 49	09/25/25
05/01/2018 18:45	CTG2 NOx High P75	Upscale	88.60	88.10	0.50	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
05/02/2018 12:09	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00	⑦	0	Pass	ON	ON	ON	CC4779 49	09/25/25
05/02/2018 12:15	CTG2 NOx High P75	Upscale	88.60	87.90	0.70	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
05/03/2018 14:08	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
05/03/2018 14:14	CTG2 NOx High P75	Upscale	88.60	87.80	0.80	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25
05/07/2018 17:15	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00		0	Pass	ON	ON	ON	CC4779 49	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
05/07/2018 17:21	CTG2 NOx High P75	Upscale	88.60	87.20	1.40	2.50	100.00		0	Pass			ON	CC4779 49	09/25/25
05/08/2018 15:32	CTG2 NOx High P75	Zero	0.00	0.00	0.00	2.50	100.00		0	Pass			ON		
05/08/2018 15:38	CTG2 NOx High P75	Upscale	88.60	87.20	1.40	2.50	100.00		0	Pass			ON	CC4779 49	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/25/2018 11:33	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/25/2018 11:42	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/28/2018 15:08	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/28/2018 15:17	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/29/2018 14:57	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/29/2018 15:06	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 01:29	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 01:38	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 05:36	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 05:45	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/01/2018 18:09	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/01/2018 18:18	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/02/2018 12:09	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/02/2018 12:18	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/03/2018 14:08	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/03/2018 14:17	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/07/2018 17:15	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/07/2018 17:24	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25
05/08/2018 15:32	CTG2 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 371	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
05/08/2018 15:41	CTG2 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00		0	Pass			ON	EB0095 371	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/24/2018 09:53	CTG2 CO Low	Zero	0.00	0.00	0.00	5.00	10.00	Pass	0	①	ON	ON	ON	CC2807 97	12/06/20
04/24/2018 09:56	CTG2 CO Low	Upscale	9.00	8.90	1.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
04/25/2018 11:33	CTG2 CO Low	Zero	0.00	-0.10	1.00	5.00	10.00	Pass	0	②	ON	ON	ON	CC2807 97	12/06/20
04/25/2018 11:36	CTG2 CO Low	Upscale	9.00	9.10	-1.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
04/28/2018 15:08	CTG2 CO Low	Zero	0.00	0.10	-1.00	5.00	10.00	Pass	0	③	ON	ON	ON	CC2807 97	12/06/20
04/28/2018 15:11	CTG2 CO Low	Upscale	9.00	9.30	-3.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
04/29/2018 14:57	CTG2 CO Low	Zero	0.00	0.00	0.00	5.00	10.00	Pass	0	④	ON	ON	ON	CC2807 97	12/06/20
04/29/2018 15:00	CTG2 CO Low	Upscale	9.00	9.10	-1.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
04/30/2018 01:29	CTG2 CO Low	Zero	0.00	0.20	-2.00	5.00	10.00	Pass	0	⑤	ON	ON	ON	CC2807 97	12/06/20
04/30/2018 01:32	CTG2 CO Low	Upscale	9.00	9.00	0.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
04/30/2018 05:36	CTG2 CO Low	Zero	0.00	0.30	-3.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
04/30/2018 05:39	CTG2 CO Low	Upscale	9.00	8.90	1.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
05/01/2018 18:09	CTG2 CO Low	Zero	0.00	0.10	-1.00	5.00	10.00	Pass	0	⑥	ON	ON	ON	CC2807 97	12/06/20
05/01/2018 18:12	CTG2 CO Low	Upscale	9.00	8.90	1.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
05/02/2018 12:09	CTG2 CO Low	Zero	0.00	0.10	-1.00	5.00	10.00	Pass	0	⑦	ON	ON	ON	CC2807 97	12/06/20
05/02/2018 12:12	CTG2 CO Low	Upscale	9.00	8.80	2.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
05/03/2018 14:08	CTG2 CO Low	Zero	0.00	0.20	-2.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
05/03/2018 14:11	CTG2 CO Low	Upscale	9.00	9.20	-2.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20
05/07/2018 17:15	CTG2 CO Low	Zero	0.00	0.20	-2.00	5.00	10.00	Pass	0		ON	ON	ON	CC2807 97	12/06/20

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/24/2018 09:53	CTG2 CO High	Zero	0.00	0.80	-0.03	5.00	3,000.00	Pass	0	①	ON	ON	ON	EB0095 371	09/25/25
04/24/2018 10:02	CTG2 CO High	Upscale	2591.00	2578.10	0.43	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
04/25/2018 11:33	CTG2 CO High	Zero	0.00	-0.90	0.03	5.00	3,000.00	Pass	0	②	ON	ON	ON	EB0095 371	09/25/25
04/25/2018 11:42	CTG2 CO High	Upscale	2591.00	2601.40	-0.35	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
04/28/2018 15:08	CTG2 CO High	Zero	0.00	-1.90	0.06	5.00	3,000.00	Pass	0	③	ON	ON	ON	EB0095 371	09/25/25
04/28/2018 15:17	CTG2 CO High	Upscale	2591.00	2604.40	-0.45	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
04/29/2018 14:57	CTG2 CO High	Zero	0.00	-0.40	0.01	5.00	3,000.00	Pass	0	④	ON	ON	ON	EB0095 371	09/25/25
04/29/2018 15:06	CTG2 CO High	Upscale	2591.00	2611.30	-0.68	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
04/30/2018 01:29	CTG2 CO High	Zero	0.00	-0.60	0.02	5.00	3,000.00	Pass	0	⑤	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 01:38	CTG2 CO High	Upscale	2591.00	2608.90	-0.60	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
04/30/2018 05:36	CTG2 CO High	Zero	0.00	-0.60	0.02	5.00	3,000.00	Pass	0	⑥	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 05:45	CTG2 CO High	Upscale	2591.00	2600.10	-0.30	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
05/01/2018 18:09	CTG2 CO High	Zero	0.00	-0.80	0.03	5.00	3,000.00	Pass	0	⑥	ON	ON	ON	EB0095 371	09/25/25
05/01/2018 18:18	CTG2 CO High	Upscale	2591.00	2599.90	-0.30	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
05/02/2018 12:09	CTG2 CO High	Zero	0.00	-0.90	0.03	5.00	3,000.00	Pass	0	⑦	ON	ON	ON	EB0095 371	09/25/25
05/02/2018 12:18	CTG2 CO High	Upscale	2591.00	2598.00	-0.23	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
05/03/2018 14:08	CTG2 CO High	Zero	0.00	-0.90	0.03	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
05/03/2018 14:17	CTG2 CO High	Upscale	2591.00	2603.20	-0.41	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25
05/07/2018 17:15	CTG2 CO High	Zero	0.00	0.60	-0.02	5.00	3,000.00	Pass	0		ON	ON	ON	EB0095 371	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
05/07/2018 17:24	CTG2 CO High	Upscale	2591.00	2607.90	-0.56	5.00	3,000.00	Pass	0				ON	EB0095 371	09/25/25
05/08/2018 15:32	CTG2 CO High	Zero	0.00	-1.90	0.06	5.00	3,000.00	Pass	0				ON		
05/08/2018 15:41	CTG2 CO High	Upscale	2591.00	2595.20	-0.14	5.00	3,000.00	Pass	0				ON	EB0095 371	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
05/07/2018 17:18	CTG2 CO Low	Upscale	9.00	9.00	0.00	5.00	10.00	Pass	0				ON	CC2807 97	12/06/20
05/08/2018 15:32	CTG2 CO Low	Zero	0.00	0.00	0.00	5.00	10.00	Pass	0				ON		
05/08/2018 15:35	CTG2 CO Low	Upscale	8.80	9.10	-3.00	5.00	10.00	Pass	0				ON	CC2807 97	12/06/20

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/24/2018 09:53	CTG2 CO2 P60	Zero	0.00	0.00	0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/24/2018 10:02	CTG2 CO2 P60	Upscale	8.90	8.70	① 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/25/2018 11:33	CTG2 CO2 P60	Zero	0.00	0.00	② 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/25/2018 11:42	CTG2 CO2 P60	Upscale	8.90	8.60	③ 0.30	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/28/2018 15:08	CTG2 CO2 P60	Zero	0.00	0.00	④ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/28/2018 15:17	CTG2 CO2 P60	Upscale	8.90	8.70	⑤ 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/29/2018 14:57	CTG2 CO2 P60	Zero	0.00	0.00	⑥ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/29/2018 15:06	CTG2 CO2 P60	Upscale	8.90	8.70	⑦ 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 01:29	CTG2 CO2 P60	Zero	0.00	0.00	⑧ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 01:38	CTG2 CO2 P60	Upscale	8.90	8.70	⑨ 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 05:36	CTG2 CO2 P60	Zero	0.00	0.00	⑩ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
04/30/2018 05:45	CTG2 CO2 P60	Upscale	8.90	8.70	⑪ 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
05/01/2018 18:09	CTG2 CO2 P60	Zero	0.00	0.00	⑫ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
05/01/2018 18:18	CTG2 CO2 P60	Upscale	8.90	8.70	⑬ 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
05/02/2018 12:09	CTG2 CO2 P60	Zero	0.00	0.00	⑭ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
05/02/2018 12:18	CTG2 CO2 P60	Upscale	8.90	8.70	⑮ 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
05/03/2018 14:08	CTG2 CO2 P60	Zero	0.00	0.00	⑯ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
05/03/2018 14:17	CTG2 CO2 P60	Upscale	8.90	8.70	⑰ 0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25
05/07/2018 17:15	CTG2 CO2 P60	Zero	0.00	0.00	⑱ 0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 371	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
05/07/2018 17:24	CTG2 CO2 P60	Upscale	8.90	8.70	0.20	0.50	10.00	Pass	0				ON	EB0095 371	09/25/25
05/08/2018 15:32	CTG2 CO2 P60	Zero	0.00	0.00	0.00	0.50	10.00	Pass	0				ON		
05/08/2018 15:41	CTG2 CO2 P60	Upscale	8.90	8.70	0.20	0.50	10.00	Pass	0				ON	EB0095 371	09/25/25

4.2 Linearity and CGA Data

The following pages contain DAHS printouts and supporting documentation for the linearity and CGA checks performed on the gas analyzers. All test results are in accordance with the methods outlined in 40 CFR 75 Appendix A, section 6.2 and 40 CFR 60 Appendix F (as applicable).

Siemens
 CPV Valley Energy Center
 CTG 2
 Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project # CN50478

Linearity Test - NOx Low Range

40 CFR 75, Appendix A, Section 3.2

Manufacturer: TAPI
 Model: T200M
 Serial Number: 646
 Analyzer Range: 10 ppm
 Test Date: 11-May-18

Pass

	Gas Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check
Low	2.42	24.20	OK	EB0072315	07/04/20	OK
Mid	5.09	50.90	OK	EB0101725	12/03/20	OK
High	8.68	86.80	OK	CC280797	12/06/20	OK

Run Number	Run Level	Cal Gas Value (R)	Time	Monitor Response (A)	Difference (R-A)		
					Low	Mid	High
1	Low	2.42	8:48	2.40	0.02	-0.21	0.18
2	Mid	5.09	8:52	5.30			
3	High	8.68	8:56	8.50			
4	Low	2.42	9:00	2.30	0.12	-0.21	0.18
5	Mid	5.09	9:04	5.30			
6	High	8.68	9:08	8.50			
7	Low	2.42	9:12	2.30	0.12	-0.21	0.18
8	Mid	5.09	9:16	5.30			
9	High	8.68	9:20	8.50			
<i>Average Response</i>					2.33	5.30	8.50
<i>Absolute Difference of Average</i>					0.09	0.21	0.18
<i>Status (for alternate criteria of 5 ppm difference)</i>					PASS	PASS	PASS
<i>Linearity Error, %</i>					3.58	4.13	2.07
<i>Status</i>					PASS	PASS	PASS

Notes:
 Pass/fail criteria = 5% or less; or abs mean difference = 5 ppm or less
 (40 CFR 75, Appendix A, Section 3.2)

Cal Gas Allowances (40 CFR 75)
 Low = 20-30% of span
 Mid = 50-60% of span
 High = 80-100% of span

Equation (40 CFR 75, Appendix A, Eq A-4):
 $LE = (|R - A| / R) \times 100$
 or
 $LE = |R - A|$ (40 CFR 75, Appendix A, Section 3.2)
 LE = Linearity Error
 R = Calibration Gas Reference Value
 A = Average of Monitor Response

Siemens
CPV Valley Energy Center
CTG 2
Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project # CN50478

Linearity Test - NOx High Range

40 CFR 75, Appendix A, Section 3.2

Manufacturer: TAPI
 Model: T200M
 Serial Number: 646
 Analyzer Range: 100 ppm
 Test Date: 10-May-18

Pass

	Gas Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check
Low	24.60	24.60	OK	EB0073000	03/19/21	OK
Mid	50.89	50.89	OK	CC503502	11/01/25	OK
High	88.75	88.75	OK	CC477949	09/25/25	OK

Run Number	Run Level	Cal Gas Value (R)	Time	Monitor Response (A)	Difference (R-A)		
					Low	Mid	High
1	Low	24.60	16:48	25.40	-0.80	-1.11	1.55
2	Mid	50.89	16:52	52.00			
3	High	88.75	16:56	87.20			
4	Low	24.60	17:00	25.50	-0.90	-1.01	1.55
5	Mid	50.89	17:04	51.90			
6	High	88.75	17:08	87.20			
7	Low	24.60	17:13	25.40	-0.80	-1.11	1.85
8	Mid	50.89	17:17	52.00			
9	High	88.75	17:20	86.90			
<i>Average Response</i>					25.43	51.97	87.10
<i>Absolute Difference of Average</i>					0.83	1.08	1.65
<i>Status (for alternate criteria of 5 ppm difference)</i>					PASS	PASS	PASS
<i>Linearity Error, %</i>					3.39	2.12	1.86
<i>Status</i>					PASS	PASS	PASS

Notes:
 Pass/fail criteria = 5% or less; or abs mean difference = 5 ppm or less
 (40 CFR 75, Appendix A, Section 3.2)

Cal Gas Allowances (40 CFR 75)
 Low = 20-30% of span
 Mid = 50-60% of span
 High = 80-100% of span

Equation (40 CFR 75, Appendix A, Eq A-4):
 $LE = (|R - A| / R) \times 100$
 or
 $LE = |R - A|$ (40 CFR 75, Appendix A, Section 3.2)
 LE = Linearity Error
 R = Calibration Gas Reference Value
 A = Average of Monitor Response

Siemens
CPV Valley Energy Center
CTG 2
Middletown, NY

Tested by: Justin Saporito

Company: Cemtek KVB-Enertec

Project # CN50478

Linearity Test - O2

40 CFR 75, Appendix A, Section 3.2

Manufacturer: **TAPI**

Model: **T200M**

Serial Number: **646**

Analyzer Range: **25** %

Test Date: **11-May-18**

Pass

	Gas Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check
Low	6.36	25.44	OK	EB0049201	08/13/21	OK
Mid	13.82	55.28	OK	EB0060674	04/01/26	OK
High	20.89	83.56	OK	EB0095371	09/19/25	OK

Run Number	Run Level	Cal Gas Value (R)	Time	Monitor Response (A)	Difference (R-A)		
					Low	Mid	High
1	Low	6.36	10:23	6.20	0.16	0.02	-0.01
2	Mid	13.82	10:27	13.80			
3	High	20.89	10:32	20.90			
4	Low	6.36	10:36	6.20	0.16	0.02	-0.01
5	Mid	13.82	10:40	13.80			
6	High	20.89	10:44	20.90			
7	Low	6.36	10:48	6.20	0.16	0.02	-0.01
8	Mid	13.82	10:52	13.80			
9	High	20.89	10:56	20.90			
<i>Average Response</i>					6.20	13.80	20.90
<i>Absolute Difference of Average</i>					0.16	0.02	0.01
<i>Status (for alternate criteria of .5% difference)</i>					PASS	PASS	PASS
<i>Linearity Error, %</i>					2.52	0.14	0.05
<i>Status</i>					PASS	PASS	PASS

Notes:

Pass/fail criteria = 5% or less; or abs mean difference = 0.5% or less
(40 CFR 75, Appendix A, Section 3.2)

Cal Gas Allowances
Low = 20-30% of span
Mid = 50-60% of span
High = 80 100% of span

Equation (40 CFR 75, Appendix A, Eq A-4):

LE = (|R - A| / R) x 100
or
LE = |R - A| (40 CFR 75, Appendix A, Section 3.2)

LE = Linearity Error
R = Calibration Gas Reference Value
A = Average of Monitor Response

Cylinder Gas Audit - CO Low Range

Manufacturer: TAPI
 Model: T300M
 Serial Number: 354
 Analyzer Range: 10
 Test Date: 05/11/18

	Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	2.67	26.70	OK	EB0072315	07/04/20	OK
Mid	5.66	56.60	OK	EB0101725	12/30/20	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	8:48	2.30	8:52	5.50
2	8:59	2.50	9:03	5.40
3	9:12	2.30	9:16	5.30
Average Response (Cm)		2.37		5.40
Difference (Cm-Ca)		-0.30		-0.26
Status (for alternate criteria of 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-11.36		-4.59
Status (for primary criteria of 15%)		PASS		PASS

Cylinder Gas Audit - CO High Range

Analyzer Range: 3000
 Test Date: 05/10/18

	Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	753.00	25.10	OK	EB0040994	04/04/26	OK
Mid	1670.00	55.67	OK	EB0072144	04/04/26	OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	17:39	777.10	17:43	1698.80
2	17:47	775.00	17:51	1699.30
3	17:55	775.50	18:00	1697.40
Average Response (Cm)		775.87		1698.50
Difference (Cm-Ca)		22.87		28.50
Status (for alternate criteria of 5 ppm difference)		FAIL		FAIL
Accuracy %, ((Cm-Ca)/Ca) * 100		3.04		1.71
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% or 5.0 ppm difference for pollutants
 (40 CFR 60, Appendix F)

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

CTG2 HTP_OIL_P75 CTG2 NOX_LOW_P75

MMBTUHR	OS	MS	PPMD	OS	MS
1488.9	ON	GD	2.5	ON	QA
1528.1	ON	GD	3.2	ON	QA
1567.3	ON	GD	2.5	ON	QA
1606.5	ON	GD	2.4	ON	QA
1665.2	ON	GD	2.4	ON	QA
1704.4	ON	GD	4.4	ON	QA
1743.6	ON	GD	5.3	ON	QA
1782.8	ON	GD	5.3	ON	QA
1822.0	ON	GD	5.3	ON	QA
1861.1	ON	GD	7.9	ON	QA
1919.9	ON	GD	8.6	ON	QA
1959.1	ON	GD	8.5	ON	QA
1978.7	ON	GD	8.5	ON	QA
1978.7	ON	GD	3.9	ON	QA
1978.7	ON	GD	2.4	ON	QA
1978.7	ON	GD	2.3	ON	QA
1978.7	ON	GD	2.3	ON	QA
1959.1	ON	GD	4.1	ON	QA
1959.1	ON	GD	5.4	ON	QA
1959.1	ON	GD	5.3	ON	QA
1959.1	ON	GD	5.3	ON	QA
1959.1	ON	GD	7.8	ON	QA
1959.1	ON	GD	8.6	ON	QA
1959.1	ON	GD	8.5	ON	QA
1959.1	ON	GD	8.5	ON	QA
1959.1	ON	GD	4.0	ON	QA
1959.1	ON	GD	2.4	ON	QA
1959.1	ON	GD	2.3	ON	QA

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation

MS - General Monitor Status:

OFF - off-line
 CF - changing fuels
 CM - control equipment malfunction
 CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

Report generated on: 05/11/2018 09:24

Data is expressed in Standard Time

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 HTP_OIL_P75 CTG2 NOX_LOW_P75

MMBTUHR	OS	MS	PPMD	OS	MS
1959.1	ON	GD	2.3	ON	QA
1959.1	ON	GD	4.5	ON	QA
1959.1	ON	GD	5.3	ON	QA
1959.1	ON	GD	5.3	ON	QA
1959.1	ON	GD	5.3	ON	QA
1959.1	ON	GD	7.7	ON	QA
1959.1	ON	GD	8.5	ON	QA
1959.1	ON	GD	8.5	ON	QA
1959.1	ON	GD	8.5	ON	QA
1959.1	ON	GD	9.9	ON	GD
1959.1	ON	GD	10.6	ON	GD
1959.1	ON	GD	10.6	ON	GD
1959.1	ON	GD	10.6	ON	GD

Average	1890.0	10.4
Maximum	1978.7	10.6
Minimum	1488.9	9.9
Total	75601.7	41.7

OS - Operating Status:
 SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction MD - unknown operating status

MS - General Monitor Status:
 GD - good data CP - clean process equipment
 GO - monitor over range CC - clean control equipment
 QA - quality assurance activity MD - unknown operating status

MS - General Monitor Status:
 MN - maintenance activity
 IV - invalid

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

CTG2 HTIP_OIL_P75 CTG2 NOX_HIGH_P75

MMBTUHR	OS	MS	PPMD	OS	MS
1880.7	SU	GD	3.9	SU	QA
1880.7	SU	GD	5.7	SU	QA
1880.7	SU	GD	19.7	SU	QA
1880.7	SU	GD	25.4	SU	QA
1880.7	SU	GD	25.4	SU	QA
1880.7	SU	GD	25.4	SU	QA
1880.7	SU	GD	44.7	SU	QA
1880.7	SU	GD	52.0	SU	QA
1880.7	SU	GD	52.0	SU	QA
1880.7	SU	GD	51.9	SU	QA
1880.7	SU	GD	72.0	SU	QA
1880.7	SU	GD	87.2	SU	QA
1880.7	SU	GD	87.2	SU	QA
1880.7	SU	GD	87.3	SU	QA
1880.7	SU	GD	61.6	SU	QA
1880.7	SU	GD	25.5	SU	QA
1880.7	SU	GD	25.5	SU	QA
1880.7	SU	GD	25.5	SU	QA
1880.7	SU	GD	31.7	SU	QA
1880.7	SU	GD	52.0	SU	QA
1880.7	SU	GD	51.9	SU	QA
1880.7	SU	GD	51.9	SU	QA
1880.7	SU	GD	54.8	SU	QA
1880.7	SU	GD	87.0	SU	QA
1880.7	SU	GD	87.2	SU	QA
1880.7	SU	GD	87.2	SU	QA
1880.7	SU	GD	82.2	SU	QA
1880.7	SU	GD	30.6	SU	QA

2

3

1

2

3

OS - Operating Status:
 SU - startup mode OFF - off-line CP - clean process equipment MS - General Monitor Status:
 SD - shutdown mode CF - changing fuels CC - clean control equipment GD - good data MN - maintenance activity
 ON - normal operation CM - control equipment malfunction MD - unknown operating status GO - monitor over range IV - invalid
 QA - quality assurance activity

Report generated on: 05/10/2018 17:20 Data is expressed in Standard Time

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 HTIP_OIL_P75 CTG2 NOX_HIGH_P75

MMBTUHR	OS	MS	PPMD	OS	MS
1880.7	SU	GD	25.5	SU	QA
1880.7	SU	GD	25.4	SU	QA
1880.7	SU	GD	25.4	SU	QA
1880.7	SU	GD	45.3	SU	QA
1880.7	SU	GD	52.0	SU	QA
1880.7	SU	GD	52.0	SU	QA
1880.7	SU	GD	51.9	SU	QA
1880.7	SU	GD	72.4	SU	QA
1880.7	SU	GD	86.9	SU	QA

Average	1880.7
Maximum	1880.7
Minimum	1880.7
Total	69585.9

OS - Operating Status:

- SU - startup mode
- SD - shutdown mode
- ON - normal operation
- OFF - off-line
- CF - changing fuels
- CM - control equipment malfunction

MS - General Monitor Status:

- GD - good data
- GO - monitor over range
- QA - quality assurance activity
- CP - clean process equipment
- CC - clean control equipment
- MD - unknown operating status
- MN - maintenance activity
- IV - invalid

Report generated on: 05/10/2018 17:20

Data is expressed in Standard Time

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Mawayanda

CTG2 HTIP_OIL_P75 CTG2 O2_P75

MMBTUHR	OS	MS	PCT	OS	MS
1939.5	ON	GD	13.8	ON	GD
1939.5	ON	GD	13.8	ON	GD
1939.5	ON	GD	13.8	ON	GD
1939.5	ON	GD	13.8	ON	GD
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	13.6	ON	QA
1939.5	ON	GD	9.8	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	7.9	ON	QA
1939.5	ON	GD	13.7	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	14.0	ON	QA
1939.5	ON	GD	20.7	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	20.8	ON	QA
1939.5	ON	GD	6.9	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	6.3	ON	QA
1939.5	ON	GD	13.3	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	19.0	ON	QA

OS - Operating Status:
 SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:
 CP - clean process equipment GD - good data
 CC - clean control equipment GO - monitor over range
 MD - unknown operating status QA - quality assurance activity
 MN - maintenance activity
 IV - invalid

Report generated on: 05/11/2018 12:46 Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

CTG2 HTIP_OIL_P75 CTG2 O2_P75

MMBTUHR	OS	MS	PCT	OS	MS
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	11.4	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	6.2	ON	QA
1939.5	ON	GD	9.9	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	13.8	ON	QA
1939.5	ON	GD	17.2	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	20.9	ON	QA
1939.5	ON	GD	14.4	ON	QA
1939.5	ON	GD	0.1	ON	QA
1939.5	ON	GD	0.0	ON	QA
Average			13.8		
Maximum			13.8		
Minimum			13.8		
Total			89217.0		55.2

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation
 OFF - off-line
 CF - changing fuels
 CM - control equipment malfunction

MS - General Monitor Status:

GD - good data
 GO - monitor over range
 QA - quality assurance activity
 CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

Report generated on: 05/11/2018 12:46

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

CTG2 CO CTG2 HTIP_OIL_P75

	PPMD	OS	MS	MMBTUHR	OS	MS
05/11/2018 08:45	2.6	ON	QA	1488.9	ON	GD
05/11/2018 08:46	3.1	ON	QA	1528.1	ON	GD
05/11/2018 08:47	2.4	ON	QA	1567.3	ON	GD
05/11/2018 08:48	2.3	ON	QA	1606.5	ON	GD
05/11/2018 08:49	2.3	ON	QA	1665.2	ON	GD
05/11/2018 08:50	4.0	ON	QA	1704.4	ON	GD
05/11/2018 08:51	5.5	ON	QA	1743.6	ON	GD
05/11/2018 08:52	5.5	ON	QA	1782.8	ON	GD
05/11/2018 08:53	5.3	ON	QA	1822.0	ON	GD
05/11/2018 08:54	7.1	ON	QA	1861.1	ON	GD
05/11/2018 08:55	8.7	ON	QA	1919.9	ON	GD
05/11/2018 08:56	8.7	ON	QA	1959.1	ON	GD
05/11/2018 08:57	8.6	ON	QA	1978.7	ON	GD
05/11/2018 08:58	5.5	ON	QA	1978.7	ON	GD
05/11/2018 08:59	2.5	ON	QA	1978.7	ON	GD
05/11/2018 09:00	2.4	ON	QA	1978.7	ON	GD
05/11/2018 09:01	2.5	ON	QA	1978.7	ON	GD
05/11/2018 09:02	4.0	ON	QA	1959.1	ON	GD
05/11/2018 09:03	5.4	ON	QA	1959.1	ON	GD
05/11/2018 09:04	5.3	ON	QA	1959.1	ON	GD
05/11/2018 09:05	5.4	ON	QA	1959.1	ON	GD
05/11/2018 09:06	6.9	ON	QA	1959.1	ON	GD
05/11/2018 09:07	8.5	ON	QA	1959.1	ON	GD
05/11/2018 09:08	8.6	ON	QA	1959.1	ON	GD
05/11/2018 09:09	8.5	ON	QA	1959.1	ON	GD
05/11/2018 09:10	5.5	ON	QA	1959.1	ON	GD
05/11/2018 09:11	2.4	ON	QA	1959.1	ON	GD
05/11/2018 09:12	2.3	ON	QA	1959.1	ON	GD

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data
 CC - clean control equipment GO - monitor over range
 MD - unknown operating status QA - quality assurance activity

Report generated on: 05/11/2018 09:25

Data is expressed in Standard Time

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 CO CTG2 HTIP_OIL_P75

	PPMD	OS	MS	MMBTUHR	OS	MS
05/11/2018 09:13	2.4	ON	QA	1959.1	ON	GD
05/11/2018 09:14	3.8	ON	QA	1959.1	ON	GD
05/11/2018 09:15	5.1	ON	QA	1959.1	ON	GD
05/11/2018 09:16	5.3	ON	QA	1959.1	ON	GD
05/11/2018 09:17	5.3	ON	QA	1959.1	ON	GD
05/11/2018 09:18	7.2	ON	QA	1959.1	ON	GD
05/11/2018 09:19	8.6	ON	QA	1959.1	ON	GD
05/11/2018 09:20	8.6	ON	QA	1959.1	ON	GD
05/11/2018 09:21	8.5	ON	QA	1959.1	ON	GD
05/11/2018 09:22	6.0	ON	GD	1959.1	ON	GD
05/11/2018 09:23	3.9	ON	GD	1959.1	ON	GD
05/11/2018 09:24	3.6	ON	GD	1959.1	ON	GD
05/11/2018 09:25	3.4	ON	GD	1959.1	ON	GD
05/11/2018 09:26	3.4	ON	GD	1959.1	ON	GD

Average	4.1	1891.7
Maximum	6.0	1978.7
Minimum	3.4	1488.9
Total	20.3	77560.8

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation

OFF - off-line
 CF - changing fuels
 CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

GD - good data
 GO - monitor over range
 QA - quality assurance activity

MS - General Monitor Status:

GD - good data
 GO - monitor over range
 QA - quality assurance activity

MIN - maintenance activity
 IV - invalid

Report generated on: 05/11/2018 09:25

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

CTG2 CO_HIGH CTG2 HTIP_OIL_P75

	PPMD	OS	MS	MMBTUHR	OS	MS
05/10/2018 17:33	0.2	SU	MN	1880.7	SU	GD
05/10/2018 17:34	-0.1	SU	MN	1880.7	SU	GD
05/10/2018 17:35	-0.5	SU	QA	1880.7	SU	GD
05/10/2018 17:36	241.0	SU	QA	1880.7	SU	GD
05/10/2018 17:37	761.5	SU	QA	1880.7	SU	GD
05/10/2018 17:38	775.6	SU	QA	1880.7	SU	GD
05/10/2018 17:39	777.1	SU	QA	1880.7	SU	GD
05/10/2018 17:40	862.5	SU	QA	1880.7	SU	GD
05/10/2018 17:41	1629.8	SU	QA	1880.7	SU	GD
05/10/2018 17:42	1698.8	SU	QA	1880.7	SU	GD
05/10/2018 17:43	1698.8	SU	QA	1880.7	SU	GD
05/10/2018 17:44	1670.0	SU	QA	1880.7	SU	GD
05/10/2018 17:45	905.9	SU	QA	1880.7	SU	GD
05/10/2018 17:46	775.1	SU	QA	1880.7	SU	GD
05/10/2018 17:47	775.0	SU	QA	1880.7	SU	GD
05/10/2018 17:48	775.2	SU	QA	1900.3	SU	GD
05/10/2018 17:49	1508.1	SU	QA	1900.3	SU	GD
05/10/2018 17:50	1698.1	SU	QA	1900.3	SU	GD
05/10/2018 17:51	1699.3	SU	QA	1900.3	SU	GD
05/10/2018 17:52	1701.8	SU	QA	1900.3	SU	GD
05/10/2018 17:53	969.5	SU	QA	1900.3	SU	GD
05/10/2018 17:54	775.5	SU	QA	1900.3	SU	GD
05/10/2018 17:55	775.5	SU	QA	1900.3	SU	GD
05/10/2018 17:56	775.6	SU	QA	1900.3	SU	GD
05/10/2018 17:57	1319.8	SU	QA	1900.3	SU	GD
05/10/2018 17:58	1692.5	SU	QA	1900.3	SU	GD
05/10/2018 17:59	1698.5	SU	QA	1900.3	SU	GD
05/10/2018 18:00	1697.4	SU	QA	1900.3	SU	GD

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

GD - good data CP - clean process equipment
 GO - monitor over range CC - clean control equipment
 QA - quality assurance activity MD - unknown operating status
 MN - maintenance activity IV - invalid

Report generated on: 05/10/2018 18:21

Data is expressed in Standard Time

4.3 Cycle/Response Time Data

The following pages contain DAHS printouts and supporting documentation for the cycle/response time checks performed on the gas analyzers. All test results are in accordance with the methods outlined in 40 CFR 75 Appendix A, section 6.4 and 40 CFR 60, Appendix B, PS-4A (as applicable).

Siemens
 CPV Valley Energy Center
 CTG 2
 Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project #: CN50478

Cycle Time - NOx Low Range

Manufacturer: TAPI
 Model: T200M
 Serial Number: 646
 Measurement Span (ppm): 10
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 8.68
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
86.84	OK	CC280797	12/06/20	OK

	Step 1. Monitor Response at Stack Gas (start point)	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response at 95% Step Change (from 1-min stable)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
Downscale (Stack gas to zero gas)	6.90	14:04	0.00	0.35	0.00	14:06	0:02:00
Upscale (Stack gas to span gas)	7.00	14:15	8.60	8.52	8.20	14:18	0:03:00

Maximum Response Time: 0:03:00

Cycle Time - NOx High Range

Measurement Span (ppm): 100
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 88.75
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
88.75	OK	CC477949	09/25/25	OK

	Step 1. Monitor Response at Stack Gas (start point)	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response Value at Step Change (from 1-min stable)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
Downscale (Stack gas to zero gas)	6.20	15:05	0.00	0.31	0.00	15:08	0:03:00
Upscale (Stack gas to span gas)	6.30	15:14	87.40	83.35	87.10	15:17	0:03:00

Maximum Response Time: 0:03:00
 Analyzer Response (max value from low and high range): 0:03:00

Notes:

Pass/fail criteria = 15 minutes or less
 (40 CFR 75, Appendix A, Section 3.5)

Stabilized response value = reading with a change < 2% of span value for 2 minutes, or a reading with a change < 6% of the measured average concentration over 6 minutes. Or, reading is considered stable if it changes by no more than 0.5 ppm, or 0.2% CO2/O2 for two minutes.

Downscale: Stable flue gas point down to stable zero cal gas point
 Upscale: Stable flue gas point "up to" stable span cal gas point

Collect 1-minute data from the DAHS and cal gas certs. Send minute data, cal gas certs and spreadsheet to office.

Siemens
 CPV Valley Energy Center
 CTG 2
 Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project #: CN50478

Cycle Time - O2

Manufacturer: TAPI
 Model: T200M
 Serial Number: 646
 Measurement Span (ppm): 25
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 20.89
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
83.56	OK	EB0095371	9/19/2025	OK

	Step 1. Monitor Response at Stack Gas (start point)	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response Value at Step Change (from 1-min data)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
Downscale (Stack gas to zero gas)	13.70	15:29	0.00	0.69	0.00	15:31	0:02:00
Upscale (Stack gas to span gas)	12.90	15:39	20.90	20.50	20.80	15:40	0:01:00

Maximum Response Time: 0:02:00

Notes:

Pass/fail criteria = 15 minutes or less (40 CFR 75, Appendix A, Section 3.5)

Stablized response value = reading with a change < 2% of span value for 2 minutes, or a reading with a change < 6% of the measured average concentration over 6 minutes. Or, reading is considered stable if it changes by no more than 0.5 ppm, or 0.2% CO2/O2 for two minutes.

Collect 1-minute data from the DAHS and cal gas certs. Send minute data, cal gas certs and spreadsheet to office.

Siemens
 CPV Valley Energy Center
 CTG 2
 Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project #: CN50478

Cycle Time - CO Low Range

40 CFR 60, PS-4A

Manufacturer: TAPI
 Model: T300M
 Serial Number: 354
 Measurement Span (ppm): 10
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 8.95
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
89.49	OK	CC280797	12/06/20	OK

	Step 1. Monitor Response at start point	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response Value at Step Change (from 1-min data)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
Zero to Span Cal Gas 1 (upscale)	0.90	15:56:00	9.30	8.88	9.30	15:59:00	0:03:00
Span to Zero Cal Gas 1 (downscale)	9.20	16:00:00	0.20	0.65	0.40	16:02:00	0:02:00
Zero to Span Cal Gas 2 (upscale)	0.20	16:03:00	9.40	8.94	9.20	16:05:00	0:02:00
Span to Zero Cal Gas 2 (downscale)	9.40	16:06:00	0.30	0.76	0.30	16:09:00	0:03:00
Zero to Span Cal Gas 3 (upscale)	0.30	16:09:00	9.30	8.85	9.30	16:12:00	0:03:00
Span to Zero Cal Gas 3 (downscale)	9.30	16:12:00	0.30	0.75	0.30	16:15:00	0:03:00

Average of Zero Gas Runs	0:02:40
Average of High Gas Runs	0:02:40
Longest Response Time	0:02:40

Cycle Time - CO High Range

40 CFR 60, PS-4A

Measurement Span (ppm): 3000
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 2591.00
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
86.37	OK	EB0095371	09/19/25	OK

	Step 1. Monitor Response at start point	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response Value at Step Change (from 1-min data)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
Zero to Span Cal Gas 1 (upscale)	0.20	15:06:00	2610.40	2479.89	2583.80	15:09:00	0:03:00
Span to Zero Cal Gas 1 (downscale)	2610.40	15:11:00	0.50	131.00	48.60	15:14:00	0:03:00
Zero to Span Cal Gas 2 (upscale)	0.50	15:16:00	2617.20	2486.37	2611.10	15:19:00	0:03:00
Span to Zero Cal Gas 2 (downscale)	2617.20	15:20:00	0.50	131.34	24.80	15:22:00	0:02:00
Zero to Span Cal Gas 3 (upscale)	0.50	15:23:00	2611.00	2480.48	2591.90	15:25:00	0:02:00
Span to Zero Cal Gas 3 (downscale)	2611.20	15:26:00	1.10	131.61	64.40	15:28:00	0:02:00

Average of Zero Gas Runs	0:02:40
Average of High Gas Runs	0:02:20
Longest Response Time	0:02:40
Analyzer Response Time	0:02:40

Notes:

Analyzer response time pass/fail criteria = 240 seconds (4 minutes or less (40 CFR 60, PS-4A per eCFR))
 The longest average from the two ranges is reported as the analyzer response time.
 Performed as a remote (at the probe) cal gas injection.
 Collect 1-minute data

Test sequence:

Zero cal gas "up to" span cal gas (upscale)
 Span cal gas "down to" zero cal gas (downscale)
 3 upscale runs and 3 downscale runs

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 GEN_GT CTG2 NOX_LOW_P75

	MW	OS	MS	PPMD	OS	MS
05/08/2018 14:00	188	SU	GD	6.8	SU	GD
05/08/2018 14:01	188	SU	GD	6.7	SU	GD
05/08/2018 14:02	188	SU	GD	6.6	SU	GD
05/08/2018 14:03	188	SU	GD	6.7	SU	MN
05/08/2018 14:04	188	SU	GD	6.9	SU	QA <i>START</i>
05/08/2018 14:05	188	SU	GD	5.2	SU	QA
05/08/2018 14:06	188	SU	GD	0.0	SU	QA <i>-95%</i>
05/08/2018 14:07	188	SU	GD	0.0	SU	QA
05/08/2018 14:08	188	SU	GD	0.0	SU	QA
05/08/2018 14:09	188	SU	GD	0.0	SU	QA
05/08/2018 14:10	189	SU	GD	0.0	SU	QA
05/08/2018 14:11	189	SU	GD	2.9	SU	MN
05/08/2018 14:12	189	SU	GD	6.9	SU	MN
05/08/2018 14:13	189	SU	GD	6.8	SU	MN
05/08/2018 14:14	189	SU	GD	7.0	SU	MN
05/08/2018 14:15	189	SU	GD	7.0	SU	MN <i>START</i>
05/08/2018 14:16	189	SU	GD	7.1	SU	QA
05/08/2018 14:17	189	SU	GD	6.0	SU	QA
05/08/2018 14:18	188	SU	GD	8.2	SU	QA <i>95%</i>
05/08/2018 14:19	189	SU	GD	8.6	SU	QA
05/08/2018 14:20	188	SU	GD	8.5	SU	QA
Average	188			6.7		
Maximum	189			6.8		
Minimum	188			6.6		
Total	3957			20.1		

OS - Operating Status:
 SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction MD - unknown operating status

MS - General Monitor Status:
 GD - good data CP - clean process equipment MN - maintenance activity
 GO - monitor over range CC - clean control equipment IV - invalid
 QA - quality assurance activity MD - unknown operating status QA - quality assurance activity

Report generated on: 05/08/2018 14:17 Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: NOX-H-RESPONSE

CTG2 GEN_GT CTG2 NOX_HIGH_P75

	MW	OS	MS	PPMD	OS	MS
05/08/2018 15:00	189	SU	GD	6.2	SU	MN
05/08/2018 15:01	188	SU	GD	6.2	SU	MN
05/08/2018 15:02	189	SU	GD	6.3	SU	MN
05/08/2018 15:03	188	SU	GD	6.3	SU	MN
05/08/2018 15:04	189	SU	GD	6.2	SU	MN
05/08/2018 15:05	189	SU	GD	6.2	SU	QA
05/08/2018 15:06	189	SU	GD	5.4	SU	QA
05/08/2018 15:07	188	SU	GD	0.6	SU	QA
05/08/2018 15:08	189	SU	GD	0.0	SU	QA
05/08/2018 15:09	189	SU	GD	0.0	SU	QA
05/08/2018 15:10	188	SU	GD	0.5	SU	MN
05/08/2018 15:11	188	SU	GD	6.1	SU	MN
05/08/2018 15:12	188	SU	GD	6.3	SU	MN
05/08/2018 15:13	188	SU	GD	6.4	SU	MN
05/08/2018 15:14	189	SU	GD	6.3	SU	QA
05/08/2018 15:15	189	SU	GD	12.6	SU	QA
05/08/2018 15:16	188	SU	GD	79.6	SU	QA
05/08/2018 15:17	188	SU	GD	87.1	SU	QA
05/08/2018 15:18	188	SU	GD	87.2	SU	QA
05/08/2018 15:19	189	SU	GD	87.4	SU	QA
05/08/2018 15:20	189	SU	GD	80.9	SU	MN
05/08/2018 15:21	189	SU	GD	20.3	SU	MN
Average	189					
Maximum	189					
Minimum	188					
Total	4148					

Handwritten notes:
 - 05/08/2018 15:05: SU
 - 05/08/2018 15:08: -9510
 - 05/08/2018 15:09: 7.68
 - 05/08/2018 15:14: SU
 - 05/08/2018 15:17: -9510
 - 05/08/2018 15:20: SPAN

OS - Operating Status:

- SU - startup mode
- SD - shutdown mode
- ON - normal operation
- OFF - off-line
- CF - changing fuels
- CM - control equipment malfunction

MS - General Monitor Status:

- GD - good data
- GO - monitor over range
- QA - quality assurance activity
- CP - clean process equipment
- CC - clean control equipment
- MD - unknown operating status
- MN - maintenance activity
- IV - invalid

Report generated on: 05/08/2018 15:18

Data is expressed in Standard Time

Date/Time	CTG2: O2_P75 (PCT) Raw Value
5/8/2018 15:25	13.7
5/8/2018 15:26	13.7
5/8/2018 15:27	13.7
5/8/2018 15:28	13.7
5/8/2018 15:29	13.7
5/8/2018 15:30	4.6
5/8/2018 15:31	0
5/8/2018 15:32	0
5/8/2018 15:33	0
5/8/2018 15:34	0
5/8/2018 15:35	0
5/8/2018 15:36	0
5/8/2018 15:37	0
5/8/2018 15:38	0
5/8/2018 15:39	12.9
5/8/2018 15:40	20.8
5/8/2018 15:41	20.9
5/8/2018 15:42	16.3
5/8/2018 15:43	13.7
5/8/2018 15:44	13.7
5/8/2018 15:45	13.7
5/8/2018 15:46	13.7
5/8/2018 15:47	13.7

START

-95%

START

95%

02

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 CO_LOW CTG2 HTIP_OIL_P75

Time	PPMD	OS	MS	MMBTUHR	OS	MS
05/10/2018 15:56	0.9	SU	QA	1900.3	SU	GD
05/10/2018 15:57	0.6	SU	QA	1900.3	SU	GD
05/10/2018 15:58	5.9	SU	QA	1880.7	SU	GD
05/10/2018 15:59	9.3	SU	QA	1900.3	SU	GD
05/10/2018 16:00	9.2	SU	QA	1900.3	SU	GD
05/10/2018 16:01	5.6	SU	QA	1900.3	SU	GD
05/10/2018 16:02	0.4	SU	QA	1900.3	SU	GD
05/10/2018 16:03	0.2	SU	QA	1900.3	SU	GD
05/10/2018 16:04	3.7	SU	QA	1900.3	SU	GD
05/10/2018 16:05	9.2	SU	QA	1900.3	SU	GD
05/10/2018 16:06	9.4	SU	QA	1880.7	SU	GD
05/10/2018 16:07	7.3	SU	QA	1900.3	SU	GD
05/10/2018 16:08	0.9	SU	QA	1880.7	SU	GD
05/10/2018 16:09	0.3	SU	QA	1900.3	SU	GD
05/10/2018 16:10	2.1	SU	QA	1900.3	SU	GD
05/10/2018 16:11	8.7	SU	QA	1900.3	SU	GD
05/10/2018 16:12	9.3	SU	QA	1900.3	SU	GD
05/10/2018 16:13	8.9	SU	QA	1900.3	SU	GD
05/10/2018 16:14	2.8	SU	QA	1900.3	SU	GD
05/10/2018 16:15	0.3	SU	QA	1900.3	SU	GD
05/10/2018 16:16	0.3	SU	QA	1900.3	SU	GD
05/10/2018 16:17	6.4	SU	QA	1880.7	SU	GD
05/10/2018 16:18	9.3	SU	QA	1900.3	SU	GD
05/10/2018 16:19	9.3	SU	QA	1880.7	SU	GD

Average 1896.2

Maximum 1900.3

Minimum 1880.7

OS - Operating Status:

SU - startup mode

SD - shutdown mode

ON - normal operation

OFF - off-line

CF - changing fuels

CM - control equipment malfunction

CP - clean process equipment

CC - clean control equipment

MD - unknown operating status

GD - good data

GO - monitor over range

QA - quality assurance activity

MN - maintenance activity

IV - invalid

Report generated on: 05/10/2018 16:19

Data is expressed in Standard Time

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 CO_HIGH CTG2 HTIP_OIL_P75

PPMD	OS	MS	MMBTUHR	OS	MS	
05/10/2018 15:00	-1.0	SU	QA	1900.3	SU	GD
05/10/2018 15:01	0.4	SU	QA	1900.3	SU	GD
05/10/2018 15:02	0.3	SU	QA	1900.3	SU	GD
05/10/2018 15:03	0.2	SU	QA	1900.3	SU	GD
05/10/2018 15:04	0.5	SU	MN	1900.3	SU	GD
05/10/2018 15:05	0.1	SU	MN	1900.3	SU	GD
05/10/2018 15:06	0.2	SU	MN	1900.3	SU	GD
05/10/2018 15:07	-0.4	SU	QA	1900.3	SU	GD
05/10/2018 15:08	918.6	SU	QA	1900.3	SU	GD
05/10/2018 15:09	0.510-2583.8	SU	QA	1900.3	SU	GD
05/10/2018 15:10	2613.4	SU	QA	1900.3	SU	GD
05/10/2018 15:11	2610.4	SU	QA	1900.3	SU	GD
05/10/2018 15:12	2202.0	SU	MN	1900.3	SU	GD
05/10/2018 15:13	132.4	SU	QA	1900.3	SU	GD
05/10/2018 15:14	0.510-48.6	SU	QA	1900.3	SU	GD
05/10/2018 15:15	13.8	SU	QA	1900.3	SU	GD
05/10/2018 15:16	0.5	SU	QA	1900.3	SU	GD
05/10/2018 15:17	9.1	SU	QA	1900.3	SU	GD
05/10/2018 15:18	2035.2	SU	QA	1900.3	SU	GD
05/10/2018 15:19	0.510-2611.1	SU	QA	1900.3	SU	GD
05/10/2018 15:20	2617.2	SU	QA	1900.3	SU	GD
05/10/2018 15:21	1405.8	SU	QA	1900.3	SU	GD
05/10/2018 15:22	0.510-24.8	SU	QA	1900.3	SU	GD
05/10/2018 15:23	0.5	SU	QA	1900.3	SU	GD
05/10/2018 15:24	1175.1	SU	QA	1900.3	SU	GD
05/10/2018 15:25	2591.9	SU	QA	1900.3	SU	GD
05/10/2018 15:26	2611.0	SU	QA	1900.3	SU	GD
05/10/2018 15:27	1857.5	SU	QA	1900.3	SU	GD

OS - Operating Status:
 SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:
 GD - good data CP - clean process equipment
 GO - monitor over range CC - clean control equipment
 QA - quality assurance activity MD - unknown operating status
 MN - maintenance activity IV - invalid

Report generated on: 05/10/2018 15:38 Data is expressed in Standard Time

Data Summary Report

Source: CTG2

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 CO_HIGH CTG2 HTP_OIL_P75

Time	PPMD	OS	MS	MMBTUHR	OS	MS
05/10/2018 15:28	64.4	SU	QA	1900.3	SU	GD
05/10/2018 15:29	1.1	SU	QA	1900.3	SU	GD
05/10/2018 15:30	7.9	SU	QA	1900.3	SU	GD
05/10/2018 15:31	2023.4	SU	QA	1900.3	SU	GD
05/10/2018 15:32	2603.0	SU	QA	1900.3	SU	GD
05/10/2018 15:33	2611.2	SU	QA	1900.3	SU	GD
05/10/2018 15:34	922.5	SU	QA	1900.3	SU	GD
05/10/2018 15:35	9.2	SU	QA	1900.3	SU	GD
05/10/2018 15:36	0.7	SU	QA	1900.3	SU	GD
05/10/2018 15:37	929.4	SU	QA	1900.3	SU	GD
05/10/2018 15:38	2567.8	SU	QA	1900.3	SU	GD

Average	1900.3
Maximum	1900.3
Minimum	1900.3
Total	74111.7

OS - Operating Status:
 SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:
 GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

CP - clean process equipment MD - unknown operating status
 CC - clean control equipment Data is expressed in Standard Time

Report generated on: 05/10/2018 15:38

4.4 Calibration Gas Certificates

The following attached pages contain copies of the calibration gas certificates representing the cylinder bottles used during the test program.

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E04NI95E15A0029	Reference Number: 82-401041883-1
Cylinder Number: CC280797	Cylinder Volume: 146.4 CF
Laboratory: 124 - Riverton (SAP) - NJ	Cylinder Pressure: 2015 PSIG
PGVP Number: B52017	Valve Outlet: 660
Gas Code: CO,CO2,NO,NOX,BALN	Certification Date: Dec 06, 2017

Expiration Date: Dec 06, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.684 PPM	G1	+/- 1.1% NIST Traceable	11/28/2017, 12/06/2017
CARBON MONOXIDE	9.000 PPM	8.949 PPM	G1	+/- 0.4% NIST Traceable	11/28/2017
NITRIC OXIDE	9.000 PPM	8.655 PPM	G1	+/- 1.1% NIST Traceable	11/28/2017, 12/06/2017
CARBON DIOXIDE	4.000 %	4.019 %	G1	+/- 0.5% NIST Traceable	11/22/2017
NITROGEN	Balance				

CALIBRATION STANDARDS						
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date	
NTRM	12062815	CC366700	9.766 PPM CARBON MONOXIDE/NITROGEN	+/- 0.3%	Sep 07, 2018	
NTRM	16060728	CC437497	10.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 28, 2018	
NTRM	16060728	CC437497-NOX	10.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 28, 2018	
NTRMplus	10060137	CC307784	5.027 % CARBON DIOXIDE/NITROGEN	+/- 0.4%	Dec 02, 2021	

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA 510-CO2-19GYCXEG	NDIR	Oct 30, 2017
Thermo 48i-TLE-CO-1133350708	NDIR	Nov 20, 2017
Thermo 42i-LS-NO-1123749326	Chemiluminescence	Nov 20, 2017
Thermo 42i-LS-NOx-1123749326	Chemiluminescence	Nov 20, 2017

Triad Data Available Upon Request



Approved for Release

CERTIFICATE OF ANALYSIS Grade of Product: EPA Protocol

Part Number: E03NI95E15A0019 Reference Number: 82-400992434-1
 Cylinder Number: CC477949 Cylinder Volume: 146.4 CF
 Laboratory: 124 - Riverton (SAP) - NJ Cylinder Pressure: 2015 PSIG
 PGVP Number: B52017 Valve Outlet: 660
 Gas Code: CO2,NO,NOX,BALN Certification Date: Sep 25, 2017
 Expiration Date: Sep 25, 2025

Certification performed in accordance with EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)* document EPA 800/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.


ANALYTICAL RESULTS				
Component	Requested Concentration	Actual Concentration	Protocol Method	Assay Dates
NOX	90.00 PPM	88.75 PPM	G1	09/18/2017, 09/25/2017
NITRIC OXIDE	80.00 PPM	88.61 PPM	G1	09/18/2017, 09/25/2017
CARBON DIOXIDE	4.000 %	3.995 %	G1	09/18/2017
NITROGEN	Balance			

CALIBRATION STANDARDS			
Type	Lot ID	Cylinder No	Concentration
NTRM	13010402	KAL003271	97.6 PPM NITRIC OXIDE/NITROGEN
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/AIR
GMS	0315201604	CC503358	4.975 PPM NITROGEN DIOXIDE/NITROGEN
NTRM	10060122	CC281392	5.027 % CARBON DIOXIDE/NITROGEN

The SRM, PRM or RGM noted above is only in reference to the GMS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT	
Instrument/Make/Model	Analytical Principle
Nicolet 6700 APW1100391 CO2	FTIR
Nicolet 6700 APW1100391 NO	FTIR
Nicolet 6700 APW1100391 NO2	FTIR

Triad Data Available Upon Request



Last Multipoint Calibration
 Sep 11, 2017
 Sep 08, 2017
 Sep 08, 2017

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E04NI69E15A0002	Reference Number:	82-400992440-1
Cylinder Number:	EB0095371	Cylinder Volume:	151.5 CF
Laboratory:	124 - Riverton (SAP) - NJ	Cylinder Pressure:	2015 PSIG
PGVP Number:	B52017	Valve Outlet:	590
Gas Code:	CO,CO2,O2,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	2700 PPM	2591 PPM	G1	+/- 1.0% NIST Traceable	09/19/2017
CARBON DIOXIDE	9.000 %	8.898 %	G1	+/- 0.7% NIST Traceable	09/19/2017
OXYGEN	21.00 %	20.89 %	G1	+/- 0.5% NIST Traceable	09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12060724	CC356171	2498 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Dec 21, 2017
NTRM	13060408	CC412683	7.489 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 14, 2019
NTRM	09061415	CC273526	22.53 % OXYGEN/NITROGEN	+/- 0.4%	Mar 08, 2019

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA 510-CO2-19GYCXEG	NDIR	Aug 31, 2017
Siemens Ultramat 6 J3-599 COHIGH	NDIR	Sep 15, 2017
Horiba MPA 510-O2-7TWMJ041	Paramagnetic	Aug 31, 2017

Triad Data Available Upon Request



C. Modylowski
Approved for Release

10-NOX-L



Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8153

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0072315	Certification Date:	07/05/2017
Product ID Number:	124743	Expiration Date:	07/04/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport, LA
COA #	EB0072315.20170613-0	Lot Number:	EB0072315.20170613
Customer PO. NO.:		Tracking Number:	02A248967
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-800/P-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	2.67 PPM	±0.02 PPM	FTIR	08/30/2017
Nitric Oxide	2.4208 PPM	±0.0009 PPM	Chemiluminescence	06/19/2017, 06/28/2017, 07/05/2017
Total Oxides of Nitrogen	2.5177 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty (%)	NIST Reference
EB0003154	EB0003154.20160721	01/11/2025	GMS	N2	CO	12.16 PPM	1.033	091092
EB0005492	EB0005492.20160721	01/10/2025	GMS	N2	CO	13.63 PPM	1.014	091092
EB00052431	EB00052431.20161012	01/21/2019	GMS	N2	NO	5.795 PPM	1.012	2522a
		11/2/2016		N2	NO	0.34 PPM		2522a

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T40C	40C-53459-367	06/12/2017
CO	FTIR	MKS	MCS 2331DJG22GVS13T	017146267	06/06/2017

Red Ball Technical Gas Service
PGVP Vendor ID # G12017
Information and Ordering
800-551-8153
Fax (318-425-6305)



Ned Fisher
Nate Fielder
Analyst

This is to certify the gases referenced have been calibrated, tested, and verified to meet the defined specifications. This calibration was performed using Gases or Solids that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the acceptability of calibrations are available upon request and were taken into account when determining pass or fail.



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

~~02~~
02

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0060674	Certification Date:	04/06/2018
Product ID Number:	126054	Expiration Date:	04/04/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0060674.20180402-0	Lot Number:	EB0060674.20180402
Customer PO. NO.:		Tracking Number:	082989800
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.


Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)				
Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Oxygen	13.82 %	±0.07 %	MPA	04/06/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)								
Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0019964	EB0019964.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0032313	EB0032313.20170112	05/22/2025	GMIS	N2	O2	9.34 %	0.235	2858a

Analytical Instrumentation					
Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	03/26/2018



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder
 Analyst
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



HiQ® Certificate / Certificat HiQ®

02
LINDE CANADA LIMITED

530 Watson St. East
Whitby, ON, Canada L1N 5R9

CERTIFICATE OF ANALYSIS

EPA PROTOCOL MIXTURE

Purchase order #110585036

PGVP ID # L12013

Lot #1263941

Procedure: G1

Cylinder Number: EB 0049201

Gas Type Code: OC2

Cylinder pressure: 2000 psig

Certification date
August 12, 2013

Expiration Date
August 13, 2021

ANALYTICAL RESULTS

Component	Requested Concentration <small>Blending tolerance</small>	Date of Assay	Mean Concentration	Certified Concentration <small>Uncertainty expressed at 95% confidence</small>
Carbon Dioxide	5 % ± 5%	August 12, 2013	5.07 %	5.07 ± 0.02 %
Oxygen	6 % ± 5%	August 9, 2013	6.36 %	6.36 ± 0.01 %

BALANCE GAS: Nitrogen

REFERENCE STANDARDS

Component	Type	Serial Number	Reference Number	Concentration	Expiration Date
Carbon Dioxide	GMIS	SX 21992	1187915	10 ± 0.02 %	August 20, 2013
	NTRM	SG 9916842	101001	19.98 ± 0.14 %	April 15, 2016
Oxygen	GMIS	SX 31579	1107503	9.975 ± 0.06 %	August 18, 2013
	NTRM	CC 237234	021001	24.12 ± 0.12 %	March 27, 2017

CERTIFICATION INSTRUMENTS

Component	Make/Model	Measurement Principle	Serial Number	Last Calibration
Carbon Dioxide	SICK MCS 100E	Infrared Photometer	04310670	August 1, 2013
Oxygen	Servomex 04100 C1	Paramagnetic Sensor	392350	August 9, 2013

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE 2012 EPA PROTOCOL PROCEDURE

DO NOT USE THIS CYLINDER WHEN THE PRESSURE FALLS BELOW 100 PSIG

Analyst: Keith Cybulski

Signature

Date 08/12/13

Notes:



Red Ball Technical Gas Service *20X-M*
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0073000	Certification Date:	03/19/2018
Product ID Number:	125416	Expiration Date:	03/18/2021
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0073000.20180228-0	Lot Number:	EB0073000.20180228
Customer PO. NO.:		Tracking Number:	084247373
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	24.7 PPM	±0.14 PPM	FTIR	03/06/2018
Nitric Oxide	24.6 PPM	±0.3 PPM	Chemiluminescence	03/05/2018, 03/12/2018, 03/19/2018
Total Oxides of Nitrogen	24.7 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC-349582	12100115CC-349582	07/22/2019	NTRM	N2	NO	95.2 PPM	1.05	12100115
ALM022135	ALM022135.20160913	02/07/2021	GMIS	N2	NO	15.2 PPM	1.103	12100115
CC349576	CC349576.20170821	12/03/2025	GMIS	N2	NO	294 PPM	0.451	2735
EB0026633	EB0026633.20160718	01/19/2025	GMIS	N2	NO	90.67 PPM	1.054	12100115
EB0055450	EB0055450.20140403-0	12/21/2020	GMIS	N2	NO	32.02 PPM	1.058	12100115
EB0087668	EB0087668.20160721	10/30/2025	GMIS	N2	CO	202.6 PPM	0.395	1681B
EB0087736	EB0087736.20160721	10/30/2025	GMIS	N2	CO	202.6 PPM	0.395	1681B

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	02/08/2018
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	02/14/2018
NO	Chemiluminescence	Thermo	42i-HL	1162380008	02/13/2018
NO	Chemiluminescence	Thermo	42i-HL	1162380008	03/16/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder
 Nate Fielder
 Analyst

Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07

NOX-H

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0147
 Cylinder Number: CC 503502
 Laboratory: 124 - Durham (SAP) - NC
 PGVP Number: B22017
 Gas Code: NO,NOX,BALN

Reference Number: 122-401038758-1
 Cylinder Volume: 144.3 Cubic Feet
 Cylinder Pressure: 2016 PSIG
 Valve Outlet: 660
 Certification Date: Nov 01, 2017

Expiration Date: Nov 01, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.89 PPM	G1	+/- 1.3% NIST Traceable	10/24/2017, 11/01/2017
NITRIC OXIDE	50.00 PPM	50.85 PPM	G1	+/- 1.1% NIST Traceable	10/24/2017, 11/01/2017
NITROGEN	Balance				

CALIBRATION STANDARDS


Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16080810	CC442567	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/AIR	+/- 1.5%	May 29, 2016
NTRM	16080655	CC465081	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
GMIS	1114201603	CC506722	4.995 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 NO	FTIR	Oct 26, 2017
Nicolet 6700 AHR0801549 NO	FTIR	Oct 26, 2017

Triad Data Available Upon Request



[Signature]
Approved for Release



Rod Ball Technical Gas Service C0-4
 555 Crnig Kennody Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0072144	Certification Date:	04/06/2018
Product ID Number:	127180	Expiration Date:	04/04/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0072144 20180402-0	Lot Number:	EB0072144, 20180402
Customer PO. NO.:		Tracking Number:	004214278
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	1670 PPM	±17 PPM	FTIR	04/06/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ES0003650	ES0003650, 20161027	03/17/2026	GA/IS	N2	CO	1514 PPM	0.569	2840A

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/06/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

CO-H

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0040994	Certification Date:	04/06/2018
Product ID Number:	127179	Expiration Date:	04/04/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0040994.20180402-0	Lot Number:	EB0040994.20180402
Customer PD. NO.:		Tracking Number:	065159615
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	753 PPM	±6 PPM	FTIR	04/06/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0016838	EB0016838.20161027	03/17/2026	GMIS	N2	CO	2310 PPM	0.56	2649a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/05/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Floder

Nate Floder
 Analyst
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service *CO-10X*
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0101725	Certification Date:	12/04/2017
Product ID Number:	124744	Expiration Date:	12/03/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0101725.20171114-0	Lot Number:	EB0101725.20171114
Customer PO. NO.:		Tracking Number:	095707020
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	5.66 PPM	±0.07 PPM	FTIR	11/24/2017
Nitric Oxide	5.09 PPM	±0.06 PPM	Chemiluminescence	11/20/2017, 11/27/2017, 12/04/2017
Total Oxides of Nitrogen	5.19 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM034813	ALM034813.20160913	09/01/2020	GMIS	N2	NO	15.5 PPM	1.075	12100115
EB0003184	EB0003184.20160721	01/11/2025	GMIS	N2	CO	12.16 PPM	1.033	091002
EB0052431	EB0052431.20151012g	01/21/2019	GMIS	N2	NO	5.799 PPM	1.012	2622a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	11/20/2017
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/24/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
 Anthony Cyr
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07

5 Relative Accuracy Test Audit

The full RATA report, provided by Air Hygiene Inc., is attached.



AIR HYGIENE, INC.

Testing Solutions for a Better World

RELATIVE ACCURACY TEST AUDIT
FOR THE
SIEMENS, SCC6-5000F, UNIT #2 CEMS
PREPARED FOR
CPV VALLEY LLC
AT THE
CPV VALLEY ENERGY CENTER
MIDDLETOWN, NEW YORK
MAY 10-12, 2018



Corporate Headquarters

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012



AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices


Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

**RELATIVE ACCURACY TEST AUDIT
FOR THE
SIEMENS, SCC6-5000F, UNIT #2 CEMS
PREPARED FOR
CPV VALLEY LLC
AT THE
CPV VALLEY ENERGY CENTER
MIDDLETOWN, NEW YORK
MAY 10-12, 2018**

Prepared and Reviewed by:



Michael Whisenhunt, QSTI
Sr. Project Manager



Logan Tsotsoros
AHU Support Staff

I, 

Michael Stockwell, QSTI
Sr. Project Manager

certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

Table of Contents

1.0	INTRODUCTION	1
1.1	TEST PURPOSE AND OBJECTIVES	1
1.2	SUMMARY OF TEST PROGRAM	2
1.2.1	Participating Organizations	2
1.2.2	Industry	2
1.2.3	Air Permit and Federal Requirements	2
1.2.4	Plant Location	2
1.2.5	Equipment Tested	2
1.2.6	Emission Points	2
1.2.7	Emission Parameters Measured	2
1.2.8	Dates of Emission Test	2
1.2.9	Federal and State Certifications	3
1.3	KEY PERSONNEL	3
2.0	SUMMARY OF TEST RESULTS	3
3.0	SOURCE OPERATION	5
3.1	PROCESS DESCRIPTION	5
3.2	SAMPLING LOCATION	5
4.0	SAMPLING AND ANALYTICAL PROCEDURES	5
4.1	TEST METHODS	5
4.2	INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS	6

APPENDICES

Appendix A	Test Results and Calculations
Appendix B	CEMS and Reference Method Data
Appendix C	Calibration Gas Certifications
Appendix D	Quality Assurance and Quality Control Data
Appendix E	Fuel Analysis Records
Appendix F	Stratification Test Data

Relative Accuracy Test Audit
Siemens, SCC6-5000F, Unit #2 CEMS
CPV VALLEY LLC
CPV VALLEY ENERGY CENTER
Middletown, New York
May 10-12, 2018

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Relative Accuracy Test Audit (RATA) for nitrogen oxides (NO_x), carbon monoxide (CO), and oxygen (O₂) from the exhaust of the Siemens, SCC6-5000F, Unit #2 for CPV VALLEY LLC at the CPV VALLEY ENERGY CENTER near Middletown, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on May 10-12, 2018.

The accumulated data from the RATA provides the figures for evaluating the acceptability of the operation of the on-site continuous emission monitoring system (CEMS) for the monitoring of NO_x, CO, and O₂ from the Siemens, SCC6-5000F, Unit #2 for CPV VALLEY LLC at the CPV VALLEY ENERGY CENTER near Middletown, New York.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to perform the initial certification RATA on the CEMS that serves the Siemens, SCC6-5000F, Unit #2 for CPV VALLEY LLC at the CPV VALLEY ENERGY CENTER near Middletown, New York. Reference method (RM) testing followed the Code of Federal Regulations (CFR), Title 40 (40 CFR), Part 60 (40 CFR 60), Appendix A, Methods 1, 3A, 7E, 10, and 19. RM values are compared with the on-site CEMS to document performance as required in the 40 CFR 60, Appendix B, Performance Specifications (PS) and 40 CFR 75 Appendix A and B. All relative accuracies were established on-site and were governed by the following sets of rules:

In accordance with 40 CFR 60, Appendix B, PS 2, Section 13.2, the NO_x RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent when average emissions during the test are greater than 50 percent of the emission standard or alternative relative accuracy (ARA) does not exceed 10.0 percent when the average emissions during the test are less than 50 percent of the emission standard. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

In accordance with 40 CFR 75, Appendix A, Section 3.3.2(a) and (b), the NO_x RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average NO_x emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and reference method (RM) values does not exceed 0.020 lb/MMBtu. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (f), and Appendix B, Figure 2, the NO_x RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average NO_x emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and RM values does not exceed 0.015 lb/MMBtu. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 3, Section 13.2, the O₂ RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent or if the average difference between the CEMS and reference method (RM) values does not exceed plus or minus 1.0 percent of the measured value.

In accordance with 40 CFR 75, Appendix A, Section 3.3.3, the O₂ RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average difference between the CEMS and reference method (RM) values does not exceed 1.0 percent. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (h), and Appendix B, Figure 2, the O₂ RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average difference between the CEMS and RM values does not exceed 0.7 percent absolute. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 4 and 4A, Sections 13.2 of each, the CO relative accuracy (RA) test results are acceptable if the RA does not exceed 10.0 percent, if the average difference between the CEMS and reference method (RM) values plus the 2.5 percent confidence coefficient (2.5%CC) does not exceed 5.0 parts per million (ppm), or if the alternative relative accuracy (ARA) does not exceed 5.0 percent. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

- 1.2.1 Participating Organizations
 - New York State Department of Environmental Conservation (NYDEC)
 - CPV VALLEY LLC
 - Air Hygiene
- 1.2.2 Industry
 - Electric Utility / Electric Services
- 1.2.3 Air Permit and Federal Requirements
 - Permit Number: 3-3356-00136/00001
 - 40 CFR 60, Appendix B, Performance Specifications (PS)
 - 40 CFR 75, Appendix A
 - 40 CFR 75, Appendix B
- 1.2.4 Plant Location
 - CPV VALLEY ENERGY CENTER near Middletown, New York
 - GPS Coordinates [Latitude 41.413, Longitude -74.435]
 - Federal Registry System / Facility Registry Service (FRS) No. – 110043332471
 - Source Classification Code (SCC) – 20100201
- 1.2.5 Equipment Tested
 - Siemens, SCC6-5000F, Unit #2
 - NO_x Analyzer (Teledyne API, T200M, 646)
 - CO Analyzer (Teledyne API, T300M, 354)
 - O₂ Analyzer (Teledyne API, T200M, 646)
- 1.2.6 Emission Points
 - Exhaust from the Siemens, SCC6-5000F, Unit #2
 - For all gases, one sample point in the exhaust duct from the Siemens, SCC6-5000F, Unit #2, determined after conducting a stratification test (refer to Appendix F)
- 1.2.7 Emission Parameters Measured
 - NO_x
 - CO
 - O₂
- 1.2.8 Dates of Emission Test
 - May 10-12, 2018

1.2.9 Federal and State Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Siemens:	Jordan Haywood	407-736-3045
Air Hygiene:	Michael Stockwell (mstockwell@airhygiene.com)	918-307-8865
Air Hygiene:	Hunter Neal	918-307-8865
Air Hygiene:	Zach Van Ness	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on CPV VALLEY LLC’s Siemens, SCC6-5000F, Unit #2 located at the CPV VALLEY ENERGY CENTER on May 10-12, 2018 are summarized in the following table and relate only to the items tested.

**TABLE 2.1
SUMMARY OF SIEMENS, SCC6-5000F, UNIT #2 RATA RESULTS**

Pollutant	Units	Criteria			Results	Passed / Test Frequency
		CFR	Specification / Section	Standard		
NOx	ppmvd	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 4.6%	YES / ANNUAL
NOx	ppmvd@15%O ₂	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 5%	YES / ANNUAL
NOx	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 5.4%	YES / ANNUAL
NOx	lb/MMBtu	Part 75	Appendix A, Section 3.3.2(a),(b) Appendix B, Section 2.3.1.2(a),(f), Figure 2	RA ≤ 10%, or if lb/MMBtu ≤ 0.200, d ≤ ±0.020 lb/MMBtu Annual Incentive RA ≤ 7.5%, or if lb/MMBtu ≤ 0.2, d ≤ ±0.015 lb/MMBtu	RA = 7% RM = 0.02 lb/MMBtu d = 0.001 lb/MMBtu BAF=1.052	YES / ANNUAL
O ₂	%vd	Part 60	Appendix B, Performance Specification 3, Section 13.2	RA ≤ 20%, or d ≤ ±1.0%	RA = 0.5% d = 0 %	YES / ANNUAL
O ₂	%vd	Part 75	Appendix A, Section 3.3.3 Appendix B, Section 2.3.1.2(a),(h), Figure 2	RA ≤ 10%, or d ≤ ±1.0% Annual Incentive RA ≤ 7.5%, or d ≤ ±0.7%	RA = 0.5% d = 0 %	YES / ANNUAL
CO	ppmvd	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	d +2.5%CC = 0.6 ppm	YES / ANNUAL
CO	ppmvd@15%O ₂	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	d +2.5%CC = 0.6 ppm	YES / ANNUAL
CO	lb/hr	Part 60	Appendix B, Performance Specification 4, 4A Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	d +2.5%CC = 0.6 ppm	YES / ANNUAL
Load	MW	Part 60	Appendix B, Performance Specifications	> 50% max load	187.7	WITHIN TOLERANCE
Load	MW	Part 75	Appendix A and B	normal or alternative normal load range	187.7	WITHIN TOLERANCE

Notes: RA = relative accuracy, ARA = alternative relative accuracy, RM = reference method value, d = difference between RM and CEMS value, CC = confidence coefficient, v = velocity, BAF = bias adjustment factor

The RATA passed for all pollutants (NO_x, CO, and O₂) in all units (ppm, ppm@15%O₂, lb/hr, lb/MMBtu, and %) under all 40 CFR 60 and 40 CFR 75 criteria.

Specifically, NO_x in units of ppm, ppm@15%O₂, and lb/hr, passed 40 CFR 60 criteria with an RA less than 20 percent. NO_x in units of lb/MMBtu passed the 40 CFR 75 alternative annual incentive criteria with an emissions rate of less than 0.200 lb/MMBtu and a difference between the RM and CEMS analyzers of less than 0.015 lb/MMBtu. Also the Bias Adjustment Factor test passed with an adjustment factor equal to 1.052 (adjustment required). O₂ in units of % passed the 40 CFR 75 annual incentive criteria with an RA less than 7.5 percent. CO in units of ppm and ppm@15%O₂ passed the 40 CFR 60 alternative criteria with a concentration difference between the RM and CEMS analyzers plus the confidence coefficient of less than 5 ppm.

Unit load was within the 40 CFR 60 required criteria of greater than 50 percent of the maximum load and also fell within the alternative normal load criteria as defined by the plants Quality Control and Monitoring Plan which defined the upper and lower boundary on the unit and the normal and alternative normal load ranges.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

The CPV Valley Energy Center is located at 3330 U.S. Route 6 in Middletown, New York. CPV Valley Energy Center is an electric generation facility. The facility consists of two Siemens SCC6-5000F Combined Cycle Combustion Turbines (CTG), designated as CTG1 and CTG2. Each CTG is rated for the turbine at 2,234 MMBtu/hr (HHV) on natural gas; and 2,145 MMBtu/hr (HHV) on ULSD fuel oil; and is rated at 500 MMBtu/hr on natural gas for the duct burner. The CTG's are equipped with dry low NO_x combustors, selective catalytic reduction (SCR), and catalytic oxidizers. The interests of this report are CTG1 and CTG2 operating while burning fuel oil (ULSD).

3.2 SAMPLING LOCATION

The CTG1 and CTG2 stacks are vertical, circular and measures 19.35 feet (ft) (232.25 inches) in diameter at the test ports which are approximately 175 ft above grade level with an exit elevation of approximately 275 ft above grade level. The test ports are located approximately 91.25 ft (1095 inches) downstream and approximately 100 ft (1200 inches) upstream from the nearest disturbances.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the Siemens, SCC6-5000F, Unit #2 at the CPV VALLEY ENERGY CENTER was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on May 10-12, 2018.

**TABLE 4.1
SUMMARY OF SAMPLING METHODS**

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Oxygen	EPA Method 3A	Paramagnetic Cell
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 3A, 7E, 10, and 19.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in an air-conditioned, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NO_x calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. Data records can be found in Appendix A and B of this report.

Ten test runs of approximately 21 minutes each were conducted on the Siemens, SCC6-5000F, Unit #2 at the maximum test load for NO_x, CO, and O₂. The unit operation was greater than 50 percent of capacity as required by the 40 CFR 60, Performance Specifications. The unit operation was at the normal / alternative normal load as required by 40 CFR 75.

The stack gas analysis for O₂ concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O₂ analyzer uses a paramagnetic cell detector.

EPA Method 7E was used to determine concentrations of NO_x. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO₂ in nitrogen certified gas cylinder was used to verify at least a 90 percent NO₂ conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

**TABLE 4.2
ANALYTICAL INSTRUMENTATION**


Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NO _x	THERMO 42i-HL	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO ₂ to NO. Chemiluminescence of reaction of NO with O ₃ . Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48i	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
O ₂	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

EPA Method 7E was used to determine concentrations of NO_x. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO₂ in nitrogen certified gas cylinder was used to verify at least a 90 percent NO₂ conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

**TABLE 4.2
ANALYTICAL INSTRUMENTATION**

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NO _x	THERMO 42i-HL	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO ₂ to NO. Chemiluminescence of reaction of NO with O ₃ . Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48i	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
O ₂	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.



Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.



Figure 1
EMISSIONS TESTING LAB
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
www.airhygiene.com
 (888) 461-8778

APPENDIX A
TEST RESULTS AND CALCULATIONS

**TABLE A.1:
EMISSIONS TESTING SCHEDULE**

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
2	Max	Stratification Test	1	05/10/18	12:40:06	13:52:06	DAHS
2	Max	Gas RATA	1	05/11/18	12:06:21	12:26:51	DAHS
2	Max	Gas RATA	2	05/11/18	12:41:21	13:01:51	DAHS
2	Max	Gas RATA	3	05/11/18	13:15:22	13:35:52	DAHS
2	Max	Gas RATA	4	05/11/18	13:48:22	14:08:52	DAHS
2	Max	Gas RATA	5	05/11/18	14:23:22	14:43:52	DAHS
2	Max	Gas RATA	6	05/11/18	15:00:22	15:20:52	DAHS
2	Max	Gas RATA	7	05/12/18	8:08:07	8:28:37	DAHS
2	Max	Gas RATA	8	05/12/18	8:59:09	9:19:39	DAHS
2	Max	Gas RATA	9	05/12/18	9:32:00	9:52:30	DAHS
2	Max	Gas RATA	10	05/12/18	10:53:01	11:13:31	DAHS

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd)	(ppmvd)	(diff)	(diff ²)
1	12:06 - 12:26	YES	184.0	7.00	6.60	0.4000	0.16
2	12:41 - 13:01	YES	185.0	6.80	6.70	0.1000	0.01
3	13:15 - 13:35	YES	185.0	7.00	6.70	0.3000	0.09
4	13:48 - 14:08	NO	185.0	7.00	6.60		
5	14:23 - 14:43	YES	185.0	6.70	6.50	0.2000	0.04
6	15:00 - 15:20	YES	185.0	7.00	6.70	0.3000	0.09
7	08:08 - 08:28	YES	191.0	6.80	6.60	0.2000	0.04
8	08:59 - 09:19	YES	193.0	7.00	6.70	0.3000	0.09
9	09:32 - 09:52	YES	192.0	6.80	6.80	0.0000	0.00
10	10:53 - 11:13	YES	192.0	6.90	6.70	0.2000	0.04
11		NO					
12		NO					
Total			1692.0	62.00	60.00	2.000000	0.560000
Average			188.0	6.89	6.67	0.222222	
Number of Runs				9			
Standard Deviation				0.120185			
T-value				2.306			
Confidence Coefficient				0.092382			
Relative Accuracy = 4.6%							

Part 60, Appendix B, Performance Specification 2,

8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.

13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).

Eq. 2.6 $RA = (|d| + |CC|) * 100 / RM$

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
CO RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd)	(ppmvd)	(diff)	(diff ²)
1	12:06 - 12:26	YES	184.0	0.30	0.00	0.3000	0.09
2	12:41 - 13:01	YES	185.0	0.30	0.00	0.3000	0.09
3	13:15 - 13:35	YES	185.0	0.20	0.00	0.2000	0.04
4	13:48 - 14:08	YES	185.0	0.30	0.00	0.3000	0.09
5	14:23 - 14:43	YES	185.0	0.30	0.00	0.3000	0.09
6	15:00 - 15:20	YES	185.0	0.20	0.00	0.2000	0.04
7	08:08 - 08:28	YES	191.0	0.60	1.50	-0.9000	0.81
8	08:59 - 09:19	YES	193.0	0.40	1.40	-1.0000	1.00
9	09:32 - 09:52	YES	192.0	0.30	1.40	-1.1000	1.21
10	10:53 - 11:13	NO	192.0	0.30	1.20		
11		NO					
12		NO					
Total			1685.0	2.90	4.30	-1.400000	3.460000
Average			187.2	0.32	0.48	-0.155556	
Number of Runs				9			
Standard Deviation				0.636614			
T-value				2.306			
Confidence Coefficient				0.489344			
Relative Accuracy = 200.1% d (difference in ppm) + CC = 0.6							

Part 60, Appendix B, Performance Specification 4,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
O₂ RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(%vd)	(%vd)	(diff)	(diff ²)
1	12:06 - 12:26	YES	184.0	13.80	13.80	0.0000	0.00
2	12:41 - 13:01	YES	185.0	13.90	13.80	0.1000	0.01
3	13:15 - 13:35	YES	185.0	13.80	13.80	0.0000	0.00
4	13:48 - 14:08	YES	185.0	13.80	13.80	0.0000	0.00
5	14:23 - 14:43	YES	185.0	13.80	13.80	0.0000	0.00
6	15:00 - 15:20	YES	185.0	13.80	13.80	0.0000	0.00
7	08:08 - 08:28	YES	191.0	13.70	13.70	0.0000	0.00
8	08:59 - 09:19	YES	193.0	13.80	13.70	0.1000	0.01
9	09:32 - 09:52	YES	192.0	13.80	13.70	0.1000	0.01
10	10:53 - 11:13	NO	192.0	13.80	13.70		
11		NO					
12		NO					
Total			1685.0	124.20	123.90	0.300000	0.030000
Average			187.2	13.80	13.77	0.033333	
Number of Runs				9			
Standard Deviation				0.050000			
T-value				2.306			
Confidence Coefficient				0.038433			
Average Difference = 0.0 Relative Accuracy = 0.5%							

Part 60, Appendix B, Performance Specification 3,

13.2 CEMS Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent of the mean value of the reference method (RM) data. The results are also acceptable if the absolute value of the difference between the mean RM value and the mean CEMS value is less than or equal to 1.0 percent O₂ (or CO₂).

Part 75, Appendix A,

3.3.3 Relative Accuracy for CO₂ and O₂ Monitors

The relative accuracy for CO₂ and O₂ monitors shall not exceed 10.0 percent. The relative accuracy test results are also acceptable if the difference between the mean value of the CO₂ or O₂ monitor measurements and the corresponding reference method measurement mean value, calculated using equation A-7 of this appendix, does not exceed ± 1.0 percent CO₂ or O₂.

Part 75, Appendix B,

2.3.1.2 Reduced RATA Frequencies

Relative accuracy test audits of primary and redundant backup SO₂ pollutant concentration monitors, CO₂ pollutant concentration monitors (including O₂ monitors used to determine CO₂ emissions), CO₂ or O₂ diluent monitors used to determine heat input, moisture monitoring systems, NO_x concentration monitoring systems, flow monitors, NO_x-diluent monitoring systems or SO₂-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:

(a) The relative accuracy during the audit of an SO₂ or CO₂ pollutant concentration monitor (including an O₂ pollutant monitor used to measure CO₂ using the procedures in appendix F to this part), or of a CO₂ or O₂ diluent monitor used to determine heat input, or of a NO_x concentration monitoring system, or of a NO_x-diluent monitoring system, or of an SO₂-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(e) For low SO₂ or NO_x emitting units (average SO₂ or NO_x reference method concentrations ≤ 250 ppm) during the RATA, when an SO₂ pollutant concentration monitor or NO_x concentration monitoring system fails to achieve a relative accuracy ≤ 7.5 percent during the audit, but the monitor mean value from the RATA is within ± 12 ppm of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO ₂ or NO _x (3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO ₂ -diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NO _x -diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO ₂ or O ₂	7.5% < RA ≤ 10.0% or ± 1.0% CO ₂ /O ₂ (2)	RA ≤ 7.5% or ± 0.7% CO ₂ /O ₂ (2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H ₂ O(2)	RA ≤ 7.5% or ± 1.0% H ₂ O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO₂ monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.

(2) The difference between monitor and reference method mean values applies to moisture monitors, CO₂, and O₂ monitors, low emitters, or low flow, only.

(3) A NO_x concentration monitoring system used to determine NO_x mass emissions under § 75.71.

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O ₂)	(ppmvd@15%O ₂)	(diff)	(diff ²)
1	12:06 - 12:26	YES	184.0	5.80	5.40	0.4000	0.16
2	12:41 - 13:01	YES	185.0	5.70	5.60	0.1000	0.01
3	13:15 - 13:35	YES	185.0	5.80	5.60	0.2000	0.04
4	13:48 - 14:08	NO	185.0	5.80	5.50		
5	14:23 - 14:43	YES	185.0	5.60	5.40	0.2000	0.04
6	15:00 - 15:20	YES	185.0	5.80	5.60	0.2000	0.04
7	08:08 - 08:28	YES	191.0	5.60	5.40	0.2000	0.04
8	08:59 - 09:19	YES	193.0	5.80	5.50	0.3000	0.09
9	09:32 - 09:52	YES	192.0	5.70	5.50	0.2000	0.04
10	10:53 - 11:13	YES	192.0	5.70	5.50	0.2000	0.04
11		NO					
12		NO					
Total			1692.0	51.50	49.50	2.000000	0.500000
Average			188.0	5.72	5.50	0.222222	
Number of Runs				9			
Standard Deviation				0.083333			
T-value				2.306			
Confidence Coefficient				0.064056			
Relative Accuracy = 5.0%							

Part 60, Appendix B, Performance Specification 2,

8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.

13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).

Eq. 2.6 $RA = (|d| + |CC|) * 100 / RM$

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
CO RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O ₂)	(ppmvd@15%O ₂)	(diff)	(diff ²)
1	12:06 - 12:26	YES	184.0	0.30	0.00	0.3000	0.09
2	12:41 - 13:01	YES	185.0	0.20	0.00	0.2000	0.04
3	13:15 - 13:35	YES	185.0	0.20	0.00	0.2000	0.04
4	13:48 - 14:08	YES	185.0	0.20	0.00	0.2000	0.04
5	14:23 - 14:43	YES	185.0	0.20	0.00	0.2000	0.04
6	15:00 - 15:20	YES	185.0	0.20	0.00	0.2000	0.04
7	08:08 - 08:28	YES	191.0	0.50	1.20	-0.7000	0.49
8	08:59 - 09:19	YES	193.0	0.40	1.10	-0.7000	0.49
9	09:32 - 09:52	YES	192.0	0.30	1.10	-0.8000	0.64
10	10:53 - 11:13	NO	192.0	0.30	1.00		
11		NO					
12		NO					
Total			1685.0	2.50	3.40	-0.900000	1.910000
Average			187.2	0.28	0.38	-0.100000	
Number of Runs				9			
Standard Deviation				0.476970			
T-value				2.306			
Confidence Coefficient				0.366631			
Relative Accuracy = 168.0% d (difference in ppm) + CC = 0.6							

Part 60, Appendix B, Performance Specification 4,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	(diff ²)
1	12:06 - 12:26	YES	184.0	44.00	41.00	3.0000	9.00
2	12:41 - 13:01	YES	185.0	43.20	42.10	1.1000	1.21
3	13:15 - 13:35	YES	185.0	44.10	42.10	2.0000	4.00
4	13:48 - 14:08	NO	185.0	44.00	41.60		
5	14:23 - 14:43	YES	185.0	42.60	41.20	1.4000	1.96
6	15:00 - 15:20	YES	185.0	44.00	41.80	2.2000	4.84
7	08:08 - 08:28	YES	191.0	43.50	41.50	2.0000	4.00
8	08:59 - 09:19	YES	193.0	44.90	42.60	2.3000	5.29
9	09:32 - 09:52	YES	192.0	43.90	42.40	1.5000	2.25
10	10:53 - 11:13	YES	192.0	44.30	42.40	1.9000	3.61
11		NO					
12		NO					
Total			1692.0	394.50	377.10	17.400000	36.160000
Average			188.0	43.83	41.90	1.933333	
Number of Runs				9			
Standard Deviation				0.561249			
T-value				2.306			
Confidence Coefficient				0.431413			
Relative Accuracy = 5.4%							

Part 60, Appendix B, Performance Specification 2,

8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.

13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).

Eq. 2.6 $RA = (|d| + |CC|) * 100 / RM$

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
CO RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	(diff ²)
1	12:06 - 12:26	YES	184.0	1.20	0.00	1.2000	1.44
2	12:41 - 13:01	YES	185.0	1.10	0.00	1.1000	1.21
3	13:15 - 13:35	YES	185.0	0.90	0.00	0.9000	0.81
4	13:48 - 14:08	YES	185.0	1.10	0.00	1.1000	1.21
5	14:23 - 14:43	YES	185.0	1.10	0.00	1.1000	1.21
6	15:00 - 15:20	YES	185.0	0.90	0.00	0.9000	0.81
7	08:08 - 08:28	YES	191.0	2.40	5.90	-3.5000	12.25
8	08:59 - 09:19	YES	193.0	1.70	5.70	-4.0000	16.00
9	09:32 - 09:52	YES	192.0	1.40	5.50	-4.1000	16.81
10	10:53 - 11:13	NO	192.0	1.30	4.50		
11		NO					
12		NO					
Total			1685.0	11.80	17.10	-5.300000	51.750000
Average			187.2	1.31	1.90	-0.588889	
Number of Runs				9			
Standard Deviation				2.465484			
T-value				2.306			
Confidence Coefficient				1.895135			
Relative Accuracy = 189.5% d (difference in ppm) + CC = 0.6							

Part 60, Appendix B, Performance Specification 4,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS									
			(MW)	(lb/MMBtu)	(lb/MMBtu)	(diff)	(diff ²)								
1	12:06 - 12:26	YES	184.0	0.023	0.021	0.0020	0.0000								
2	12:41 - 13:01	YES	185.0	0.022	0.022	0.0000	0.0000								
3	13:15 - 13:35	YES	185.0	0.023	0.022	0.0010	0.0000								
4	13:48 - 14:08	NO	185.0	0.023	0.022										
5	14:23 - 14:43	YES	185.0	0.022	0.021	0.0010	0.0000								
6	15:00 - 15:20	YES	185.0	0.023	0.022	0.0010	0.0000								
7	08:08 - 08:28	YES	191.0	0.022	0.021	0.0010	0.0000								
8	08:59 - 09:19	YES	193.0	0.023	0.021	0.0020	0.0000								
9	09:32 - 09:52	YES	192.0	0.022	0.021	0.0010	0.0000								
10	10:53 - 11:13	YES	192.0	0.022	0.021	0.0010	0.0000								
11		NO													
12		NO													
Total			1692.0	0.202	0.192	0.010000	0.000014								
Average			188.0	0.022	0.021	0.001111									
Number of Runs				9											
Standard Deviation				0.000601											
T-value				2.306											
Confidence Coefficient				0.000462											
Relative Accuracy = 7.01%															
<p>If the mean difference is less than or equal to the absolute value of the confidence coefficient, then the Bias Test passes and the bias adjustment factor is not applicable.</p> <table style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Mean Difference =</td> <td style="padding: 5px;">0.0011</td> </tr> <tr> <td style="padding: 5px;">Confidence Coefficient =</td> <td style="padding: 5px;">0.0005</td> </tr> </table> <p style="text-align: center; margin-top: 10px;">BAF = 1 + (abs. value mean difference/avg. CEMS reading)</p> <table style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Average CEMS Reading =</td> <td style="padding: 5px;">0.021</td> </tr> <tr> <td style="padding: 5px;">BAF =</td> <td style="padding: 5px;">1.052</td> </tr> </table>								Mean Difference =	0.0011	Confidence Coefficient =	0.0005	Average CEMS Reading =	0.021	BAF =	1.052
Mean Difference =	0.0011														
Confidence Coefficient =	0.0005														
Average CEMS Reading =	0.021														
BAF =	1.052														

Part 75, Appendix A,

3.3.2 Relative Accuracy for NOX-Diluent Continuous Emission Monitoring Systems

(a) The relative accuracy for NOX-diluent continuous emission monitoring systems shall not exceed 10.0 percent.

(b) For affected units where the average of the reference method measurements of NOX emission rate (this means lb/MMBtu) during the relative accuracy test audit is less than or equal to 0.200 lb/mmBtu, the difference between the mean value of the continuous emission monitoring system measurements and the reference method mean value shall not exceed ±0.020 lb/mmBtu, wherever the relative accuracy specification of 10.0 percent is not achieved.

7.6.5 Bias Adjustment

(b) For single-load RATAs of SO2 pollutant concentration monitors, NOX concentration monitoring systems, and NOX-diluent monitoring systems and for the single-load flow RATAs required or allowed under section 6.5.2 of this appendix and sections 2.3.1.3(b) and 2.3.1.3(c) of Appendix B to this part, the appropriate BAF is determined directly from the RATA results at normal load, using Equation A-12. Notwithstanding, when a NOX concentration CEMS or an SO2 CEMS or a NOX-diluent CEMS installed on a low-emitting affected unit (i.e., average SO2 or NOX concentration during the RATA &IE; 250 ppm or average NOX emission rate &IE; 0.200 lb/mmBtu) meets the normal 10.0 percent relative accuracy specification (as calculated using Equation A-10) or the alternate relative accuracy specification in section 3.3 of this appendix for low-emitters, but fails the bias test, the BAF may either be determined using Equation A-12, or a default BAF of 1.111 may be used.

Part 75, Appendix B,

2.3.1.2 Reduced RATA Frequencies. Relative accuracy test audits of primary and redundant backup SO2 pollutant concentration monitors, CO2 pollutant concentration monitors (including O2 monitors used to determine CO2 emissions), CO2 or O2 diluent monitors used to determine heat input, moisture monitoring systems, NOX concentration monitoring systems, flow monitors, NOX-diluent monitoring systems or SO2-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:

(a) The relative accuracy during the audit of an SO2 or CO2 pollutant concentration monitor (including an O2 pollutant monitor used to measure CO2 using the procedures in appendix F to this part), or of a CO2 or O2 diluent monitor used to determine heat input, or of a NOX concentration monitoring system, or of a NOX-diluent monitoring system, or of an SO2-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(f) For units with low NOX emission rates (average NOX emission rate measured by the reference method during the RATA ≤ 0.200 lb/mmBtu), when a NOX-diluent continuous emission monitoring system fails to achieve a relative accuracy ≤ 7.5 percent, but the monitoring system mean value from the RATA, calculated using Equation A-7 in appendix A to this part, is within ± 0.015 lb/mmBtu of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO2 or NOX(3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO2-diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NOX-diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO2 or O2	7.5% < RA ≤ 10.0% or ± 1.0% CO2/O2(2)	RA ≤ 7.5% or ± 0.7% CO2/O2(2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H2O(2)	RA ≤ 7.5% or ± 1.0% H2O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO2 monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.

(2) The difference between monitor and reference method mean values applies to moisture monitors, CO2, and O2 monitors, low emitters, or low flow, only.

(3) A NOX concentration monitoring system used to determine NOX mass emissions under § 75.71.

**Relative Accuracy Test Data
CEMS Results (NOx)
Siemens, SCC6-5000F, Unit #2**

Parameter:	Oxides of Nitrogen
Date of Test:	May 11, 2018
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Chemiluminescence
Manufacturer:	Teledyne API
Model #:	T200M
Serial #:	646

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:06 - 12:26	184.0	6.60	5.40	41.00	0.021
2	12:41 - 13:01	185.0	6.70	5.60	42.10	0.022
3	13:15 - 13:35	185.0	6.70	5.60	42.10	0.022
4	13:48 - 14:08	185.0	6.60	5.50	41.60	0.022
5	14:23 - 14:43	185.0	6.50	5.40	41.20	0.021
6	15:00 - 15:20	185.0	6.70	5.60	41.80	0.022
7	08:08 - 08:28	191.0	6.60	5.40	41.50	0.021
8	08:59 - 09:19	193.0	6.70	5.50	42.60	0.021
9	09:32 - 09:52	192.0	6.80	5.50	42.40	0.021
10	10:53 - 11:13	192.0	6.70	5.50	42.40	0.021
11						
12						

**Relative Accuracy Test Data
CEMS Results (CO)
Siemens, SCC6-5000F, Unit #2**

Parameter:	Carbon Monoxide
Date of Test:	May 11, 2018
Reference Method:	EPA Method 10
CEMS Analyzer Type:	Infrared Absorption
Manufacturer:	Teledyne API
Model #:	T300M
Serial #:	354

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:06 - 12:26	184.0	0.00	0.00	0.00	
2	12:41 - 13:01	185.0	0.00	0.00	0.00	
3	13:15 - 13:35	185.0	0.00	0.00	0.00	
4	13:48 - 14:08	185.0	0.00	0.00	0.00	
5	14:23 - 14:43	185.0	0.00	0.00	0.00	
6	15:00 - 15:20	185.0	0.00	0.00	0.00	
7	08:08 - 08:28	191.0	1.50	1.20	5.90	
8	08:59 - 09:19	193.0	1.40	1.10	5.70	
9	09:32 - 09:52	192.0	1.40	1.10	5.50	
10	10:53 - 11:13	192.0	1.20	1.00	4.50	
11						
12						

**Relative Accuracy Test Data
CEMS Results (O₂)
Siemens, SCC6-5000F, Unit #2**

Parameter:	Oxygen
Date of Test:	May 11, 2018
Reference Method:	EPA Method 3A
CEMS Analyzer Type:	Paramagnetic Cell
Manufacturer:	Teledyne API
Model #:	T200M
Serial #:	646

RUN #	RUN TIME	UNIT LOAD	CONC.
		(MW)	(%vd)
1	12:06 - 12:26	184.0	13.80
2	12:41 - 13:01	185.0	13.80
3	13:15 - 13:35	185.0	13.80
4	13:48 - 14:08	185.0	13.80
5	14:23 - 14:43	185.0	13.80
6	15:00 - 15:20	185.0	13.80
7	08:08 - 08:28	191.0	13.70
8	08:59 - 09:19	193.0	13.70
9	09:32 - 09:52	192.0	13.70
10	10:53 - 11:13	192.0	13.70
11			
12			

**Relative Accuracy Test Data
Reference Method Results (NOx)
Siemens, SCC6-5000F, Unit #2**

Parameter:	Oxides of Nitrogen
Date of Test:	May 11, 2018
Reference Method:	EPA Method 7E
RM Analyzer Type:	Chemiluminescence
Manufacturer:	THERMO 42i-HL
Model #:	
Serial #:	INST-NX-0064

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:06 - 12:26	184.0	6.95	5.80	43.99	0.023
2	12:41 - 13:01	185.0	6.79	5.70	43.17	0.022
3	13:15 - 13:35	185.0	6.97	5.82	44.07	0.023
4	13:48 - 14:08	185.0	6.95	5.81	43.97	0.023
5	14:23 - 14:43	185.0	6.73	5.62	42.60	0.022
6	15:00 - 15:20	185.0	6.96	5.81	44.03	0.023
7	08:08 - 08:28	191.0	6.85	5.61	43.47	0.022
8	08:59 - 09:19	193.0	6.96	5.78	44.86	0.023
9	09:32 - 09:52	192.0	6.82	5.67	43.89	0.022
10	10:53 - 11:13	192.0	6.90	5.72	44.26	0.022
11						
12						

**Relative Accuracy Test Data
Reference Method Results (CO)
Siemens, SCC6-5000F, Unit #2**

Parameter:	Carbon Monoxide
Date of Test:	May 11, 2018
Reference Method:	EPA Method 10
RM Analyzer Type:	Infrared Absorption
Manufacturer:	THERMO 48i
Model #:	
Serial #:	INST-CO-0016

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:06 - 12:26	184.0	0.31	0.26	1.19	
2	12:41 - 13:01	185.0	0.28	0.24	1.09	
3	13:15 - 13:35	185.0	0.23	0.19	0.88	
4	13:48 - 14:08	185.0	0.29	0.24	1.10	
5	14:23 - 14:43	185.0	0.30	0.25	1.14	
6	15:00 - 15:20	185.0	0.24	0.20	0.92	
7	08:08 - 08:28	191.0	0.61	0.50	2.37	
8	08:59 - 09:19	193.0	0.44	0.37	1.74	
9	09:32 - 09:52	192.0	0.35	0.29	1.36	
10	10:53 - 11:13	192.0	0.34	0.28	1.32	
11						
12						

**Relative Accuracy Test Data
Reference Method Results (O₂)
Siemens, SCC6-5000F, Unit #2**

Parameter:	Oxygen
Date of Test:	May 11, 2018
Reference Method:	EPA Method 3A
RM Analyzer Type:	Paramagnetic Cell
Manufacturer:	SERVOMEX 1440
Model #:	
Serial #:	inst-O2-0023

RUN #	RUN TIME	UNIT LOAD	CONC.
		(MW)	(%vd)
1	12:06 - 12:26	184.0	13.83
2	12:41 - 13:01	185.0	13.87
3	13:15 - 13:35	185.0	13.83
4	13:48 - 14:08	185.0	13.84
5	14:23 - 14:43	185.0	13.83
6	15:00 - 15:20	185.0	13.83
7	08:08 - 08:28	191.0	13.71
8	08:59 - 09:19	193.0	13.80
9	09:32 - 09:52	192.0	13.81
10	10:53 - 11:13	192.0	13.78
11			
12			

EXAMPLE CALCULATIONS (INFORMATION)**Specific Humidity (RH_{sp})**

Note: RH_{sp} (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} (lb/lb) = \left[\left(\frac{gr}{lb} \right) \times \frac{lb}{7000 gr} \right]$$

$$RH_{sp} = \frac{36.94 \text{ gr}}{lb} \times \frac{1 \text{ lb}}{7000 \text{ gr}} = 0.005278 \frac{\text{lb H}_2\text{O}}{\text{lb Air}}$$

EXAMPLE CALCULATIONS (CALIBRATION)**Analyzer Calibration Error**

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NO_x analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100 \quad \text{Eq. 7E-1}$$

$$ACE = \frac{9.60 \text{ ppm} - 9.30 \text{ ppm}}{18.30 \text{ ppm}} \times 100 = 1.64 \%$$

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)**System Bias**

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NO_x analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS} \right) \times 100 \quad \text{Eq. 7E-2}$$

$$SB = \frac{9.26 \text{ ppm} - 9.60 \text{ ppm}}{18.30 \text{ ppm}} \times 100 = -1.86 \%$$

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NO_x analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{final} - SB_i| \quad \text{Eq. 7E-4}$$

$$D = |0.16 \% - -1.86 \%| = 2.02 \%$$

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate C_{avg}, the arithmetic average of all valid NO_x concentration values (e.g., 1-minute averages). Then adjust the value of C_{avg} for bias, using Equation 7E-5b. (calc for NO_x analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right) \quad \text{Eq. 7E-5b}$$

$$C_{Gas} = \left(7.15 \text{ ppm} - 0.38 \text{ ppm} \right) \left(\frac{9.30 \text{ ppm}}{9.45 \text{ ppm} - 0.38 \text{ ppm}} \right) = 6.95 \text{ ppm}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RATA RESULTS)

Difference (d)

40 CFR 75, App A, (12-17-09), 7.3.1 Arithmetic Mean. Calculate the arithmetic mean of the differences, d , of a data set as follows. (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$d = \sum_{i=1}^n d_i \quad \text{Eq. A-7} \quad d = 6.889 \text{ ppm} - 6.667 \text{ ppm} = 0.222 \text{ ppm}$$

Standard Deviation

40 CFR 75, App A, (12-17-09), 7.3.2 Standard Deviation. Calculate the standard deviation, S_d , of a data set as follows: (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{\left(\sum_{i=1}^n d_i\right)^2}{n}}{n-1}} \quad \text{Eq. A-8} \quad S_d = \sqrt{\frac{0.560 \text{ ppm}^2 - \frac{[2.000 \text{ ppm}]^2}{9}}{9-1}} = 0.120 \text{ ppm}$$

Confidence Coefficient

40 CFR 75, App A, (12-17-09), 7.3.3 Confidence Coefficient. Calculate the confidence coefficient (one-tailed), cc , of a data set as follows. (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}} \quad \text{Eq. A-9} \quad CC = 2.306 \times \frac{0.120 \text{ ppm}}{\sqrt{9}} = 0.092 \text{ ppm}$$

T-Values	n	2	3	4	5	6	7	8	9
$t_{0.025}$		12.706	4.303	3.182	2.776	2.571	2.447	2.365	2.306

2.5 percent confidence coefficients

Relative Accuracy

40 CFR 75, App A, (12-17-09), 7.3.4 Relative Accuracy. Calculate the relative accuracy of a data set using the following equation. (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100 \quad \text{Eq. A-10} \quad RA = \frac{|0.222| \text{ ppm} + |0.092| \text{ ppm}}{6.889 \text{ ppm}} \times 100 = 4.57 \%$$

Bias Adjustment Factor (BAF)

40 CFR 75, App A, (12-17-09), 7.6.5 Bias Adjustment. (a) If the monitor or monitoring system fails to meet the bias test requirement, adjust the value obtained from the monitor using the following equation: (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right) \quad \text{Eq. A-12} \quad d_{AVG} = 0.222 > |CC| = 0.092 \Rightarrow BAF = 1 + \frac{|0.222| \text{ ppm}}{6.667 \text{ ppm}} = 1.033 \text{ ppm}$$

Note: BAF only applies if the mean difference (d) is greater than the absolute value of the confidence coefficient.

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NO_x measured in the spiked sample.
C_{Spike} = Concentration of NO_x in the undiluted spike gas.
C_{Calc} = Calculated concentration of NO_x in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO₂} = NO₂ to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NO_{Final} = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NO_xCorr = The NO_x concentration corrected for the converter efficiency.
NO_xFinal = The final NO_x concentration observed during the converter efficiency test in Section 16.2.2.
NO_xPeak = The highest NO_x concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H₂O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
%_C = Concentration of carbon from an ultimate analysis of fuel, weight percent.
%_{CO_{2d}}, %_{CO_{2w}} = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{aoi}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu)
E_{di} = Average inlet SO₂ rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O₂.
E_{jo}, E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft³ = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
%_H = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
%_{H₂O} = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10⁻⁵ (kJ/J)/(%) [10⁶ Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = 2x10⁴ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p, L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
%_N = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
M% = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)¹
NCM = net Btu per SCF (constant based on compound)
%_O = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
%_{O_{2d}}, %_{O_{2w}} = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO₂ emissions, percent.
%_S = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
%_{S_f} = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
%S_p, %S_r = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
t_{0.95} = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO₂} = CO₂ Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole)	= 46.01
Molecular Weight of CO (lb/lb-mole)	= 28.00
Molecular Weight of SO ₂ (lb/lb-mole)	= 64.00
Molecular Weight of THC (propane) (lb/lb-mole)	= 44.00
Molecular Weight of VOC (methane) (lb/lb-mole)	= 16.00
Molecular Weight of NH ₃ (lb/lb-mole)	= 17.03
Molecular Weight of HCHO (lb/lb-mole)	= 30.03
Molecular Weight of CO ₂ (lb/lb-mole)	= 44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx	= 0.0000001194351
Conversion Constant for CO	= 0.0000000726839
Conversion Constant for SO ₂	= 0.0000001661345
Conversion Constant for THC	= 0.0000001142175
Conversion Constant for VOC (methane)	= 0.0000000415336
Conversion Constant for NH ₃	= 0.0000000442074
Conversion Constant for HCHO	= 0.0000000779534
Conversion Constant for CO ₂	= 0.0000001142434

NOTE: units are lb/ppm*ft³

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_o) \times \left(\frac{C_{MA}}{C_M - C_o} \right)$$

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_s \times MW}{G}$$

2. Correction to % O₂, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

3. Correction to % O₂ and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_o - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

6. Emission Rate in tons per year

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O_2)}}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_s = \left(\frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

7. Emission Concentration in lb/MMBtu (O₂ based)

$$E_{g/hp-hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp}$$

RATA SHEET CALCULATIONS

d = Reference Method Data - CEMS Data

S_d = Standard Deviation

CC = Confident Coefficient

n = number of runs

t_{0.025} = 2.5 percent confidence coefficient T-values

RA = relative accuracy

ARA = alternative relative accuracy

BAF = Bias adjustment factor

n	t	n	t	n	t
2	12.706	7	2.447	12	2.201
3	4.303	8	2.365	13	2.179
4	3.182	9	2.306	14	2.160
5	2.776	10	2.262	15	2.145
6	2.571	11	2.228	16	2.131

1. Difference

$$d = \sum_{i=1}^n d_i$$

4. Relative Accuracy

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$

2. Standard Deviation

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{\left(\sum_{i=1}^n d_i \right)^2}{n}}{n-1}}$$

5. Alternative Relative Accuracy

$$ARA = \frac{|d_{AVG}| + |CC|}{AS} \times 100$$

3. Confident Coefficient

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$

5. Bias Adjustment Factor

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right)$$

APPENDIX B

CEMS AND REFERENCE METHOD DATA

CPV VALLEY LLC

Air Permit Number:	3-3356-00136/00001
Plant Name or Location:	CPV VALLEY ENERGY CENTER
Date:	May 11, 2018
Project Number:	sie-17-middletown.ny-start#1
Manufacturer & Equipment:	Siemens
Model:	SCC6-5000F
Unit Number:	2
Test Load:	Max
Tester(s) / Test Unit(s):	MS

#N/A

		RUN									
	UNITS	1	2	3	4	5	6	7	8	9	10
Start Time	hh:mm:ss	12:06:21	12:41:21	13:15:22	13:48:22	14:23:22	15:00:22	08:08:07	08:59:09	09:32:00	10:53:01
End Time	hh:mm:ss	12:26:51	13:01:51	13:35:52	14:08:52	14:43:52	15:20:52	08:28:37	09:19:39	09:52:30	11:13:31
Bar. Pressure	in. Hg	29.55	29.54	29.56	29.56	29.56	29.57	29.71	29.65	29.66	29.66
Amb. Temp.	°F	68	67	67	68	67	68	57	70	51	51
Rel. Humidity	%	36	35	35	35	36	35	61	69	71	71
Spec. Humidity	lb water / lb air	0.005278	0.004956	0.004953	0.005128	0.005096	0.005126	0.006044	0.010893	0.005654	0.005654
Date	mm/dd/yy	05/11/18	05/11/18	05/11/18	05/11/18	05/11/18	05/11/18	05/12/18	05/12/18	05/12/18	05/12/18
Turbine Fuel Flow	gal/hr	14,049	14,036	14,036	14,016	14,049	14,049	14,347	14,374	14,333	14,333
Total Fuel Flow	SCFH	1,878	1,876	1,876	1,874	1,878	1,878	1,918	1,921	1,916	1,916
Power Output	megawatts	184.0	185.0	185.0	185.0	185.0	185.0	191.0	193.0	192.0	192.0
O₂ CEMS Data	%vd	13.8	13.8	13.8	13.8	13.8	13.8	13.7	13.7	13.7	13.7
NOx CEMS Data	ppmvd	6.60	6.70	6.70	6.60	6.50	6.70	6.60	6.70	6.80	6.70
	ppmvd@15%O ₂	5.40	5.60	5.60	5.50	5.40	5.60	5.40	5.50	5.50	5.50
	lb/hr	41.00	42.10	42.10	41.60	41.20	41.80	41.50	42.60	42.40	42.40
	lb/MMBtu	0.021	0.022	0.022	0.022	0.021	0.022	0.021	0.021	0.021	0.021
CO CEMS Data	ppmvd	0.00	0.00	0.00	0.00	0.00	0.00	1.50	1.40	1.40	1.20
	ppmvd@15%O ₂	0.00	0.00	0.00	0.00	0.00	0.00	1.20	1.10	1.10	1.00
	lb/hr	0.00	0.00	0.00	0.00	0.00	0.00	5.90	5.70	5.50	4.50

Created with Comp&RATA&Eng-AHI v20180227

CEMS AND REFERENCE METHOD DATA

CEMS Data

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/11/2018 12:06	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:07	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:08	1939.5	ON	GD	13.8	ON	GD	0.1	ON	GD	0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:09	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:10	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:11	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:12	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:13	1919.9	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 12:14	1919.9	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	184
05/11/2018 12:15	1919.9	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 12:16	1919.9	ON	GD	13.8	ON	GD	0.2	ON	GD	0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 12:17	1919.9	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:18	1939.5	ON	GD	13.8	ON	GD	0.1	ON	GD	0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:19	1939.5	ON	GD	13.8	ON	GD	0.1	ON	GD	0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:20	1939.5	ON	GD	13.8	ON	GD	0.2	ON	GD	0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:21	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 12:22	1919.9	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 12:23	1919.9	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	183
05/11/2018 12:24	1919.9	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	183
05/11/2018 12:25	1919.9	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 12:26	1919.9	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	184
Average	1930.2			13.8			-0.1			-0.1			-0.1			0.000			184
Maximum	1939.5			13.8			0.2			0.2			0.0			0.000			185
Minimum	1919.9			13.8			-0.3			-0.2			-1.9			-0.001			183
Total	40533.5			289.8			-1.2			-1.1			-1.9			-0.001			3874

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	KLBHR	OS	MS
05/11/2018 12:06	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99	ON	GD
05/11/2018 12:07	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99	ON	GD
05/11/2018 12:08	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99	ON	GD
05/11/2018 12:09	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99	ON	GD
05/11/2018 12:10	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99	ON	GD
05/11/2018 12:11	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99	ON	GD
05/11/2018 12:12	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99	ON	GD
05/11/2018 12:13	ON	GD	5.6	ON	GD	42.2	ON	GD	6.7	ON	GD	0.022	ON	GD	98	ON	GD
05/11/2018 12:14	ON	GD	5.6	ON	GD	42.2	ON	GD	6.7	ON	GD	0.022	ON	GD	98	ON	GD
05/11/2018 12:15	ON	GD	5.5	ON	GD	40.3	ON	GD	6.6	ON	GD	0.021	ON	GD	98	ON	GD
05/11/2018 12:16	ON	GD	5.3	ON	GD	40.3	ON	GD	6.4	ON	GD	0.021	ON	GD	98	ON	GD
05/11/2018 12:17	ON	GD	5.2	ON	GD	38.4	ON	GD	6.2	ON	GD	0.020	ON	GD	98	ON	GD
05/11/2018 12:18	ON	GD	5.2	ON	GD	38.8	ON	GD	6.2	ON	GD	0.020	ON	GD	99	ON	GD
05/11/2018 12:19	ON	GD	5.2	ON	GD	38.8	ON	GD	6.2	ON	GD	0.020	ON	GD	99	ON	GD
05/11/2018 12:20	ON	GD	5.2	ON	GD	38.8	ON	GD	6.3	ON	GD	0.020	ON	GD	99	ON	GD
05/11/2018 12:21	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99	ON	GD
05/11/2018 12:22	ON	GD	6.2	ON	GD	46.1	ON	GD	7.5	ON	GD	0.024	ON	GD	98	ON	GD
05/11/2018 12:23	ON	GD	6.4	ON	GD	48.0	ON	GD	7.7	ON	GD	0.025	ON	GD	98	ON	GD
05/11/2018 12:24	ON	GD	6.3	ON	GD	48.0	ON	GD	7.6	ON	GD	0.025	ON	GD	98	ON	GD
05/11/2018 12:25	ON	GD	5.0	ON	GD	36.5	ON	GD	6.0	ON	GD	0.019	ON	GD	98	ON	GD
05/11/2018 12:26	ON	GD	4.6	ON	GD	34.6	ON	GD	5.5	ON	GD	0.018	ON	GD	98	ON	GD
Average			5.4			41.0			6.6			0.021			99		
Maximum			6.4			48.0			7.7			0.025			99		
Minimum			4.6			34.6			5.5			0.018			98		
Total			114.4			860.6			137.6			0.446			2069		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/11/2018 13:15	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 13:16	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:17	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:18	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:19	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:20	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:21	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:22	1919.9	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 13:23	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:24	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:25	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:26	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 13:27	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:28	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 13:29	1919.9	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:30	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 13:31	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 13:32	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:33	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 13:34	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:35	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	184
Average	1937.6			13.8			-0.1			-0.1			-0.2			0.000			185
Maximum	1939.5			13.8			0.0			0.0			0.0			0.000			186
Minimum	1919.9			13.8			-0.3			-0.2			-1.9			-0.001			184
Total	40690.3			289.8			-2.3			-2.1			-3.8			-0.002			3885

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/11/2018 13:15	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:16	ON	GD	5.9	ON	GD	44.6	ON	GD	7.1	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:17	ON	GD	6.0	ON	GD	44.6	ON	GD	7.2	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:18	ON	GD	5.9	ON	GD	44.6	ON	GD	7.1	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:19	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:20	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:21	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:22	ON	GD	5.4	ON	GD	40.3	ON	GD	6.5	ON	GD	0.021	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 13:23	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:24	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:25	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:26	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:27	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:28	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:29	ON	GD	5.7	ON	GD	42.2	ON	GD	6.8	ON	GD	0.022	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 13:30	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:31	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:32	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:33	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:34	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:35	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
Average			5.6			42.1			6.7			0.022			98905			99		
Maximum			6.0			44.6			7.2			0.023			99000			99		
Minimum			5.3			40.3			6.4			0.021			98000			98		
Total			117.0			883.3			140.7			0.456			2077000			2077		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/11/2018 13:15	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 13:16	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:17	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:18	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:19	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:20	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:21	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:22	1919.9	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 13:23	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:24	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:25	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:26	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 13:27	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:28	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 13:29	1919.9	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:30	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 13:31	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 13:32	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:33	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 13:34	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:35	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	184
Average	1937.6			13.8			-0.1			-0.1			-0.2			0.000			185
Maximum	1939.5			13.8			0.0			0.0			0.0			0.000			186
Minimum	1919.9			13.8			-0.3			-0.2			-1.9			-0.001			184
Total	40690.3			289.8			-2.3			-2.1			-3.8			-0.002			3885

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/11/2018 13:15	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:16	ON	GD	5.9	ON	GD	44.6	ON	GD	7.1	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:17	ON	GD	6.0	ON	GD	44.6	ON	GD	7.2	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:18	ON	GD	5.9	ON	GD	44.6	ON	GD	7.1	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:19	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:20	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:21	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:22	ON	GD	5.4	ON	GD	40.3	ON	GD	6.5	ON	GD	0.021	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 13:23	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:24	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:25	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:26	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:27	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:28	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:29	ON	GD	5.7	ON	GD	42.2	ON	GD	6.8	ON	GD	0.022	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 13:30	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:31	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:32	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:33	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:34	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:35	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
Average			5.6			42.1			6.7			0.022			98905			99		
Maximum			6.0			44.6			7.2			0.023			99000			99		
Minimum			5.3			40.3			6.4			0.021			98000			98		
Total			117.0			883.3			140.7			0.456			2077000			2077		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/11/2018 13:48	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:49	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 13:50	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:51	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:52	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	186
05/11/2018 13:53	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 13:54	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 13:55	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 13:56	1919.9	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 13:57	1919.9	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 13:58	1919.9	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 13:59	1919.9	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	184
05/11/2018 14:00	1919.9	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:01	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:02	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	186
05/11/2018 14:03	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:04	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:05	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:06	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:07	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:08	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
Average	1934.8			13.8			-0.2			-0.2			-0.7			0.000			185
Maximum	1939.5			13.8			0.0			0.0			0.0			0.000			186
Minimum	1919.9			13.8			-0.4			-0.3			-1.9			-0.001			184
Total	40631.5			289.8			-4.1			-3.3			-15.2			-0.008			3884

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/11/2018 13:48	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:49	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:50	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:51	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:52	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:53	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:54	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:55	ON	GD	5.9	ON	GD	44.6	ON	GD	7.1	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 13:56	ON	GD	5.9	ON	GD	44.2	ON	GD	7.1	ON	GD	0.023	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 13:57	ON	GD	5.7	ON	GD	42.2	ON	GD	6.8	ON	GD	0.022	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 13:58	ON	GD	5.6	ON	GD	42.2	ON	GD	6.7	ON	GD	0.022	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 13:59	ON	GD	5.5	ON	GD	40.3	ON	GD	6.6	ON	GD	0.021	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 14:00	ON	GD	5.4	ON	GD	40.3	ON	GD	6.5	ON	GD	0.021	ON	GD	98000	ON	GD	98	ON	GD
05/11/2018 14:01	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:02	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:03	ON	GD	5.2	ON	GD	38.8	ON	GD	6.3	ON	GD	0.020	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:04	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:05	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:06	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:07	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:08	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
Average			5.5			41.6			6.6			0.022			98762			99		
Maximum			5.9			44.6			7.1			0.023			99000			99		
Minimum			5.2			38.8			6.3			0.020			98000			98		
Total			116.1			874.4			139.4			0.452			2074000			2074		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/11/2018 14:23	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:24	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:25	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:26	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:27	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:28	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:29	1939.5	ON	GD	13.8	ON	GD	-0.5	ON	GD	-0.4	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:30	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:31	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	186
05/11/2018 14:32	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	186
05/11/2018 14:33	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	186
05/11/2018 14:34	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:35	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:36	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:37	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:38	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:39	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:40	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 14:41	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:42	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 14:43	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
Average	1939.5			13.8			-0.2			-0.2			-0.9			0.000			185
Maximum	1939.5			13.8			-0.1			-0.1			0.0			0.000			186
Minimum	1939.5			13.8			-0.5			-0.4			-1.9			-0.001			185
Total	40729.5			289.8			-5.2			-4.2			-19.0			-0.010			3888

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/11/2018 14:23	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:24	ON	GD	5.9	ON	GD	44.6	ON	GD	7.1	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:25	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:26	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:27	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:28	ON	GD	5.8	ON	GD	44.6	ON	GD	7.0	ON	GD	0.023	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:29	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:30	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:31	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:32	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:33	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:34	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:35	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:36	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:37	ON	GD	5.3	ON	GD	40.7	ON	GD	6.4	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:38	ON	GD	5.1	ON	GD	38.8	ON	GD	6.1	ON	GD	0.020	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:39	ON	GD	4.8	ON	GD	36.9	ON	GD	5.8	ON	GD	0.019	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:40	ON	GD	4.7	ON	GD	34.9	ON	GD	5.6	ON	GD	0.018	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:41	ON	GD	4.6	ON	GD	34.9	ON	GD	5.5	ON	GD	0.018	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:42	ON	GD	4.7	ON	GD	34.9	ON	GD	5.6	ON	GD	0.018	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 14:43	ON	GD	4.9	ON	GD	36.9	ON	GD	5.9	ON	GD	0.019	ON	GD	99000	ON	GD	99	ON	GD
Average			5.4			41.2			6.5			0.021			99000			99		
Maximum			5.9			44.6			7.1			0.023			99000			99		
Minimum			4.6			34.9			5.5			0.018			99000			99		
Total			114.3			865.2			137.4			0.446			2079000			2079		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/11/2018 15:00	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:01	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:02	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:03	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:04	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:05	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 15:06	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 15:07	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 15:08	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	186
05/11/2018 15:09	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	186
05/11/2018 15:10	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 15:11	1939.5	ON	GD	13.8	ON	GD	-0.3	ON	GD	-0.2	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 15:12	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:13	1939.5	ON	GD	13.8	ON	GD	0.0	ON	GD	0.0	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:14	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:15	1939.5	ON	GD	13.8	ON	GD	-0.1	ON	GD	-0.1	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:16	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:17	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:18	1939.5	ON	GD	13.8	ON	GD	-0.2	ON	GD	-0.2	ON	GD	0.0	ON	GD	0.000	ON	GD	185
05/11/2018 15:19	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
05/11/2018 15:20	1939.5	ON	GD	13.8	ON	GD	-0.4	ON	GD	-0.3	ON	GD	-1.9	ON	GD	-0.001	ON	GD	185
Average	1939.5			13.8			-0.2			-0.2			-0.7			0.000			185
Maximum	1939.5			13.8			0.0			0.0			0.0			0.000			186
Minimum	1939.5			13.8			-0.4			-0.3			-1.9			-0.001			185
Total	40729.5			289.8			-4.1			-3.3			-15.2			-0.008			3887

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/11/2018 15:00	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:01	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:02	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:03	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:04	ON	GD	5.6	ON	GD	42.7	ON	GD	6.7	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:05	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:06	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:07	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:08	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:09	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:10	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:11	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:12	ON	GD	5.7	ON	GD	42.7	ON	GD	6.9	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:13	ON	GD	5.7	ON	GD	42.7	ON	GD	6.8	ON	GD	0.022	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:14	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:15	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:16	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:17	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:18	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:19	ON	GD	5.5	ON	GD	40.7	ON	GD	6.6	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
05/11/2018 15:20	ON	GD	5.4	ON	GD	40.7	ON	GD	6.5	ON	GD	0.021	ON	GD	99000	ON	GD	99	ON	GD
Average			5.6			41.8			6.7			0.022			99000			99		
Maximum			5.7			42.7			6.9			0.022			99000			99		
Minimum			5.4			40.7			6.5			0.021			99000			99		
Total			117.4			878.7			140.8			0.453			2079000			2079		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/12/2018 08:08	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:09	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:10	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:11	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:12	1978.7	SU	GD	13.7	SU	GD	1.7	SU	GD	1.4	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:13	1978.7	SU	GD	13.7	SU	GD	1.7	SU	GD	1.4	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:14	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:15	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:16	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:17	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:18	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:19	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:20	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:21	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 08:22	1998.3	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 08:23	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 08:24	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 08:25	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 08:26	1998.3	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 08:27	1978.7	SU	GD	13.7	SU	GD	1.8	SU	GD	1.5	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 08:28	1978.7	SU	GD	13.7	SU	GD	1.7	SU	GD	1.4	SU	GD	5.9	SU	GD	0.003	SU	GD	192
Average	1980.6			13.7			1.5			1.2			5.9			0.003			192
Maximum	1998.3			13.7			1.8			1.5			6.0			0.003			193
Minimum	1978.7			13.7			1.3			1.1			5.9			0.003			192
Total	41591.9			287.7			32.4			26.2			124.1			0.063			4038

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/12/2018 08:08	SU	GD	4.9	SU	GD	37.6	SU	GD	6.0	SU	GD	0.019	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:09	SU	GD	4.9	SU	GD	37.6	SU	GD	6.0	SU	GD	0.019	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:10	SU	GD	4.9	SU	GD	37.6	SU	GD	6.0	SU	GD	0.019	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:11	SU	GD	5.0	SU	GD	37.6	SU	GD	6.1	SU	GD	0.019	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:12	SU	GD	5.0	SU	GD	37.6	SU	GD	6.1	SU	GD	0.019	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:13	SU	GD	5.1	SU	GD	39.6	SU	GD	6.2	SU	GD	0.020	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:14	SU	GD	5.2	SU	GD	39.6	SU	GD	6.4	SU	GD	0.020	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:15	SU	GD	5.4	SU	GD	41.6	SU	GD	6.6	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:16	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:17	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:18	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:19	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:20	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:21	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:22	SU	GD	5.5	SU	GD	42.0	SU	GD	6.7	SU	GD	0.021	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 08:23	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:24	SU	GD	5.7	SU	GD	43.5	SU	GD	7.0	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:25	SU	GD	5.8	SU	GD	45.5	SU	GD	7.1	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:26	SU	GD	5.7	SU	GD	44.0	SU	GD	7.0	SU	GD	0.022	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 08:27	SU	GD	5.7	SU	GD	43.5	SU	GD	7.0	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 08:28	SU	GD	5.8	SU	GD	45.5	SU	GD	7.1	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
Average			5.4			41.5			6.6			0.021			101095			101		
Maximum			5.8			45.5			7.1			0.023			102000			102		
Minimum			4.9			37.6			6.0			0.019			101000			101		
Total			113.5			871.6			138.6			0.440			2123000			2123		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/12/2018 08:59	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:00	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	194
05/12/2018 09:01	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:02	1998.3	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 09:03	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:04	1998.3	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 09:05	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:06	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:07	1998.3	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 09:08	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:09	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:10	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 09:11	1998.3	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 09:12	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:13	1998.3	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 09:14	1998.3	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	6.0	SU	GD	0.003	SU	GD	193
05/12/2018 09:15	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	194
05/12/2018 09:16	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:17	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 09:18	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:19	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
Average	1984.3			13.7			1.4			1.1			5.7			0.003			193
Maximum	1998.3			13.7			1.6			1.3			6.0			0.003			194
Minimum	1978.7			13.7			1.1			0.9			4.0			0.002			193
Total	41670.3			287.7			29.5			23.8			120.7			0.061			4055

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/12/2018 08:59	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:00	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:01	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:02	SU	GD	5.5	SU	GD	42.0	SU	GD	6.7	SU	GD	0.021	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 09:03	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:04	SU	GD	5.6	SU	GD	44.0	SU	GD	6.8	SU	GD	0.022	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 09:05	SU	GD	6.0	SU	GD	45.5	SU	GD	7.3	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:06	SU	GD	5.8	SU	GD	45.5	SU	GD	7.1	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:07	SU	GD	5.7	SU	GD	44.0	SU	GD	6.9	SU	GD	0.022	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 09:08	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:09	SU	GD	5.3	SU	GD	41.6	SU	GD	6.5	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:10	SU	GD	5.1	SU	GD	39.6	SU	GD	6.2	SU	GD	0.020	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:11	SU	GD	5.1	SU	GD	40.0	SU	GD	6.2	SU	GD	0.020	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 09:12	SU	GD	5.2	SU	GD	39.6	SU	GD	6.3	SU	GD	0.020	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:13	SU	GD	5.2	SU	GD	40.0	SU	GD	6.4	SU	GD	0.020	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 09:14	SU	GD	5.4	SU	GD	42.0	SU	GD	6.6	SU	GD	0.021	SU	GD	102000	SU	GD	102	SU	GD
05/12/2018 09:15	SU	GD	5.7	SU	GD	43.5	SU	GD	6.9	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:16	SU	GD	5.7	SU	GD	43.5	SU	GD	7.0	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:17	SU	GD	5.8	SU	GD	45.5	SU	GD	7.1	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:18	SU	GD	5.8	SU	GD	45.5	SU	GD	7.1	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:19	SU	GD	5.8	SU	GD	45.5	SU	GD	7.1	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
Average			5.5			42.6			6.7			0.021			101286			101		
Maximum			6.0			45.5			7.3			0.023			102000			102		
Minimum			5.1			39.6			6.2			0.020			101000			101		
Total			116.2			895.3			141.7			0.451			2127000			2127		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/12/2018 09:35	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:36	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:37	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:38	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:39	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:40	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 09:41	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:42	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:43	1978.7	SU	GD	13.7	SU	GD	1.5	SU	GD	1.2	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:44	1978.7	SU	GD	13.7	SU	GD	1.6	SU	GD	1.3	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:45	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:46	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 09:47	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 09:48	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:49	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 09:50	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 09:51	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 09:52	1978.7	SU	GD	13.7	SU	GD	1.4	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
Average	1978.7			13.7			1.4			1.1			5.5			0.003			192
Maximum	1978.7			13.7			1.6			1.3			5.9			0.003			193
Minimum	1978.7			13.7			1.2			1.0			4.0			0.002			192
Total	35616.6			246.6			24.3			19.7			98.6			0.050			3458

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/12/2018 09:35	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:36	SU	GD	5.2	SU	GD	39.6	SU	GD	6.4	SU	GD	0.020	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:37	SU	GD	5.2	SU	GD	39.6	SU	GD	6.4	SU	GD	0.020	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:38	SU	GD	5.3	SU	GD	41.6	SU	GD	6.5	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:39	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:40	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:41	SU	GD	5.7	SU	GD	43.5	SU	GD	6.9	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:42	SU	GD	5.7	SU	GD	43.5	SU	GD	7.0	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:43	SU	GD	6.2	SU	GD	47.5	SU	GD	7.6	SU	GD	0.024	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:44	SU	GD	5.8	SU	GD	45.5	SU	GD	7.1	SU	GD	0.023	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:45	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:46	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:47	SU	GD	5.4	SU	GD	41.6	SU	GD	6.6	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:48	SU	GD	5.2	SU	GD	39.6	SU	GD	6.4	SU	GD	0.020	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:49	SU	GD	5.4	SU	GD	41.6	SU	GD	6.6	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:50	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:51	SU	GD	5.7	SU	GD	43.5	SU	GD	7.0	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 09:52	SU	GD	5.7	SU	GD	43.5	SU	GD	7.0	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
Average			5.5			42.4			6.8			0.021			101000			101		
Maximum			6.2			47.5			7.6			0.024			101000			101		
Minimum			5.2			39.6			6.4			0.020			101000			101		
Total			99.7			764.0			121.9			0.386			1818000			1818		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 HTIP_OIL_P75			CTG2 O2_P75			CTG2 CO			CTG2 CO_C15			CTG2 CO_MASS			CTG2 CO_RATE			CTG2 GEN_TOTAL
	MMBTUHR	OS	MS	PCT	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	MW
05/12/2018 10:53	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 10:54	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 10:55	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 10:56	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 10:57	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 10:58	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 10:59	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	193
05/12/2018 11:00	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:01	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 11:02	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 11:03	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 11:04	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:05	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:06	1978.7	SU	GD	13.7	SU	GD	1.3	SU	GD	1.1	SU	GD	5.9	SU	GD	0.003	SU	GD	192
05/12/2018 11:07	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:08	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:09	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:10	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:11	1978.7	SU	GD	13.7	SU	GD	1.1	SU	GD	0.9	SU	GD	4.0	SU	GD	0.002	SU	GD	192
05/12/2018 11:12	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	193
05/12/2018 11:13	1978.7	SU	GD	13.7	SU	GD	1.2	SU	GD	1.0	SU	GD	4.0	SU	GD	0.002	SU	GD	192
Average	1978.7			13.7			1.2			1.0			4.5			0.002			192
Maximum	1978.7			13.7			1.3			1.1			5.9			0.003			193
Minimum	1978.7			13.7			1.1			0.9			4.0			0.002			192
Total	41552.7			287.7			25.0			20.8			93.5			0.047			4042

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG2

	CTG2 GEN_TOT.		CTG2 NOX_C15_O			CTG2 NOX_MASS_P75			CTG2 NOX_P75			CTG2 NOX_RATE_P75			CTG2 OIL_FLOW_EPA			CTG2 OIL_FLOW_RAW_P75		
	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	LBHR	OS	MS	KLBHR	OS	MS
05/12/2018 10:53	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 10:54	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 10:55	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 10:56	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 10:57	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 10:58	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 10:59	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:00	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:01	SU	GD	5.4	SU	GD	41.6	SU	GD	6.6	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:02	SU	GD	5.4	SU	GD	41.6	SU	GD	6.6	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:03	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:04	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:05	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:06	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:07	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:08	SU	GD	5.7	SU	GD	43.5	SU	GD	6.9	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:09	SU	GD	5.7	SU	GD	43.5	SU	GD	6.9	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:10	SU	GD	5.7	SU	GD	43.5	SU	GD	6.9	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:11	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:12	SU	GD	5.5	SU	GD	41.6	SU	GD	6.7	SU	GD	0.021	SU	GD	101000	SU	GD	101	SU	GD
05/12/2018 11:13	SU	GD	5.6	SU	GD	43.5	SU	GD	6.8	SU	GD	0.022	SU	GD	101000	SU	GD	101	SU	GD
Average			5.5			42.4			6.7			0.021			101000			101		
Maximum			5.7			43.5			6.9			0.022			101000			101		
Minimum			5.4			41.6			6.6			0.021			101000			101		
Total			116.5			890.7			141.7			0.450			2121000			2121		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

CEMS AND REFERENCE METHOD DATA

Reference Method Data

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	14,036	gal/hr

Weather Data

Barometric Pressure	29.54	in. Hg
Relative Humidity	35	%
Ambient Temperature	67	° F
Specific Humidity	0.004956	lb H ₂ O / lb air

Unit Data

Unit Load	185.0	megawatts
Stack Exhaust Flow (M19)	53,219,608	SCFH

Max Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
05/11/18 12:41:21	50	13.87	7.05	0.34
05/11/18 12:41:51	80	13.85	6.41	0.34
05/11/18 12:42:21	110	13.85	6.05	0.35
05/11/18 12:42:51	140	13.85	5.89	0.33
05/11/18 12:43:21	170	13.85	5.89	0.24
05/11/18 12:43:51	200	13.84	6.17	0.37
05/11/18 12:44:21	230	13.84	6.52	0.28
05/11/18 12:44:51	260	13.83	6.65	0.32
05/11/18 12:45:21	290	13.84	6.72	0.29
05/11/18 12:45:51	320	13.85	7.01	0.36
05/11/18 12:46:21	350	13.87	7.33	0.36
05/11/18 12:46:51	380	13.88	7.81	0.30
05/11/18 12:47:21	410	13.87	7.98	0.41
05/11/18 12:47:51	440	13.87	8.02	0.29
05/11/18 12:48:21	470	13.87	7.69	0.44
05/11/18 12:48:51	500	13.87	7.53	0.35
05/11/18 12:49:21	530	13.87	7.61	0.40
05/11/18 12:49:51	560	13.86	7.59	0.37
05/11/18 12:50:21	590	13.86	7.53	0.30
05/11/18 12:50:51	620	13.87	7.35	0.45
05/11/18 12:51:21	650	13.87	7.30	0.36
05/11/18 12:51:51	680	13.87	7.30	0.38
05/11/18 12:52:21	710	13.87	7.22	0.26
05/11/18 12:52:51	740	13.87	7.25	0.36
05/11/18 12:53:21	770	13.87	7.31	0.38
05/11/18 12:53:51	800	13.86	7.33	0.36
05/11/18 12:54:21	830	13.86	7.21	0.31
05/11/18 12:54:51	860	13.87	7.08	0.29
05/11/18 12:55:21	890	13.87	7.18	0.44
05/11/18 12:55:51	920	13.86	7.36	0.35
05/11/18 12:56:21	950	13.85	7.36	0.31
05/11/18 12:56:51	980	13.85	7.11	0.41
05/11/18 12:57:21	1010	13.86	6.82	0.30
05/11/18 12:57:51	1040	13.84	6.84	0.31
05/11/18 12:58:21	1070	13.84	7.09	0.32
05/11/18 12:58:51	1100	13.83	7.22	0.24
05/11/18 12:59:21	1130	13.85	7.05	0.33
05/11/18 12:59:51	1160	13.86	7.17	0.40
05/11/18 13:00:21	1190	13.88	7.41	0.42
05/11/18 13:00:51	1220	13.89	7.70	0.34
05/11/18 13:01:21	1250	13.89	7.87	0.40
05/11/18 13:01:51	1280	13.88	7.51	0.40

RAW AVERAGE 13.86 7.15 0.35

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
Serial Number: inst-O2-0023 INST-NX-0064 INST-CO-0016			
Initial Zero	0.03	0.52	0.05
Final Zero	0.01	0.33	0.08
Avg. Zero	0.02	0.43	0.07
Initial UpScale	11.99	9.63	9.11
Final UpScale	12.04	9.65	9.09
Avg. UpScale	12.02	9.64	9.10

Upscale Cal Gas 12.02 9.30 9.10

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)	13.87	6.79	0.28
Concentration (ppm@ 15%O ₂)	N/A	5.70	0.24
Emission Rate (lb/hr)	N/A	43.17	1.09
Emission Rate (lb/MMBtu)	N/A	0.022	0.001

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	14,049	gal/hr

Weather Data

Barometric Pressure	29.57	in. Hg
Relative Humidity	35	%
Ambient Temperature	68	° F
Specific Humidity	0.005126	lb H ₂ O / lb air

Unit Data

Unit Load	185.0	megawatts
Stack Exhaust Flow (M19)	52,972,991	SCFH

Max Load, Run - 6

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)
05/11/18 15:00:22	50	13.85	7.42	0.37
05/11/18 15:00:52	80	13.85	7.31	0.31
05/11/18 15:01:22	110	13.86	7.23	0.30
05/11/18 15:01:52	140	13.86	7.37	0.26
05/11/18 15:02:22	170	13.85	7.46	0.27
05/11/18 15:02:52	200	13.85	7.29	0.40
05/11/18 15:03:22	230	13.86	7.25	0.18
05/11/18 15:03:52	260	13.86	7.21	0.32
05/11/18 15:04:22	290	13.87	7.19	0.27
05/11/18 15:04:52	320	13.87	7.24	0.22
05/11/18 15:05:22	350	13.87	7.27	0.24
05/11/18 15:05:52	380	13.88	7.35	0.23
05/11/18 15:06:22	410	13.88	7.36	0.33
05/11/18 15:06:52	440	13.88	7.33	0.18
05/11/18 15:07:22	470	13.89	7.31	0.24
05/11/18 15:07:52	500	13.89	7.29	0.34
05/11/18 15:08:22	530	13.88	7.18	0.27
05/11/18 15:08:52	560	13.88	7.18	0.26
05/11/18 15:09:22	590	13.88	7.19	0.25
05/11/18 15:09:52	620	13.87	7.18	0.31
05/11/18 15:10:22	650	13.87	7.23	0.34
05/11/18 15:10:52	680	13.86	7.46	0.16
05/11/18 15:11:22	710	13.86	7.49	0.20
05/11/18 15:11:52	740	13.87	7.45	0.30
05/11/18 15:12:22	770	13.87	7.47	0.40
05/11/18 15:12:52	800	13.87	7.38	0.09
05/11/18 15:13:22	830	13.87	7.09	0.27
05/11/18 15:13:52	860	13.88	6.99	0.25
05/11/18 15:14:22	890	13.88	6.94	0.25
05/11/18 15:14:52	920	13.87	6.80	0.30
05/11/18 15:15:22	950	13.87	6.67	0.12
05/11/18 15:15:52	980	13.87	6.64	0.37
05/11/18 15:16:22	1010	13.87	6.65	0.19
05/11/18 15:16:52	1040	13.86	6.65	0.30
05/11/18 15:17:22	1070	13.87	6.63	0.40
05/11/18 15:17:52	1100	13.87	6.71	0.26
05/11/18 15:18:22	1130	13.88	6.84	0.27
05/11/18 15:18:52	1160	13.88	7.07	0.23
05/11/18 15:19:22	1190	13.88	7.06	0.31
05/11/18 15:19:52	1220	13.88	7.06	0.21
05/11/18 15:20:22	1250	13.88	6.99	0.25
05/11/18 15:20:52	1280	13.88	6.90	0.19

RAW AVERAGE 13.87 7.14 0.27

	O ₂ (%)	NO _x (ppmvd)	CO (ppmvd)
Serial Number:	inst-O2-0023	INST-NX-0064	INST-CO-0016
Initial Zero	0.05	0.36	0.04
Final Zero	0.02	0.29	0.02
Avg. Zero	0.04	0.33	0.03
Bias			
Initial UpScale	12.07	9.30	9.02
Final UpScale	12.05	9.56	9.02
Avg. UpScale	12.06	9.43	9.02
Upscale Cal Gas	12.02	9.30	9.10
	<i>Cal/Bias</i>	<i>Cal/Bias</i>	<i>Cal/Bias</i>

EMISSIONS DATA	O ₂	NO _x	CO
Corrected Raw Average (ppm/% dry basis)	13.83	6.96	0.24
Concentration (ppm@ 15%O ₂)	N/A	5.81	0.20
Emission Rate (lb/hr)	N/A	44.03	0.92
Emission Rate (lb/MMBtu)	N/A	0.023	0.000

APPENDIX C
CALIBRATION GAS CERTIFICATIONS



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0018276	Certification Date:	11/14/2017
Product ID Number:	124731	Expiration Date:	11/13/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0018276.20171101-0	Lot Number:	EB0018276.20171101
Customer PO. NO.:		Tracking Number:	040342692
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	49.7 PPM	±0.6 PPM	FTIR	11/07/2017, 11/14/2017
Air Balance				

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0085284	EB0085284.20161201	11/02/2020	GMIS	AIR	NO2	97 PPM	1.027	5605008

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/06/2017
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/14/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
Analyst

Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Assay Laboratory: Red Ball TGS
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0026154	Certification Date:	09/30/2016
Product ID Number:	125780	Expiration Date:	09/30/2019
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport-LA
COA #	EB0026154.20160901-0	Lot Number:	EB0026154.20160901
Customer PO. NO.:		Tracking Number:	083029619
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	18.41 PPM	±0.07 PPM	FTIR	09/30/2016
Nitric Oxide	18.1 PPM	±0.11 PPM	Chemiluminescence	09/09/2016, 09/17/2016, 09/29/2016
Total Oxides of Nitrogen	18.3 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC279029	091002	03/10/2020	NTRM	N2	CO	19.14 PPM	0.9927	091002
EB0006931	EB0006931.20150713g	10/22/2018	GMIS	N2	NO	14.95 PPM	1.095	121001
EB0011692	EB0011692.20160329g	06/11/2024	GMIS	N2	NO	276.5 PPM	0.476	2735

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	09/06/2016
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/12/2016

Red Ball Technical Gas Service
 PGVP Vendor ID # G12016
 Information and Ordering
 800-551-8150
 Fax (318-425-6309)



Fred Holt

Fred Holt
Analyst

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0098858	Certification Date:	09/19/2017
Product ID Number:	124737	Expiration Date:	09/18/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0098858.20170825-0	Lot Number:	EB0098858.20170825
Customer PO. NO.:		Tracking Number:	095688549
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	9.1 PPM	±0.1 PPM	FTIR	09/08/2017
Nitric Oxide	9.2 PPM	±0.10 PPM	Chemiluminescence	09/12/2017, 09/19/2017
Total Oxides of Nitrogen	9.3 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC279029	091002	03/10/2020	NTRM	N2	CO	19.14 PPM	0.9927	091002
CC-349582	12100115CC-349582	07/22/2019	NTRM	N2	NO	95.2 PPM	1.05	12100115
ALM066143	ALM066143.20160913	05/24/2025	GMIS	N2	NO	31.77 PPM	1.05	12100115
CC238282	CC238282.2015012-0	12/20/2018	GMIS	N2	NO	9.36 PPM	1.004	2628a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/08/2017
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	08/18/2017
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	09/01/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0027723	Certification Date:	01/26/2018
Product ID Number:	125564	Expiration Date:	01/25/2021
Cylinder Pressure:	1800 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0027723.20171229-0	Lot Number:	EB0027723.20171229
Customer PO. NO.:		Tracking Number:	048406516
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	5.07 PPM	±0.07 PPM	FTIR	01/03/2018
Nitric Oxide	5.09 PPM	±0.06 PPM	Chemiluminescence	01/18/2018, 01/26/2018
Total Oxides of Nitrogen	5.17 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0001986	EB0001986.20160718	01/19/2025	GMIS	N2	NO	90.61 PPM	1.054	12100115
EB0004877	EB0004877.20160721	07/05/2025	GMIS	N2	CO	18.78 PPM	1.005	091002
EB0027596	EB0027596.20151012g	12/20/2018	GMIS	N2	NO	5.802 PPM	1.01	2628a
EB0055450	EB0055450.20140403-0	12/21/2020	GMIS	N2	NO	32.02 PPM	1.058	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	12/26/2017
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	12/22/2017
NO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	12/29/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0032327	Certification Date:	10/09/2017
Product ID Number:	124605	Expiration Date:	10/07/2025
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0032327.20171005-0	Lot Number:	EB0032327.20171005
Customer PO. NO.:		Tracking Number:	056562288
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	18.7 %	±0.15 %	NDIR	10/09/2017
Oxygen	21.0 %	±0.11 %	MPA	10/09/2017
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0060740	EB0060740.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0064384	EB0064384.20170112	08/13/2025	GMIS	N2	CO2	19.6 %	0.761	101001
SG9916836	SG-9916836	06/06/2022	NTRM	N2	CO2	19.98 %	0.7	101001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	09/13/2017
CO2	NDIR	Thermo	410i	1162980025	09/22/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
Analyst

Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0081248	Certification Date:	03/14/2018
Product ID Number:	124606	Expiration Date:	03/12/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0081248.20180306-0	Lot Number:	EB0081248.20180306
Customer PO. NO.:		Tracking Number:	084092913
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	8.98 %	±0.08 %	NDIR	03/14/2018
Oxygen	12.02 %	±0.06 %	MPA	03/12/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0019964	EB0019964.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0032313	EB0032313.20170112	05/22/2025	GMIS	N2	O2	9.34 %	0.235	2658a
EB0045483	EB0045483.20170424	11/25/2025	GMIS	N2	CO2	9.53 %	0.724	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	02/23/2018
CO2	NDIR	Thermo	410i	1162980025	03/14/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

B. Theus

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07

CPV VALLEY LLC
May 11, 2018
Siemens, SCC6-5000F, Unit #2
AETB/QI and PGVP RATA Data Sheet
CPV VALLEY ENERGY CENTER

AirEmissionTestingData - Level 3

QILastName	QIFirstName	QIMiddleInitial	AETBName	AETBPhoneNumber	AETBEmail	ExamDate	ProviderName	ProviderEmail
Stockwell	Michael	D	Air Hygiene International Inc	888-461-8778	info@airhygiene.com	01/06/2017	Source Evaluation Society	qstiprogram@gmail.com

ProtocolGasData - Level 3

GasLevelCode	GasTypeCode	CylinderIdentifier	VendorIdentifier	ExpirationDate
HIGH	BALN,CO2,O2	EB0032327	G12017	1/7/2025
MID	BALN,CO2,O2	EB0081248	G12018	3/12/2026
HIGH	BALN,CO,NO,NOX	EB0026154	G12016	9/30/2019
MID	BALN,CO,NO,NOX	EB0098858	G12017	9/18/2020
LOW	BALN,CO,NO,NOX	EB0027723	G12018	1/25/2021

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the “hands of the test” on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the “hands of the test” on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene’s review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer’s instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3. A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO₂ to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO₂ in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS QUALITY ASSURANCE DATA

Date: May 10-12, 2018
Company: CPV VALLEY LLC
Location: Middletown, New York
Techs: MS/CM

Sample System Leak Check


Date	Sample System	Leak Rate (l/min)
May 10-12, 2018	1	0

Calibration Date: May 11, 2018
 Client: CPV VALLEY LLC

Location: CPV VALLEY ENERGY CENTER - Unit 2


NOx Span (ppm) = 18.30

THERMO 42i-HL (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
0.00	0.08	0.44	0.08	YES (%)
9.30	9.60	1.64	0.30	YES (%)
18.30	18.40	0.55	0.10	YES (%)
Linearity = 0.999				




CO Span (ppm) = 9.10

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
0.00	0.01	0.11	0.01	YES (%)
5.07	5.18	1.21	0.11	YES (%)
9.10	9.10	0.00	0.00	YES (%)
Linearity = 1.000				



O₂ Span (%) = 21.00

SERVOMEX 1440 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail ($\pm 2\%$, $\leq 0.5\%$)
0.00	-0.04	-0.19	0.04	YES (%)
12.02	11.88	-0.67	0.14	YES (%)
21.00	21.02	0.10	0.02	YES (%)
Linearity = 0.998				



NOx Converter Efficiency

Date: May 11, 2018

Analyzer: INST-NX-0064

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO₂ to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO₂ concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas: NO₂ Concentration (C_v), ppmvd **49.70**

Converter Efficiency Calculations:

Analyzer Reading, NO Channel, ppmvd **4.88**

Analyzer Reading, NOx Channel, ppmvd **52.43**

Analyzer Reading, NO₂ Channel (C_{Dir(NO₂)}), ppmvd **47.55**

Converter Efficiency, % **95.67**

RM 7E, (02-27-14), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{47.55 \text{ ppmvd}}{49.70 \text{ ppmvd}} \times 100 = 95.67\%$$


Date/Time mm/dd/yy hh:mm:ss	Elapsed Time Seconds	NOx ppmvd	NO ppmvd
05/11/18 06:06:24	2160	51.82	5.14
05/11/18 06:06:34	2170	51.86	5.10
05/11/18 06:06:44	2180	51.90	5.06
05/11/18 06:06:54	2190	51.95	5.02
05/11/18 06:07:04	2200	52.02	5.01
05/11/18 06:07:14	2210	52.05	4.99
05/11/18 06:07:24	2220	52.09	4.95
05/11/18 06:07:34	2230	52.16	4.90
05/11/18 06:07:44	2240	52.31	4.90
05/11/18 06:07:54	2250	52.43	4.88
05/11/18 06:08:04	2260	52.48	4.86

Calibration Date: May 12, 2018
 Client: CPV VALLEY LLC

Location: CPV VALLEY ENERGY CENTER - Unit 2


NOx Span (ppm) = 18.30

THERMO 42i-HL (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
0.00	0.06	0.33	0.06	YES (%)
9.30	9.63	1.80	0.33	YES (%)
18.30	18.38	0.44	0.08	YES (%)
Linearity = 0.998				




CO Span (ppm) = 9.10

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
0.00	-0.10	-1.10	0.10	YES (%)
5.07	5.01	-0.66	0.06	YES (%)
9.10	9.21	1.21	0.11	YES (%)
Linearity = 0.978				



O2 Span (%) = 21.00

SERVOMEX 1440 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail ($\pm 2\%$, $\leq 0.5\%$)
0.00	-0.06	-0.29	0.06	YES (%)
12.02	11.92	-0.48	0.10	YES (%)
21.00	21.05	0.24	0.05	YES (%)
Linearity = 0.995				



NOx Converter Efficiency

Date: May 11, 2018

Analyzer: INST-NX-0064

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO₂ to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO₂ concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas: NO₂ Concentration (C_v), ppmvd **49.70**

Converter Efficiency Calculations:

Analyzer Reading, NO Channel, ppmvd **4.67**

Analyzer Reading, NOx Channel, ppmvd **53.45**

Analyzer Reading, NO₂ Channel (C_{Dir(NO₂)}), ppmvd **48.78**

Converter Efficiency, % **98.15**

RM 7E, (02-27-14), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{48.78 \text{ ppmvd}}{49.70 \text{ ppmvd}} \times 100 = 98.15\%$$

Date/Time mm/dd/yy hh:mm:ss	Elapsed Time Seconds	NOx ppmvd	NO ppmvd
05/12/18 06:51:37	1700	52.87	5.03
05/12/18 06:51:47	1710	52.97	4.97
05/12/18 06:51:57	1720	53.03	4.89
05/12/18 06:52:07	1730	53.09	4.86
05/12/18 06:52:17	1740	53.12	4.81
05/12/18 06:52:27	1750	53.14	4.76
05/12/18 06:52:37	1760	53.16	4.73
05/12/18 06:52:47	1770	53.23	4.71
05/12/18 06:52:57	1780	53.31	4.70
05/12/18 06:53:07	1790	53.39	4.69
05/12/18 06:53:17	1800	53.45	4.67

DRIFT AND BIAS CHECK			
Max Load, Run - 1	O₂	NOx	CO
Raw Average	13.85	7.15	0.38
Corrected Average	13.83	6.95	0.31
Initial Zero	0.03	0.23	0.09
Final Zero	0.03	0.52	0.05
Avg. Zero	0.03	0.38	0.07
Initial UpScale	12.09	9.26	9.04
Final UpScale	11.99	9.63	9.11
Avg. UpScale	12.04	9.45	9.08
Sys Resp (Zero)	-0.04	0.08	0.01
Sys Resp (Upscale)	11.88	9.60	9.10
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.33%	0.82%	0.88%
Final Zero Bias	0.33%	2.40%	0.44%
Zero Drift	0.00%	1.58%	0.44%
Initial Upscale Bias	1.00%	-1.86%	-0.66%
Final Upscale Bias	0.52%	0.16%	0.11%
Upscale Drift	0.48%	2.02%	0.77%
Alternative Specification Abs Diff	Initial Zero	0.07	0.15
	Final Zero	0.07	0.44
	Initial Upscale	0.21	0.34
	Final Upscale	0.11	0.03
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 2	O₂	NOx	CO
Raw Average	13.86	7.15	0.35
Corrected Average	13.87	6.79	0.28
Initial Zero	0.03	0.52	0.05
Final Zero	0.01	0.33	0.08
Avg. Zero	0.02	0.43	0.07
Initial UpScale	11.99	9.63	9.11
Final UpScale	12.04	9.65	9.09
Avg. UpScale	12.02	9.64	9.10
Sys Resp (Zero)	-0.04	0.08	0.01
Sys Resp (Upscale)	11.88	9.60	9.10
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.33%	2.40%	0.44%
Final Zero Bias	0.23%	1.37%	0.77%
Zero Drift	0.10%	1.04%	0.33%
Initial Upscale Bias	0.52%	0.16%	0.11%
Final Upscale Bias	0.76%	0.27%	-0.11%
Upscale Drift	0.24%	0.11%	0.22%
Alternative Specification Abs Diff	Initial Zero	0.07	0.44
	Final Zero	0.05	0.25
	Initial Upscale	0.11	0.03
	Final Upscale	0.16	0.05
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 3	O₂	NOx	CO
Raw Average	13.86	7.23	0.29
Corrected Average	13.83	6.97	0.23
Initial Zero	0.01	0.33	0.08
Final Zero	0.02	0.29	0.05
Avg. Zero	0.01	0.31	0.07
Initial UpScale	12.04	9.65	9.09
Final UpScale	12.05	9.43	9.02
Avg. UpScale	12.05	9.54	9.06
Sys Resp (Zero)	-0.04	0.08	0.01
Sys Resp (Upscale)	11.88	9.60	9.10
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.23%	1.37%	0.77%
Final Zero Bias	0.27%	1.15%	0.44%
Zero Drift	0.04%	0.22%	0.33%
Initial Upscale Bias	0.76%	0.27%	-0.11%
Final Upscale Bias	0.81%	-0.93%	-0.88%
Upscale Drift	0.05%	1.20%	0.77%
Alternative Specification Abs Diff	Initial Zero	0.05	0.07
	Final Zero	0.06	0.04
	Initial Upscale	0.16	0.01
	Final Upscale	0.17	0.08
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 4	O₂	NOx	CO
Raw Average	13.88	7.20	0.29
Corrected Average	13.84	6.95	0.29
Initial Zero	0.02	0.29	0.05
Final Zero	0.02	0.29	-0.04
Avg. Zero	0.02	0.29	0.01
Initial UpScale	12.05	9.43	9.02
Final UpScale	12.05	9.63	9.04
Avg. UpScale	12.05	9.53	9.03
Sys Resp (Zero)	-0.04	0.08	0.01
Sys Resp (Upscale)	11.88	9.60	9.10
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.27%	1.15%	0.44%
Final Zero Bias	0.29%	1.15%	-0.55%
Zero Drift	0.01%	0.00%	0.99%
Initial Upscale Bias	0.81%	-0.93%	-0.88%
Final Upscale Bias	0.81%	0.16%	-0.66%
Upscale Drift	0.00%	1.09%	0.22%
Alternative Specification Abs Diff	Initial Zero	0.06	0.04
	Final Zero	0.06	0.05
	Initial Upscale	0.17	0.08
	Final Upscale	0.17	0.06
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 5	O₂	NOx	CO
Raw Average	13.88	6.94	0.29
Corrected Average	13.83	6.73	0.30
Initial Zero	0.02	0.29	-0.04
Final Zero	0.05	0.36	0.04
Avg. Zero	0.04	0.33	0.00
Initial UpScale	12.05	9.63	9.04
Final UpScale	12.07	9.30	9.02
Avg. UpScale	12.06	9.47	9.03
Sys Resp (Zero)	-0.04	0.08	0.01
Sys Resp (Upscale)	11.88	9.60	9.10
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.29%	1.15%	-0.55%
Final Zero Bias	0.43%	1.53%	0.33%
Zero Drift	0.14%	0.38%	0.88%
Initial Upscale Bias	0.81%	0.16%	-0.66%
Final Upscale Bias	0.90%	-1.64%	-0.88%
Upscale Drift	0.10%	1.80%	0.22%
Alternative Specification Abs Diff	Initial Zero	0.06	0.21
	Final Zero	0.09	0.28
	Initial Upscale	0.17	0.03
	Final Upscale	0.19	0.30
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 6	O₂	NOx	CO
Raw Average	13.87	7.14	0.27
Corrected Average	13.83	6.96	0.24
Initial Zero	0.05	0.36	0.04
Final Zero	0.02	0.29	0.02
Avg. Zero	0.04	0.33	0.03
Initial UpScale	12.07	9.30	9.02
Final UpScale	12.05	9.56	9.02
Avg. UpScale	12.06	9.43	9.02
Sys Resp (Zero)	-0.06	0.06	-0.10
Sys Resp (Upscale)	11.92	9.63	9.21
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.52%	1.64%	1.54%
Final Zero Bias	0.38%	1.26%	1.32%
Zero Drift	0.14%	0.38%	0.22%
Initial Upscale Bias	0.71%	-1.80%	-2.09%
Final Upscale Bias	0.62%	-0.38%	-2.09%
Upscale Drift	0.10%	1.42%	0.00%
Alternative Specification Abs Diff	Initial Zero	0.11	0.30
	Final Zero	0.08	0.23
	Initial Upscale	0.15	0.33
	Final Upscale	0.13	0.07
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 7	O₂	NOx	CO
Raw Average	13.66	7.03	0.59
Corrected Average	13.71	6.85	0.61
Initial Zero	0.02	0.08	0.05
Final Zero	0.01	0.22	-0.07
Avg. Zero	0.01	0.15	-0.01
Initial UpScale	12.08	9.44	8.93
Final UpScale	11.88	9.55	8.95
Avg. UpScale	11.98	9.50	8.94
Sys Resp (Zero)	-0.06	0.06	-0.10
Sys Resp (Upscale)	11.92	9.63	9.21
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.37%	0.11%	1.65%
Final Zero Bias	0.31%	0.87%	0.33%
Zero Drift	0.06%	0.77%	1.32%
Initial Upscale Bias	0.76%	-1.04%	-3.08%
Final Upscale Bias	-0.19%	-0.44%	-2.86%
Upscale Drift	0.95%	0.60%	0.22%
Alternative Specification Abs Diff	Initial Zero	0.08	0.15
	Final Zero	0.07	0.03
	Initial Upscale	0.16	0.28
	Final Upscale	0.04	0.26
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 8	O₂	NOx	CO
Raw Average	13.64	7.30	0.43
Corrected Average	13.80	6.96	0.44
Initial Zero	0.01	0.22	-0.07
Final Zero	0.02	0.40	0.06
Avg. Zero	0.01	0.31	-0.01
Initial UpScale	11.88	9.55	8.95
Final UpScale	11.88	9.76	9.05
Avg. UpScale	11.88	9.66	9.00
Sys Resp (Zero)	-0.06	0.06	-0.10
Sys Resp (Upscale)	11.92	9.63	9.21
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.31%	0.87%	0.33%
Final Zero Bias	0.38%	1.86%	1.76%
Zero Drift	0.07%	0.98%	1.43%
Initial Upscale Bias	-0.19%	-0.44%	-2.86%
Final Upscale Bias	-0.19%	0.71%	-1.76%
Upscale Drift	0.00%	1.15%	1.10%
Alternative Specification Abs Diff	Initial Zero	0.07	0.03
	Final Zero	0.08	0.16
	Initial Upscale	0.04	0.26
	Final Upscale	0.04	0.16
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 9	O₂	NOx	CO
Raw Average	13.64	7.23	0.37
Corrected Average	13.81	6.82	0.35
Initial Zero	0.02	0.40	0.06
Final Zero	0.01	0.33	-0.02
Avg. Zero	0.01	0.37	0.02
Initial UpScale	11.88	9.76	9.05
Final UpScale	11.88	9.69	9.10
Avg. UpScale	11.88	9.73	9.08
Sys Resp (Zero)	-0.06	0.06	-0.10
Sys Resp (Upscale)	11.92	9.63	9.21
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.38%	1.86%	1.76%
Final Zero Bias	0.31%	1.48%	0.88%
Zero Drift	0.07%	0.38%	0.88%
Initial Upscale Bias	-0.19%	0.71%	-1.76%
Final Upscale Bias	-0.19%	0.33%	-1.21%
Upscale Drift	0.00%	0.38%	0.55%
Alternative Specification Abs Diff	Initial Zero	0.08	0.16
	Final Zero	0.07	0.08
	Initial Upscale	0.04	0.16
	Final Upscale	0.04	0.11
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 10	O₂	NOx	CO
Raw Average	13.62	7.24	0.33
Corrected Average	13.78	6.90	0.34
Initial Zero	0.01	0.33	-0.02
Final Zero	0.03	0.28	0.01
Avg. Zero	0.02	0.31	-0.01
Initial UpScale	11.88	9.69	9.10
Final UpScale	11.89	9.60	9.03
Avg. UpScale	11.89	9.65	9.07
Sys Resp (Zero)	-0.06	0.06	-0.10
Sys Resp (Upscale)	11.92	9.63	9.21
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.31%	1.48%	0.88%
Final Zero Bias	0.43%	1.20%	1.18%
Zero Drift	0.12%	0.27%	0.30%
Initial Upscale Bias	-0.19%	0.33%	-1.21%
Final Upscale Bias	-0.14%	-0.16%	-1.98%
Upscale Drift	0.05%	0.49%	0.77%
Alternative Specification Abs Diff	Initial Zero	0.07	0.08
	Final Zero	0.09	0.11
	Initial Upscale	0.04	0.11
	Final Upscale	0.03	0.18
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK		
Strat Test Pre and Post QA/QC Check	O2	NOx
Initial Zero	0.06	0.50
Final Zero	0.02	0.11
Avg. Zero	0.04	0.31
Initial UpScale	12.09	9.32
Final UpScale	12.04	10.07
Avg. UpScale	12.07	9.70
Sys Resp (Zero)	-0.05	-0.20
Sys Resp (Upscale)	11.98	9.50
Upscale Cal Gas	12.02	9.30
Initial Zero Bias	0.50%	3.83%
Final Zero Bias	0.30%	1.69%
Zero Drift	0.20%	2.13%
Initial Upscale Bias	0.52%	-0.98%
Final Upscale Bias	0.29%	3.11%
Upscale Drift	0.24%	4.10%
Alternative Specification Abs Diff	Initial Zero	0.11
	Final Zero	0.06
	Initial Upscale	0.11
	Final Upscale	0.06
Calibration Span	21.00	18.30
3% of Range (drift)	0.63	0.55
5% of Range (bias)	1.05	0.92

Response Time (min)	0.7	2.8
Sys. Response (min)	2.8	

INJECTIONS

Date/Time mm/dd/yy hh:mm:ss	Z	O2 %	S	Z	NOx PPM	S
12:26:56		13.82			6.43	
12:27:06		13.84			6.42	
12:27:16		7.47			6.48	
12:27:26		11.68		x	6.52	
12:27:36		12.04			6.51	
12:27:46		12.05			6.58	
12:27:56		12.06			6.64	
12:28:06		12.06			6.66	
12:28:16		12.06			6.72	
12:28:26		12.07			6.73	
12:28:36		12.07			6.75	
12:28:46		12.07			6.78	
12:28:56		12.07			7.06	
12:29:06		12.07			7.80	
12:29:16		12.07			5.61	
12:29:26		12.08			2.54	
12:29:36		12.08			1.59	
12:29:46		12.08		x	0.79	
12:29:56		12.07			0.58	
12:30:06		12.08			0.51	
12:30:16		12.08			0.41	x
12:30:26		12.08			0.33	
12:30:36		10.08			0.29	
12:30:46		0.67			0.30	
12:30:56	x	0.15			0.30	
12:31:06		0.10			0.28	
12:31:16		0.08			0.27	
12:31:26		0.06			0.26	
12:31:36		0.06			0.20	
12:31:46		0.05			0.21	
12:31:56		0.04			0.18	
12:32:06		0.04			0.14	
12:32:16		0.04			0.20	
12:32:26		0.03			-0.46	
12:32:36		0.02			2.59	
12:32:46		0.02			6.90	
12:32:56		0.02			8.17	
12:33:06		0.02			9.04	x
12:33:16		0.02			9.32	



Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 General requirements for the competence of testing and calibration laboratories. This laboratory also meets the NELAP Institute Field Sampling and Measurement Organization Volume 1 (TNI FSMO V1 2007, Rev 0.1) requirements. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated 8 January 2009).



Presented this 20th day of July 2015



President & CEO

For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2017

For the tests to which this accreditation applies, please refer to the laboratory's Environmental Scope of Accreditation.



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited


AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036 - Standard Practice for Competence of Air Emission Testing Bodies.



Presented this 20th day of July 2015.



President & CEO
Certificate Number 3796.02
Valid to August 31, 2017

This accreditation program is not included under the A2LA ILAC Recognition Arrangement.

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

MICHAEL D. STOCKWELL

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR


GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 6TH DAY OF JANAUARY 2017 AND EFFECTIVE UNTIL JANAURY 5TH, 2022





Peter R. Westlin, QSTI/QSTO Review Board

Peter R. Westlin, QSTI/QSTO Review Board


Peter S. Pakalnis, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board


Theresa M. Lowe, QSTI/QSTO Review Board

Theresa M. Lowe, QSTI/QSTO Review Board



J. Wade Bice, QSTI/QSTO Review Board



Karen D. Kajiya-Mills, QSTI/QSTO Review Board



Bruce Randall QSTI/QSTO Review Board

CERTIFICATE

NO.

2010-503

APPENDIX E
FUEL ANALYSIS RECORDS

Client: CPV VALLEY LLC
Location: CPV VALLEY ENERGY CENTER
Date: May 11, 2018
Project #: sie-17-middletown.ny-start#1

Fuel Oil - Fuel Analysis

Characteristics of Fuel Gas		
Molecular Weight of oil =	15.243	lb/lb-mole
Btu per lb. of oil =	19,602.00	gross (HHV)
Btu per lb. of oil =	18,371.000	net (LHV)
Density of fuel oil ² =	52.7120	lb/cu. ft
Density of fuel oil ² =	7.0466	lb/gal
Specific Gravity =	0.8461	@ 68 deg F

Standardized to 68 deg F and 14.696 psia

Component	Wt%
carbon	86.21
oxygen	0.00
hydrogen	13.49
nitrogen	0.00
helium	0.00
sulfur	0.00
Total	99.70

Fuel Oil HHV Conv.	
HHV (Btu/lb)	19,602.00
HHV (Btu/SCF)	1,033,261

Fuel Oil LHV Conv.	
LHV (Btu/lb)	18,371.00
LHV (Btu/SCF)	968,373

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 9,234.02 (Based on EPA RM-19) at 68 deg F and 14.696 psia
--

F-Factor Calculation:

$$F\text{-Factor} = 1,000,000 * ((3.64 * \%H) + (1.53 * \%C) + (0.57 * \%S) + (0.14 * \%N) - (0.46 * \%O)) / GCV$$

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of fuel oil based on lab analysis or specific gravity multiplied by density of water at 68 deg F and 14.696 psia.

References:

- ¹ ASTM D 3588
- ² Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg
- ³ Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III
- ⁴ Introduction to Fluid Mechanics, 3rd ed. - William S. Janna
- ⁵ GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-001	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 02:25 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,602
Net Heat of Combustion	18,371

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.79
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.27
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8486
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8381
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8275
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.21
Hydrogen	13.49
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-002	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 02:45 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,601
Net Heat of Combustion	18,369

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.82
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.25
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8487
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8381
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8275
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.20
Hydrogen	13.50
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-003	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 03:05 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,602
Net Heat of Combustion	18,375

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.82
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.26
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.26
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8488
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8382
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8276
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.25
Hydrogen	13.45
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.





Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-004	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 03:25 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,604
Net Heat of Combustion	18,372

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.82
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.27
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8488
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8383
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8275
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.20
Hydrogen	13.50
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-005	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 03:45 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,602
Net Heat of Combustion	18,375

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.84
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.26
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8489
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8383
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8277
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.25
Hydrogen	13.45
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-006	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 04:05 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,601
Net Heat of Combustion	18,374

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.83
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.25
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.26
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8490
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8383
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8277
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.25
Hydrogen	13.45
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



APPENDIX F
STRATIFICATION TEST DATA

Source Information	
Company	CPV Valley LLC
Plant Name	CPV Valley Energy Center
Equipment	Siemens SCC6-5000F, CTG1 and CTG2
Location	Middletown, New York

Test Information	
Date	05/10/18
Project #	sie-17-middletown.ny-start#1
Unit Number	2
Load	multiple
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing)	Circular Stack
<input type="radio"/> Velocity Traverse (Flow and Flow RATA Test)	
<input type="radio"/> Stratification Traverse (Compliance Test) <input type="checkbox"/> RM 20	
<input checked="" type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input checked="" type="checkbox"/> Part 75	

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	CPV Valley LLC	Date	05/10/18
Plant Name	CPV Valley Energy Center	Project #	sie-17-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, CTG1 and CTG2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	239.00	in.
Distance to Near Wall of Stack	(L _{nw})	6.75	in.*
Diameter of Stack	(D)	232.25	in.
Area of Stack	(A _s)	294.20	ft ²



*assume 6.75 in. reference (must be measured and verified in field)

Distance from Disturbances to Port			
Distance Upstream	(A)	1200.00	in.
Diameters Upstream	(A _D)	5.17	diameters
Distance Downstream	(B)	1095.00	in.
Diameters Downstream	(B _D)	4.71	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B _D) Stream	Up (A _D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	
2.00-4.99	0.50-1.24	24	16	○ RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	○ Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>= 2.00	8 or 12 ²	8 or 12 ²	Minimum Number of Traverse Points	
Upstream Spec		12	12	RATA Stratification	
Downstream Spec		24	16	Criteria	
Traverse Pts Required		24	16	Points	
¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.					
² 8 for Circular Stacks 12 to 24 inches					
12 for Circular Stacks over 24 inches					
				● Part75/60	12 RM1 pts
				○ 75 abrv (a)	3 points
				○ 75 abrv (b)	6 points
				12 points	

Number of Traverse Points Used				
4	Ports by	3	Pts / port	Stratification Traverse
12	Pts Used	12	Required	(RATA)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	10 2/8	17
2	14.6%	33 7/8	40 5/8
3	29.6%	68 6/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	CPV Valley LLC	Date	05/10/18
Plant Name	CPV Valley Energy Center	Project #	sie-17-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, CTG1 and CTG2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	232.25	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	294.20	ft ²	Run Start	12:40:06	Run End	13:52:06


Traverse Point	Time Per Point	Point Start Time	Point Stop Time (Reading)	O ₂	Percent Difference	NO _x	Percent Difference
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	6.00	12:40:06	12:46:06	13.83	0.02%	7.73	4.94%
D-2	6.00	12:46:06	12:52:06	13.84	0.09%	7.76	5.35%
D-1	6.00	12:52:06	12:58:06	13.86	0.24%	7.95	7.93%
C-3	6.00	12:58:06	13:04:06	13.85	0.16%	7.19	2.39%
C-2	6.00	13:04:06	13:10:06	13.83	0.02%	7.30	0.89%
C-1	6.00	13:10:06	13:16:06	13.84	0.09%	7.33	0.49%
B-3	6.00	13:16:06	13:22:06	13.86	0.24%	7.49	1.69%
B-2	6.00	13:22:06	13:28:06	13.85	0.16%	7.24	1.71%
B-1	6.00	13:28:06	13:34:06	13.83	0.02%	7.68	4.27%
A-3	6.00	13:34:06	13:40:06	13.76	0.49%	7.18	2.52%
A-2	6.00	13:40:06	13:46:06	13.79	0.27%	6.90	6.32%
A-1	6.00	13:46:06	13:52:06	13.79	0.27%	6.64	9.85%
Average				13.83		7.37	

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	CPV Valley LLC	Date	05/10/18
Plant Name	CPV Valley Energy Center	Project #	sie-17-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, CTG1 and CTG2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	232.25	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	294.20	ft ²	Run Start	12:40:06	Run End	13:52:06

40 CFR 75 Criteria												
Stratification Results		Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length							
Maximum Percent Difference	9.85 % for NOx											
Maximum Pollutant Conc. Diff.	0.73 ppm for NOx											
Maximum Diluent Conc. Diff.	0.07 % for O2											
Stack Diameter	232.25 in.		%	in.	in.							
Stratification Conclusions		1	>16.95%	>39.37	>46.12							
Maximum % Diff.	Percent Diff. ≤10% Passed 6.5.6.3(a) Criteria	2										
Maximum Conc. Diff.	Conc. Diff. ≤ 3ppm Passed 6.5.6.3(b) Criteria	3										
Stack Diameter	D > 93.6 in.											
Passed Strat. Test Under 6.5.6.3(b) Criteria		<table border="0"> <tr> <td rowspan="3">Test Type</td> <td><input type="checkbox"/> Moisture, for MW</td> <td><input type="checkbox"/> Use 6.5.6.3(a) points?</td> </tr> <tr> <td><input type="checkbox"/> Moisture, for wet-to-dry</td> <td><input type="checkbox"/> 6.5.6(b)(2) alt. points could apply</td> </tr> <tr> <td><input checked="" type="checkbox"/> Gas</td> <td></td> </tr> </table>				Test Type	<input type="checkbox"/> Moisture, for MW	<input type="checkbox"/> Use 6.5.6.3(a) points?	<input type="checkbox"/> Moisture, for wet-to-dry	<input type="checkbox"/> 6.5.6(b)(2) alt. points could apply	<input checked="" type="checkbox"/> Gas	
Test Type	<input type="checkbox"/> Moisture, for MW	<input type="checkbox"/> Use 6.5.6.3(a) points?										
	<input type="checkbox"/> Moisture, for wet-to-dry	<input type="checkbox"/> 6.5.6(b)(2) alt. points could apply										
	<input checked="" type="checkbox"/> Gas											



**this page intentionally left blank
end of report**

40 CFR 75 and 40 CFR 60 Certification Test Report

Report Date: June 2018

Revision: A

CEMTEK Project No.: 50478A

Siemens UNID No.: 498368484

Prepared for:

CPV Valley Energy Center

CTG Unit 1 Stack CEMS

Middletown, NY

Prepared by:

CEMTEK KVB-Enertec

3041 S. Orange Ave

Santa Ana, CA 92707-4247

Phone: 714-437-7100

Fax: 714-437-7177

www.cemteks.com



Contents

1	Introduction	1
1.1	Facility Description.....	1
1.2	CEMS Overview	1
1.2.1	CEMS Analyzers.....	2
1.2.2	Data Acquisition System	2
2	Summary of Results	3
2.1	Results Summary Tables	3
3	Test Procedures	6
3.1	7-Day Calibration Error Test – NO _x , O ₂	6
3.2	7-Day Calibration Drift Test CO and CO ₂ Monitors	7
3.3	Linearity Error Check – NO _x , O ₂	8
3.4	CO Analyzer Cylinder Gas Audit	9
3.5	Cycle/Response Time Check – NO _x , O ₂	9
3.6	CO Analyzer Response Time Check.....	10
4	Test Data and Supporting Documentation	11
4.1	7-Day Calibration Drift Data.....	11
4.2	Linearity and CGA Data	12
4.3	Cycle/Response Time Data	13
4.4	Calibration Gas Certificates.....	14
5	Relative Accuracy Test Audit.....	15
	Table 1: NO _x Analyzer Test Results Summary.....	3
	Table 2: O ₂ Analyzer Test Results Summary	4
	Table 3: CO Analyzer Test Results Summary.....	4
	Table 4: CO ₂ Analyzer Test Results Summary	5

1 Introduction

This document is intended to satisfy the CEMS certification requirements of the USEPA as required by the Code of Federal Regulations, Title 40, Part 75 (40 CFR 75 or Part 75), Appendix A and 40 CFR 60 (Part 60) Appendix B Performance Specifications. This document summarizes the test program and test results.

Data from the various tests performed under this program provides resources for evaluating the acceptability of the operation of the facility's continuous emissions monitoring system (CEMS).

Tests were performed by personnel from CEMTEK Environmental Inc. with assistance from facility technicians.

The performance tests completed in this certification test program include:

- Part 75 Linearity Check – NO_x, O₂
- Part 75/Part 60 Cycle/Response Time Check – NO_x, O₂, CO
- Part 75/Part 60 Calibration Drift Check (7-day drift test) – NO_x, O₂, CO, CO₂
- Part 60 CGA – CO
- Relative Accuracy Test Audit (RATA)

1.1 Facility Description

The Valley Energy Center facility is located in Wawayanda, NY and consists of one combined cycle power plant operating on dual-fuel (natural gas and fuel oil) with duct burning.

The Facility consists of: two (2) Siemens SGT6-5000F (4) gas turbines with Dry Low NO_x (DLN) Combustion Systems, operating in 2x1 combined cycle configuration, firing natural gas and ultra-low sulfur diesel (ULSD) fuel oil; two (2) 3-drum HRSG's equipped with SCR systems for NO_x control and oxidation catalysts for CO and VOC control; and one (1) Siemens SST6-5000 steam turbine generator (STG).

This report summarizes test results for Unit 1.

1.2 CEMS Overview

The CEMS measures concentrations of carbon monoxide (CO), oxides of nitrogen (NO_x), and oxygen (O₂) from the turbine exhaust stack. All measurements are done on a real time basis. Contact closures are provided for alarms and system status.

All flue gas pollutant and diluent measurements are made on a dry basis. Effluent gas from the sampling location is filtered and transported through heated sample lines to the sample conditioning system in the main analyzer equipment rack. The sample conditioning system again filters the effluent gas. A sample gas cooler removes moisture. The dry, particulate-free effluent gas sample is supplied to each analyzer within the equipment rack. The analog outputs of each analyzer and certain plant signal inputs are transmitted to a system controller located with the analyzer components.

The system operates automatically so operator attention is necessary only for manual verification and accuracy and normal maintenance. Automatic zero and span calibrations are performed on the CEMS monitors every 24 hours. Certified EPA Protocol calibration gases are injected at a valve box in the back of the probe.

1.2.1 CEMS Analyzers

The following table summarizes the analyzer components of the CEMS.

CTG CEMS Unit 1

Analyzer	Manufacturer/Model	Range(s)	Serial Number
NO _x	Teledyne API T200M	0-10 ppm/0-100 ppm	645
O ₂		0-25%	
CO	Teledyne API T300M	0-10 ppm/0-3000 ppm	355
CO ₂		0-10%	

1.2.2 Data Acquisition System

The CEMS Data Acquisition and Reporting is controlled by the DAHS. The DAHS is a PC-based, multi-user, multi-tasking system. The DAHS provides automated data monitoring and management capabilities to the CEMS. The DAHS is utilized for operator interface, data storage, report generation, and data display.

The PLC transmits data from the analyzers to the DAHS. The DAHS polls the PLC for data to generate and store one (1) minute averages. The DAHS will indicate any occurrence of specification limit exceedances or CEM operational problems. In the DAHS, necessary reports are generated in the required format for submittal to the applicable regulatory agencies. These reports may be produced in either hard copy or electronic format and can be made available to state and local agencies.

All required reporting parameters follow the equations in 40 CFR Part 75 Appendices D, F, and G and facility operating permit as applicable.

2 Summary of Results

The results of all tests performed are summarized in the following tables. Procedural test descriptions are located in Section 3. DAHS printouts and supporting documentation for the 7-day calibration drift, response time, and linearity/CGA tests are located within Section 4 of this document. The Relative Accuracy Test Audit (RATA) report is attached as Section 5.

2.1 Results Summary Tables

Table 1: NO_x Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
Part 75 RATA	5.45% lb/mmBtu by RM	≤10% semi-annual, ≤7.5% annual (by RM) or alternately ≤0.02 lb/mmBtu difference semi-annual, ≤0.015 lb/mmBtu difference annual (40 CFR 75, Appendix A and B)	5/9/28
Part 75 BAF	1.000	d > cc , the monitoring system has failed to meet bias test criteria, data to be adjusted to calculated BAF. If passed, BAF = 1.000	
Part 60 RATA	3.3% ppm @15% O ₂ 2.8% ppm 3.9% lb/hr	≤20% or ≤10% applicable standard (40 CFR 60, Appendix B, PS-2)	
Low Range Results			
Linearity Check	Low = 3.31% Mid = 0.28 ppm High = 2.08%	≤5% of reference or ≤5 ppm absolute difference (40 CFR 75, Appendix A)	5/8/18
Cycle Time	Zero run = 2 min Span run = 2 min	≤15 minutes (40 CFR 75, Appendix A)	5/8/18
7-Day Drift, Highest Reading	zero = 1.00% span = 1.70%	≤2.5% of span or for ranges ≤200 ppm, then ≤5 ppm absolute difference (40 CFR 75, Appendix A)	4/29/18 thru 5/8/18
High Range Results			
Linearity Check	Low = 1.90% Mid = 1.07% High = 1.36%	≤5% of reference or ≤5 ppm absolute difference (40 CFR 75, Appendix A)	5/8/18
Cycle Time	Zero run = 3 min Span run = 2 min	≤15 minutes (40 CFR 75, Appendix A)	5/8/18
7-Day Drift, Highest Reading	zero = 0.10% span = 1.42%	≤2.5% of span or for ranges ≤200 ppm, then ≤5 ppm absolute difference (40 CFR 75, Appendix A)	4/29/18 thru 5/8/18

Table 2: O₂ Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
Part 75 RATA	0.5% by RM	≤10% semi-annual, ≤7.5% annual (by RM) or alternately ≤1.0% difference semi-annual, ≤0.7% difference annual (40 CFR 75, Appendix A and B)	5/9/18
Linearity Check	Low = 4.09% Mid = 0.87% High = 0.14%	≤5% of reference or ≤0.5% difference (40 CFR 75, Appendix A)	5/8/18
Cycle Time	Zero run = 3 min Span run = 3 min	≤15 minutes (40 CFR 75, Appendix A)	5/8/18
7-Day Drift, Highest Reading	zero = 0.00% span = 0.03%	≤0.5% difference (40 CFR 75, Appendix A)	4/29/18 thru 5/8/18

Table 3: CO Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
Part 60 RATA	0.3% ppm diff @ 15% O ₂ diff 0.3 ppm diff 0.3 lb/hr diff	≤10% by RM or ≤5% of applicable standard or difference + CC ≤5 ppm (40 CFR 60, Appendix B, PS-4/4A)	5/9/18
Low Range Results			
Response Time	2 min 40 sec	≤240 seconds (4 minutes) (40 CFR 60, PS-4A eCFR)	5/8/18
7-Day Drift, Highest Reading	zero = 4.00% span = 1.22%	≤5.0% of full span 6 out of 7 days (40 CFR 60, Appendix B, PS-4)	4/29/18 thru 5/8/18
CGA	Low = -0.60 ppm Mid = -5.18%	≤15.0% of reference value or ≤5.0 ppm difference (40 CFR 60 Appendix F Procedure 1)	5/8/18
High Range Results			
Response Time	2 min	≤240 seconds (4 minutes) (40 CFR 60, PS-4A eCFR)	5/8/18
7-Day Drift, Highest Reading	zero = 0.04% span = 0.50%	≤5.0% of full span 6 out of 7 days (40 CFR 60, Appendix B, PS-4)	4/29/18 thru 5/8/18
CGA	Low = 0.42% Mid = 0.55%	≤15.0% of reference value or ≤5.0 ppm difference (40 CFR 60 Appendix F Procedure 1)	5/8/18

Table 4: CO₂ Analyzer Test Results Summary

Test	Results	Criteria	Test Date(s)
7-Day Drift, Highest Reading	zero = 0.10% span = 0.28%	≤0.5% difference (40 CFR 60, Appendix B, PS-3)	4/29/18 thru 5/8/18

3 Test Procedures

The test procedures used in this certification program were done in accordance with the methods outlined in 40 CFR 75 Appendix A and 40 CFR 60 Appendix B Performance Specifications. The following provides a brief overview on individual test procedures.

Test description for the RATA portion of the test program is attached as Section 5.

3.1 7-Day Calibration Error Test – NO_x, O₂

An on-site calibration error test (7-day drift test) was performed for each NO_x and O₂ monitoring system in accordance with 40 CFR 75, Appendix A, Section 6.3. The tests were performed while the unit was combusting fuel at stabilized stack temperature and pressure conditions.

The calibration error test consists of measuring the calibration error of each monitor scale once each day for seven (7) consecutive unit operating (process on line) days. The calibration error tests were conducted at two EPA Traceability Protocol 1 calibration gas concentrations: zero-level (0-20%) and high-level (80-100%) as specified in 40 CFR 75, Appendix A, Section 6.3.1.

In accordance with 40 CFR 75, Appendix A, Section 3.1, results of the 7-day calibration error test are acceptable if the daily calibration error does not exceed: 2.5% for NO_x and 0.5% for O₂. Alternatively, if the pollutant monitor's span value is equal to or less than 200 ppm, then calibration error shall not exceed 5.0 ppm difference.

Calibrations were performed automatically at approximately 24-hour intervals by the system controller during the drift test period. The readings for each analyzer were taken from the DAHS at the completion of the calibration routine. Copies of the DAHS reports are included with this test report. Manual or automatic adjustments were not made to the monitors until after the zero and high drift responses had been taken for that day during the 7-day test.

The percent calibration error is determined using the following equation:

Daily Drift for Pollutants 40 CFR 75, Appendix A Equation A-5	
$CE = \frac{ R - A }{S} \times 100$	<p>CE = Calibration error as a percentage of instrument span</p> <p>R = Zero or high-level calibration gas value in ppm</p> <p>A = Actual monitor response to calibration gas in ppm</p> <p>S = Span of the instrument</p>

The calibration error for diluent (O₂) monitors is computed by the DAHS from the test results for each concentration level as follows:

Daily Drift for Diluents 40 CFR 75, Appendix A, Equation A-5	
$CE = R - A $	<p>CE = Calibration error as a percentage of O₂</p> <p>R = Zero or high-level calibration gas value in percent (%).</p> <p>A = Actual monitor response to calibration gas in percent (%)</p>

3.2 7-Day Calibration Drift Test CO and CO₂ Monitors

The CO₂ analyzer is used for process monitoring and control (non-compliance). A 7-day caliabrtaion drift check was performed as a demonstration of analyzer accuracy with results reported in this report.

Calibrations were performed on the CO and CO₂ analyzer(s) automatically at approximately 24-hour intervals by the DAHS for seven consecutive unit operating (process on-line) days. The calibration drift tests were conducted at two calibration gas concentrations: zero-level (0-20%) and high-level (50-100%) as specified in 40 CFR 60 Appendix B Performance Specifications. The low and high span (zero and span gas) readings for each analyzer were taken from the DAHS at the completion of the calibration routine (40 CFR 60, Appendix B, PS-2, Section 4.1).

The 24-hour calibration drifts were calculated and reported by the following method (40 CFR 60, Appendix B, PS-2). For CO analyzers, the raw zero reading is subtracted from the zero-gas bottle value, the difference is then divided by the analyzer’s span and the resultant value is multiplied by 100 to give the percent calibration drift. The preceding procedure is repeated with the span gas to give the span drift.

Daily Drift for CO 40 CFR 60, Appendix B, PS-2 and PS-4	
$CD = \frac{R - A}{S} \times 100$	<p>CD = Calibration error as a percentage of instrument span</p> <p>R = Zero or high-level calibration gas value in ppm</p> <p>A = Actual monitor response to calibration gas in ppm</p> <p>S = Span of the instrument</p>

The calibration error for the CO₂ monitor is computed by the DAHS from the test results for each concentration level as follows:

Daily Drift for Diluents 40 CFR 60, Appendix B, PS-3 for CO₂	
CD = R – A	CD = Calibration drift as a percentage of CO ₂ R = Zero or high level calibration gas value in percent (%) A = Actual monitor response to calibration gas in percent (%)

The 24-hour calibration drift must not exceed ±5% for CO (6 out of 7 days) and ±0.5% difference for CO₂.

3.3 Linearity Error Check – NO_x, O₂

An on-site linearity check test was conducted in accordance with the 40 CFR 75, Appendix A, for each NO_x and O₂ monitoring system. The test was performed while the unit was combusting primary fuel at stabilized stack temperature and pressure conditions.

EPA Protocol certified calibration gases were used to conduct the linearity checks of the analyzers. Three points (concentrations) of calibration gases, low (20-30%), mid (50-60%) and high (80-100%) were introduced at the probe (40 CFR 75, Appendix A, Section 5.2). Each monitor was challenged three times with the appropriate reference gas, without using the same gas twice in succession. The monitors’ response for each concentration was recorded. The average of the three responses will be used to calculate the linearity error (40 CFR 75, Appendix A, Section 6.2).

Linearity error was calculated using the following equation.

Linearity Error Equation A-4, 40 CFR 75, Appendix A	
$LE = \frac{ R - A }{R} \times 100$	LE = Percent Linearity Error R = Calibration gas reference value A = Average of monitor response

Linearity Check: Alternate Criteria 40 CFR 75, Appendix A, Section 3	
LE = R – A 	LE = Percent linearity error R = Calibration gas reference value A = Average of monitor response

Linearity checks are acceptable for monitor certification if none of the test results exceed the applicable performance specification of 40 CFR 75, Appendix A, Section 3.2. The results of the NO_x and O₂ shall be less than 5.0% as calculated by the above equation or the alternative criteria of ≤0.5% O₂ or ≤5 ppm difference for NO_x.

Note: If the NO_x span value is ≤30 ppm, that range of the analyzer is exempt from the linearity test requirements per 40 CFR 75, Appendix A, Section 6.2.

3.4 CO Analyzer Cylinder Gas Audit

Although not required for certification compliance (per Part 60 PS-4A) a Cylinder Gas Audit (CGA) was performed on the CO analyzer utilizing procedures from 40 CFR 60 Appendix F Procedure 1. The CGA was conducted as a demonstration check with results included in the CO analyzer summary table.

Separate calibration gas cylinders are used for the two required concentration levels during the audit. Three non-consecutive runs at each concentration level are performed. The calibration gases are introduced at the probe interface box and transported through the CEMS sampling system (normal sampling flow path).

The accuracy values for each concentration should not exceed 15% as calculated in the following equation or 5 ppm difference:

Cylinder Gas Audit Accuracy 40 CFR 60, Appendix F, Section 6.3	
$A = \frac{C_m - C_a}{C_a} \times 100$	<p>A = Percent accuracy of the CEM</p> <p>C_m = The average monitor response to the specific audit gas (high or low) in units of concentration</p> <p>C_a = Certified value of audit gas (value according to EPA Protocol certification) in units of concentration</p>

3.5 Cycle/Response Time Check – NO_x, O₂

The cycle time test measures the monitor's reaction time to a change in gas concentration (40 CFR 75, Appendix A, Section 6.4). The system measured stack concentrations until a stable response was observed. The stable stack value was recorded. A low-level (zero) calibration gas was injected at the probe sample interface. Gas injection at the probe continued until a stable monitor response was reached. Next the monitor was switched back to monitor stack gas until a stable reading was achieved and the time recorded. A span-level (80-100% of span) calibration gas was then injected at the probe until a stable response was reached. The amount of time required for the system to respond to 95% of the final stable calibration gas response value was recorded. The time was recorded for the upscale test and the downscale test for each analyzer. The response time for NO_x and O₂ will be ≤15 minutes.

The two cycle times for the upscale and downscale tests were compared. The longer of these two times was recorded as the cycle time for the analyzer.

For monitors with dual ranges, the test results from the range giving the longer cycle time was reported.

3.6 CO Analyzer Response Time Check

An on-site response time test for the CO monitoring system was performed in accordance with Performance Specification 4A, section 8.3 (as specified in recent eCFR posting). The response time test measures the monitor's reaction time to a change in gas concentration. A zero-level calibration gas was injected at the probe interface valve box such that the entire sampling system is included in the test. Gas injection continued until a stable monitor response was reached. A high span gas was then introduced to probe valve box until a stable value was observed. The upscale response time required is the amount of time to reach 95% of the final stable end value. The zero gas was re-introduced until a stable reading was reached. The downscale response time required is the amount of time to reach 95% of the final stable end value. The response times for 3 repetitions of upscale and downscale runs were recorded. An average of the 3 upscale and 3 downscale runs was determined. The response time of the longer (slower) of the two means must be ≤ 240 seconds (4 minutes).

The daily zero and span calibration gases were utilized for response time testing.

4 Test Data and Supporting Documentation

This section contains DAHS printouts and supporting documentation for tests performed in this certification test program.

4.1 7-Day Calibration Drift Data

The following pages contain DAHS printouts and supporting documentation for the drift tests performed on the gas analyzers and flow monitors. All test results are in accordance with the methods outlined in 40 CFR 75 Appendix A and 40 CFR 60 Appendix B Performance Specifications (as applicable).

7-Day Calibration Error (Drift) - NOx Low Range

40 CFR 75

Manufacturer: TAPI

Model: T200M

Serial Number: 645

Measurement Span (ppm): 10

Span Gas Option
 High 80-100%

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	8.17	81.70	OK	CC19317	09/27/20	OK

Zero Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Zero Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	29-Apr-18	12:26	0.00	0.00	0.00	PASS	0.00	PASS
2	30-Apr-18	17:00	0.00	0.00	0.00	PASS	0.00	PASS
3	1-May-18	16:15	0.00	0.00	0.00	PASS	0.00	PASS
4	2-May-18	12:08	0.00	0.00	0.00	PASS	0.00	PASS
5	3-May-18	10:53	0.00	0.00	0.00	PASS	0.00	PASS
6	7-May-18	14:46	0.00	0.10	0.10	PASS	1.00	PASS
7	8-May-18	12:35	0.00	0.00	0.00	PASS	0.00	PASS

Highest Zero Difference 0.10

Highest Zero Drift 1.00

Span Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Span Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	29-Apr-18	9:56	8.17	8.30	0.13	PASS	1.30	PASS
2	30-Apr-18	11:36	8.17	8.20	0.03	PASS	0.30	PASS
3	1-May-18	15:11	8.17	8.10	0.07	PASS	0.70	PASS
4	2-May-18	15:00	8.17	8.20	0.03	PASS	0.30	PASS
5	3-May-18	1:32	8.17	8.20	0.03	PASS	0.30	PASS
6	7-May-18	18:12	8.17	8.20	0.03	PASS	0.30	PASS
7	8-May-18	12:12	8.17	8.00	0.17	PASS	1.70	PASS

Highest Span Difference 0.17

Highest Span Drift 1.70

Notes:

Allowed calibration gas ranges (40 CFR 75)
 0-20% of span
 80-100% of span

Alternately a 40-60% of span may be used.
 Change the Span Gas Option cell if a mid-level gas is used.

Pass/Fail Criteria: 2.5% of span each day of drift period
 or if the span is 200 ppm or less, then 5 ppm difference
 (40 CFR 75, Appendix A, Section 3.1)

*Only use alternate criteria when span is less than 200 ppm

Equation (40 CFR 75, Appendix A, Eq. A-5):

$CE = (|R - A| / R) \times 100$
 or alternate for span ranges less than or equal to 200 ppm
 $CE = |R - A|$

CE = Calibration Error, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

7-Day Calibration Error (Drift) - NOx High Range

40 CFR 75

Manufacturer: TAPI
 Model: T200M
 Serial Number: 645
 Measurement Span (ppm): 100

Span Gas Option
 High 80-100%

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	89.52	89.52	OK	CC329952	12/17/25	OK

Zero Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Zero Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	29-Apr-18	12:26	0.00	0.10	0.10	PASS	0.10	PASS
2	30-Apr-18	17:00	0.00	0.10	0.10	PASS	0.10	PASS
3	1-May-18	16:15	0.00	0.00	0.00	PASS	0.00	PASS
4	2-May-18	12:08	0.00	0.10	0.10	PASS	0.10	PASS
5	3-May-18	10:53	0.00	0.00	0.00	PASS	0.00	PASS
6	7-May-18	14:46	0.00	0.10	0.10	PASS	0.10	PASS
7	8-May-18	12:35	0.00	0.00	0.00	PASS	0.00	PASS

Highest Zero Difference **0.10** Highest Zero Drift **0.10**

Span Reading								
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Difference R-A	Alt. Criteria (5 ppm diff)	Span Calibration Error (R-A /S) x 100	Primary Criteria (%span)
1	29-Apr-18	12:32	89.52	90.40	0.88	PASS	0.88	PASS
2	30-Apr-18	17:06	89.52	89.30	0.22	PASS	0.22	PASS
3	1-May-18	16:21	89.52	88.80	0.72	PASS	0.72	PASS
4	2-May-18	12:14	89.52	88.30	1.22	PASS	1.22	PASS
5	3-May-18	10:59	89.52	88.40	1.12	PASS	1.12	PASS
6	7-May-18	14:52	89.52	88.20	1.32	PASS	1.32	PASS
7	8-May-18	12:41	89.52	88.10	1.42	PASS	1.42	PASS

Highest Span Difference **1.42** Highest Span Drift **1.42**

Notes:

Allowed calibration gas ranges (40 CFR 75)
 0-20% of span
 80-100% of span

Alternately a 40-60% of span may be used.
 Change the Span Gas Option cell if a mid-level gas is used.

Pass/Fail Criteria: 2.5% of span each day of drift period
 or if the span is 200 ppm or less, then 5 ppm difference
 (40 CFR 75, Appendix A, Section 3.1)

*Only use alternate criteria when span is less than 200 ppm

Equation (40 CFR 75, Appendix A, Eq. A-5):

CE = (|R - A| / R) x 100
 or alternate for span ranges less than or equal to 200 ppm
 CE = |R - A|

CE = Calibration Error, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

7-Day Calibration Error (Drift) - O2

40 CFR 75, Appendix A, Section 3.1

Manufacturer: **TAPI**
 Model: **T200M**
 Serial Number: **645**
 Analyzer Range (%): 25

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	20.93	83.72	OK	EB0095428	09/19/25	OK

Zero Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift R-A	Criteria (% diff)
1	29-Apr-18	12:26	0.00	0.00	0.00	PASS
2	30-Apr-18	17:00	0.00	0.00	0.00	PASS
3	1-May-18	16:15	0.00	0.00	0.00	PASS
4	2-May-18	12:08	0.00	0.00	0.00	PASS
5	3-May-18	10:53	0.00	0.00	0.00	PASS
6	7-May-18	14:46	0.00	0.00	0.00	PASS
7	8-May-18	12:44	0.00	0.00	0.00	PASS

Highest Zero Drift 0.00

Span Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift R-A	Criteria (% diff)
1	29-Apr-18	12:35	20.93	20.90	0.03	PASS
2	30-Apr-18	17:09	20.93	20.90	0.03	PASS
3	1-May-18	16:24	20.93	20.90	0.03	PASS
4	2-May-18	12:17	20.93	20.90	0.03	PASS
5	3-May-18	11:02	20.93	20.90	0.03	PASS
6	7-May-18	14:55	20.93	20.90	0.03	PASS
7	8-May-18	12:44	20.93	20.90	0.03	PASS

Highest Span Drift 0.03

Notes:

Allowed calibration gas ranges (40 CFR 75)
 0-20% of span
 80-100% of span

Pass/Fail Criteria: 0.5% difference for each day of the drift period
 (40 CFR 75, Appendix A, Section 3.1)

Equation (40 CFR 75, Appendix A, Section 3.1):

$$CE = |R - A|$$

CE = Calibration Error, %
 R = Calibration Gas Reference Value, %O2
 A = Monitor Response, %O2

7-Day Calibration Error (Drift) - CO Low Range

Manufacturer: **TAPI**
 Model: **T300M**
 Serial Number: **355**
 Measurement Span (ppm): 10

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	8.78	87.78	OK	CC192317	09/26/20	OK

Day	Date	Cal Time	Zero Reading			Primary Criteria (%span)
			Cal Gas (R)	Response (A)	Zero Calibration Error ((R-A)/S) x 100	
1	29-Apr-18	12:26	0.00	0.00	0.00	PASS
2	30-Apr-18	17:00	0.00	0.00	0.00	PASS
3	1-May-18	16:15	0.00	0.00	0.00	PASS
4	2-May-18	12:08	0.00	0.00	0.00	PASS
5	3-May-18	10:53	0.00	0.00	0.00	PASS
6	7-May-18	14:46	0.00	0.00	0.00	PASS
7	8-May-18	12:35	0.00	0.40	4.00	PASS

Highest Zero Drift 4.00

Day	Date	Cal Time	Span Reading			Primary Criteria (%span)
			Cal Gas (R)	Response (A)	Span Calibration Error ((R-A)/S) x 100	
1	29-Apr-18	12:29	8.78	8.90	1.22	PASS
2	30-Apr-18	17:03	8.78	8.90	1.22	PASS
3	1-May-18	16:18	8.78	8.90	1.22	PASS
4	2-May-18	12:11	8.78	8.90	1.22	PASS
5	3-May-18	10:56	8.78	8.90	1.22	PASS
6	7-May-18	14:49	8.78	8.70	0.78	PASS
7	8-May-18	12:38	8.78	8.80	0.22	PASS

Highest Span Drift 1.22

Notes:

Allowed calibration gas ranges (40 CFR 60)
 0-20% of span
 50-100% of span

Pass/Fail Criteria: 5.0% of span for 6 out of 7 days

Equation (40 CFR 60, Appendix B, PS-4):

$CD = (R - A / S) \times 100$
 CD = Calibration Drift, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

Siemens
 CPV Valley Energy Center
 CTG 1
 Middletown, NY

Project # CN50478

Result: **PASS**

7-Day Calibration Error (Drift) - CO High Range

Manufacturer: **TAPI**
 Model: **T300M**
 Serial Number: **355**
 Measurement Span (ppm): **3000**

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	2635.00	87.83	OK	EB0095428	09/19/25	OK

Zero Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Zero Calibration Error ((R-A)/S) x 100	Primary Criteria (%span)
1	29-Apr-18	12:26	0.00	-0.80	0.03	PASS
2	30-Apr-18	17:00	0.00	-1.10	0.04	PASS
3	1-May-18	16:15	0.00	-0.20	0.01	PASS
4	2-May-18	12:08	0.00	0.90	0.03	PASS
5	3-May-18	10:53	0.00	0.80	0.03	PASS
6	7-May-18	14:46	0.00	-0.90	0.03	PASS
7	8-May-18	12:35	0.00	-0.20	0.01	PASS

Highest Zero Drift **0.04**

Span Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Span Calibration Error ((R-A)/S) x 100	Primary Criteria (%span)
1	29-Apr-18	12:35	2635.00	2642.60	0.25	PASS
2	30-Apr-18	17:09	2635.00	2643.90	0.30	PASS
3	1-May-18	16:24	2635.00	2642.80	0.26	PASS
4	2-May-18	12:17	2635.00	2649.20	0.47	PASS
5	3-May-18	11:02	2635.00	2650.10	0.50	PASS
6	7-May-18	14:55	2635.00	2638.30	0.11	PASS
7	8-May-18	12:44	2635.00	2639.80	0.16	PASS

Highest Span Drift **0.50**

Notes:

Allowed calibration gas ranges (40 CFR 60)
 0-20% of span
 50-100% of span

Pass/Fail Criteria: 5.0% of span for 6 out of 7 days

Equation (40 CFR 60, Appendix B, PS-4):

CD = (R - A / S) x 100
 CD = Calibration Drift, %
 R = Calibration Gas Reference Value, ppm
 A = Monitor Response, ppm
 S = Analyzer Span Value

Siemens
 CPV Valley Energy Center
 CTG 1
 Middletown, NY

Project # CN50478

Result: Pass

7-Day Calibration Error (Drift) - CO2

40 CFR 60, PS-3

Manufacturer: **TAPI**
 Model: **T300M**
 Serial Number: **355**
 Analyzer Range (%): 10

	Ref Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check*
Zero Calibration Gas (ppm):	0.00	0.00	OK	CC307646	08/22/25	OK
Span Calibration Gas (ppm):	8.82	88.20	OK	EB0095428	09/19/25	OK

Zero Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift R-A	Criteria (% diff)
1	29-Apr-18	12:26	0.00	0.00	0.00	PASS
2	30-Apr-18	17:00	0.00	0.00	0.00	PASS
3	1-May-18	16:15	0.00	0.10	0.10	PASS
4	2-May-18	12:08	0.00	0.10	0.10	PASS
5	3-May-18	10:53	0.00	0.00	0.00	PASS
6	7-May-18	14:46	0.00	0.00	0.00	PASS
7	8-May-18	12:35	0.00	0.10	0.10	PASS

Highest Zero Drift 0.10

Span Reading						
Day	Date	Cal Time	Cal Gas (R)	Response (A)	Drift (CD) R-A	Criteria (% diff)
1	29-Apr-18	12:35	8.82	9.00	0.18	PASS
2	30-Apr-18	17:09	8.82	9.10	0.28	PASS
3	1-May-18	16:24	8.82	9.00	0.18	PASS
4	2-May-18	12:17	8.82	9.00	0.18	PASS
5	3-May-18	11:02	8.82	9.10	0.28	PASS
6	7-May-18	14:55	8.82	9.00	0.18	PASS
7	8-May-18	12:44	8.82	9.00	0.18	PASS

Highest Span Drift 0.28

Notes:

Allowed calibration gas ranges (40 CFR 60, PS-3)
 0-20% of span
 50-100% of span

Pass/Fail Criteria: 0.5% difference for each day of the drift period

Equation (40 CFR 60, Appendix B):

$CD = R - A$

CD = Calibration Drift, %
 R = Calibration Gas Value, %CO2
 A = Monitor Response, %CO2

Calibration Report

Facility Name: CPV_Valley_Wawayanda
 Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/29/2018 12:26	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
04/29/2018 12:29	CTG1 NOx Low P75	Upscale	8.00	8.30	-3.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
04/30/2018 17:00	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
04/30/2018 17:03	CTG1 NOx Low P75	Upscale	8.00	8.20	-2.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/01/2018 16:15	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/01/2018 16:18	CTG1 NOx Low P75	Upscale	8.00	8.10	-1.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/02/2018 12:08	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/02/2018 12:11	CTG1 NOx Low P75	Upscale	8.00	8.20	-2.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/03/2018 10:53	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/03/2018 10:56	CTG1 NOx Low P75	Upscale	8.00	8.20	-2.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/07/2018 14:46	CTG1 NOx Low P75	Zero	0.00	0.10	-1.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/07/2018 14:49	CTG1 NOx Low P75	Upscale	8.00	8.20	-2.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/08/2018 12:35	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/08/2018 12:38	CTG1 NOx Low P75	Upscale	8.00	8.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/09/2018 11:17	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/09/2018 11:20	CTG1 NOx Low P75	Upscale	8.20	8.20	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/09/2018 11:32	CTG1 NOx Low P75	Zero	0.00	0.00	0.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20
05/09/2018 11:36	CTG1 NOx Low P75	Upscale	8.20	8.50	-3.00	2.50	10.00	0	0	Pass			ON	CC1923 17	09/26/20

Calibration Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Date Time	Analyzer	Target Value	Type	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/29/2018 12:26	CTG1 NOx High P75	0.00	Zero	0.10	-0.10	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
04/29/2018 12:32	CTG1 NOx High P75	89.00	Upscale	90.40	-1.40	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
04/30/2018 17:00	CTG1 NOx High P75	0.00	Zero	0.10	-0.10	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
04/30/2018 17:06	CTG1 NOx High P75	89.00	Upscale	89.30	-0.30	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/01/2018 16:15	CTG1 NOx High P75	0.00	Zero	0.00	0.00	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/01/2018 16:21	CTG1 NOx High P75	89.00	Upscale	88.80	0.20	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/02/2018 12:08	CTG1 NOx High P75	0.00	Zero	0.10	-0.10	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/02/2018 12:14	CTG1 NOx High P75	89.00	Upscale	88.30	0.70	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/03/2018 10:53	CTG1 NOx High P75	0.00	Zero	0.00	0.00	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/03/2018 10:59	CTG1 NOx High P75	89.00	Upscale	88.40	0.60	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/07/2018 14:46	CTG1 NOx High P75	0.00	Zero	0.10	-0.10	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/07/2018 14:52	CTG1 NOx High P75	89.00	Upscale	88.20	0.80	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/08/2018 12:35	CTG1 NOx High P75	0.00	Zero	0.00	0.00	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/08/2018 12:41	CTG1 NOx High P75	89.00	Upscale	88.10	0.90	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/09/2018 11:17	CTG1 NOx High P75	0.00	Zero	0.10	-0.10	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/09/2018 11:23	CTG1 NOx High P75	89.00	Upscale	88.00	1.00	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/09/2018 11:32	CTG1 NOx High P75	0.00	Zero	0.10	-0.10	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19
05/09/2018 11:40	CTG1 NOx High P75	89.50	Upscale	88.50	1.00	2.50	100.00	Pass	0	Pass			ON	CC3299	04/06/19

Calibration Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/29/2018 12:26	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
04/29/2018 12:35	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
04/30/2018 17:00	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
04/30/2018 17:09	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/01/2018 16:15	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/01/2018 16:24	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/02/2018 12:08	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/02/2018 12:17	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/03/2018 10:53	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/03/2018 11:02	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/07/2018 14:46	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/07/2018 14:55	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/08/2018 12:35	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/08/2018 12:44	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:17	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:26	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:32	CTG1 O2 P75	Zero	0.00	0.00	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:43	CTG1 O2 P75	Upscale	20.90	20.90	0.00	0.50	25.00	Pass	0	Pass	ON	ON	ON	EB0095 428	09/25/25

4/29/2018 12:26	CTG1	CO_HIGH	Daily	Zero	0	-0.8	0.03	PASS	0	5	3000	FALSE	ON						
4/29/2018 12:35	CTG1	CO_HIGH	Daily	Upscale	2635	2642.6	-0.25	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
4/30/2018 17:00	CTG1	CO_HIGH	Daily	Zero	0	-1.1	0.04	PASS	0	5	3000	FALSE	ON						
4/30/2018 17:09	CTG1	CO_HIGH	Daily	Upscale	2635	2643.9	-0.3	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/1/2018 16:15	CTG1	CO_HIGH	Daily	Zero	0	-0.2	0.01	PASS	0	5	3000	FALSE	ON						
5/1/2018 16:24	CTG1	CO_HIGH	Daily	Upscale	2635	2642.8	-0.26	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/2/2018 12:08	CTG1	CO_HIGH	Daily	Zero	0	0.9	-0.03	PASS	0	5	3000	FALSE	ON						
5/2/2018 12:17	CTG1	CO_HIGH	Daily	Upscale	2635	2649.2	-0.47	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/3/2018 10:53	CTG1	CO_HIGH	Daily	Zero	0	0.8	-0.03	PASS	0	5	3000	FALSE	ON						
5/3/2018 11:02	CTG1	CO_HIGH	Daily	Upscale	2635	2650.1	-0.5	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/7/2018 14:46	CTG1	CO_HIGH	Daily	Zero	0	-0.9	0.03	PASS	0	5	3000	FALSE	ON						
5/7/2018 14:55	CTG1	CO_HIGH	Daily	Upscale	2635	2638.3	-0.11	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/8/2018 12:35	CTG1	CO_HIGH	Daily	Zero	0	-0.2	0.01	PASS	0	5	3000	FALSE	ON						
5/8/2018 12:44	CTG1	CO_HIGH	Daily	Upscale	2635	2639.8	-0.16	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/9/2018 11:17	CTG1	CO_HIGH	Daily	Zero	0	0.8	-0.03	PASS	0	5	3000	FALSE	ON						
5/9/2018 11:26	CTG1	CO_HIGH	Daily	Upscale	2635	2635.1	0	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/9/2018 11:32	CTG1	CO_HIGH	Daily	Zero	0	1.1	-0.04	PASS	0	5	3000	FALSE	ON						
5/9/2018 11:43	CTG1	CO_HIGH	Daily	Upscale	2635	2637.2	-0.07	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/10/2018 7:51	CTG1	CO_HIGH	Daily	Zero	0	-0.8	0.23	PASS	0	5	3000	FALSE	ON						
5/10/2018 8:00	CTG1	CO_HIGH	Daily	Upscale	2635	2641.9	-0.23	PASS	0	5	3000	FALSE	ON	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
5/10/2018 13:08	CTG1	CO_HIGH	Daily	Zero	0	1.3	-0.04	PASS	0	5	3000	FALSE	OFF						
5/10/2018 13:17	CTG1	CO_HIGH	Daily	Upscale	2635	2640	-0.17	PASS	0	5	3000	FALSE	OFF	CO,CO2,O2,BALN	EB0095428	B52017			9/25/2025
4/29/2018 12:26	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	ON						
4/29/2018 12:29	CTG1	CO_LOW	Daily	Upscale	8.8	8.9	-1	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
4/30/2018 17:00	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	ON						
4/30/2018 17:03	CTG1	CO_LOW	Daily	Upscale	8.8	8.9	-1	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/1/2018 16:15	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	ON						
5/1/2018 16:18	CTG1	CO_LOW	Daily	Upscale	8.8	8.9	-1	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/2/2018 12:08	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	ON						
5/2/2018 12:11	CTG1	CO_LOW	Daily	Upscale	8.8	8.9	-1	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/3/2018 10:53	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	ON						
5/3/2018 10:56	CTG1	CO_LOW	Daily	Upscale	8.8	8.9	-1	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/7/2018 14:46	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	ON						
5/7/2018 14:49	CTG1	CO_LOW	Daily	Upscale	8.8	8.7	1	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/8/2018 12:35	CTG1	CO_LOW	Daily	Zero	0	0.4	-4	PASS	0	5	10	FALSE	ON						
5/8/2018 12:38	CTG1	CO_LOW	Daily	Upscale	8.8	8.8	0	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/9/2018 11:17	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	ON						
5/9/2018 11:20	CTG1	CO_LOW	Daily	Upscale	8.8	0.2	86	FAIL	1	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/9/2018 11:32	CTG1	CO_LOW	Daily	Zero	0	0.3	-3	PASS	0	5	10	FALSE	ON						
5/9/2018 11:36	CTG1	CO_LOW	Daily	Upscale	8.8	8.8	0	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/10/2018 7:51	CTG1	CO_LOW	Daily	Zero	0	0.4	-4	PASS	0	5	10	FALSE	ON						
5/10/2018 7:54	CTG1	CO_LOW	Daily	Upscale	8.8	9.1	-3	PASS	0	5	10	FALSE	ON	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020
5/10/2018 13:08	CTG1	CO_LOW	Daily	Zero	0	0	0	PASS	0	5	10	FALSE	OFF						
5/10/2018 13:11	CTG1	CO_LOW	Daily	Upscale	8.8	8.8	0	PASS	0	5	10	FALSE	OFF	CO,CO2,NO,NOX,B	CC192317	B52017			9/26/2020

Calibration Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
04/29/2018 12:26	CTG1 CO2 P60	Zero	0.00	0.00	0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
04/29/2018 12:35	CTG1 CO2 P60	Upscale	8.80	9.00	-0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
04/30/2018 17:00	CTG1 CO2 P60	Zero	0.00	0.00	0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
04/30/2018 17:09	CTG1 CO2 P60	Upscale	8.80	9.10	-0.30	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/01/2018 16:15	CTG1 CO2 P60	Zero	0.00	0.10	-0.10	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/01/2018 16:24	CTG1 CO2 P60	Upscale	8.80	9.00	-0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/02/2018 12:08	CTG1 CO2 P60	Zero	0.00	0.10	-0.10	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/02/2018 12:17	CTG1 CO2 P60	Upscale	8.80	9.00	-0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/03/2018 10:53	CTG1 CO2 P60	Zero	0.00	0.00	0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/03/2018 11:02	CTG1 CO2 P60	Upscale	8.80	9.10	-0.30	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/07/2018 14:46	CTG1 CO2 P60	Zero	0.00	0.00	0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/07/2018 14:55	CTG1 CO2 P60	Upscale	8.80	9.00	-0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/08/2018 12:35	CTG1 CO2 P60	Zero	0.00	0.10	-0.10	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/08/2018 12:44	CTG1 CO2 P60	Upscale	8.80	9.00	-0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:17	CTG1 CO2 P60	Zero	0.00	0.10	-0.10	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:26	CTG1 CO2 P60	Upscale	8.80	9.00	-0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:32	CTG1 CO2 P60	Zero	0.00	0.10	-0.10	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/09/2018 11:43	CTG1 CO2 P60	Upscale	8.80	9.00	-0.20	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25
05/10/2018 07:51	CTG1 CO2 P60	Zero	0.00	0.00	0.00	0.50	10.00	Pass	0	ON	ON	ON	ON	EB0095 428	09/25/25

Calibration Report

Facility Name: CPV_Valley_Wawayanda
Location: Middletown, NY

Date Time	Analyzer	Type	Target Value	Analyzer Value	Analyzer Drift	Perf Spec	Span	P60 Status	5-day Count	P75 Status	PADEP Status	CA Status	Process Status	Cylinder Number	Cylinder Exp
05/10/2018 08:00	CTG1 CO2 P60	Upscale	8.80	9.10	-0.30	0.50	10.00	Pass	0				ON	EB0095 428	09/25/25

4.2 Linearity and CGA Data

The following pages contain DAHS printouts and supporting documentation for the linearity and CGA checks performed on the gas analyzers. All test results are in accordance with the methods outlined in 40 CFR 75 Appendix A, section 6.2 and 40 CFR 60 Appendix F (as applicable).

Siemens
CPV Valley Energy Center
CTG 1
Middletown, NY

Tested by: Justin Saporito
Company: Cemtek KVB-Enertec
Project # CN50478

Linearity Test - NOx Low Range

40 CFR 75, Appendix A, Section 3.2

Manufacturer: TAPI
Model: T200M
Serial Number: 645
Analyzer Range: 10 ppm
Test Date: 8-May-18

Pass

	Gas Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check
Low	2.42	24.20	OK	EB0072315	07/04/20	OK
Mid	5.09	50.90	OK	EB0101725	12/03/20	OK
High	8.17	81.70	OK	CC192317	09/26/20	OK

Run Number	Run Level	Cal Gas Value (R)	Time	Monitor Response (A)	Difference (R-A)		
					Low	Mid	High
1	Low	2.42	9:48	2.50	-0.08	-0.21	0.17
2	Mid	5.09	9:52	5.30			
3	High	8.17	9:58	8.00			
4	Low	2.42	10:02	2.50	-0.08	-0.31	0.17
5	Mid	5.09	10:09	5.40			
6	High	8.17	10:15	8.00			
7	Low	2.42	10:19	2.50	-0.08	-0.31	0.17
8	Mid	5.09	10:24	5.40			
9	High	8.17	10:29	8.00			
<i>Average Response</i>					2.50	5.37	8.00
<i>Absolute Difference of Average</i>					0.08	0.28	0.17
<i>Status (for alternate criteria of 5 ppm difference)</i>					PASS	PASS	PASS
<i>Linearity Error, %</i>					3.31	5.44	2.08
<i>Status</i>					PASS	FAIL	PASS

Notes:
Pass/fail criteria = 5% or less; or abs mean difference = 5 ppm or less
(40 CFR 75, Appendix A, Section 3.2)

Cal Gas Allowances (40 CFR 75)
Low = 20-30% of span
Mid = 50-60% of span
High = 80-100% of span

Equation (40 CFR 75, Appendix A, Eq A-4):
 $LE = (|R - A| / R) \times 100$
or
 $LE = |R - A|$ (40 CFR 75, Appendix A, Section 3.2)
LE = Linearity Error
R = Calibration Gas Reference Value
A = Average of Monitor Response

Siemens
CPV Valley Energy Center
CTG 1
Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project # CN50478

Linearity Test - NOx High Range

40 CFR 75, Appendix A, Section 3.2

Manufacturer: TAPI
 Model: T200M
 Serial Number: 645
 Analyzer Range: 100 ppm
 Test Date: 8-May-18

Pass

	Gas Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check
Low	24.60	24.60	OK	EB0073000	03/19/21	OK
Mid	50.89	50.89	OK	CC503502	11/01/25	OK
High	89.52	89.52	OK	CC329952	12/17/25	OK

Run Number	Run Level	Cal Gas Value (R)	Time	Monitor Response (A)	Difference (R-A)		
					Low	Mid	High
1	Low	24.60	9:51	25.00	-0.40	-0.51	1.32
2	Mid	50.89	9:55	51.40			
3	High	89.52	10:00	88.20			
4	Low	24.60	10:04	25.10	-0.50	-0.51	1.32
5	Mid	50.89	10:08	51.40			
6	High	89.52	10:12	88.20			
7	Low	24.60	10:16	25.10	-0.50	-0.61	1.02
8	Mid	50.89	10:20	51.50			
9	High	89.52	10:24	88.50			
<i>Average Response</i>					25.07	51.43	88.30
<i>Absolute Difference of Average</i>					0.47	0.54	1.22
<i>Status (for alternate criteria of 5 ppm difference)</i>					PASS	PASS	PASS
<i>Linearity Error, %</i>					1.90	1.07	1.36
<i>Status</i>					PASS	PASS	PASS

Notes:
 Pass/fail criteria = 5% or less; or abs mean difference = 5 ppm or less
 (40 CFR 75, Appendix A, Section 3.2)

Cal Gas Allowances (40 CFR 75)
 Low = 20-30% of span
 Mid = 50-60% of span
 High = 80-100% of span

Equation (40 CFR 75, Appendix A, Eq A-4):
 $LE = (|R - A| / R) \times 100$
 or
 $LE = |R - A|$ (40 CFR 75, Appendix A, Section 3.2)
 LE = Linearity Error
 R = Calibration Gas Reference Value
 A = Average of Monitor Response

Siemens
CPV Valley Energy Center
CTG 1
Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project # CN50478

Linearity Test - O2

40 CFR 75, Appendix A, Section 3.2

Manufacturer: TAPI
 Model: T200M
 Serial Number: 645
 Analyzer Range: 25 %
 Test Date: 8-May-18

Pass

	Gas Value	% of Span	% Span Status	Bottle #	Exp. Date	Date Check
Low	6.36	25.44	OK	EB0049201	08/13/21	OK
Mid	13.82	55.28	OK	EB0060674	04/01/26	OK
High	20.93	83.72	OK	EB0095428	09/17/25	OK

Run Number	Run Level	Cal Gas Value (R)	Time	Monitor Response (A)	Difference (R-A)		
					Low	Mid	High
1	Low	6.36	7:05	6.10	0.26	0.12	0.03
2	Mid	13.82	7:09	13.70			
3	High	20.93	7:13	20.90			
4	Low	6.36	7:18	6.10	0.26	0.12	0.03
5	Mid	13.82	7:21	13.70			
6	High	20.93	7:26	20.90			
7	Low	6.36	7:30	6.10	0.26	0.12	0.03
8	Mid	13.82	7:34	13.70			
9	High	20.93	7:38	20.90			
<i>Average Response</i>					6.10	13.70	20.90
<i>Absolute Difference of Average</i>					0.26	0.12	0.03
<i>Status (for alternate criteria of .5% difference)</i>					PASS	PASS	PASS
<i>Linearity Error, %</i>					4.09	0.87	0.14
<i>Status</i>					PASS	PASS	PASS

Notes:

Pass/fail criteria = 5% or less; or abs mean difference = 0.5% or less
 (40 CFR 75, Appendix A, Section 3.2)

Cal Gas Allowances
 Low = 20-30% of span
 Mid = 50-60% of span
 High = 80 100% of span

Equation (40 CFR 75, Appendix A, Eq A-4):

LE = (|R - A| / R) x 100
 or
 LE = |R - A| (40 CFR 75, Appendix A, Section 3.2)

LE = Linearity Error
 R = Calibration Gas Reference Value
 A = Average of Monitor Response

CPV Valley Energy Center
 CTG 1
 Middletown NY

Project# 50478

Cylinder Gas Audit - CO Low Range

For quarter ending: 06/30/18

Manufacturer: TAPI
 Model: T300M
 Serial Number: 355
 Analyzer Range: 10
 Test Date: 05/08/18

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	2.67	26.70	OK	EB0072315	07/04/20 OK
Mid	5.66	56.60	OK	EB0101725	12/30/20 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	9:48	2.10	9:53	5.40
2	10:02	2.00	10:09	5.40
3	10:19	2.10	10:24	5.30
Average Response (Cm)		2.07		5.37
Difference (Cm-Ca)		-0.60		-0.29
Status (for alternate criteria of 5 ppm difference)		PASS		PASS
Accuracy %, ((Cm-Ca)/Ca) * 100		-22.60		-5.18
Status (for primary criteria of 15%)		FAIL		PASS

Cylinder Gas Audit - CO High Range

Analyzer Range: 3000
 Test Date: 05/08/18

Reference Gas Value (Ca)	% of Span	Status	Bottle #	Exp. Date	Exp. Date Status
Low	753.00	25.10	OK	EB0040994	04/04/26 OK
Mid	1670.00	55.67	OK	EB00722144	04/04/26 OK

Note: Cal gas values must be between 20-30% of span value for low and 50-60% of span value for mid

Run Number	Run Time	Low Response	Run Time	Mid Response
1	8:19	755.20	8:24	1680.80
2	8:29	754.70	8:33	1678.00
3	8:38	758.60	8:42	1678.90
Average Response (Cm)		756.17		1679.23
Difference (Cm-Ca)		3.17		9.23
Status (for alternate criteria of 5 ppm difference)		PASS		FAIL
Accuracy %, ((Cm-Ca)/Ca) * 100		0.42		0.55
Status (for primary criteria of 15%)		PASS		PASS

Notes:

Pass/Fail Criteria: +/- 15% or 5.0 ppm difference for pollutants
 (40 CFR 60, Appendix F)

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 OIL_FLOW_EPA CTG1 NOX_LOW_P75

	LBHR	OS	MS	PPMD	OS	MS
05/08/2018 10:15	96000	SU	GD	8.0	SU	QA
05/08/2018 10:16	96000	SU	GD	8.0	SU	QA
05/08/2018 10:17	96000	SU	GD	5.7	SU	MN
05/08/2018 10:18	96000	SU	GD	2.5	SU	MN
05/08/2018 10:19	96000	SU	GD	2.5	SU	MN
05/08/2018 10:20	96000	SU	GD	2.5	SU	MN
05/08/2018 10:21	96000	SU	GD	2.5	SU	MN
05/08/2018 10:22	96000	SU	GD	2.8	SU	MN
05/08/2018 10:23	96000	SU	GD	5.4	SU	MN
05/08/2018 10:24	96000	SU	GD	5.4	SU	MN
05/08/2018 10:25	96000	SU	GD	5.4	SU	MN
05/08/2018 10:26	96000	SU	GD	5.4	SU	MN
05/08/2018 10:27	96000	SU	GD	5.4	SU	QA
05/08/2018 10:28	96000	SU	GD	7.8	SU	QA
05/08/2018 10:29	96000	SU	GD	8.0	SU	QA
05/08/2018 10:30	96000	SU	GD	8.0	SU	QA

Average	96000
Maximum	96000
Minimum	96000
Total	4224000

OS - Operating Status:
 SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:
 GD - good data CP - clean process equipment
 GO - monitor over range CC - clean control equipment
 QA - quality assurance activity MD - unknown operating status
 MN - maintenance activity MN - invalid

Data is expressed in Standard Time

Report generated on: 05/10/2018 10:29

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 OIL_FLOW_EPA CTG1 NOX_LOW_P75

	LBHR	OS	MS	PPMD	OS	MS
05/08/2018 09:47	96000	SU	GD	2.5	SU	MN
05/08/2018 09:48	96000	SU	GD	2.5	SU	MN
05/08/2018 09:49	96000	SU	GD	2.5	SU	MN
05/08/2018 09:50	96000	SU	GD	3.2	SU	MN
05/08/2018 09:51	96000	SU	GD	5.3	SU	MN
05/08/2018 09:52	96000	SU	GD	5.3	SU	MN
05/08/2018 09:53	96000	SU	GD	5.3	SU	MN
05/08/2018 09:54	96000	SU	GD	5.5	SU	QA
05/08/2018 09:55	96000	SU	GD	7.7	SU	QA
05/08/2018 09:56	96000	SU	GD	8.1	SU	QA
05/08/2018 09:57	96000	SU	GD	8.0	SU	QA
05/08/2018 09:58	96000	SU	GD	8.0	SU	QA
05/08/2018 09:59	96000	SU	GD	8.0	SU	QA
05/08/2018 10:00	96000	SU	GD	3.1	SU	MN
05/08/2018 10:01	96000	SU	GD	2.5	SU	MN
05/08/2018 10:02	96000	SU	GD	2.5	SU	MN
05/08/2018 10:03	96000	SU	GD	2.5	SU	MN
05/08/2018 10:04	96000	SU	GD	2.4	SU	MN
05/08/2018 10:05	96000	SU	GD	2.4	SU	MN
05/08/2018 10:06	96000	SU	GD	2.4	SU	MN
05/08/2018 10:07	96000	SU	GD	3.2	SU	MN
05/08/2018 10:08	96000	SU	GD	5.3	SU	MN
05/08/2018 10:09	96000	SU	GD	5.4	SU	MN
05/08/2018 10:10	96000	SU	GD	5.4	SU	MN
05/08/2018 10:11	96000	SU	GD	5.4	SU	QA
05/08/2018 10:12	96000	SU	GD	6.5	SU	QA
05/08/2018 10:13	96000	SU	GD	8.1	SU	QA
05/08/2018 10:14	96000	SU	GD	8.0	SU	QA

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Report generated on: 05/10/2018 10:29

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 OIL_FLOW_EPA CTG1 NOX_P75

	LBHR	OS	MS	PPMD	OS	MS
05/10/2018 09:50	73000	SU	GD	25.0	SU	QA
05/10/2018 09:51	72000	SU	GD	25.0	SU	QA
05/10/2018 09:52	73000	SU	GD	25.0	SU	QA
05/10/2018 09:53	73000	SU	GD	27.2	SU	QA
05/10/2018 09:54	72000	SU	GD	51.4	SU	QA
05/10/2018 09:55	73000	SU	GD	51.4	SU	QA
05/10/2018 09:56	73000	SU	GD	51.4	SU	QA
05/10/2018 09:57	73000	SU	GD	54.4	SU	QA
05/10/2018 09:58	73000	SU	GD	81.6	SU	QA
05/10/2018 09:59	73000	SU	GD	88.2	SU	QA
05/10/2018 10:00	72000	SU	GD	88.2	SU	QA
05/10/2018 10:01	73000	SU	GD	88.2	SU	QA
05/10/2018 10:02	72000	SU	GD	69.8	SU	QA
05/10/2018 10:03	72000	SU	GD	25.2	SU	QA
05/10/2018 10:04	70000	SU	GD	25.1	SU	QA
05/10/2018 10:05	68000	SU	GD	25.1	SU	QA
05/10/2018 10:06	67000	SU	GD	38.2	SU	QA
05/10/2018 10:07	65000	SU	GD	51.4	SU	QA
05/10/2018 10:08	64000	SU	GD	51.4	SU	QA
05/10/2018 10:09	64000	SU	GD	51.4	SU	QA
05/10/2018 10:10	64000	SU	GD	66.6	SU	QA
05/10/2018 10:11	64000	SU	GD	88.1	SU	QA
05/10/2018 10:12	63000	SU	GD	88.2	SU	QA
05/10/2018 10:13	63000	SU	GD	88.3	SU	QA
05/10/2018 10:14	62000	SU	GD	67.3	SU	QA
05/10/2018 10:15	59000	SU	GD	25.2	SU	QA
05/10/2018 10:16	58000	SU	GD	25.1	SU	QA
05/10/2018 10:17	56000	SU	GD	25.1	SU	QA

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Report generated on: 05/10/2018 10:23

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 OIL_FLOW_EPA CTG1 NOX_P75

	LBHR	OS	MS	PPMD	OS	MS
05/10/2018 10:18	55000	SU	GD	32.1	SU	QA
05/10/2018 10:19	52000	SU	GD	51.4	SU	QA
05/10/2018 10:20	50000	SU	GD	51.5	SU	QA
05/10/2018 10:21	48000	SU	GD	51.4	SU	QA
05/10/2018 10:22	46000	SU	GD	51.4	SU	QA
05/10/2018 10:23	44000	SU	GD	85.1	SU	QA
05/10/2018 10:24	42000	SU	GD	88.5	SU	QA
05/10/2018 10:25	40000	SU	GD	88.4	SU	QA
05/10/2018 10:26				81.5	SU	MN

Average	63361
Maximum	73000
Minimum	40000
Total	2281000

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Report generated on: 05/10/2018 10:23

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 OIL_FLOW_EPA CTG1 O2_P75

	LBHR	OS	MS	PCT	OS	MS
05/10/2018 07:04	72000	SU	GD	6.1	SU	QA
05/10/2018 07:05	72000	SU	GD	6.1	SU	QA
05/10/2018 07:06	72000	SU	GD	6.1	SU	QA
05/10/2018 07:07	72000	SU	GD	10.1	SU	QA
05/10/2018 07:08	72000	SU	GD	13.7	SU	QA
05/10/2018 07:09	72000	SU	GD	13.7	SU	QA
05/10/2018 07:10	72000	SU	GD	13.7	SU	QA
05/10/2018 07:11	72000	SU	GD	16.5	SU	QA
05/10/2018 07:12	72000	SU	GD	20.9	SU	QA
05/10/2018 07:13	72000	SU	GD	20.9	SU	QA
05/10/2018 07:14	72000	SU	GD	20.9	SU	QA
05/10/2018 07:15	72000	SU	GD	19.9	SU	QA
05/10/2018 07:16	72000	SU	GD	6.3	SU	QA
05/10/2018 07:17	72000	SU	GD	6.1	SU	QA
05/10/2018 07:18	72000	SU	GD	6.1	SU	QA
05/10/2018 07:19	72000	SU	GD	6.3	SU	QA
05/10/2018 07:20	72000	SU	GD	13.5	SU	QA
05/10/2018 07:21	72000	SU	GD	13.7	SU	QA
05/10/2018 07:22	72000	SU	GD	13.7	SU	QA
05/10/2018 07:23	72000	SU	GD	13.7	SU	QA
05/10/2018 07:24	72000	SU	GD	19.7	SU	QA
05/10/2018 07:25	72000	SU	GD	20.9	SU	QA
05/10/2018 07:26	72000	SU	GD	20.9	SU	QA
05/10/2018 07:27	72000	SU	GD	20.9	SU	QA
05/10/2018 07:28	72000	SU	GD	11.6	SU	QA
05/10/2018 07:29	72000	SU	GD	6.1	SU	QA
05/10/2018 07:30	72000	SU	GD	6.1	SU	QA
05/10/2018 07:31	72000	SU	GD	6.1	SU	QA

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation

MS - General Monitor Status:

GD - good data
 GO - monitor over range
 QA - quality assurance activity

Report generated on: 05/10/2018 07:39

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 OIL_FLOW_EPA CTG1 O2_P75

	LBHR	OS	MS	PCT	OS	MS
05/10/2018 07:32	72000	SU	GD	9.9	SU	QA
05/10/2018 07:33	72000	SU	GD	13.7	SU	QA
05/10/2018 07:34	72000	SU	GD	13.7	SU	QA
05/10/2018 07:35	72000	SU	GD	13.7	SU	QA
05/10/2018 07:36	72000	SU	GD	16.6	SU	QA
05/10/2018 07:37	72000	SU	GD	20.9	SU	QA
05/10/2018 07:38	72000	SU	GD	20.9	SU	QA
05/10/2018 07:39	72000	SU	GD	20.9	SU	QA
05/10/2018 07:40	72000	SU	GD	18.1	SU	MN
05/10/2018 07:41	72000	SU	GD	13.8	SU	MN
05/10/2018 07:42	72000	SU	GD	13.7	SU	MN

Average	72000
Maximum	72000
Minimum	72000
Total	2808000

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation

OFF - off-line
 CF - changing fuels
 CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

GD - good data
 GO - monitor over range
 QA - quality assurance activity

MN - maintenance activity
 IV - invalid

Report generated on: 05/10/2018 07:39

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CO LO CGA

	CTG1 CO_LOW		CTG2 GEN_GT	
	PPMD	OS MS	MW	OS MS
05/08/2018 09:47	2.1	SU QA	189	SU GD
05/08/2018 09:48	2.1	SU QA	189	SU GD
05/08/2018 09:49	2.0	SU QA	190	SU GD
05/08/2018 09:50	2.7	SU QA	189	SU GD
05/08/2018 09:51	5.2	SU QA	189	SU GD
05/08/2018 09:52	5.4	SU QA	189	SU GD
05/08/2018 09:53	5.4	SU QA	190	SU GD
05/08/2018 09:54	5.5	SU QA	189	SU GD
05/08/2018 09:55	8.0	SU QA	189	SU GD
05/08/2018 09:56	8.8	SU QA	189	SU GD
05/08/2018 09:57	8.8	SU QA	189	SU GD
05/08/2018 09:58	8.7	SU QA	189	SU GD
05/08/2018 09:59	8.7	SU QA	189	SU GD
05/08/2018 10:00	5.4	SU QA	189	SU GD
05/08/2018 10:01	2.1	SU QA	189	SU GD
05/08/2018 10:02	2.0	SU QA	189	SU GD
05/08/2018 10:03	2.0	SU QA	189	SU GD
05/08/2018 10:04	2.0	SU QA	189	SU GD
05/08/2018 10:05	2.1	SU QA	189	SU GD
05/08/2018 10:06	2.1	SU QA	189	SU GD
05/08/2018 10:07	2.5	SU QA	189	SU GD
05/08/2018 10:08	5.2	SU QA	190	SU GD
05/08/2018 10:09	5.4	SU QA	190	SU GD
05/08/2018 10:10	5.4	SU QA	189	SU GD
05/08/2018 10:11	5.3	SU QA	189	SU GD
05/08/2018 10:12	6.5	SU QA	189	SU GD
05/08/2018 10:13	8.6	SU QA	189	SU GD
05/08/2018 10:14	8.7	SU QA	190	SU GD
05/08/2018 10:15	8.7	SU QA	190	SU GD

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation

MS - General Monitor Status:

OFF - off-line
 CF - changing fuels
 CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

GD - good data
 GO - monitor over range
 QA - quality assurance activity

MN - maintenance activity
 IV - invalid

Report generated on: 05/08/2018 10:24

Data is expressed in Standard Time

Data Summary Report

Source: CO LO CGA

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

	CTG1 CO_LOW		CTG2 GEN_GT	
	PPMD	OS MS	MW	OS MS
05/08/2018 10:16	8.7	SU QA	189	SU GD
05/08/2018 10:17	7.0	SU QA	190	SU GD
05/08/2018 10:18	2.4	SU QA	190	SU GD
05/08/2018 10:19	2.1	SU QA	189	SU GD
05/08/2018 10:20	2.1	SU QA	189	SU GD
05/08/2018 10:21	2.0	SU QA	189	SU GD
05/08/2018 10:22	2.6	SU QA	189	SU GD
05/08/2018 10:23	5.1	SU QA	189	SU GD
05/08/2018 10:24	5.3	SU QA	189	SU GD
05/08/2018 10:25	5.3	SU QA	190	SU GD
05/08/2018 10:26	5.3	SU QA	189	SU GD
05/08/2018 10:27			190	SU GD

Average	189
Maximum	190
Minimum	189
Total	7759

OS - Operating Status:
 SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:
 CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Report generated on: 05/08/2018 10:24 Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CO HIGH CGA

	CTG1 CO_HIGH		CTG2 GEN_GT	
	PPMD	OS MS	MW	OS MS
05/08/2018 08:17	747.8	SU QA	189	SU GD
05/08/2018 08:18	757.6	SU QA	190	SU GD
05/08/2018 08:19	755.2	SU QA	190	SU GD
05/08/2018 08:20	752.3	SU QA	190	SU GD
05/08/2018 08:21	1403.7	SU QA	190	SU GD
05/08/2018 08:22	1676.0	SU QA	190	SU GD
05/08/2018 08:23	1679.4	SU QA	190	SU GD
05/08/2018 08:24	1680.8	SU QA	190	SU GD
05/08/2018 08:25	1681.5	SU QA	190	SU GD
05/08/2018 08:26	1241.0	SU QA	190	SU GD
05/08/2018 08:27	760.5	SU QA	190	SU GD
05/08/2018 08:28	759.6	SU QA	190	SU GD
05/08/2018 08:29	754.7	SU QA	190	SU GD
05/08/2018 08:30	1115.9	SU QA	190	SU GD
05/08/2018 08:31	1672.3	SU QA	190	SU GD
05/08/2018 08:32	1676.7	SU QA	190	SU GD
05/08/2018 08:33	1678.0	SU QA	190	SU GD
05/08/2018 08:34	1677.3	SU QA	189	SU GD
05/08/2018 08:35	1649.3	SU QA	189	SU GD
05/08/2018 08:36	873.2	SU QA	189	SU GD
05/08/2018 08:37	758.0	SU QA	189	SU GD
05/08/2018 08:38	758.6	SU QA	189	SU GD
05/08/2018 08:39	758.6	SU QA	189	SU GD
05/08/2018 08:40	1431.2	SU QA	188	SU GD
05/08/2018 08:41	1678.5	SU QA	188	SU GD
05/08/2018 08:42	1678.9	SU QA	188	SU GD
05/08/2018 08:43	1677.1	SU QA	188	SU GD
05/08/2018 08:44	508.9	SU MN	189	SU GD
05/08/2018 08:45			189	SU GD

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation

MS - General Monitor Status:

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

GD - good data
 GO - monitor over range
 QA - quality assurance activity
 MN - maintenance activity
 IV - invalid

Report generated on: 05/08/2018 08:42

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CO HIGH CGA

Average	189
Maximum	190
Minimum	188
Total	5493

OS - Operating Status:

SU - startup mode OFF - off-line
SD - shutdown mode CF - changing fuels
ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data
CC - clean control equipment GO - monitor over range
MD - unknown operating status QA - quality assurance activity

MN - maintenance activity
IV - invalid

Report generated on: 05/08/2018 08:42

Data is expressed in Standard Time

4.3 Cycle/Response Time Data

The following pages contain DAHS printouts and supporting documentation for the cycle/response time checks performed on the gas analyzers. All test results are in accordance with the methods outlined in 40 CFR 75 Appendix A, section 6.4 and 40 CFR 60, Appendix B, PS-4A (as applicable).

Siemens
 CPV Valley Energy Center
 CTG 1
 Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project #: CN50478

Cycle Time - NOx Low Range

Manufacturer: TAPI
 Model: T200M
 Serial Number: 645
 Measurement Span (ppm): 10
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 8.17
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
81.70	OK	CC192317	09/27/20	OK

	Step 1. Monitor Response at Stack Gas (start point)	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change	Step 5. Monitor Response at 95% Step Change (from 1-min)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
<i>Downscale (Stack gas to zero gas)</i>	4.20	10:39	0.00	0.21	0.00	10:41	0:02:00
<i>Upscale (Stack gas to span gas)</i>	4.20	10:48	8.10	7.91	8.10	10:50	0:02:00

Maximum Response Time: 0:02:00

Cycle Time - NOx High Range

Measurement Span (ppm): 100
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 89.52
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
89.52	OK	CC329952	04/06/19	OK

	Step 1. Monitor Response at Stack Gas (start point)	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change	Step 5. Monitor Response Value at Step Change (from 1-min)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
<i>Downscale (Stack gas to zero gas)</i>	43.90	9:12	0.10	2.29	0.20	9:15	0:03:00
<i>Upscale (Stack gas to span gas)</i>	42.80	9:22	87.60	85.36	87.60	9:24	0:02:00

Maximum Response Time: 0:03:00

Analyzer Response (max value from low and high range): 0:03:00

Notes:

Pass/fail criteria = 15 minutes or less (40 CFR 75, Appendix A, Section 3.5)

Stabilized response value = reading with a change < 2% of span value for 2 minutes, or a reading with a change < 6% of the measured average concentration over 6 minutes. Or, reading is considered stable if it changes by no more than 0.5 ppm, or 0.2% CO2/O2 for two minutes.

Downscale: Stable flue gas point "down to" stable zero cal gas point.
 Upscale: Stable flue gas point "up to" stable span cal gas point

Collect 1-minute data from the DAHS and cal gas certs. Send minute data, cal gas certs and spreadsheet to office.

Siemens
CPV Valley Energy Center
CTG 1
Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project #: CN50478

Cycle Time - O2

Manufacturer: **TAPI**
 Model: **T200M**
 Serial Number: **645**
 Measurement Span (ppm): **25**
 Zero Calibration Gas (ppm): **0.00**
 Span Calibration Gas (ppm): **20.93**
 Test Date: **05/08/18**

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
83.72	OK	EB0095428	9/17/2025	OK

	Step 1. Monitor Response at Stack Gas (start point)	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response Value at Step Change (from 1-min data)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
<i>Downscale</i> (Stack gas to zero gas)	13.70	18:11	0.00	0.69	0.00	18:14	0:03:00
<i>Upscale</i> (Stack gas to span gas)	13.90	18:18	20.90	20.55	20.90	18:21	0:03:00

Maximum Response Time **0:03:00**

Notes:

Pass/fail criteria = 15 minutes or less
 (40 CFR 75, Appendix A, Section 3.5)

Stabilized response value = reading with a change < 2% of span value for 2 minutes, or a reading with a change < 6% of the measured average concentration over 6 minutes. Or, reading is considered stable if it changes by no more than 0.5 ppm, or 0.2% CO2/O2 for two minutes.

Downscale: Stable flue gas point "down to" stable zero cal gas point
 Upscale: Stable flue gas point "up to" stable span cal gas point

Collect 1-minute data from the DAHS and cal gas certs. Send minute data, cal gas certs and spreadsheet to office.

Siemens
 CPV Valley Energy Center
 CTG 1
 Middletown, NY

Tested by: Justin Saporito
 Company: Cemtek KVB-Enertec
 Project #: CN50478

Cycle Time - CO Low Range

40 CFR 60, PS-4A

Manufacturer: TAPI
 Model: T300M
 Serial Number: 355
 Measurement Span (ppm): 10
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 8.78
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
87.80	OK	CC192317	09/26/20	OK

	Step 1. Monitor Response at start point	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response Value at Step Change (from 1-min data)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
Zero to Span Cal Gas 1 (upscale)	0.00	11:27:00	8.70	8.27	8.60	11:29:00	0:02:00
Span to Zero Cal Gas 1 (downscale)	8.70	11:30:00	0.00	0.44	0.00	11:33:00	0:03:00
Zero to Span Cal Gas 2 (upscale)	0.00	11:33:00	8.70	8.27	8.40	11:35:00	0:02:00
Span to Zero Cal Gas 2 (downscale)	8.70	11:36:00	0.00	0.44	0.00	11:39:00	0:03:00
Zero to Span Cal Gas 3 (upscale)	0.20	11:40:00	8.70	8.28	8.70	11:42:00	0:02:00
Span to Zero Cal Gas 3 (downscale)	8.70	11:44:00	0.00	0.44	0.20	11:46:00	0:02:00

Average of Zero Gas Runs	0:02:00
Average of High Gas Runs	0:02:40
Longest Response Time	0:02:40

Cycle Time - CO High Range

40 CFR 60, PS-4A

Measurement Span (ppm): 3000
 Zero Calibration Gas (ppm): 0.00
 Span Calibration Gas (ppm): 2635.00
 Test Date: 05/08/18

Pass

% of Span	% Span Status	Bottle #	Exp. Date	Date Check
87.83	OK	EB0095428	09/19/25	OK

	Step 1. Monitor Response at start point	Step 2. DAHS Time @ Step 1	Step 3. Monitor Response to Cal Gas Injection (end point)	Step 4. 95% of Step Change (calculated)	Step 5. Monitor Response Value at Step Change (from 1-min data)	Step 6. DAHS Time @ Step 5	Step 7. Cycle Time (calculated)
Zero to Span Cal Gas 1 (upscale)	0.00	8:49:00	2638.00	2506.10	2637.50	8:51:00	0:02:00
Span to Zero Cal Gas 1 (downscale)	2636.50	8:53:00	0.40	132.21	1.10	8:55:00	0:02:00
Zero to Span Cal Gas 2 (upscale)	0.40	8:56:00	2633.70	2502.04	2630.50	8:58:00	0:02:00
Span to Zero Cal Gas 2 (downscale)	2633.70	8:59:00	0.00	131.69	7.00	9:01:00	0:02:00
Zero to Span Cal Gas 3 (upscale)	0.40	9:04:00	2634.40	2502.70	2608.70	9:06:00	0:02:00
Span to Zero Cal Gas 3 (downscale)	2636.70	9:15:00	0.00	131.84	1.80	9:17:00	0:02:00

Average of Zero Gas Runs	0:02:00
Average of High Gas Runs	0:02:00
Longest Response Time	0:02:00
Analyzer Response Time	0:02:40

Notes:

Analyzer response time pass/fail criteria = 240 seconds (4 minutes or less (40 CFR 60, PS-4A per eCFR))
 The longest average from the two ranges is reported as the analyzer response time.
 Performed as a remote (at the probe) cal gas injection.
 Collect 1-minute data

Test sequence:

Zero cal gas "up to" span cal gas (upscale)
 Span cal gas "down to" zero cal gas (downscale)
 3 upscale runs and 3 downscale runs

Data Summary Report

Source: NOX L LIN

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG2 GEN_GT CTG1 NOX_LOW_P75

	MW	OS	MS	PPMD	OS	MS	
05/08/2018 10:35	190	SU	GD	4.3	SU	MN	
05/08/2018 10:36	190	SU	GD	4.3	SU	MN	
05/08/2018 10:37	190	SU	GD	4.2	SU	MN	
05/08/2018 10:38	190	SU	GD	4.2	SU	MN	
05/08/2018 10:39	189	SU	GD	4.2	SU	QA	
05/08/2018 10:40	189	SU	GD	0.4	SU	QA	
05/08/2018 10:41	189	SU	GD	0.5/b	0.0	SU	QA
05/08/2018 10:42	189	SU	GD	0.0	SU	QA	
05/08/2018 10:43	189	SU	GD	0.0	SU	QA	
05/08/2018 10:44	189	SU	GD	0.0	SU	QA	
05/08/2018 10:45	189	SU	GD	0.0	SU	QA	
05/08/2018 10:46	189	SU	GD	3.8	SU	MN	
05/08/2018 10:47	189	SU	GD	4.2	SU	MN	
05/08/2018 10:48	189	SU	GD	4.2	SU	QA	
05/08/2018 10:49	189	SU	GD	4.3	SU	QA	
05/08/2018 10:50	189	SU	GD	8.1	SU	QA	
05/08/2018 10:51	189	SU	GD	8.1	SU	QA	
05/08/2018 10:52	189	SU	GD	8.0	SU	QA	
05/08/2018 10:53	190	SU	GD	8.0	SU	MN	
05/08/2018 10:54	190	SU	GD	5.1	SU	MN	
05/08/2018 10:55	190	SU	GD	4.2	SU	MN	
05/08/2018 10:56	190	SU	GD	4.2	SU	GD	
05/08/2018 10:57	190	SU	GD	4.1	SU	GD	
05/08/2018 10:58	189	SU	GD	4.0	SU	GD	
05/08/2018 10:59	190	SU	GD	4.0	SU	GD	
Average	189			4.1			
Maximum	190			4.2			

OS - Operating Status:
 SU - startup mode OFF - off-line CP - clean process equipment GD - good data MN - maintenance activity
 SD - shutdown mode CF - changing fuels CC - clean control equipment GO - monitor over range IV - invalid
 ON - normal operation CM - control equipment malfunction MD - unknown operating status QA - quality assurance activity

MS - General Monitor Status:
 GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Report generated on: 05/08/2018 11:15 Data is expressed in Standard Time

Data Summary Report

Source: NOX- RESPONSE

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG1 GEN_ST CTG1 NOX_HIGH_P75 CTG1 OIL_FLOW_EPA

	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS
05/09/2018 09:10	0	SU	GD	44.2	SU	GD	63000	SU	GD
05/09/2018 09:11	0	SU	GD	44.3	SU	GD	63000	SU	GD
05/09/2018 09:12	0	SU	GD	43.9	SU	GD	64000	SU	GD
05/09/2018 09:13	0	SU	GD	43.1	SU	QA	64000	SU	GD
05/09/2018 09:14	0	SU	GD	35.8	SU	QA	64000	SU	GD
05/09/2018 09:15	0	SU	GD	0.5% 0.2	SU	QA	64000	SU	GD
05/09/2018 09:16	0	SU	GD	0.1	SU	QA	64000	SU	GD
05/09/2018 09:17	0	SU	GD	0.1	SU	QA	64000	SU	GD
05/09/2018 09:18	0	SU	GD	0.1	SU	QA	64000	SU	GD
05/09/2018 09:19	0	SU	GD	3.6	SU	MIN	64000	SU	GD
05/09/2018 09:20	0	SU	GD	42.8	SU	MIN	64000	SU	GD
05/09/2018 09:21	0	SU	GD	42.6	SU	MIN	64000	SU	GD
05/09/2018 09:22	0	SU	GD	42.8	SU	QA	65000	SU	GD
05/09/2018 09:23	0	SU	GD	50.7	SU	QA	68000	SU	GD
05/09/2018 09:24	0	SU	GD	87.6% 85%	SU	QA	69000	SU	GD
05/09/2018 09:25	0	SU	GD	87.7	SU	QA	71000	SU	GD
Average	0			44.1			64938		
Maximum	0			44.3			71000		
Minimum	0			43.9			63000		
Total	0			132.4			1039000		

OS - Operating Status:
 SU - startup mode OFF - off-line CP - clean process equipment GD - good data MN - maintenance activity
 SD - shutdown mode CF - changing fuels CC - clean control equipment GO - monitor over range IV - invalid
 ON - normal operation CM - control equipment malfunction MD - unknown operating status QA - quality assurance activity

MS - General Monitor Status:
 Data is expressed in Standard Time

Report generated on: 05/09/2018 09:22

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 CO_LOW

Time	PPMD	OS	MS
05/10/2018 11:20	10.0	OFF	MN
05/10/2018 11:21	10.0	OFF	MN
05/10/2018 11:22	9.6	OFF	MN
05/10/2018 11:23	9.2	OFF	MN
05/10/2018 11:24	8.5	OFF	QA
05/10/2018 11:25	2.5	OFF	QA
05/10/2018 11:26	0.0	OFF	QA
05/10/2018 11:27	0.0	OFF	QA START
05/10/2018 11:28	3.0	OFF	QA
05/10/2018 11:29	8.6	OFF	QA - 95%
05/10/2018 11:30	8.7	OFF	QA START
05/10/2018 11:31	6.9	OFF	QA
05/10/2018 11:32	0.5	OFF	QA
05/10/2018 11:33	0.0	OFF	QA - 95% START
05/10/2018 11:34	2.0	OFF	QA
05/10/2018 11:35	8.4	OFF	QA - 95%
05/10/2018 11:36	8.7	OFF	QA
05/10/2018 11:37	7.8	OFF	QA
05/10/2018 11:38	1.2	OFF	QA
05/10/2018 11:39	0.0	OFF	QA - 95%
05/10/2018 11:40	0.2	OFF	QA START
05/10/2018 11:41	6.4	OFF	QA
05/10/2018 11:42	8.7	OFF	QA 95%
05/10/2018 11:43	8.7	OFF	QA 95%
05/10/2018 11:44	8.7	OFF	QA
05/10/2018 11:45	6.0	OFF	QA
05/10/2018 11:46	0.2	OFF	QA ✓
05/10/2018 11:47	0.0	OFF	QA
05/10/2018 11:48	0.1	OFF	QA

OS - Operating Status:

- SU - startup mode
- SD - shutdown mode
- ON - normal operation
- OFF - off-line
- CF - changing fuels
- CM - control equipment malfunction

MS - General Monitor Status:

- CP - clean process equipment
- CC - clean control equipment
- MD - unknown operating status
- GD - good data
- GO - monitor over range
- QA - quality assurance activity
- MN - maintenance activity
- IV - invalid

Report generated on: 05/10/2018 11:58

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

CTG1 CO_LOW

	PPMD	OS	MS
05/10/2018 11:49	6.1	OFF	QA
05/10/2018 11:50	8.7	OFF	QA
05/10/2018 11:51	8.7	OFF	QA
05/10/2018 11:52	8.6	OFF	QA
05/10/2018 11:53	8.6	OFF	QA
05/10/2018 11:54	3.3	OFF	QA
05/10/2018 11:55	0.0	OFF	QA
05/10/2018 11:56	0.0	OFF	QA
05/10/2018 11:57	0.0	OFF	QA
05/10/2018 11:58	5.2	OFF	QA
05/10/2018 11:59	8.6	OFF	QA
05/10/2018 12:00	8.6	OFF	QA
05/10/2018 12:01	8.4	OFF	MIN

Average
Maximum
Minimum
Total

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

Report generated on: 05/10/2018 11:58

MS - General Monitor Status:

CP - clean process equipment GD - good data
 CC - clean control equipment GO - monitor over range
 MD - unknown operating status QA - quality assurance activity

Data is expressed in Standard Time

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CO HIGH RESPONSE

CTG1 CO_HIGH CTG2 GEN_GT

	PPMD	OS	MS	MW	OS	MS
05/08/2018 08:41	1678.5	SU	QA	188	SU	GD
05/08/2018 08:42	1678.9	SU	QA	188	SU	GD
05/08/2018 08:43	1677.1	SU	QA	188	SU	GD
05/08/2018 08:44	508.9	SU	MN	189	SU	GD
05/08/2018 08:45	1.2	SU	MN	189	SU	GD
05/08/2018 08:46	-0.3	SU	MN	189	SU	GD
05/08/2018 08:47	-0.5	SU	MN	189	SU	GD
05/08/2018 08:48	0.1	SU	MN	188	SU	GD
05/08/2018 08:49	0.0	SU	QA	188	SU	GD
05/08/2018 08:50	1898.5	SU	QA	188	SU	GD
05/08/2018 08:51	2637.5	SU	QA	188	SU	GD
05/08/2018 08:52	2638.0	SU	QA	189	SU	GD
05/08/2018 08:53	2636.5	SU	QA	189	SU	GD
05/08/2018 08:54	633.8	SU	QA	189	SU	GD
05/08/2018 08:55	-1.1	SU	QA	189	SU	GD
05/08/2018 08:56	0.4	SU	QA	188	SU	GD
05/08/2018 08:57	1843.6	SU	QA	188	SU	GD
05/08/2018 08:58	2630.5	SU	QA	188	SU	GD
05/08/2018 08:59	2633.7	SU	QA	188	SU	GD
05/08/2018 09:00	1214.7	SU	QA	188	SU	GD
05/08/2018 09:01	-7.0	SU	QA	189	SU	GD
05/08/2018 09:02	-0.4	SU	QA	189	SU	GD
05/08/2018 09:03	0.0	SU	QA	190	SU	GD
05/08/2018 09:04	0.4	SU	QA	190	SU	GD
05/08/2018 09:05	825.2	SU	QA	190	SU	GD
05/08/2018 09:06	2608.7	SU	QA	190	SU	GD
05/08/2018 09:07	2634.4	SU	QA	190	SU	GD
05/08/2018 09:08	2089.0	SU	QA	190	SU	GD
05/08/2018 09:09	86.5	SU	QA	190	SU	GD

OS - Operating Status:

SU - startup mode
 SD - shutdown mode
 ON - normal operation

MS - General Monitor Status:

GD - good data
 GO - monitor over range
 QA - quality assurance activity

Report generated on: 05/08/2018 09:19

Data is expressed in Standard Time

Data Summary Report

Source: CO HIGH RESPONSE

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

	CTG1 CO_HIGH		CTG2 GEN_GT	
	PPMD	OS MS	MW	OS MS
05/08/2018 09:10	0.4	SU QA	190	SU GD
05/08/2018 09:11	393.6	SU QA	190	SU GD
05/08/2018 09:12	2518.0	SU QA	190	SU GD
05/08/2018 09:13	2632.1	SU QA	190	SU GD
05/08/2018 09:14	2635.3	SU QA	190	SU GD
05/08/2018 09:15	2636.7	SU QA	190	SU GD
05/08/2018 09:16	661.6	SU QA	190	SU GD
05/08/2018 09:17	1.8	SU QA	190	SU GD
05/08/2018 09:18	0.0	SU QA	190	SU GD
05/08/2018 09:19	1079.8	SU QA	190	SU GD
05/08/2018 09:20	2620.5	SU QA	190	SU GD
05/08/2018 09:21	2634.3	SU QA	190	SU GD
05/08/2018 09:22	2634.7	SU QA	190	SU GD

Average	189
Maximum	190
Minimum	188
Total	7946

OS - Operating Status:
 SU - startup mode OFF - off-line CP - clean process equipment GD - good data MN - maintenance activity
 SD - shutdown mode CF - changing fuels CC - clean control equipment GO - monitor over range IV - invalid
 ON - normal operation CM - control equipment malfunction MD - unknown operating status QA - quality assurance activity

MS - General Monitor Status:
 Data is expressed in Standard Time

Report generated on: 05/08/2018 09:19

Data Summary Report

Source: CTG1

Location: Middletown, NY

Facility Name: CPV_Valley_Wawayanda

CTG1 OIL_FLOW_EPA CTG1 O2_P75

Date	LBHR	OS	MS	PCT	OS	MS
05/09/2018 18:08	93000	SU	GD	13.7	SU	GD
05/09/2018 18:09	92000	SU	GD	13.7	SU	GD
05/09/2018 18:10	92000	SU	GD	13.7	SU	GD
05/09/2018 18:11	90000	SU	GD	13.7	SU	QA
05/09/2018 18:12	84000	SU	GD	0.9	SU	QA
05/09/2018 18:13	78000	SU	GD	0.0	SU	QA
05/09/2018 18:14	74000	SU	GD	0.0	SU	QA
05/09/2018 18:15	71000	SU	GD	0.0	SU	QA
05/09/2018 18:16	68000	SU	GD	1.1	SU	MN
05/09/2018 18:17	64000	SU	GD	13.7	SU	MN
05/09/2018 18:18	59000	SU	GD	13.9	SU	MN
05/09/2018 18:19	56000	SU	GD	14.2	SU	QA
05/09/2018 18:20	53000	SU	GD	18.4	SU	QA
05/09/2018 18:21	49000	SU	GD	20.9	SU	QA
05/09/2018 18:22	44000	SU	GD	20.9	SU	QA
05/09/2018 18:23	40000	SU	GD	18.2	SU	MN
05/09/2018 18:24	37000	SU	GD	15.2	SU	MN
05/09/2018 18:25	36000	SU	GD	15.4	SU	MN
05/09/2018 18:26	31000	SU	GD	15.7	SU	GD
Average	63737			14.2		
Maximum	93000			15.7		
Minimum	31000			13.7		
Total	1211000			56.8		

OS - Operating Status:

- SU - startup mode
- SD - shutdown mode
- ON - normal operation
- OFF - off-line
- CF - changing fuels
- CM - control equipment malfunction

MS - General Monitor Status:

- GD - good data
- GO - monitor over range
- QA - quality assurance activity
- CP - clean process equipment
- CC - clean control equipment
- MD - unknown operating status
- MN - maintenance activity
- IV - invalid

Report generated on: 05/09/2018 18:23

Data is expressed in Standard Time

4.4 Calibration Gas Certificates

The following attached pages contain copies of the calibration gas certificates representing the cylinder bottles used during the test program.

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E04NI95E15A0029	Reference Number:	82-400992455-1
Cylinder Number:	CC192317	Cylinder Volume:	146.4 CF
Laboratory:	124 - Riverton (SAP) - NJ	Cylinder Pressure:	2015 PSIG
PGVP Number:	B52017	Valve Outlet:	660
Gas Code:	CO,CO2,NO,NOX,BALN	Certification Date:	Sep 26, 2017

Expiration Date: Sep 26, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.170 PPM	G1	+/- 1.2% NIST Traceable	09/19/2017, 09/26/2017
CARBON MONOXIDE	9.000 PPM	8.778 PPM	G1	+/- 0.7% NIST Traceable	09/19/2017
NITRIC OXIDE	9.000 PPM	8.036 PPM	G1	+/- 1.1% NIST Traceable	09/19/2017, 09/26/2017
CARBON DIOXIDE	4.000 %	4.076 %	G1	+/- 0.5% NIST Traceable	09/19/2017
NITROGEN	Balance			-	

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060728	CC437497	10.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 28, 2018
NTRM	16060728	CC437497-NOX	10.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 28, 2018
NTRM	10060122	CC281392	5.027 % CARBON DIOXIDE/NITROGEN	+/- 0.4%	Oct 02, 2021

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA 510-CO2-19GYCXEG	NDIR	Aug 31, 2017
Thermo 48i-TLE-CO-1133350708	NDIR	Aug 25, 2017
Thermo 42i-LS-NO-1123749326	Chemiluminescence	Sep 22, 2017
Thermo 42i-LS-NOx-1123749326	Chemiluminescence	Sep 22, 2017

Triad Data Available Upon Request



Signature on file
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI95E15A0019	Reference Number: 82-401041129-1
Cylinder Number: CC329952	Cylinder Volume: 146.4 CF
Laboratory: 124 - Riverton (SAP) - NJ	Cylinder Pressure: 2015 PSIG
PGVP Number: B52017	Valve Outlet: 660
Gas Code: CO2,NO,NOX,BALN	Certification Date: Nov 17, 2017

Expiration Date: Nov 17, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	90.00 PPM	89.52 PPM	G1	+/- 1.0% NIST Traceable	11/10/2017, 11/17/2017
NITRIC OXIDE	90.00 PPM	89.05 PPM	G1	+/- 1.0% NIST Traceable	11/10/2017, 11/17/2017
CARBON DIOXIDE	4.000 %	4.009 %	G1	+/- 1.0% NIST Traceable	11/10/2017
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010402	KAL003271	97.6 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/AIR	+/- 2.0%	Jun 02, 2017
GMIS	0315201604	CC503358	4.975 PPM NITROGEN DIOXIDE/NITROGEN	+/- 1.6%	Mar 15, 2019
NTRMplus	10060137	CC307784	5.027 % CARBON DIOXIDE/NITROGEN	+/- 0.4%	Dec 02, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 APW1100391 CO2	FTIR	Nov 06, 2017
Nicolet 6700 APW1100391 NO	FTIR	Oct 27, 2017
Nicolet 6700 APW1100391 NO2	FTIR	Oct 30, 2017

Triad Data Available Upon Request



Signature on file
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E04NI69E15A0002 Reference Number: 82-400992440-1
 Cylinder Number: EB0095428 Cylinder Volume: 151.5 CF
 Laboratory: 124 - Riverton (SAP) - NJ Cylinder Pressure: 2015 PSIG
 PGVP Number: B52017 Valve Outlet: 590
 Gas Code: CO,CO2,O2,BALN Certification Date: Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	2700 PPM	2635 PPM	G1	+/- 1.0% NIST Traceable	09/19/2017
CARBON DIOXIDE	9.000 %	8.824 %	G1	+/- 0.7% NIST Traceable	09/19/2017
OXYGEN	21.00 %	20.93 %	G1	+/- 0.5% NIST Traceable	09/19/2017
NITROGEN	Balance			-	

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12060724	CC356171	2498 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Dec 21, 2017
NTRM	13060408	CC412683	7.489 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 14, 2019
NTRM	09061415	CC273526	22.53 % OXYGEN/NITROGEN	+/- 0.4%	Mar 08, 2019

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA 510-CO2-19GYCXEG	NDIR	Aug 31, 2017
Siemens Ultramat 6 J3-599 COHIGH	NDIR	Sep 15, 2017
Horiba MPA 510-O2-7TWMJ041	Paramagnetic	Aug 31, 2017

Triad Data Available Upon Request



Signature on file
Approved for Release

CO-NOX-L



Assay Laboratory: Red Ball TGS
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8153

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0072315	Certification Date:	07/05/2017
Product ID Number:	124743	Expiration Date:	07/04/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport-LA
COA #:	EB0072315.20170613-0	Lot Number:	EB0072315.20170513
Customer PO. NO.:		Tracking Number:	084249967
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-800/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	2.67 PPM	±0.02 PPM	FTIR	06/30/2017
Nitric Oxide	2.4208 PPM	±0.0009 PPM	Chemluminescence	06/19/2017, 06/28/2017, 07/05/2017
Total Oxides of Nitrogen	2.5177 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003154	EB0003154.20150721	01/11/2025	GMS	N2	CO	12.16 PPM	1.033	091002
EB0005432	EB0005432.20150721	01/10/2025	GMS	N2	CO	13.83 PPM	1.014	091002
EB0052431	EB0052431.20151012	01/21/2019	GMS	N2	NO	5.739 PPM	1.012	2828a
		11/23/2016			NO	5.32 PPM		281902

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
NO	Chemluminescence	Thermo	T42C	42C-63400-360	06/12/2017
CO	FTIR	MKS	MKS 2331D322XYS13T	07745467	06/30/2017

Red Ball Technical Gas Service
 PGVP Vendor ID # G12017
 Information and Ordering
 800-551-8150
 Fax (318-425-6309)



Nata Fielder
 Nata Fielder
 Analyst

This is to certify the gases referenced have been calibrated/checked, and verified to meet the defined specifications. This calibration/checked was performed using Gases or Solutions that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibrating process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.



Red Ball Technical Gas Service *CO-VOX 2*
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number: EB0101725
 Product ID Number: 124744
 Cylinder Pressure: 1900 PSIG
 COA #: EB0101725.20171114-0
 Customer PO. NO.:
 Customer:

Certification Date: 12/04/2017
 Expiration Date: 12/03/2020
 MFG Facility: - Shreveport - LA
 Lot Number: EB0101725.20171114
 Tracking Number: 095707020
 Previous Certification Dates:

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	5.66 PPM	±0.07 PPM	FTIR	11/24/2017
Nitric Oxide	5.09 PPM	±0.06 PPM	Chemiluminescence	11/20/2017, 11/27/2017, 12/04/2017
Total Oxides of Nitrogen	5.19 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM034813	ALM034813.20160913	09/01/2020	GMIS	N2	NO	15.5 PPM	1.079	12100115
EB0003194	EB0003194.20160721	01/11/2025	GMIS	N2	CO	12.16 PPM	1.033	091002
EB0052431	EB0052431.20151012g	01/21/2019	GMIS	N2	NO	5.799 PPM	1.012	2622a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	11/20/2017
CO	FTIR	MKS	MKS 2031DJ2EKVS13T	017146467	11/24/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
 Anthony Cyr
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service *NOX-H*
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0073000	Certification Date:	03/19/2018
Product ID Number:	125416	Expiration Date:	03/18/2021
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0073000.20180228-0	Lot Number:	EB0073000.20180228
Customer PO. NO.:		Tracking Number:	084247373
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	24.7 PPM	±0.14 PPM	FTIR	03/06/2018
Nitric Oxide	24.6 PPM	±0.3 PPM	Chemiluminescence	03/05/2018, 03/12/2018, 03/19/2018
Total Oxides of Nitrogen	24.7 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC-349582	12100115CC-349582	07/22/2019	NTRM	N2	NO	95.2 PPM	1.05	12100115
ALM022135	ALM022135.20160913	02/07/2021	GMIS	N2	NO	15.2 PPM	1.103	12100115
CC349576	CC349576.20170821	12/03/2025	GMIS	N2	NO	294 PPM	0.451	2735
EB0026633	EB0026633.20160718	01/19/2025	GMIS	N2	NO	93.67 PPM	1.054	12100115
EB0055450	EB0055450.20140403-0	12/21/2020	GMIS	N2	NO	32.02 PPM	1.058	12100115
EB0087668	EB0087668.20160721	10/30/2025	GMIS	N2	CO	202.6 PPM	0.395	1681B
EB0087736	EB0087736.20160721	10/30/2025	GMIS	N2	CO	202.6 PPM	0.395	1681B

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-88400-360	02/08/2018
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	02/14/2018
NO	Chemiluminescence	Thermo	42i-HL	1162380008	02/13/2018
NO	Chemiluminescence	Thermo	42i-HL	1162380008	03/16/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
 Analyst
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07

NOX-11

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number: E02NI99E15A0147
Cylinder Number: CC 503502
Laboratory: 124 - Durham (SAP) - NC
PGVP Number: B22017
Gas Code: NO,NOX,BALN

Reference Number: 122-401038758-1
Cylinder Volume: 144.3 Cubic Feet
Cylinder Pressure: 2015 PSIG
Valve Outlet: 660
Certification Date: Nov 01, 2017

Expiration Date: Nov 01, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" (document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.


ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.89 PPM	G1	+/- 1.3% NIST Traceable	10/24/2017, 11/01/2017
NITRIC OXIDE	50.00 PPM	50.65 PPM	G1	+/- 1.1% NIST Traceable	10/24/2017, 11/01/2017
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060610	CC442587	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/AIR	+/- 1.5%	May 29, 2018
NTRM	16060655	CC485081	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
GMS	1114201803	CC508722	4.995 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 8700 AHR0801549 NO	FTIR	Oct 26, 2017
Nicolet 8700 AHR0801549 NO	FTIR	Oct 26, 2017

Triad Data Available Upon Request



[Signature]
Approved for Release



HiQ® Certificate / Certificat HiQ®

02
LINDE CANADA LIMITED

530 Watson St. East
Whitby, ON, Canada L1N 5R9

CERTIFICATE OF ANALYSIS

EPA PROTOCOL MIXTURE

Purchase order # 110585036

Lot # 1263941

Cylinder Number: EB 0049201

PGVP ID # L12013

Procedure: G1

Gas Type Code: OC2

Cylinder pressure: 2000 psig

Certification date

August 12, 2013

Expiration Date

August 13, 2021

ANALYTICAL RESULTS

Component	Requested Concentration <small>± Blending tolerance</small>	Date of Assay	Mean Concentration	Certified Concentration <small>Uncertainty expressed at 95% confidence</small>
Carbon Dioxide	5 % ± 5%	August 12, 2013	5.07 %	5.07 ± 0.02 %
Oxygen	6 % ± 5%	August 9, 2013	6.36 %	6.36 ± 0.01 %

BALANCE GAS: Nitrogen

REFERENCE STANDARDS

Component	Type	Serial Number	Reference Number	Concentration	Expiration Date
Carbon Dioxide	GMIS	SX 21992	1187915	10 ± 0.02 %	August 20, 2013
	NTRM	SG 9916842	101001	19.98 ± 0.14 %	April 15, 2016
Oxygen	GMIS	SX 31579	1107503	9.975 ± 0.06 %	August 18, 2013
	NTRM	CC 237234	071001	24.12 ± 0.12 %	March 27, 2017

CERTIFICATION INSTRUMENTS

Component	Make/Model	Measurement Principle	Serial Number	Last Calibration
Carbon Dioxide	SICK MCS 100E	Infrared Photometer	04310670	August 1, 2013
Oxygen	Servomex 04100 C1	Paramagnetic Sensor	392350	August 9, 2013

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE 2012 EPA PROTOCOL PROCEDURE

DO NOT USE THIS CYLINDER WHEN THE PRESSURE FALLS BELOW 100 PSIG

Analyst: Keith Cybulski Signature

Date 08/12/13

Notes:



Rod Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

02

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0060674	Certification Date:	04/06/2018
Product ID Number:	126054	Expiration Date:	04/04/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0060674.20180402-0	Lot Number:	EB0060674.20180402
Customer PO. NO.:		Tracking Number:	082989800
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Oxygen	13.82 %	±0.07 %	MPA	04/06/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0019964	EB0019964.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0032313	EB0032313.20170112	05/22/2025	GMIS	N2	O2	9.34 %	0.235	2658a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	4101	1162980025	03/26/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
 Analyst

Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

CO-11

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number: EB0040994
 Product ID Number: 127179
 Cylinder Pressure: 1900 PSIG
 COA #: EB0040994.20180402-0
 Customer PO. NO.:
 Customer:

Certification Date:
 Expiration Date:
 MFG Facility:
 Lot Number:
 Tracking Number:
 Previous Certification Dates:

04/06/2018
 04/04/2026
 - Shreveport - LA
 EB0040994.20180402
 065159615

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	753 PPM	±6 PPM	FTIR	04/06/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0016838	EB0016839.20161027	03/17/2026	GMIS	N2	CO	2310 PPM	0.5%	2640a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/05/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder
 Nate Fielder
 Analyst
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Rod Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

CO-4

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0072144	Certification Date:	04/06/2018
Product ID Number:	127180	Expiration Date:	04/04/2028
Cylinder Pressure:	1500 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0072144.20180402-0	Lot Number:	EB0072144.20180402
Customer PO. NO.:		Tracking Number:	084214278
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Component	Certified Concentration(s)			Assayed On
	Concentration	Uncertainty	Analytical Principle	
Carbon Monoxide	1670 PPM	±17 PPM	FTIR	04/06/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0035550	EB0035550.20161027	03/17/2026	GMIS	N2	CO	1514 PPM	0.568	2610A

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/06/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07

CERTIFICATE OF ANALYSIS

Grade of Product: CEM-CAL ZERO

Part Number:	NI CZ15A	Reference Number:	82-400984857-1
Cylinder Number:	CC307646	Cylinder Volume:	142.0 CF
Laboratory:	124 - Riverton (SAP) - NJ	Cylinder Pressure:	2000 PSIG
Analysis Date:	Aug 22, 2017	Valve Outlet:	580
Lot Number:	82-400984857-1		

Expiration Date: Aug 22, 2025

ANALYTICAL RESULTS

Component	Requested Purity	Certified Concentration
NITROGEN	99.9995 %	99.9995 %
CARBON DIOXIDE	< 1.0 PPM	<LDL 0.06 PPM
NOx	< 0.1 PPM	<LDL 0.02 PPM
SO2	< 0.1 PPM	<LDL 0.10 PPM
THC	< 0.1 PPM	<LDL 0.02 PPM
CARBON MONOXIDE	< 0.5 PPM	0.160 PPM

Permanent Notes: Airgas certifies that the contents of this cylinder meet the requirements of 40 CFR 72.2

Impurities verified against analytical standards traceable to NIST by weight and/or analysis.

Signature on file
Approved for Release

5 Relative Accuracy Test Audit

The full RATA report, provided by Air Hygiene Inc., is attached.



AIR HYGIENE, INC.

Testing Solutions for a Better World

RELATIVE ACCURACY TEST AUDIT
FOR THE
SIEMENS, SCC6-5000F, UNIT #1 CEMS
PREPARED FOR
CPV VALLEY LLC
AT THE
CPV VALLEY ENERGY CENTER
MIDDLETOWN, NEW YORK
MAY 8-9, 2018



Corporate Headquarters

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012



AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices


Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

**RELATIVE ACCURACY TEST AUDIT
FOR THE
SIEMENS, SCC6-5000F, UNIT #1 CEMS
PREPARED FOR
CPV VALLEY LLC
AT THE
CPV VALLEY ENERGY CENTER
MIDDLETOWN, NEW YORK
MAY 8-9, 2018**

Prepared and Reviewed by:



Michael Whisenhunt, QSTI
Sr. Project Manager



Logan Tsotsoros
AHU Support Staff

I, 

Michael Stockwell, QSTI
Sr. Project Manager

certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

Table of Contents

1.0	INTRODUCTION	1
1.1	TEST PURPOSE AND OBJECTIVES	1
1.2	SUMMARY OF TEST PROGRAM	2
1.2.1	Participating Organizations	2
1.2.2	Industry	2
1.2.3	Air Permit and Federal Requirements	2
1.2.4	Plant Location	2
1.2.5	Equipment Tested	2
1.2.6	Emission Points	2
1.2.7	Emission Parameters Measured	2
1.2.8	Dates of Emission Test	2
1.2.9	Federal and State Certifications	3
1.3	KEY PERSONNEL	3
2.0	SUMMARY OF TEST RESULTS	3
3.0	SOURCE OPERATION	5
3.1	PROCESS DESCRIPTION	5
3.2	SAMPLING LOCATION	5
4.0	SAMPLING AND ANALYTICAL PROCEDURES	5
4.1	TEST METHODS	5
4.2	INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS	6

APPENDICES

Appendix A	Test Results and Calculations
Appendix B	CEMS and Reference Method Data
Appendix C	Calibration Gas Certifications
Appendix D	Quality Assurance and Quality Control Data
Appendix E	Fuel Analysis Records
Appendix F	Stratification Test Data

Relative Accuracy Test Audit
Siemens, SCC6-5000F, Unit #1 CEMS
CPV VALLEY LLC
CPV VALLEY ENERGY CENTER
Middletown, New York
May 8-9, 2018

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Relative Accuracy Test Audit (RATA) for nitrogen oxides (NO_x), carbon monoxide (CO), and oxygen (O₂) from the exhaust of the Siemens, SCC6-5000F, Unit #1 for CPV VALLEY LLC at the CPV VALLEY ENERGY CENTER near Middletown, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on May 8-9, 2018.

The accumulated data from the RATA provides the figures for evaluating the acceptability of the operation of the on-site continuous emission monitoring system (CEMS) for the monitoring of NO_x, CO, and O₂ from the Siemens, SCC6-5000F, Unit #1 for CPV VALLEY LLC at the CPV VALLEY ENERGY CENTER near Middletown, New York.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to perform the initial certification RATA on the CEMS that serves the Siemens, SCC6-5000F, Unit #1 for CPV VALLEY LLC at the CPV VALLEY ENERGY CENTER near Middletown, New York. Reference method (RM) testing followed the Code of Federal Regulations (CFR), Title 40 (40 CFR), Part 60 (40 CFR 60), Appendix A, Methods 1, 3A, 7E, 10, and 19. RM values are compared with the on-site CEMS to document performance as required in the 40 CFR 60, Appendix B, Performance Specifications (PS) and 40 CFR 75 Appendix A and B. All relative accuracies were established on-site and were governed by the following sets of rules:

In accordance with 40 CFR 60, Appendix B, PS 2, Section 13.2, the NO_x RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent when average emissions during the test are greater than 50 percent of the emission standard or alternative relative accuracy (ARA) does not exceed 10.0 percent when the average emissions during the test are less than 50 percent of the emission standard. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

In accordance with 40 CFR 75, Appendix A, Section 3.3.2(a) and (b), the NO_x RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average NO_x emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and reference method (RM) values does not exceed 0.020 lb/MMBtu. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (f), and Appendix B, Figure 2, the NO_x RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average NO_x emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and RM values does not exceed 0.015 lb/MMBtu. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 3, Section 13.2, the O₂ RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent or if the average difference between the CEMS and reference method (RM) values does not exceed plus or minus 1.0 percent of the measured value.

In accordance with 40 CFR 75, Appendix A, Section 3.3.3, the O₂ RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average difference between the CEMS and reference method (RM) values does not exceed 1.0 percent. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (h), and Appendix B, Figure 2, the O₂ RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average difference between the CEMS and RM values does not exceed 0.7 percent absolute. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 4 and 4A, Sections 13.2 of each, the CO relative accuracy (RA) test results are acceptable if the RA does not exceed 10.0 percent, if the average difference between the CEMS and reference method (RM) values plus the 2.5 percent confidence coefficient (2.5%CC) does not exceed 5.0 parts per million (ppm), or if the alternative relative accuracy (ARA) does not exceed 5.0 percent. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

- 1.2.1 Participating Organizations
 - New York State Department of Environmental Conservation (NYDEC)
 - CPV VALLEY LLC
 - Air Hygiene
- 1.2.2 Industry
 - Electric Utility / Electric Services
- 1.2.3 Air Permit and Federal Requirements
 - Permit Number: 3-3356-00136/00001
 - 40 CFR 60, Appendix B, Performance Specifications (PS)
 - 40 CFR 75, Appendix A
 - 40 CFR 75, Appendix B
- 1.2.4 Plant Location
 - CPV VALLEY ENERGY CENTER near Middletown, New York
 - GPS Coordinates [Latitude 41.413, Longitude -74.435]
 - Federal Registry System / Facility Registry Service (FRS) No. – 110043332471
 - Source Classification Code (SCC) – 20100201
- 1.2.5 Equipment Tested
 - Siemens, SCC6-5000F, Unit #1
 - NO_x Analyzer (Teledyne API, T200M, 645)
 - CO Analyzer (Teledyne API, T300M, 355)
 - O₂ Analyzer (Teledyne API, T200M, 645)
- 1.2.6 Emission Points
 - Exhaust from the Siemens, SCC6-5000F, Unit #1
 - For all gases, one sample point in the exhaust duct from the Siemens, SCC6-5000F, Unit #1, determined after conducting a stratification test (refer to Appendix F)
- 1.2.7 Emission Parameters Measured
 - NO_x
 - CO
 - O₂
- 1.2.8 Dates of Emission Test
 - May 8-9, 2018

1.2.9 Federal and State Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Siemens:	Jordan Haywood	407-736-3045
Air Hygiene:	Michael Stockwell (mstockwell@airhygiene.com)	918-307-8865
Air Hygiene:	Hunter Neal	918-307-8865
Air Hygiene:	Zach Van Ness	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on CPV VALLEY LLC's Siemens, SCC6-5000F, Unit #1 located at the CPV VALLEY ENERGY CENTER on May 8-9, 2018 are summarized in the following table and relate only to the items tested.

**TABLE 2.1
SUMMARY OF SIEMENS, SCC6-5000F, UNIT #1 RATA RESULTS**

Pollutant	Units	Criteria			Results	Passed / Test Frequency
		CFR	Specification / Section	Standard		
NOx	ppmvd	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 2.8%	YES / ANNUAL
NOx	ppmvd@15%O ₂	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 3.3%	YES / ANNUAL
NOx	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 3.9%	YES / ANNUAL
NOx	lb/MMBtu	Part 75	Appendix A, Section 3.3.2(a),(b) Appendix B, Section 2.3.1.2(a),(f), Figure 2	RA ≤ 10%, or if lb/MMBtu ≤ 0.200, d ≤ ±0.020 lb/MMBtu Annual Incentive RA ≤ 7.5%, or if lb/MMBtu ≤ 0.2, d ≤ ±0.015 lb/MMBtu	RA = 5.4% RM = 0.02 lb/MMBtu d = 0.001 lb/MMBtu BAF=1.000	YES / ANNUAL
O ₂	%vd	Part 75	Appendix A, Section 3.3.3 Appendix B, Section 2.3.1.2(a),(h), Figure 2	RA ≤ 10%, or d ≤ ±1.0% Annual Incentive RA ≤ 7.5%, or d ≤ ±0.7%	RA = 0.5% d = 0 %	YES / ANNUAL
CO	ppmvd	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	d +2.5%CC = 0.3 ppm	YES / ANNUAL
CO	ppmvd@15%O ₂	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	d +2.5%CC = 0.3 ppm	YES / ANNUAL
CO	lb/hr	Part 60	Appendix B, Performance Specification 4, 4A Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	d +2.5%CC = 0.3 ppm	YES / ANNUAL
Load	MW	Part 60	Appendix B, Performance Specifications	> 50% max load	177.8	WITHIN TOLERANCE
Load	MW	Part 75	Appendix A and B	normal or alternative normal load range	177.8	WITHIN TOLERANCE

Notes: RA = relative accuracy, ARA = alternative relative accuracy, RM = reference method value, d = difference between RM and CEMS value, CC = confidence coefficient, v = velocity, BAF = bias adjustment factor

The RATA passed for all pollutants (NOx, CO, and O₂) in all units (ppm, ppm@15%O₂, lb/hr, lb/MMBtu, and %) under all 40 CFR 60 and 40 CFR 75 criteria.

Specifically, NO_x in units of ppm, ppm@15%O₂, and lb/hr, passed 40 CFR 60 criteria with an RA less than 20 percent. NO_x in units of lb/MMBtu passed the 40 CFR 75 alternative annual incentive criteria with an emissions rate of less than 0.200 lb/MMBtu and a difference between the RM and CEMS analyzers of less than 0.015 lb/MMBtu. Also the Bias Adjustment Factor test passed with an adjustment factor equal to 1.0 (no adjustment required). O₂ in units of % passed the 40 CFR 75 annual incentive criteria with an RA less than 7.5 percent. CO in units of ppm and ppm@15%O₂ passed the 40 CFR 60 alternative criteria with a concentration difference between the RM and CEMS analyzers plus the confidence coefficient of less than 5 ppm.

Unit load was within the 40 CFR 60 required criteria of greater than 50 percent of the maximum load and also fell within the alternative normal load criteria as defined by the plants Quality Control and Monitoring Plan which defined the upper and lower boundary on the unit and the normal and alternative normal load ranges.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

The CPV Valley Energy Center is located at 3330 U.S. Route 6 in Middletown, New York. CPV Valley Energy Center is an electric generation facility. The facility consists of two Siemens SCC6-5000F Combined Cycle Combustion Turbines (CTG), designated as CTG1 and CTG2. Each CTG is rated for the turbine at 2,234 MMBtu/hr (HHV) on natural gas; and 2,145 MMBtu/hr (HHV) on ULSD fuel oil; and is rated at 500 MMBtu/hr on natural gas for the duct burner. The CTG's are equipped with dry low NO_x combustors, selective catalytic reduction (SCR), and catalytic oxidizers. The interests of this report are CTG1 and CTG2 operating while burning fuel oil (ULSD).

3.2 SAMPLING LOCATION

The CTG1 and CTG2 stacks are vertical, circular and measures 19.35 feet (ft) (232.25 inches) in diameter at the test ports which are approximately 175 ft above grade level with an exit elevation of approximately 275 ft above grade level. The test ports are located approximately 91.25 ft (1095 inches) downstream and approximately 100 ft (1200 inches) upstream from the nearest disturbances.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the Siemens, SCC6-5000F, Unit #1 at the CPV VALLEY ENERGY CENTER was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on May 8-9, 2018.

**TABLE 4.1
SUMMARY OF SAMPLING METHODS**

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Oxygen	EPA Method 3A	Paramagnetic Cell
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 3A, 7E, 10, and 19.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in an air-conditioned, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NO_x calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. Data records can be found in Appendix A and B of this report.

Nine test runs of approximately 21 minutes each were conducted on the Siemens, SCC6-5000F, Unit #1 at the maximum test load for NO_x, CO, and O₂. The unit operation was greater than 50 percent of capacity as required by the 40 CFR 60, Performance Specifications. The unit operation was at the normal / alternative normal load as required by 40 CFR 75.


The stack gas analysis for O₂ concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O₂ analyzer uses a paramagnetic cell detector.

EPA Method 7E was used to determine concentrations of NO_x. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO₂ in nitrogen certified gas cylinder was used to verify at least a 90 percent NO₂ conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

**TABLE 4.2
ANALYTICAL INSTRUMENTATION**

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NO _x	THERMO 42i-HL	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO ₂ to NO. Chemiluminescence of reaction of NO with O ₃ . Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48i	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
O ₂	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.



Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.



Figure 1
EMISSIONS TESTING LAB
 1600 W Tacoma Street
 Broken Arrow, Oklahoma 74012
www.airhygiene.com
 (888) 461-8778

APPENDIX A
TEST RESULTS AND CALCULATIONS

**TABLE A.1:
EMISSIONS TESTING SCHEDULE**

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
1	Max	Stratification Test	1	05/08/18	6:46:44	8:01:44	DAHS
1	Max	Gas RATA	1	05/09/18	12:46:23	13:06:53	DAHS
1	Max	Gas RATA	2	05/09/18	13:27:23	13:47:53	DAHS
1	Max	Gas RATA	3	05/09/18	14:03:23	14:23:53	DAHS
1	Max	Gas RATA	4	05/09/18	14:38:23	14:58:53	DAHS
1	Max	Gas RATA	5	05/09/18	15:16:29	15:36:59	DAHS
1	Max	Gas RATA	6	05/09/18	15:48:29	16:08:59	DAHS
1	Max	Gas RATA	7	05/09/18	16:23:29	16:43:59	DAHS
1	Max	Gas RATA	8	05/09/18	16:55:29	17:15:59	DAHS
1	Max	Gas RATA	9	05/09/18	17:28:29	17:48:59	DAHS

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd)	(ppmvd)	(diff)	(diff ²)
1	12:46 - 13:06	YES	178.0	6.40	6.30	0.1000	0.01
2	13:27 - 13:47	YES	177.0	6.40	6.40	0.0000	0.00
3	14:03 - 14:23	YES	176.0	6.20	6.20	0.0000	0.00
4	14:38 - 14:58	YES	177.0	6.70	6.20	0.5000	0.25
5	15:16 - 15:36	YES	177.0	6.10	6.20	-0.1000	0.01
6	15:48 - 16:08	YES	177.0	6.20	6.20	0.0000	0.00
7	16:23 - 16:43	YES	179.0	6.10	6.30	-0.2000	0.04
8	16:55 - 17:15	YES	179.0	6.30	6.30	0.0000	0.00
9	17:28 - 17:48	YES	180.0	6.00	6.10	-0.1000	0.01
10		NO					
11		NO					
12		NO					
Total			1600.0	56.40	56.20	0.200000	0.320000
Average			177.8	6.27	6.24	0.022222	
Number of Runs				9			
Standard Deviation				0.198606			
T-value				2.306			
Confidence Coefficient				0.152662			
Relative Accuracy = 2.8%							

Part 60, Appendix B, Performance Specification 2,

8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.

13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).

Eq. 2.6 $RA = (|d| + |CC|) * 100 / RM$

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
CO RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd)	(ppmvd)	(diff)	(diff ²)
1	12:46 - 13:06	YES	178.0	0.40	0.00	0.4000	0.16
2	13:27 - 13:47	YES	177.0	0.40	0.00	0.4000	0.16
3	14:03 - 14:23	YES	176.0	0.30	0.00	0.3000	0.09
4	14:38 - 14:58	YES	177.0	0.30	0.00	0.3000	0.09
5	15:16 - 15:36	YES	177.0	0.20	0.00	0.2000	0.04
6	15:48 - 16:08	YES	177.0	0.20	0.00	0.2000	0.04
7	16:23 - 16:43	YES	179.0	0.30	0.00	0.3000	0.09
8	16:55 - 17:15	YES	179.0	0.20	0.00	0.2000	0.04
9	17:28 - 17:48	YES	180.0	0.20	0.00	0.2000	0.04
10		NO					
11		NO					
12		NO					
Total			1600.0	2.50	0.00	2.500000	0.750000
Average			177.8	0.28	0.00	0.277778	
Number of Runs				9			
Standard Deviation				0.083333			
T-value				2.306			
Confidence Coefficient				0.064056			
Relative Accuracy = 123.1% d (difference in ppm) + CC = 0.3							

Part 60, Appendix B, Performance Specification 4,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
O₂ RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS					
			(MW)	(%vd)	(%vd)	(diff)	(diff ²)				
1	12:46 - 13:06	YES	178.0	13.80	13.80	0.0000	0.00				
2	13:27 - 13:47	YES	177.0	13.80	13.80	0.0000	0.00				
3	14:03 - 14:23	YES	176.0	13.80	13.80	0.0000	0.00				
4	14:38 - 14:58	YES	177.0	13.80	13.80	0.0000	0.00				
5	15:16 - 15:36	YES	177.0	13.80	13.80	0.0000	0.00				
6	15:48 - 16:08	YES	177.0	13.80	13.80	0.0000	0.00				
7	16:23 - 16:43	YES	179.0	13.80	13.70	0.1000	0.01				
8	16:55 - 17:15	YES	179.0	13.80	13.70	0.1000	0.01				
9	17:28 - 17:48	YES	180.0	13.80	13.70	0.1000	0.01				
10		NO									
11		NO									
12		NO									
Total			1600.0	124.20	123.90	0.300000	0.030000				
Average			177.8	13.80	13.77	0.033333					
Number of Runs				9							
Standard Deviation				0.050000							
T-value				2.306							
Confidence Coefficient				0.038433							
<table border="1" style="margin: auto;"> <tr> <td>Average Difference =</td> <td style="text-align: right;">0.0</td> </tr> <tr> <td>Relative Accuracy =</td> <td style="text-align: right;">0.5%</td> </tr> </table>								Average Difference =	0.0	Relative Accuracy =	0.5%
Average Difference =	0.0										
Relative Accuracy =	0.5%										

Part 75, Appendix A,

3.3.3 Relative Accuracy for CO₂ and O₂ Monitors

The relative accuracy for CO₂ and O₂ monitors shall not exceed 10.0 percent. The relative accuracy test results are also acceptable if the difference between the mean value of the CO₂ or O₂ monitor measurements and the corresponding reference method measurement mean value, calculated using equation A-7 of this appendix, does not exceed ± 1.0 percent CO₂ or O₂.

Part 75, Appendix B,

2.3.1.2 Reduced RATA Frequencies

Relative accuracy test audits of primary and redundant backup SO₂ pollutant concentration monitors, CO₂ pollutant concentration monitors (including O₂ monitors used to determine CO₂ emissions), CO₂ or O₂ diluent monitors used to determine heat input, moisture monitoring systems, NO_x concentration monitoring systems, flow monitors, NO_x-diluent monitoring systems or SO₂-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:

(a) The relative accuracy during the audit of an SO₂ or CO₂ pollutant concentration monitor (including an O₂ pollutant monitor used to measure CO₂ using the procedures in appendix F to this part), or of a CO₂ or O₂ diluent monitor used to determine heat input, or of a NO_x concentration monitoring system, or of a NO_x-diluent monitoring system, or of an SO₂-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(e) For low SO₂ or NO_x emitting units (average SO₂ or NO_x reference method concentrations ≤ 250 ppm) during the RATA, when an SO₂ pollutant concentration monitor or NO_x concentration monitoring system fails to achieve a relative accuracy ≤ 7.5 percent during the audit, but the monitor mean value from the RATA is within ± 12 ppm of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO ₂ or NO _x (3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO ₂ -diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NO _x -diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO ₂ or O ₂	7.5% < RA ≤ 10.0% or ± 1.0% CO ₂ /O ₂ (2)	RA ≤ 7.5% or ± 0.7% CO ₂ /O ₂ (2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H ₂ O(2)	RA ≤ 7.5% or ± 1.0% H ₂ O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO₂ monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.

(2) The difference between monitor and reference method mean values applies to moisture monitors, CO₂, and O₂ monitors, low emitters, or low flow, only.

(3) A NO_x concentration monitoring system used to determine NO_x mass emissions under § 75.71.

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O ₂)	(ppmvd@15%O ₂)	(diff)	(diff ²)
1	12:46 - 13:06	YES	178.0	5.30	5.20	0.1000	0.01
2	13:27 - 13:47	YES	177.0	5.30	5.30	0.0000	0.00
3	14:03 - 14:23	YES	176.0	5.20	5.10	0.1000	0.01
4	14:38 - 14:58	YES	177.0	5.50	5.10	0.4000	0.16
5	15:16 - 15:36	YES	177.0	5.10	5.20	-0.1000	0.01
6	15:48 - 16:08	YES	177.0	5.20	5.10	0.1000	0.01
7	16:23 - 16:43	YES	179.0	5.10	5.20	-0.1000	0.01
8	16:55 - 17:15	YES	179.0	5.20	5.20	0.0000	0.00
9	17:28 - 17:48	YES	180.0	5.00	5.00	0.0000	0.00
10		NO					
11		NO					
12		NO					
Total			1600.0	46.90	46.40	0.500000	0.210000
Average			177.8	5.21	5.16	0.055556	
Number of Runs				9			
Standard Deviation				0.150923			
T-value				2.306			
Confidence Coefficient				0.116010			
Relative Accuracy = 3.3%							

Part 60, Appendix B, Performance Specification 2,

8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.

13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).

Eq. 2.6 $RA = (|d| + |CC|) * 100 / RM$

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
CO RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O ₂)	(ppmvd@15%O ₂)	(diff)	(diff ²)
1	12:46 - 13:06	YES	178.0	0.40	0.00	0.4000	0.16
2	13:27 - 13:47	YES	177.0	0.30	0.00	0.3000	0.09
3	14:03 - 14:23	YES	176.0	0.20	0.00	0.2000	0.04
4	14:38 - 14:58	YES	177.0	0.20	0.00	0.2000	0.04
5	15:16 - 15:36	YES	177.0	0.10	0.00	0.1000	0.01
6	15:48 - 16:08	YES	177.0	0.10	0.00	0.1000	0.01
7	16:23 - 16:43	YES	179.0	0.20	0.00	0.2000	0.04
8	16:55 - 17:15	YES	179.0	0.20	0.00	0.2000	0.04
9	17:28 - 17:48	YES	180.0	0.20	0.00	0.2000	0.04
10		NO					
11		NO					
12		NO					
Total			1600.0	1.90	0.00	1.90000	0.470000
Average			177.8	0.21	0.00	0.211111	
Number of Runs				9			
Standard Deviation				0.092796			
T-value				2.306			
Confidence Coefficient				0.071329			
Relative Accuracy = 133.8% d (difference in ppm) + CC = 0.3							

Part 60, Appendix B, Performance Specification 4,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	(diff ²)
1	12:46 - 13:06	YES	178.0	37.10	36.50	0.6000	0.36
2	13:27 - 13:47	YES	177.0	37.00	36.40	0.6000	0.36
3	14:03 - 14:23	YES	176.0	36.30	35.40	0.9000	0.81
4	14:38 - 14:58	YES	177.0	38.60	35.60	3.0000	9.00
5	15:16 - 15:36	YES	177.0	35.50	35.30	0.2000	0.04
6	15:48 - 16:08	YES	177.0	36.00	35.30	0.7000	0.49
7	16:23 - 16:43	YES	179.0	35.90	36.20	-0.3000	0.09
8	16:55 - 17:15	YES	179.0	36.80	36.30	0.5000	0.25
9	17:28 - 17:48	YES	180.0	35.40	35.20	0.2000	0.04
10		NO					
11		NO					
12		NO					
Total			1600.0	328.60	322.20	6.400000	11.440000
Average			177.8	36.51	35.80	0.711111	
Number of Runs				9			
Standard Deviation				0.927961			
T-value				2.306			
Confidence Coefficient				0.713292			
Relative Accuracy = 3.9%							

Part 60, Appendix B, Performance Specification 2,

8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.

13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).

Eq. 2.6 $RA = (|d| + |CC|) * 100 / RM$

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
CO RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	(diff ²)
1	12:46 - 13:06	YES	178.0	1.50	0.00	1.5000	2.25
2	13:27 - 13:47	YES	177.0	1.30	0.00	1.3000	1.69
3	14:03 - 14:23	YES	176.0	1.10	0.00	1.1000	1.21
4	14:38 - 14:58	YES	177.0	1.00	0.00	1.0000	1.00
5	15:16 - 15:36	YES	177.0	0.60	0.00	0.6000	0.36
6	15:48 - 16:08	YES	177.0	0.60	0.00	0.6000	0.36
7	16:23 - 16:43	YES	179.0	0.90	0.00	0.9000	0.81
8	16:55 - 17:15	YES	179.0	0.80	0.00	0.8000	0.64
9	17:28 - 17:48	YES	180.0	0.70	0.00	0.7000	0.49
10		NO					
11		NO					
12		NO					
Total			1600.0	8.50	0.00	8.50000	8.81000
Average			177.8	0.94	0.00	0.944444	
Number of Runs				9			
Standard Deviation				0.312694			
T-value				2.306			
Confidence Coefficient				0.240358			
Relative Accuracy = 125.4% d (difference in ppm) + CC = 0.3							

Part 60, Appendix B, Performance Specification 4,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,

1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).

13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
NOx RATA Data Sheet
CPV VALLEY ENERGY CENTER

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS									
			(MW)	(lb/MMBtu)	(lb/MMBtu)	(diff)	(diff ²)								
1	12:46 - 13:06	YES	178.0	0.021	0.020	0.0010	0.0000								
2	13:27 - 13:47	YES	177.0	0.021	0.020	0.0010	0.0000								
3	14:03 - 14:23	YES	176.0	0.020	0.020	0.0000	0.0000								
4	14:38 - 14:58	YES	177.0	0.022	0.020	0.0020	0.0000								
5	15:16 - 15:36	YES	177.0	0.020	0.020	0.0000	0.0000								
6	15:48 - 16:08	YES	177.0	0.020	0.020	0.0000	0.0000								
7	16:23 - 16:43	YES	179.0	0.020	0.020	0.0000	0.0000								
8	16:55 - 17:15	YES	179.0	0.020	0.020	0.0000	0.0000								
9	17:28 - 17:48	YES	180.0	0.020	0.019	0.0010	0.0000								
10		NO													
11		NO													
12		NO													
Total			1600.0	0.184	0.179	0.005000	0.000007								
Average			177.8	0.020	0.020	0.000556									
Number of Runs				9											
Standard Deviation				0.000726											
T-value				2.306											
Confidence Coefficient				0.000558											
Relative Accuracy = 5.45%															
<p>If the mean difference is less than or equal to the absolute value of the confidence coefficient, then the Bias Test passes and the bias adjustment factor is not applicable.</p> <table style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <tr> <td style="padding: 2px 10px;">Mean Difference =</td> <td style="padding: 2px 10px;">0.0006</td> </tr> <tr> <td style="padding: 2px 10px;">Confidence Coefficient =</td> <td style="padding: 2px 10px;">0.0006</td> </tr> </table> <p style="text-align: center; margin-top: 10px;">BAF = 1 + (abs. value mean difference/avg. CEMS reading)</p> <table style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <tr> <td style="padding: 2px 10px;">Average CEMS Reading =</td> <td style="padding: 2px 10px;">0.020</td> </tr> <tr> <td style="padding: 2px 10px;">BAF =</td> <td style="padding: 2px 10px;">1.000</td> </tr> </table>								Mean Difference =	0.0006	Confidence Coefficient =	0.0006	Average CEMS Reading =	0.020	BAF =	1.000
Mean Difference =	0.0006														
Confidence Coefficient =	0.0006														
Average CEMS Reading =	0.020														
BAF =	1.000														

Part 75, Appendix A,

3.3.2 Relative Accuracy for NOX-Diluent Continuous Emission Monitoring Systems

(a) The relative accuracy for NOX-diluent continuous emission monitoring systems shall not exceed 10.0 percent.

(b) For affected units where the average of the reference method measurements of NOX emission rate (this means lb/MMBtu) during the relative accuracy test audit is less than or equal to 0.200 lb/mmBtu, the difference between the mean value of the continuous emission monitoring system measurements and the reference method mean value shall not exceed ±0.020 lb/mmBtu, wherever the relative accuracy specification of 10.0 percent is not achieved.

7.6.5 Bias Adjustment

(b) For single-load RATAs of SO2 pollutant concentration monitors, NOX concentration monitoring systems, and NOX-diluent monitoring systems and for the single-load flow RATAs required or allowed under section 6.5.2 of this appendix and sections 2.3.1.3(b) and 2.3.1.3(c) of Appendix B to this part, the appropriate BAF is determined directly from the RATA results at normal load, using Equation A-12. Notwithstanding, when a NOX concentration CEMS or an SO2 CEMS or a NOX-diluent CEMS installed on a low-emitting affected unit (i.e., average SO2 or NOX concentration during the RATA &IE; 250 ppm or average NOX emission rate &IE; 0.200 lb/mmBtu) meets the normal 10.0 percent relative accuracy specification (as calculated using Equation A-10) or the alternate relative accuracy specification in section 3.3 of this appendix for low-emitters, but fails the bias test, the BAF may either be determined using Equation A-12, or a default BAF of 1.111 may be used.

Part 75, Appendix B,

2.3.1.2 Reduced RATA Frequencies. Relative accuracy test audits of primary and redundant backup SO2 pollutant concentration monitors, CO2 pollutant concentration monitors (including O2 monitors used to determine CO2 emissions), CO2 or O2 diluent monitors used to determine heat input, moisture monitoring systems, NOX concentration monitoring systems, flow monitors, NOX-diluent monitoring systems or SO2-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:

(a) The relative accuracy during the audit of an SO2 or CO2 pollutant concentration monitor (including an O2 pollutant monitor used to measure CO2 using the procedures in appendix F to this part), or of a CO2 or O2 diluent monitor used to determine heat input, or of a NOX concentration monitoring system, or of a NOX-diluent monitoring system, or of an SO2-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(f) For units with low NOX emission rates (average NOX emission rate measured by the reference method during the RATA ≤ 0.200 lb/mmBtu), when a NOX-diluent continuous emission monitoring system fails to achieve a relative accuracy ≤ 7.5 percent, but the monitoring system mean value from the RATA, calculated using Equation A-7 in appendix A to this part, is within ± 0.015 lb/mmBtu of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO2 or NOX(3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO2-diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NOX-diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO2 or O2	7.5% < RA ≤ 10.0% or ± 1.0% CO2/O2(2)	RA ≤ 7.5% or ± 0.7% CO2/O2(2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H2O(2)	RA ≤ 7.5% or ± 1.0% H2O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO2 monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.

(2) The difference between monitor and reference method mean values applies to moisture monitors, CO2, and O2 monitors, low emitters, or low flow, only.

(3) A NOX concentration monitoring system used to determine NOX mass emissions under § 75.71.

**Relative Accuracy Test Data
CEMS Results (NOx)
Siemens, SCC6-5000F, Unit #1**

Parameter:	Oxides of Nitrogen
Date of Test:	May 9, 2018
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Chemiluminescence
Manufacturer:	Teledyne
Model #:	T200M
Serial #:	645

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:46 - 13:06	178.0	6.30	5.20	36.50	0.020
2	13:27 - 13:47	177.0	6.40	5.30	36.40	0.020
3	14:03 - 14:23	176.0	6.20	5.10	35.40	0.020
4	14:38 - 14:58	177.0	6.20	5.10	35.60	0.020
5	15:16 - 15:36	177.0	6.20	5.20	35.30	0.020
6	15:48 - 16:08	177.0	6.20	5.10	35.30	0.020
7	16:23 - 16:43	179.0	6.30	5.20	36.20	0.020
8	16:55 - 17:15	179.0	6.30	5.20	36.30	0.020
9	17:28 - 17:48	180.0	6.10	5.00	35.20	0.019
10						
11						
12						

**Relative Accuracy Test Data
CEMS Results (CO)
Siemens, SCC6-5000F, Unit #1**

Parameter:	Carbon Monoxide
Date of Test:	May 9, 2018
Reference Method:	EPA Method 10
CEMS Analyzer Type:	Infrared Absorption
Manufacturer:	Teledyne
Model #:	T300M
Serial #:	355

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:46 - 13:06	178.0	0.00	0.00	0.00	
2	13:27 - 13:47	177.0	0.00	0.00	0.00	
3	14:03 - 14:23	176.0	0.00	0.00	0.00	
4	14:38 - 14:58	177.0	0.00	0.00	0.00	
5	15:16 - 15:36	177.0	0.00	0.00	0.00	
6	15:48 - 16:08	177.0	0.00	0.00	0.00	
7	16:23 - 16:43	179.0	0.00	0.00	0.00	
8	16:55 - 17:15	179.0	0.00	0.00	0.00	
9	17:28 - 17:48	180.0	0.00	0.00	0.00	
10						
11						
12						

**Relative Accuracy Test Data
CEMS Results (O₂)
Siemens, SCC6-5000F, Unit #1**

Parameter:	Oxygen
Date of Test:	May 9, 2018
Reference Method:	EPA Method 3A
CEMS Analyzer Type:	Paramagnetic Cell
Manufacturer:	Teledyne
Model #:	T200M
Serial #:	645

RUN #	RUN TIME	UNIT LOAD	CONC.
		(MW)	(%vd)
1	12:46 - 13:06	178.0	13.80
2	13:27 - 13:47	177.0	13.80
3	14:03 - 14:23	176.0	13.80
4	14:38 - 14:58	177.0	13.80
5	15:16 - 15:36	177.0	13.80
6	15:48 - 16:08	177.0	13.80
7	16:23 - 16:43	179.0	13.70
8	16:55 - 17:15	179.0	13.70
9	17:28 - 17:48	180.0	13.70
10			
11			
12			

**Relative Accuracy Test Data
Reference Method Results (NOx)
Siemens, SCC6-5000F, Unit #1**

Parameter:	Oxides of Nitrogen
Date of Test:	May 9, 2018
Reference Method:	EPA Method 7E
RM Analyzer Type:	Chemiluminescence
Manufacturer:	THERMO 42i-HL
Model #:	
Serial #:	INST-NX-0064

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:46 - 13:06	178.0	6.39	5.29	37.13	0.021
2	13:27 - 13:47	177.0	6.36	5.30	37.00	0.021
3	14:03 - 14:23	176.0	6.24	5.20	36.28	0.020
4	14:38 - 14:58	177.0	6.65	5.54	38.64	0.022
5	15:16 - 15:36	177.0	6.14	5.10	35.55	0.020
6	15:48 - 16:08	177.0	6.25	5.17	36.03	0.020
7	16:23 - 16:43	179.0	6.14	5.09	35.90	0.020
8	16:55 - 17:15	179.0	6.28	5.21	36.81	0.020
9	17:28 - 17:48	180.0	6.02	5.00	35.45	0.020
10						
11						
12						

**Relative Accuracy Test Data
Reference Method Results (CO)
Siemens, SCC6-5000F, Unit #1**

Parameter:	Carbon Monoxide
Date of Test:	May 9, 2018
Reference Method:	EPA Method 10
RM Analyzer Type:	Infrared Absorption
Manufacturer:	THERMO 48i
Model #:	
Serial #:	INST-CO-0016

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O ₂)	(lb/hr)	(lb/MMBtu)
1	12:46 - 13:06	178.0	0.43	0.36	1.52	
2	13:27 - 13:47	177.0	0.38	0.31	1.33	
3	14:03 - 14:23	176.0	0.30	0.25	1.06	
4	14:38 - 14:58	177.0	0.28	0.23	0.99	
5	15:16 - 15:36	177.0	0.16	0.14	0.58	
6	15:48 - 16:08	177.0	0.16	0.13	0.56	
7	16:23 - 16:43	179.0	0.25	0.21	0.89	
8	16:55 - 17:15	179.0	0.23	0.19	0.80	
9	17:28 - 17:48	180.0	0.18	0.15	0.65	
10						
11						
12						

**Relative Accuracy Test Data
Reference Method Results (O₂)
Siemens, SCC6-5000F, Unit #1**

Parameter:	Oxygen
Date of Test:	May 9, 2018
Reference Method:	EPA Method 3A
RM Analyzer Type:	Paramagnetic Cell
Manufacturer:	SERVOMEX 1440
Model #:	
Serial #:	inst-O2-0023

RUN #	RUN TIME	UNIT LOAD	CONC.
		(MW)	(%vd)
1	12:46 - 13:06	178.0	13.77
2	13:27 - 13:47	177.0	13.82
3	14:03 - 14:23	176.0	13.82
4	14:38 - 14:58	177.0	13.82
5	15:16 - 15:36	177.0	13.79
6	15:48 - 16:08	177.0	13.77
7	16:23 - 16:43	179.0	13.78
8	16:55 - 17:15	179.0	13.79
9	17:28 - 17:48	180.0	13.80
10			
11			
12			

EXAMPLE CALCULATIONS (INFORMATION)**Specific Humidity (RH_{sp})**

Note: RH_{sp} (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} (lb/lb) = \left[\left(\frac{gr}{lb} \right) \times \frac{lb}{7000 gr} \right]$$

$$RH_{sp} = \frac{49.00 \text{ gr}}{lb} \times \frac{1 \text{ lb}}{7000 \text{ gr}} = 0.007001 \frac{\text{lb H}_2\text{O}}{\text{lb Air}}$$

EXAMPLE CALCULATIONS (CALIBRATION)**Analyzer Calibration Error**

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NO_x analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100 \quad \text{Eq. 7E-1}$$

$$ACE = \frac{9.63 \text{ ppm} - 9.30 \text{ ppm}}{18.30 \text{ ppm}} \times 100 = 1.80 \%$$

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)**System Bias**

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NO_x analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS} \right) \times 100 \quad \text{Eq. 7E-2}$$

$$SB = \frac{9.47 \text{ ppm} - 9.63 \text{ ppm}}{18.30 \text{ ppm}} \times 100 = -0.87 \%$$

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NO_x analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{final} - SB_i| \quad \text{Eq. 7E-4}$$

$$D = |0.71 \% - -0.87 \%| = 1.58 \%$$

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate C_{avg}, the arithmetic average of all valid NO_x concentration values (e.g., 1-minute averages). Then adjust the value of C_{avg} for bias, using Equation 7E-5b. (calc for NO_x analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right) \quad \text{Eq. 7E-5b}$$

$$C_{Gas} = \left(6.67 \text{ ppm} - 0.20 \text{ ppm} \right) \left(\frac{9.30 \text{ ppm}}{9.62 \text{ ppm} - 0.20 \text{ ppm}} \right) = 6.39 \text{ ppm}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RATA RESULTS)

Difference (d)

40 CFR 75, App A, (12-17-09), 7.3.1 Arithmetic Mean. Calculate the arithmetic mean of the differences, d , of a data set as follows. (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$d = \sum_{i=1}^n d_i \quad \text{Eq. A-7} \quad d = 6.267 \text{ ppm} - 6.244 \text{ ppm} = 0.022 \text{ ppm}$$

Standard Deviation

40 CFR 75, App A, (12-17-09), 7.3.2 Standard Deviation. Calculate the standard deviation, S_d , of a data set as follows: (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{\left(\sum_{i=1}^n d_i\right)^2}{n}}{n-1}} \quad \text{Eq. A-8} \quad S_d = \sqrt{\frac{0.320 \text{ ppm}^2 - \frac{[0.200 \text{ ppm}]^2}{9}}{9-1}} = 0.199 \text{ ppm}$$

Confidence Coefficient

40 CFR 75, App A, (12-17-09), 7.3.3 Confidence Coefficient. Calculate the confidence coefficient (one-tailed), cc , of a data set as follows. (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}} \quad \text{Eq. A-9} \quad CC = 2.306 \times \frac{0.199 \text{ ppm}}{\sqrt{9}} = 0.153 \text{ ppm}$$

T-Values	n	2	3	4	5	6	7	8	9
$t_{0.025}$		12.706	4.303	3.182	2.776	2.571	2.447	2.365	2.306

2.5 percent confidence coefficients

Relative Accuracy

40 CFR 75, App A, (12-17-09), 7.3.4 Relative Accuracy. Calculate the relative accuracy of a data set using the following equation. (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100 \quad \text{Eq. A-10} \quad RA = \frac{|0.022| \text{ ppm} + |0.153| \text{ ppm}}{6.267 \text{ ppm}} \times 100 = 2.79 \%$$

Bias Adjustment Factor (BAF)

40 CFR 75, App A, (12-17-09), 7.6.5 Bias Adjustment. (a) If the monitor or monitoring system fails to meet the bias test requirement, adjust the value obtained from the monitor using the following equation: (calc for NOx ppm data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right) \quad \text{Eq. A-12} \quad d_{AVG} = 0.022 < |CC| = 0.153 \Rightarrow BAF = 1 + \frac{0 \text{ ppm}}{\text{ppm}} = 1.000 \text{ ppm}$$

Note: BAF only applies if the mean difference (d) is greater than the absolute value of the confidence coefficient.

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NO_x measured in the spiked sample.
C_{Spike} = Concentration of NO_x in the undiluted spike gas.
C_{Calc} = Calculated concentration of NO_x in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO₂} = NO₂ to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NO_{Final} = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NO_xCorr = The NO_x concentration corrected for the converter efficiency.
NO_xFinal = The final NO_x concentration observed during the converter efficiency test in Section 16.2.2.
NO_xPeak = The highest NO_x concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H₂O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
%_C = Concentration of carbon from an ultimate analysis of fuel, weight percent.
%_{CO_{2d}}, %_{CO_{2w}} = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{aoi}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu)
E_{di} = Average inlet SO₂ rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O₂.
E_{jo}, E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft³ = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
%_H = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
%_{H₂O} = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10⁻⁵ (kJ/J)/(%) [10⁶ Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = 2x10⁴ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p, L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
%_N = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
M% = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)¹
NCM = net Btu per SCF (constant based on compound)
%_O = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
%_{O_{2d}}, %_{O_{2w}} = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO₂ emissions, percent.
%_S = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
%_{S_f} = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
%S_p, %S_r = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
t_{0.95} = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO₂} = CO₂ Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) = 46.01
 Molecular Weight of CO (lb/lb-mole) = 28.00
 Molecular Weight of SO₂ (lb/lb-mole) = 64.00
 Molecular Weight of THC (propane) (lb/lb-mole) = 44.00
 Molecular Weight of VOC (methane) (lb/lb-mole) = 16.00
 Molecular Weight of NH₃ (lb/lb-mole) = 17.03
 Molecular Weight of HCHO (lb/lb-mole) = 30.03
 Molecular Weight of CO₂ (lb/lb-mole) = 44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx = 0.0000001194351
 Conversion Constant for CO = 0.0000000726839
 Conversion Constant for SO₂ = 0.0000001661345
 Conversion Constant for THC = 0.0000001142175
 Conversion Constant for VOC (methane) = 0.0000000415336
 Conversion Constant for NH₃ = 0.0000000442074
 Conversion Constant for HCHO = 0.0000000779534
 Conversion Constant for CO₂ = 0.0000001142434

NOTE: units are lb/ppm*ft³

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_o) \times \left(\frac{C_{MA}}{C_M - C_o} \right)$$

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_s \times MW}{G}$$

2. Correction to % O₂, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

3. Correction to % O₂ and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_o - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

6. Emission Rate in tons per year

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O_2)}}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_s = \left(\frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

7. Emission Concentration in lb/MMBtu (O₂ based)

$$E_{g/hp-hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp}$$

RATA SHEET CALCULATIONS

d = Reference Method Data - CEMS Data

S_d = Standard Deviation

CC = Confident Coefficient

n = number of runs

t_{0.025} = 2.5 percent confidence coefficient T-values

RA = relative accuracy

ARA = alternative relative accuracy

BAF = Bias adjustment factor

n	t	n	t	n	t
2	12.706	7	2.447	12	2.201
3	4.303	8	2.365	13	2.179
4	3.182	9	2.306	14	2.160
5	2.776	10	2.262	15	2.145
6	2.571	11	2.228	16	2.131

1. Difference

$$d = \sum_{i=1}^n d_i$$

4. Relative Accuracy

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$

2. Standard Deviation

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{\left(\sum_{i=1}^n d_i \right)^2}{n}}{n-1}}$$

5. Alternative Relative Accuracy

$$ARA = \frac{|d_{AVG}| + |CC|}{AS} \times 100$$

3. Confident Coefficient

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$

5. Bias Adjustment Factor

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right)$$

APPENDIX B

CEMS AND REFERENCE METHOD DATA

CPV VALLEY LLC

Air Permit Number:	3-3356-00136/00001
Plant Name or Location:	CPV VALLEY ENERGY CENTER
Date:	May 9, 2018
Project Number:	sie-17-middletown.ny-start#1
Manufacturer & Equipment:	Siemens
Model:	SCC6-5000F
Unit Number:	1
Test Load:	Max
Tester(s) / Test Unit(s):	MS

		RUN								
	UNITS	1	2	3	4	5	6	7	8	9
Start Time	hh:mm:ss	12:46:23	13:27:23	14:03:23	14:38:23	15:16:29	15:48:29	16:23:29	16:55:29	17:28:29
End Time	hh:mm:ss	13:06:53	13:47:53	14:23:53	14:58:53	15:36:59	16:08:59	16:43:59	17:15:59	17:48:59
Bar. Pressure	in. Hg	29.64	29.64	29.63	29.63	29.68	29.68	29.57	29.57	29.57
Amb. Temp.	°F	79	79	79	78	83	84	87	87	85
Rel. Humidity	%	33	32	33	32	31	31	33	33	33
Spec. Humidity	lb water / lb air	0.007001	0.006786	0.007003	0.006566	0.007487	0.007735	0.009116	0.009116	0.008545
Turbine Fuel Flow	gal/hr	13,002	12,934	12,921	12,914	12,914	12,914	13,076	13,090	13,130
Total Fuel Flow	SCFH	1,738	1,729	1,727	1,726	1,726	1,726	1,748	1,750	1,755
Power Output	megawatts	178.0	177.0	176.0	177.0	177.0	177.0	179.0	179.0	180.0
O₂ CEMS Data	%vd	13.8	13.8	13.8	13.8	13.8	13.8	13.7	13.7	13.7
NO_x CEMS Data	ppmvd	6.30	6.40	6.20	6.20	6.20	6.20	6.30	6.30	6.10
	ppmvd@15%O ₂	5.20	5.30	5.10	5.10	5.20	5.10	5.20	5.20	5.00
	lb/hr	36.50	36.40	35.40	35.60	35.30	35.30	36.20	36.30	35.20
	lb/MMBtu	0.020	0.020	0.020	0.020	0.020	0.020	0.020	0.020	0.019
CO CEMS Data	ppmvd	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	ppmvd@15%O ₂	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	lb/hr	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Created with Comp&RATA&Eng-AHI v20180227

CEMS AND REFERENCE METHOD DATA

CEMS Data

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: NOX- RESPONSE

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 10:42	0	SU	GD	6.1	SU	GD	93000	SU	GD	0.8	SU	GD	0.7	SU	GD	3.6	SU	GD	182
05/09/2018 10:43	0	SU	GD	7.9	SU	GD	93000	SU	GD	0.8	SU	GD	0.7	SU	GD	3.6	SU	GD	181
05/09/2018 10:44	0	SU	GD	7.7	SU	GD	93000	SU	GD	0.8	SU	GD	0.7	SU	GD	3.6	SU	GD	180
05/09/2018 10:45	0	SU	GD	7.6	SU	GD	93000	SU	GD	0.8	SU	GD	0.7	SU	GD	3.6	SU	GD	178
05/09/2018 10:46	0	SU	GD	5.9	SU	GD	92000	SU	GD	0.8	SU	GD	0.7	SU	GD	3.6	SU	GD	178
05/09/2018 10:47	0	SU	GD	4.8	SU	GD	92000	SU	GD	0.7	SU	GD	0.6	SU	GD	1.8	SU	GD	178
05/09/2018 10:48	0	SU	GD	4.6	SU	GD	92000	SU	GD	0.7	SU	GD	0.6	SU	GD	1.8	SU	GD	179
05/09/2018 10:49	0	SU	GD	4.6	SU	GD	92000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	179
05/09/2018 10:50	0	SU	GD	4.6	SU	GD	93000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	180
05/09/2018 10:51	0	SU	GD	5.1	SU	GD	93000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	181
05/09/2018 10:52	0	SU	GD	7.4	SU	GD	93000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	181
05/09/2018 10:53	0	SU	GD	7.2	SU	GD	92000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	181
05/09/2018 10:54	0	SU	GD	6.4	SU	GD	92000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	180
05/09/2018 10:55	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	180
05/09/2018 10:56	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.6	SU	GD	0.5	SU	GD	1.8	SU	GD	178
05/09/2018 10:57	0	SU	GD	4.2	SU	GD	92000	SU	GD	0.5	SU	GD	0.4	SU	GD	1.8	SU	GD	179
05/09/2018 10:58	0	SU	GD	4.1	SU	GD	93000	SU	GD	0.5	SU	GD	0.4	SU	GD	1.8	SU	GD	179
05/09/2018 10:59	0	SU	GD	4.1	SU	GD	93000	SU	GD	0.4	SU	GD	0.3	SU	GD	1.8	SU	GD	179
05/09/2018 11:00	0	SU	GD	4.5	SU	GD	93000	SU	GD	0.4	SU	GD	0.3	SU	GD	1.8	SU	GD	179
05/09/2018 11:01	0	SU	GD	5.4	SU	GD	93000	SU	GD	0.3	SU	GD	0.2	SU	GD	1.8	SU	GD	179
05/09/2018 11:02	0	SU	GD	6.1	SU	GD	93000	SU	GD	0.3	SU	GD	0.2	SU	GD	1.8	SU	GD	179
Average	0			5.7			92571			0.6			0.5			2.2			180
Maximum	0			7.9			93000			0.8			0.7			3.6			182
Minimum	0			4.1			92000			0.3			0.2			1.8			178
Total	0			119.5			1944000			12.6			10.5			46.8			3770

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: NOX- RESPONSE

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_P75			CTG1 NOX_RATE_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS
05/09/2018 10:42	SU	GD	5.2	SU	GD	6.6	SU	GD	36.4	SU	GD	6.4	SU	GD	0.020	SU	GD
05/09/2018 10:43	SU	GD	7.1	SU	GD	8.7	SU	GD	51.0	SU	GD	8.7	SU	GD	0.028	SU	GD
05/09/2018 10:44	SU	GD	7.4	SU	GD	9.0	SU	GD	52.8	SU	GD	9.0	SU	GD	0.029	SU	GD
05/09/2018 10:45	SU	GD	7.0	SU	GD	8.6	SU	GD	49.2	SU	GD	8.6	SU	GD	0.027	SU	GD
05/09/2018 10:46	SU	GD	5.6	SU	GD	6.7	SU	GD	39.7	SU	GD	6.7	SU	GD	0.022	SU	GD
05/09/2018 10:47	SU	GD	4.6	SU	GD	5.5	SU	GD	32.4	SU	GD	5.5	SU	GD	0.018	SU	GD
05/09/2018 10:48	SU	GD	4.4	SU	GD	5.3	SU	GD	30.6	SU	GD	5.3	SU	GD	0.017	SU	GD
05/09/2018 10:49	SU	GD	4.3	SU	GD	5.2	SU	GD	30.6	SU	GD	5.2	SU	GD	0.017	SU	GD
05/09/2018 10:50	SU	GD	4.2	SU	GD	5.1	SU	GD	29.2	SU	GD	5.1	SU	GD	0.016	SU	GD
05/09/2018 10:51	SU	GD	4.6	SU	GD	5.5	SU	GD	32.8	SU	GD	5.5	SU	GD	0.018	SU	GD
05/09/2018 10:52	SU	GD	6.7	SU	GD	8.2	SU	GD	47.4	SU	GD	8.2	SU	GD	0.026	SU	GD
05/09/2018 10:53	SU	GD	6.7	SU	GD	8.2	SU	GD	46.9	SU	GD	8.2	SU	GD	0.026	SU	GD
05/09/2018 10:54	SU	GD	5.9	SU	GD	7.2	SU	GD	41.5	SU	GD	7.2	SU	GD	0.023	SU	GD
05/09/2018 10:55	SU	GD	5.3	SU	GD	6.5	SU	GD	37.9	SU	GD	6.5	SU	GD	0.021	SU	GD
05/09/2018 10:56	SU	GD	4.9	SU	GD	6.0	SU	GD	34.2	SU	GD	6.0	SU	GD	0.019	SU	GD
05/09/2018 10:57	SU	GD	4.0	SU	GD	4.8	SU	GD	28.8	SU	GD	4.8	SU	GD	0.016	SU	GD
05/09/2018 10:58	SU	GD	3.8	SU	GD	4.6	SU	GD	27.3	SU	GD	4.6	SU	GD	0.015	SU	GD
05/09/2018 10:59	SU	GD	3.8	SU	GD	4.6	SU	GD	27.3	SU	GD	4.6	SU	GD	0.015	SU	GD
05/09/2018 11:00	SU	GD	4.2	SU	GD	5.1	SU	GD	29.2	SU	GD	5.1	SU	GD	0.016	SU	GD
05/09/2018 11:01	SU	GD	4.8	SU	GD	5.9	SU	GD	34.6	SU	GD	5.9	SU	GD	0.019	SU	GD
05/09/2018 11:02	SU	GD	5.4	SU	GD	6.6	SU	GD	38.3	SU	GD	6.6	SU	GD	0.021	SU	GD
Average			5.2			6.4			37.1			6.4			0.020		
Maximum			7.4			9.0			52.8			9.0			0.029		
Minimum			3.8			4.6			27.3			4.6			0.015		
Total			109.9			133.9			778.1			133.7			0.429		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 12:46	0	SU	GD	5.3	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:47	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:48	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:49	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:50	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:51	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:52	0	SU	GD	5.3	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:53	0	SU	GD	5.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:54	0	SU	GD	5.1	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 12:55	0	SU	GD	5.3	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 12:56	0	SU	GD	4.6	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 12:57	0	SU	GD	4.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:58	0	SU	GD	5.3	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 12:59	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:00	0	SU	GD	5.9	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:01	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:02	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:03	0	SU	GD	5.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:04	0	SU	GD	5.3	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:05	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:06	0	SU	GD	5.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
Average	0			5.4			91619			0.0			0.0			0.0			178
Maximum	0			5.9			92000			0.0			0.0			0.0			178
Minimum	0			4.5			91000			0.0			0.0			0.0			177
Total	0			113.5			1924000			0.0			0.0			0.0			3734

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS
05/09/2018 12:46	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	6.3	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 12:47	SU	GD	5.3	SU	GD	6.4	SU	GD	37.9	SU	GD	6.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 12:48	SU	GD	5.4	SU	GD	6.5	SU	GD	37.9	SU	GD	6.5	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 12:49	SU	GD	5.3	SU	GD	6.5	SU	GD	37.9	SU	GD	6.5	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 12:50	SU	GD	5.3	SU	GD	6.4	SU	GD	37.9	SU	GD	6.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 12:51	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	6.3	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 12:52	SU	GD	5.2	SU	GD	6.2	SU	GD	36.0	SU	GD	6.2	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 12:53	SU	GD	5.2	SU	GD	6.2	SU	GD	35.7	SU	GD	6.2	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 12:54	SU	GD	5.0	SU	GD	6.0	SU	GD	34.2	SU	GD	6.0	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 12:55	SU	GD	5.1	SU	GD	6.2	SU	GD	35.7	SU	GD	6.2	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 12:56	SU	GD	4.6	SU	GD	5.5	SU	GD	32.1	SU	GD	5.5	SU	GD	0.018	SU	GD	13.8	SU	GD
05/09/2018 12:57	SU	GD	4.4	SU	GD	5.4	SU	GD	30.3	SU	GD	5.3	SU	GD	0.017	SU	GD	13.8	SU	GD
05/09/2018 12:58	SU	GD	5.2	SU	GD	6.2	SU	GD	36.0	SU	GD	6.2	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 12:59	SU	GD	5.5	SU	GD	6.7	SU	GD	37.9	SU	GD	6.7	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 13:00	SU	GD	5.7	SU	GD	6.9	SU	GD	39.2	SU	GD	6.8	SU	GD	0.022	SU	GD	13.8	SU	GD
05/09/2018 13:01	SU	GD	5.7	SU	GD	6.9	SU	GD	39.7	SU	GD	6.9	SU	GD	0.022	SU	GD	13.8	SU	GD
05/09/2018 13:02	SU	GD	5.7	SU	GD	6.9	SU	GD	39.7	SU	GD	6.9	SU	GD	0.022	SU	GD	13.7	SU	GD
05/09/2018 13:03	SU	GD	5.6	SU	GD	6.8	SU	GD	39.2	SU	GD	6.8	SU	GD	0.022	SU	GD	13.7	SU	GD
05/09/2018 13:04	SU	GD	5.2	SU	GD	6.2	SU	GD	36.0	SU	GD	6.2	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 13:05	SU	GD	5.1	SU	GD	6.2	SU	GD	35.7	SU	GD	6.2	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 13:06	SU	GD	5.2	SU	GD	6.3	SU	GD	35.7	SU	GD	6.3	SU	GD	0.020	SU	GD	13.8	SU	GD
Average			5.2			6.3			36.5			6.3			0.020			13.8		
Maximum			5.7			6.9			39.7			6.9			0.022			13.8		
Minimum			4.4			5.4			30.3			5.3			0.017			13.7		
Total			110.1			133.0			766.7			132.8			0.427			289.2		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_GT			CTG1 OIL_FLOW_RAW_P75		
	MW	OS	MS	LBHR	OS	MS
05/09/2018 12:46	178	SU	GD	92	SU	GD
05/09/2018 12:47	178	SU	GD	92	SU	GD
05/09/2018 12:48	178	SU	GD	92	SU	GD
05/09/2018 12:49	178	SU	GD	92	SU	GD
05/09/2018 12:50	178	SU	GD	92	SU	GD
05/09/2018 12:51	178	SU	GD	92	SU	GD
05/09/2018 12:52	178	SU	GD	92	SU	GD
05/09/2018 12:53	178	SU	GD	91	SU	GD
05/09/2018 12:54	177	SU	GD	92	SU	GD
05/09/2018 12:55	177	SU	GD	91	SU	GD
05/09/2018 12:56	177	SU	GD	91	SU	GD
05/09/2018 12:57	178	SU	GD	91	SU	GD
05/09/2018 12:58	178	SU	GD	92	SU	GD
05/09/2018 12:59	178	SU	GD	92	SU	GD
05/09/2018 13:00	178	SU	GD	91	SU	GD
05/09/2018 13:01	178	SU	GD	92	SU	GD
05/09/2018 13:02	178	SU	GD	92	SU	GD
05/09/2018 13:03	178	SU	GD	91	SU	GD
05/09/2018 13:04	178	SU	GD	92	SU	GD
05/09/2018 13:05	177	SU	GD	91	SU	GD
05/09/2018 13:06	178	SU	GD	91	SU	GD
Average	178			92		
Maximum	178			92		
Minimum	177			91		
Total	3734			1924		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 13:27	0	SU	GD	6.1	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 13:28	0	SU	GD	6.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 13:29	0	SU	GD	5.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 13:30	0	SU	GD	5.1	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 13:31	0	SU	GD	4.9	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:32	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:33	0	SU	GD	6.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:34	0	SU	GD	6.5	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:35	0	SU	GD	6.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 13:36	0	SU	GD	6.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:37	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:38	0	SU	GD	5.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:39	0	SU	GD	4.9	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:40	0	SU	GD	4.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:41	0	SU	GD	4.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:42	0	SU	GD	5.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 13:43	0	SU	GD	4.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 13:44	0	SU	GD	4.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:45	0	SU	GD	4.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:46	0	SU	GD	5.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 13:47	0	SU	GD	6.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
Average	0			5.4			91143			0.0			0.0			0.0			177
Maximum	0			6.5			92000			0.0			0.0			0.0			178
Minimum	0			4.2			91000			0.0			0.0			0.0			176
Total	0			113.6			1914000			0.0			0.0			0.0			3716

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS
05/09/2018 13:27	SU	GD	5.9	SU	GD	7.1	SU	GD	41.0	SU	GD	0.023	SU	GD	13.8	SU	GD
05/09/2018 13:28	SU	GD	6.0	SU	GD	7.2	SU	GD	41.0	SU	GD	0.023	SU	GD	13.8	SU	GD
05/09/2018 13:29	SU	GD	5.5	SU	GD	6.5	SU	GD	37.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 13:30	SU	GD	5.0	SU	GD	6.0	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 13:31	SU	GD	4.9	SU	GD	5.8	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 13:32	SU	GD	5.5	SU	GD	6.6	SU	GD	37.9	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 13:33	SU	GD	6.1	SU	GD	7.4	SU	GD	43.3	SU	GD	0.024	SU	GD	13.7	SU	GD
05/09/2018 13:34	SU	GD	6.3	SU	GD	7.7	SU	GD	45.1	SU	GD	0.025	SU	GD	13.7	SU	GD
05/09/2018 13:35	SU	GD	6.3	SU	GD	7.7	SU	GD	44.6	SU	GD	0.025	SU	GD	13.7	SU	GD
05/09/2018 13:36	SU	GD	5.7	SU	GD	7.0	SU	GD	39.2	SU	GD	0.022	SU	GD	13.7	SU	GD
05/09/2018 13:37	SU	GD	5.2	SU	GD	6.4	SU	GD	35.7	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 13:38	SU	GD	4.8	SU	GD	5.8	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 13:39	SU	GD	4.8	SU	GD	5.8	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 13:40	SU	GD	4.7	SU	GD	5.7	SU	GD	32.1	SU	GD	0.018	SU	GD	13.8	SU	GD
05/09/2018 13:41	SU	GD	4.7	SU	GD	5.7	SU	GD	32.1	SU	GD	0.018	SU	GD	13.7	SU	GD
05/09/2018 13:42	SU	GD	4.8	SU	GD	5.8	SU	GD	32.1	SU	GD	0.018	SU	GD	13.7	SU	GD
05/09/2018 13:43	SU	GD	4.3	SU	GD	5.2	SU	GD	30.3	SU	GD	0.017	SU	GD	13.8	SU	GD
05/09/2018 13:44	SU	GD	4.1	SU	GD	4.9	SU	GD	28.5	SU	GD	0.016	SU	GD	13.8	SU	GD
05/09/2018 13:45	SU	GD	4.5	SU	GD	5.4	SU	GD	30.3	SU	GD	0.017	SU	GD	13.8	SU	GD
05/09/2018 13:46	SU	GD	5.4	SU	GD	6.6	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 13:47	SU	GD	5.8	SU	GD	7.1	SU	GD	41.0	SU	GD	0.023	SU	GD	13.7	SU	GD
Average			5.3			6.4			36.4			0.020			13.8		
Maximum			6.3			7.7			45.1			0.025			13.8		
Minimum			4.1			4.9			28.5			0.016			13.7		
Total			110.3			133.4			764.6			0.428			288.9		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 14:03	0	SU	GD	5.6	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:04	0	SU	GD	4.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:05	0	SU	GD	4.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:06	0	SU	GD	4.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:07	0	SU	GD	4.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:08	0	SU	GD	5.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:09	0	SU	GD	6.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:10	0	SU	GD	6.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	175
05/09/2018 14:11	0	SU	GD	5.3	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	175
05/09/2018 14:12	0	SU	GD	4.6	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:13	0	SU	GD	4.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:14	0	SU	GD	5.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:15	0	SU	GD	5.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 14:16	0	SU	GD	5.9	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 14:17	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:18	0	SU	GD	6.1	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:19	0	SU	GD	6.1	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:20	0	SU	GD	5.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:21	0	SU	GD	5.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:22	0	SU	GD	4.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:23	0	SU	GD	4.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
Average	0			5.3			91048			0.0			0.0			0.0			176
Maximum	0			6.4			92000			0.0			0.0			0.0			178
Minimum	0			4.2			91000			0.0			0.0			0.0			175
Total	0			110.9			1912000			0.0			0.0			0.0			3705

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS
05/09/2018 14:03	SU	GD	5.3	SU	GD	6.5	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 14:04	SU	GD	4.8	SU	GD	5.7	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 14:05	SU	GD	4.2	SU	GD	5.0	SU	GD	28.5	SU	GD	0.016	SU	GD	13.8	SU	GD
05/09/2018 14:06	SU	GD	4.2	SU	GD	5.0	SU	GD	28.5	SU	GD	0.016	SU	GD	13.8	SU	GD
05/09/2018 14:07	SU	GD	4.6	SU	GD	5.5	SU	GD	32.1	SU	GD	0.018	SU	GD	13.8	SU	GD
05/09/2018 14:08	SU	GD	5.5	SU	GD	6.7	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 14:09	SU	GD	6.1	SU	GD	7.4	SU	GD	42.8	SU	GD	0.024	SU	GD	13.7	SU	GD
05/09/2018 14:10	SU	GD	5.8	SU	GD	7.1	SU	GD	41.0	SU	GD	0.023	SU	GD	13.7	SU	GD
05/09/2018 14:11	SU	GD	5.2	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 14:12	SU	GD	4.5	SU	GD	5.4	SU	GD	30.3	SU	GD	0.017	SU	GD	13.8	SU	GD
05/09/2018 14:13	SU	GD	4.3	SU	GD	5.2	SU	GD	30.3	SU	GD	0.017	SU	GD	13.8	SU	GD
05/09/2018 14:14	SU	GD	4.8	SU	GD	5.8	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 14:15	SU	GD	5.4	SU	GD	6.6	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 14:16	SU	GD	5.7	SU	GD	6.8	SU	GD	39.2	SU	GD	0.022	SU	GD	13.8	SU	GD
05/09/2018 14:17	SU	GD	5.7	SU	GD	6.8	SU	GD	39.7	SU	GD	0.022	SU	GD	13.8	SU	GD
05/09/2018 14:18	SU	GD	5.9	SU	GD	7.2	SU	GD	41.0	SU	GD	0.023	SU	GD	13.7	SU	GD
05/09/2018 14:19	SU	GD	5.7	SU	GD	7.0	SU	GD	39.2	SU	GD	0.022	SU	GD	13.7	SU	GD
05/09/2018 14:20	SU	GD	5.3	SU	GD	6.4	SU	GD	37.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 14:21	SU	GD	4.8	SU	GD	5.8	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 14:22	SU	GD	4.7	SU	GD	5.6	SU	GD	32.1	SU	GD	0.018	SU	GD	13.8	SU	GD
05/09/2018 14:23	SU	GD	4.6	SU	GD	5.6	SU	GD	32.1	SU	GD	0.018	SU	GD	13.7	SU	GD
Average			5.1			6.2			35.4			0.020			13.8		
Maximum			6.1			7.4			42.8			0.024			13.8		
Minimum			4.2			5.0			28.5			0.016			13.7		
Total			107.1			129.3			743.8			0.417			289.0		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 14:38	0	SU	GD	5.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:39	0	SU	GD	5.3	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:40	0	SU	GD	5.1	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:41	0	SU	GD	5.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:42	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:43	0	SU	GD	5.9	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:44	0	SU	GD	6.1	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:45	0	SU	GD	5.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:46	0	SU	GD	4.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:47	0	SU	GD	4.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:48	0	SU	GD	4.6	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:49	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 14:50	0	SU	GD	5.9	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 14:51	0	SU	GD	5.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:52	0	SU	GD	5.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:53	0	SU	GD	5.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:54	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 14:55	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:56	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:57	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 14:58	0	SU	GD	5.3	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	175
Average	0			5.4			91000			0.0			0.0			0.0			177
Maximum	0			6.1			91000			0.0			0.0			0.0			178
Minimum	0			4.4			91000			0.0			0.0			0.0			175
Total	0			112.4			1911000			0.0			0.0			0.0			3709

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS
05/09/2018 14:38	SU	GD	5.5	SU	GD	6.6	SU	GD	37.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 14:39	SU	GD	5.3	SU	GD	6.4	SU	GD	37.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 14:40	SU	GD	4.9	SU	GD	5.9	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 14:41	SU	GD	4.9	SU	GD	5.9	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 14:42	SU	GD	5.1	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 14:43	SU	GD	5.7	SU	GD	6.9	SU	GD	39.2	SU	GD	0.022	SU	GD	13.7	SU	GD
05/09/2018 14:44	SU	GD	5.7	SU	GD	7.0	SU	GD	39.2	SU	GD	0.022	SU	GD	13.7	SU	GD
05/09/2018 14:45	SU	GD	5.0	SU	GD	6.1	SU	GD	33.9	SU	GD	0.019	SU	GD	13.7	SU	GD
05/09/2018 14:46	SU	GD	4.3	SU	GD	5.2	SU	GD	30.3	SU	GD	0.017	SU	GD	13.8	SU	GD
05/09/2018 14:47	SU	GD	4.2	SU	GD	5.1	SU	GD	28.5	SU	GD	0.016	SU	GD	13.8	SU	GD
05/09/2018 14:48	SU	GD	4.4	SU	GD	5.3	SU	GD	30.3	SU	GD	0.017	SU	GD	13.8	SU	GD
05/09/2018 14:49	SU	GD	5.2	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 14:50	SU	GD	5.6	SU	GD	6.8	SU	GD	39.2	SU	GD	0.022	SU	GD	13.7	SU	GD
05/09/2018 14:51	SU	GD	5.6	SU	GD	6.7	SU	GD	39.2	SU	GD	0.022	SU	GD	13.8	SU	GD
05/09/2018 14:52	SU	GD	5.5	SU	GD	6.6	SU	GD	37.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 14:53	SU	GD	5.3	SU	GD	6.4	SU	GD	37.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 14:54	SU	GD	5.2	SU	GD	6.3	SU	GD	35.7	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 14:55	SU	GD	5.1	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 14:56	SU	GD	5.2	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 14:57	SU	GD	5.2	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 14:58	SU	GD	5.2	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
Average			5.1			6.2			35.6			0.020			13.8		
Maximum			5.7			7.0			39.2			0.022			13.8		
Minimum			4.2			5.1			28.5			0.016			13.7		
Total			108.1			130.4			747.1			0.419			289.1		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 15:16	0	SU	GD	4.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	176
05/09/2018 15:17	0	SU	GD	4.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:18	0	SU	GD	4.9	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:19	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 15:20	0	SU	GD	5.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 15:21	0	SU	GD	5.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:22	0	SU	GD	5.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 15:23	0	SU	GD	5.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:24	0	SU	GD	5.8	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:25	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:26	0	SU	GD	5.1	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:27	0	SU	GD	5.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 15:28	0	SU	GD	5.0	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 15:29	0	SU	GD	5.5	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:30	0	SU	GD	5.6	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:31	0	SU	GD	5.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:32	0	SU	GD	5.3	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:33	0	SU	GD	5.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:34	0	SU	GD	5.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 15:35	0	SU	GD	5.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 15:36	0	SU	GD	5.4	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
Average	0			5.3			91000			0.0			0.0			0.0			177
Maximum	0			5.8			91000			0.0			0.0			0.0			178
Minimum	0			4.8			91000			0.0			0.0			0.0			176
Total	0			112.0			1911000			0.0			0.0			0.0			3722

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS
05/09/2018 15:16	SU	GD	4.6	SU	GD	5.5	SU	GD	32.1	SU	GD	0.018	SU	GD	13.8	SU	GD
05/09/2018 15:17	SU	GD	4.6	SU	GD	5.5	SU	GD	32.1	SU	GD	0.018	SU	GD	13.8	SU	GD
05/09/2018 15:18	SU	GD	4.7	SU	GD	5.6	SU	GD	32.1	SU	GD	0.018	SU	GD	13.8	SU	GD
05/09/2018 15:19	SU	GD	5.2	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 15:20	SU	GD	5.2	SU	GD	6.4	SU	GD	35.7	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 15:21	SU	GD	5.5	SU	GD	6.6	SU	GD	37.4	SU	GD	0.021	SU	GD	13.8	SU	GD
05/09/2018 15:22	SU	GD	5.4	SU	GD	6.6	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 15:23	SU	GD	5.5	SU	GD	6.7	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 15:24	SU	GD	5.5	SU	GD	6.7	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 15:25	SU	GD	5.2	SU	GD	6.3	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 15:26	SU	GD	5.0	SU	GD	6.0	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 15:27	SU	GD	4.9	SU	GD	5.9	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 15:28	SU	GD	4.8	SU	GD	5.8	SU	GD	33.9	SU	GD	0.019	SU	GD	13.8	SU	GD
05/09/2018 15:29	SU	GD	5.2	SU	GD	6.4	SU	GD	35.7	SU	GD	0.020	SU	GD	13.7	SU	GD
05/09/2018 15:30	SU	GD	5.3	SU	GD	6.5	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 15:31	SU	GD	5.4	SU	GD	6.6	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD
05/09/2018 15:32	SU	GD	5.1	SU	GD	6.1	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 15:33	SU	GD	5.1	SU	GD	6.1	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 15:34	SU	GD	5.1	SU	GD	6.1	SU	GD	35.7	SU	GD	0.020	SU	GD	13.8	SU	GD
05/09/2018 15:35	SU	GD	5.0	SU	GD	6.1	SU	GD	33.9	SU	GD	0.019	SU	GD	13.7	SU	GD
05/09/2018 15:36	SU	GD	5.1	SU	GD	6.2	SU	GD	35.7	SU	GD	0.020	SU	GD	13.7	SU	GD
Average			5.1			6.2			35.3			0.020			13.8		
Maximum			5.5			6.7			37.4			0.021			13.8		
Minimum			4.6			5.5			32.1			0.018			13.7		
Total			107.4			129.9			741.9			0.416			288.9		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 16:23	0	SU	GD	5.5	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 16:24	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:25	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:26	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 16:27	0	SU	GD	5.7	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:28	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:29	0	SU	GD	5.2	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:30	0	SU	GD	5.2	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 16:31	0	SU	GD	5.3	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 16:32	0	SU	GD	5.3	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:33	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:34	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:35	0	SU	GD	5.4	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:36	0	SU	GD	5.4	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:37	0	SU	GD	5.5	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:38	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:39	0	SU	GD	5.5	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:40	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:41	0	SU	GD	5.7	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:42	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:43	0	SU	GD	5.5	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
Average	0			5.5			92143			0.0			0.0			0.0			179
Maximum	0			5.8			93000			0.0			0.0			0.0			180
Minimum	0			5.2			92000			0.0			0.0			0.0			179
Total	0			115.6			1935000			0.0			0.0			0.0			3763

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75			CTG1 CO2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS	PCT	OS	MS
05/09/2018 16:23	SU	GD	5.2	SU	GD	6.3	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:24	SU	GD	5.3	SU	GD	6.5	SU	GD	37.9	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:25	SU	GD	5.2	SU	GD	6.4	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:26	SU	GD	5.4	SU	GD	6.6	SU	GD	37.9	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:27	SU	GD	5.4	SU	GD	6.6	SU	GD	37.9	SU	GD	0.021	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:28	SU	GD	5.1	SU	GD	6.2	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:29	SU	GD	4.9	SU	GD	6.0	SU	GD	34.2	SU	GD	0.019	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:30	SU	GD	5.0	SU	GD	6.1	SU	GD	34.2	SU	GD	0.019	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:31	SU	GD	5.0	SU	GD	6.1	SU	GD	34.2	SU	GD	0.019	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:32	SU	GD	4.9	SU	GD	6.0	SU	GD	34.2	SU	GD	0.019	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:33	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:34	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:35	SU	GD	5.1	SU	GD	6.2	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:36	SU	GD	5.1	SU	GD	6.2	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:37	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:38	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:39	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:40	SU	GD	5.3	SU	GD	6.5	SU	GD	37.9	SU	GD	0.021	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:41	SU	GD	5.2	SU	GD	6.4	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:42	SU	GD	5.5	SU	GD	6.7	SU	GD	37.9	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:43	SU	GD	5.2	SU	GD	6.4	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
Average			5.2			6.3			36.2			0.020			13.7			5.4		
Maximum			5.5			6.7			37.9			0.021			13.7			5.5		
Minimum			4.9			6.0			34.2			0.019			13.7			5.4		
Total			108.8			132.7			759.5			0.421			287.7			114.2		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 16:55	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 16:56	0	SU	GD	5.6	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:57	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:58	0	SU	GD	5.4	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 16:59	0	SU	GD	5.7	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:00	0	SU	GD	5.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 17:01	0	SU	GD	5.6	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 17:02	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 17:03	0	SU	GD	5.3	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:04	0	SU	GD	5.4	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:05	0	SU	GD	5.5	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:06	0	SU	GD	5.5	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:07	0	SU	GD	5.3	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:08	0	SU	GD	5.5	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	181
05/09/2018 17:09	0	SU	GD	6.5	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	181
05/09/2018 17:10	0	SU	GD	6.9	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:11	0	SU	GD	6.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:12	0	SU	GD	5.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	177
05/09/2018 17:13	0	SU	GD	4.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 17:14	0	SU	GD	3.7	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 17:15	0	SU	GD	3.9	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
Average	0			5.5			92238			0.0			0.0			0.0			179
Maximum	0			6.9			93000			0.0			0.0			0.0			181
Minimum	0			3.7			91000			0.0			0.0			0.0			177
Total	0			114.8			1937000			0.0			0.0			0.0			3768

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

MS - General Monitor Status:

CP - clean process equipment GD - good data MN - maintenance activity
 CC - clean control equipment GO - monitor over range IV - invalid
 MD - unknown operating status QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75			CTG1 CO2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS	PCT	OS	MS
05/09/2018 16:55	SU	GD	5.2	SU	GD	6.4	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:56	SU	GD	5.2	SU	GD	6.4	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 16:57	SU	GD	5.2	SU	GD	6.3	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:58	SU	GD	5.1	SU	GD	6.2	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 16:59	SU	GD	5.3	SU	GD	6.5	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:00	SU	GD	5.3	SU	GD	6.5	SU	GD	37.9	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:01	SU	GD	5.2	SU	GD	6.4	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:02	SU	GD	5.1	SU	GD	6.2	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:03	SU	GD	4.9	SU	GD	6.0	SU	GD	34.6	SU	GD	0.019	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:04	SU	GD	5.0	SU	GD	6.1	SU	GD	34.2	SU	GD	0.019	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:05	SU	GD	5.2	SU	GD	6.3	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:06	SU	GD	5.3	SU	GD	6.5	SU	GD	37.9	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:07	SU	GD	5.1	SU	GD	6.2	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:08	SU	GD	5.1	SU	GD	6.2	SU	GD	36.0	SU	GD	0.020	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:09	SU	GD	6.3	SU	GD	7.7	SU	GD	45.1	SU	GD	0.025	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:10	SU	GD	6.4	SU	GD	7.8	SU	GD	45.1	SU	GD	0.025	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:11	SU	GD	6.2	SU	GD	7.5	SU	GD	43.3	SU	GD	0.024	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:12	SU	GD	5.6	SU	GD	6.8	SU	GD	39.7	SU	GD	0.022	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:13	SU	GD	4.2	SU	GD	5.0	SU	GD	28.5	SU	GD	0.016	SU	GD	13.8	SU	GD	5.4	SU	GD
05/09/2018 17:14	SU	GD	3.7	SU	GD	4.4	SU	GD	25.2	SU	GD	0.014	SU	GD	13.8	SU	GD	5.4	SU	GD
05/09/2018 17:15	SU	GD	3.7	SU	GD	4.5	SU	GD	27.0	SU	GD	0.015	SU	GD	13.8	SU	GD	5.4	SU	GD
Average			5.2			6.3			36.3			0.020			13.7			5.4		
Maximum			6.4			7.8			45.1			0.025			13.8			5.5		
Minimum			3.7			4.4			25.2			0.014			13.7			5.4		
Total			108.3			131.9			762.4			0.422			288.0			114.1		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_ST			CTG1 NOX_HIGH_P75			CTG1 OIL_FLOW_EPA			CTG1 CO			CTG1 CO_C15			CTG1 CO_MASS			CTG1 GEN_TOTAL
	MW	OS	MS	PPMD	OS	MS	LBHR	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	MW
05/09/2018 17:28	0	SU	GD	6.2	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:29	0	SU	GD	5.7	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:30	0	SU	GD	5.1	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 17:31	0	SU	GD	4.6	SU	GD	91000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	178
05/09/2018 17:32	0	SU	GD	3.6	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 17:33	0	SU	GD	3.7	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 17:34	0	SU	GD	3.8	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	179
05/09/2018 17:35	0	SU	GD	4.5	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:36	0	SU	GD	5.0	SU	GD	92000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:37	0	SU	GD	5.3	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:38	0	SU	GD	5.7	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:39	0	SU	GD	6.0	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:40	0	SU	GD	5.8	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:41	0	SU	GD	5.8	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:42	0	SU	GD	6.0	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:43	0	SU	GD	6.0	SU	GD	94000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:44	0	SU	GD	5.9	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:45	0	SU	GD	5.8	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:46	0	SU	GD	5.7	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:47	0	SU	GD	5.6	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	180
05/09/2018 17:48	0	SU	GD	5.7	SU	GD	93000	SU	GD	0.0	SU	GD	0.0	SU	GD	0.0	SU	GD	182
Average	0			5.3			92524			0.0			0.0			0.0			180
Maximum	0			6.2			94000			0.0			0.0			0.0			182
Minimum	0			3.6			91000			0.0			0.0			0.0			178
Total	0			111.5			1943000			0.0			0.0			0.0			3775

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

Data Summary Report

Facility Name: CPV_Valley_Wawayanda

Location: Middletown, NY

Source: CTG1

	CTG1 GEN_TOT.		CTG1 NOX_C15_O			CTG1 NOX_LOW_P75			CTG1 NOX_MASS_P75			CTG1 NOX_RATE_P75			CTG1 O2_P75			CTG1 CO2_P75		
	OS	MS	PPMD	OS	MS	PPMD	OS	MS	LBHR	OS	MS	LBMMBTU	OS	MS	PCT	OS	MS	PCT	OS	MS
05/09/2018 17:28	SU	GD	5.8	SU	GD	7.1	SU	GD	41.0	SU	GD	0.023	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:29	SU	GD	5.3	SU	GD	6.5	SU	GD	37.4	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:30	SU	GD	4.9	SU	GD	6.0	SU	GD	34.2	SU	GD	0.019	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:31	SU	GD	4.5	SU	GD	5.4	SU	GD	30.3	SU	GD	0.017	SU	GD	13.8	SU	GD	5.4	SU	GD
05/09/2018 17:32	SU	GD	3.6	SU	GD	4.3	SU	GD	25.2	SU	GD	0.014	SU	GD	13.8	SU	GD	5.4	SU	GD
05/09/2018 17:33	SU	GD	3.6	SU	GD	4.3	SU	GD	25.2	SU	GD	0.014	SU	GD	13.8	SU	GD	5.4	SU	GD
05/09/2018 17:34	SU	GD	3.7	SU	GD	4.4	SU	GD	25.2	SU	GD	0.014	SU	GD	13.8	SU	GD	5.4	SU	GD
05/09/2018 17:35	SU	GD	4.2	SU	GD	5.1	SU	GD	29.2	SU	GD	0.016	SU	GD	13.8	SU	GD	5.4	SU	GD
05/09/2018 17:36	SU	GD	4.7	SU	GD	5.7	SU	GD	32.4	SU	GD	0.018	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:37	SU	GD	5.0	SU	GD	6.1	SU	GD	34.6	SU	GD	0.019	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:38	SU	GD	5.3	SU	GD	6.5	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:39	SU	GD	5.6	SU	GD	6.8	SU	GD	40.1	SU	GD	0.022	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:40	SU	GD	5.5	SU	GD	6.7	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:41	SU	GD	5.4	SU	GD	6.6	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:42	SU	GD	5.5	SU	GD	6.7	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:43	SU	GD	5.7	SU	GD	6.9	SU	GD	40.5	SU	GD	0.022	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:44	SU	GD	5.4	SU	GD	6.7	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:45	SU	GD	5.6	SU	GD	6.8	SU	GD	40.1	SU	GD	0.022	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:46	SU	GD	5.4	SU	GD	6.6	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.5	SU	GD
05/09/2018 17:47	SU	GD	5.3	SU	GD	6.5	SU	GD	38.3	SU	GD	0.021	SU	GD	13.7	SU	GD	5.4	SU	GD
05/09/2018 17:48	SU	GD	5.2	SU	GD	6.4	SU	GD	36.4	SU	GD	0.020	SU	GD	13.7	SU	GD	5.4	SU	GD
Average			5.0			6.1			35.2			0.019			13.7			5.4		
Maximum			5.8			7.1			41.0			0.023			13.8			5.5		
Minimum			3.6			4.3			25.2			0.014			13.7			5.4		
Total			105.2			128.1			739.9			0.408			288.2			113.6		

OS - Operating Status:

SU - startup mode OFF - off-line
 SD - shutdown mode CF - changing fuels
 ON - normal operation CM - control equipment malfunction

CP - clean process equipment
 CC - clean control equipment
 MD - unknown operating status

MS - General Monitor Status:

GD - good data MN - maintenance activity
 GO - monitor over range IV - invalid
 QA - quality assurance activity

CEMS AND REFERENCE METHOD DATA

Reference Method Data

CPV VALLEY LLC
 May 9, 2018
 Siemens, SCC6-5000F, Unit #1
 CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	12,934	gal/hr

Weather Data

Barometric Pressure	29.64	in. Hg
Relative Humidity	32	%
Ambient Temperature	79	°F
Specific Humidity	0.006786	lb H ₂ O / lb air

Unit Data

Unit Load	177.0	megawatts
Stack Exhaust Flow (M19)	48,704,244	SCFH

Max Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
05/09/18 13:27:23	50	13.56	6.78	0.29
05/09/18 13:27:53	80	13.56	6.69	0.34
05/09/18 13:28:23	110	13.55	7.07	0.35
05/09/18 13:28:53	140	13.57	7.23	0.49
05/09/18 13:29:23	170	13.58	7.36	0.40
05/09/18 13:29:53	200	13.58	7.25	0.40
05/09/18 13:30:23	230	13.58	7.19	0.39
05/09/18 13:30:53	260	13.59	6.85	0.41
05/09/18 13:31:23	290	13.57	6.56	0.34
05/09/18 13:31:53	320	13.54	6.34	0.40
05/09/18 13:32:23	350	13.52	6.17	0.29
05/09/18 13:32:53	380	13.53	6.01	0.54
05/09/18 13:33:23	410	13.53	6.28	0.43
05/09/18 13:33:53	440	13.52	6.83	0.41
05/09/18 13:34:23	470	13.52	7.63	0.36
05/09/18 13:34:53	500	13.52	7.84	0.30
05/09/18 13:35:23	530	13.51	7.96	0.50
05/09/18 13:35:53	560	13.52	8.06	0.30
05/09/18 13:36:23	590	13.53	8.24	0.45
05/09/18 13:36:53	620	13.54	8.11	0.46
05/09/18 13:37:23	650	13.55	7.87	0.49
05/09/18 13:37:53	680	13.54	7.60	0.30
05/09/18 13:38:23	710	13.55	7.43	0.24
05/09/18 13:38:53	740	13.55	7.02	0.43
05/09/18 13:39:23	770	13.55	6.48	0.34
05/09/18 13:39:53	800	13.55	6.14	0.38
05/09/18 13:40:23	830	13.55	6.10	0.44
05/09/18 13:40:53	860	13.53	5.97	0.34
05/09/18 13:41:23	890	13.52	5.93	0.47
05/09/18 13:41:53	920	13.53	6.04	0.20
05/09/18 13:42:23	950	13.56	6.10	0.40
05/09/18 13:42:53	980	13.57	6.23	0.31
05/09/18 13:43:23	1010	13.59	6.33	0.35
05/09/18 13:43:53	1040	13.57	6.19	0.41
05/09/18 13:44:23	1070	13.55	5.96	0.38
05/09/18 13:44:53	1100	13.54	5.58	0.41
05/09/18 13:45:23	1130	13.52	5.24	0.27
05/09/18 13:45:53	1160	13.50	5.15	0.50
05/09/18 13:46:23	1190	13.51	5.48	0.30
05/09/18 13:46:53	1220	13.51	5.96	0.47
05/09/18 13:47:23	1250	13.52	6.51	0.32
05/09/18 13:47:53	1280	13.53	7.00	0.39

RAW AVERAGE 13.54 6.68 0.38

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
Serial Number:	inst-O2-0023	INST-NX-0064	INST-CO-0016
Initial Zero	0.00	0.23	-0.09
Final Zero	0.02	0.24	0.09
Avg. Zero	0.01	0.24	0.00
Initial UpScale	11.78	9.76	5.12
Final UpScale	11.78	9.57	5.16
Avg. UpScale	11.78	9.67	5.14

Bias

Upscale Cal Gas 12.02 9.30 5.07

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)	13.82	6.36	0.38
Concentration (ppm@ 15%O ₂)	N/A	5.30	0.31
Emission Rate (lb/hr)	N/A	37.00	1.33
Emission Rate (lb/MMBtu)	N/A	0.021	0.001

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	12,921	gal/hr

Weather Data

Barometric Pressure	29.63	in. Hg
Relative Humidity	33	%
Ambient Temperature	79	°F
Specific Humidity	0.007003	lb H ₂ O / lb air

Unit Data

Unit Load	176.0	megawatts
Stack Exhaust Flow (M19)	48,640,505	SCFH

Max Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
05/09/18 14:03:23	50	13.55	7.32	0.41
05/09/18 14:03:53	80	13.58	7.30	0.32
05/09/18 14:04:23	110	13.60	7.06	0.24
05/09/18 14:04:53	140	13.59	6.82	0.43
05/09/18 14:05:23	170	13.58	6.38	0.23
05/09/18 14:05:53	200	13.56	5.96	0.46
05/09/18 14:06:23	230	13.56	5.52	0.32
05/09/18 14:06:53	260	13.55	5.25	0.31
05/09/18 14:07:23	290	13.53	5.31	0.42
05/09/18 14:07:53	320	13.51	5.45	0.30
05/09/18 14:08:23	350	13.50	5.59	0.43
05/09/18 14:08:53	380	13.49	5.77	0.31
05/09/18 14:09:23	410	13.51	6.13	0.31
05/09/18 14:09:53	440	13.53	6.81	0.40
05/09/18 14:10:23	470	13.55	7.14	0.41
05/09/18 14:10:53	500	13.56	7.60	0.42
05/09/18 14:11:23	530	13.57	7.74	0.30
05/09/18 14:11:53	560	13.57	7.28	0.31
05/09/18 14:12:23	590	13.59	6.96	0.33
05/09/18 14:12:53	620	13.58	6.40	0.26
05/09/18 14:13:23	650	13.57	5.98	0.42
05/09/18 14:13:53	680	13.53	5.67	0.25
05/09/18 14:14:23	710	13.51	5.48	0.42
05/09/18 14:14:53	740	13.51	5.40	0.29
05/09/18 14:15:23	770	13.52	5.52	0.38
05/09/18 14:15:53	800	13.53	5.97	0.31
05/09/18 14:16:23	830	13.53	6.40	0.26
05/09/18 14:16:53	860	13.52	6.85	0.46
05/09/18 14:17:23	890	13.51	7.00	0.27
05/09/18 14:17:53	920	13.51	7.05	0.41
05/09/18 14:18:23	950	13.51	6.98	0.38
05/09/18 14:18:53	980	13.51	7.02	0.38
05/09/18 14:19:23	1010	13.53	7.14	0.33
05/09/18 14:19:53	1040	13.53	7.43	0.37
05/09/18 14:20:23	1070	13.55	7.37	0.44
05/09/18 14:20:53	1100	13.56	7.34	0.33
05/09/18 14:21:23	1130	13.56	6.98	0.42
05/09/18 14:21:53	1160	13.54	6.84	0.26
05/09/18 14:22:23	1190	13.52	6.49	0.36
05/09/18 14:22:53	1220	13.52	6.14	0.29
05/09/18 14:23:23	1250	13.52	5.77	0.30
05/09/18 14:23:53	1280	13.52	5.69	0.39

RAW AVERAGE **13.54** **6.48** **0.35**

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
Serial Number:	inst-O2-0023	INST-NX-0064	INST-CO-0016
Initial Zero	0.02	0.24	0.09
Final Zero	0.02	0.21	0.00
Avg. Zero	0.02	0.23	0.04

Bias

Initial UpScale	11.78	9.57	5.16
Final UpScale	11.78	9.52	5.22
Avg. UpScale	11.78	9.55	5.19

Upscale Cal Gas **12.02** **9.30** **5.07**

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)	13.82	6.24	0.30
Concentration (ppm@ 15%O ₂)	N/A	5.20	0.25
Emission Rate (lb/hr)	N/A	36.28	1.06
Emission Rate (lb/MMBtu)	N/A	0.020	0.001

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	12,914	gal/hr

Weather Data

Barometric Pressure	29.63	in. Hg
Relative Humidity	32	%
Ambient Temperature	78	°F
Specific Humidity	0.006566	lb H ₂ O / lb air

Unit Data

Unit Load	177.0	megawatts
Stack Exhaust Flow (M19)	48,624,352	SCFH

Max Load, Run - 4

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
05/09/18 14:38:23	650	13.57	7.28	0.36
05/09/18 14:38:53	680	13.58	7.56	0.37
05/09/18 14:39:23	710	13.58	6.95	0.36
05/09/18 14:39:53	740	13.58	6.93	0.35
05/09/18 14:40:23	770	13.57	6.82	0.30
05/09/18 14:40:53	800	13.56	6.74	0.37
05/09/18 14:41:23	830	13.54	6.62	0.42
05/09/18 14:41:53	860	13.52	6.45	0.36
05/09/18 14:42:23	890	13.52	6.33	0.28
05/09/18 14:42:53	920	13.51	6.43	0.33
05/09/18 14:43:23	950	13.51	6.62	0.26
05/09/18 14:43:53	980	13.52	6.76	0.44
05/09/18 14:44:23	1010	13.52	7.09	0.44
05/09/18 14:44:53	1040	13.55	7.29	0.22
05/09/18 14:45:23	1070	13.58	7.50	0.31
05/09/18 14:45:53	1100	13.57	7.60	0.23
05/09/18 14:46:23	1130	13.56	7.37	0.43
05/09/18 14:46:53	1160	13.56	7.05	0.29
05/09/18 14:47:23	1190	13.57	6.42	0.43
05/09/18 14:47:53	1220	13.54	6.07	0.33
05/09/18 14:48:23	1250	13.54	5.97	0.40
05/09/18 14:48:53	1280	13.52	5.82	0.41
05/09/18 14:49:23	1310	13.51	5.84	0.22
05/09/18 14:49:53	1340	13.52	6.15	0.30
05/09/18 14:50:23	1370	13.54	6.46	0.48
05/09/18 14:50:53	1400	13.54	6.94	0.23
05/09/18 14:51:23	1430	13.54	7.33	0.42
05/09/18 14:51:53	1460	13.54	7.53	0.16
05/09/18 14:52:23	1490	13.54	7.54	0.30
05/09/18 14:52:53	1520	13.54	7.30	0.27
05/09/18 14:53:23	1550	13.54	7.28	0.30
05/09/18 14:53:53	1580	13.52	7.18	0.35
05/09/18 14:54:23	1610	13.53	7.13	0.22
05/09/18 14:54:53	1640	13.53	6.99	0.42
05/09/18 14:55:23	1670	13.53	7.00	0.32
05/09/18 14:55:53	1700	13.54	7.07	0.31
05/09/18 14:56:23	1730	13.53	6.94	0.32
05/09/18 14:56:53	1760	13.53	6.96	0.30
05/09/18 14:57:23	1790	13.53	6.93	0.48
05/09/18 14:57:53	1820	13.54	6.93	0.27
05/09/18 14:58:23	1850	13.55	6.96	0.41
05/09/18 14:58:53	1880	13.57	6.89	0.33

RAW AVERAGE 13.54 6.88 0.34

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
Serial Number:	inst-O2-0023	INST-NX-0064	INST-CO-0016
Initial Zero	0.02	0.21	0.00
Final Zero	0.01	0.23	0.10
Avg. Zero	0.01	0.22	0.05
Bias			
Initial UpScale	11.78	9.52	5.22
Final UpScale	11.78	9.54	5.19
Avg. UpScale	11.78	9.53	5.21
Upscale Cal Gas	12.02	9.30	5.07

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)	13.82	6.65	0.28
Concentration (ppm@ 15%O ₂)	N/A	5.54	0.23
Emission Rate (lb/hr)	N/A	38.64	0.99
Emission Rate (lb/MMBtu)	N/A	0.022	0.001

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	12,914	gal/hr

Weather Data

Barometric Pressure	29.68	in. Hg
Relative Humidity	31	%
Ambient Temperature	83	°F
Specific Humidity	0.007487	lb H ₂ O / lb air

Unit Data

Unit Load	177.0	megawatts
Stack Exhaust Flow (M19)	48,440,939	SCFH

Max Load, Run - 5

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
05/09/18 15:16:29	80	13.55	6.77	0.41
05/09/18 15:16:59	110	13.54	6.52	0.32
05/09/18 15:17:29	140	13.54	6.35	0.43
05/09/18 15:17:59	170	13.53	6.26	0.26
05/09/18 15:18:29	200	13.52	6.28	0.38
05/09/18 15:18:59	230	13.51	6.06	0.34
05/09/18 15:19:29	260	13.52	6.12	0.24
05/09/18 15:19:59	290	13.52	6.36	0.29
05/09/18 15:20:29	320	13.52	6.59	0.23
05/09/18 15:20:59	350	13.52	6.75	0.44
05/09/18 15:21:29	380	13.51	6.72	0.19
05/09/18 15:21:59	410	13.51	6.76	0.32
05/09/18 15:22:29	440	13.51	6.85	0.33
05/09/18 15:22:59	470	13.51	6.88	0.23
05/09/18 15:23:29	500	13.51	6.87	0.27
05/09/18 15:23:59	530	13.52	7.03	0.18
05/09/18 15:24:29	560	13.52	7.08	0.46
05/09/18 15:24:59	590	13.53	6.87	0.32
05/09/18 15:25:29	620	13.53	6.55	0.32
05/09/18 15:25:59	650	13.54	6.59	0.27
05/09/18 15:26:29	680	13.54	6.52	0.25
05/09/18 15:26:59	710	13.54	6.30	0.43
05/09/18 15:27:29	740	13.53	6.12	0.25
05/09/18 15:27:59	770	13.52	5.99	0.33
05/09/18 15:28:29	800	13.52	5.85	0.34
05/09/18 15:28:59	830	13.51	5.72	0.22
05/09/18 15:29:29	860	13.51	5.85	0.36
05/09/18 15:29:59	890	13.50	6.02	0.30
05/09/18 15:30:29	920	13.52	6.11	0.38
05/09/18 15:30:59	950	13.52	6.34	0.35
05/09/18 15:31:29	980	13.54	6.52	0.29
05/09/18 15:31:59	1010	13.54	6.51	0.25
05/09/18 15:32:29	1040	13.54	6.48	0.26
05/09/18 15:32:59	1070	13.54	6.49	0.31
05/09/18 15:33:29	1100	13.54	6.27	0.25
05/09/18 15:33:59	1130	13.53	6.11	0.39
05/09/18 15:34:29	1160	13.52	6.12	0.36
05/09/18 15:34:59	1190	13.53	6.04	0.35
05/09/18 15:35:29	1220	13.53	5.91	0.38
05/09/18 15:35:59	1250	13.52	5.98	0.38
05/09/18 15:36:29	1280	13.53	6.06	0.42
05/09/18 15:36:59	1310	13.53	6.10	0.27

RAW AVERAGE 13.53 6.37 0.32

	O ₂	NOx	CO
Serial Number:	inst-O2-0023	INST-NX-0064	INST-CO-0016
	(%)	(ppmvd)	(ppmvd)
Initial Zero	0.01	0.23	0.10
Final Zero	0.03	0.15	0.21
Avg. Zero	0.02	0.19	0.16
Initial UpScale	11.78	9.54	9.20
Final UpScale	11.80	9.56	9.11
Avg. UpScale	11.79	9.55	9.16

Bias

Upscale Cal Gas 12.02 9.30 9.10

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)	13.79	6.14	0.16
Concentration (ppm@ 15%O ₂)	N/A	5.10	0.14
Emission Rate (lb/hr)	N/A	35.55	0.58
Emission Rate (lb/MMBtu)	N/A	0.020	0.000

CPV VALLEY LLC
 May 9, 2018
 Siemens, SCC6-5000F, Unit #1
 CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	12,914	gal/hr

Weather Data

Barometric Pressure	29.68	in. Hg
Relative Humidity	31	%
Ambient Temperature	84	°F
Specific Humidity	0.007735	lb H ₂ O / lb air

Unit Data

Unit Load	177.0	megawatts
Stack Exhaust Flow (M19)	48,309,679	SCFH

Max Load, Run - 6

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
05/09/18 15:48:29	80	13.54	6.67	0.40
05/09/18 15:48:59	110	13.54	6.17	0.29
05/09/18 15:49:29	140	13.53	6.08	0.41
05/09/18 15:49:59	170	13.54	6.16	0.25
05/09/18 15:50:29	200	13.54	6.17	0.27
05/09/18 15:50:59	230	13.53	6.22	0.42
05/09/18 15:51:29	260	13.54	6.29	0.20
05/09/18 15:51:59	290	13.53	6.27	0.44
05/09/18 15:52:29	320	13.52	6.33	0.36
05/09/18 15:52:59	350	13.51	6.28	0.31
05/09/18 15:53:29	380	13.52	6.34	0.26
05/09/18 15:53:59	410	13.51	6.28	0.19
05/09/18 15:54:29	440	13.52	6.43	0.31
05/09/18 15:54:59	470	13.52	6.64	0.30
05/09/18 15:55:29	500	13.52	6.56	0.37
05/09/18 15:55:59	530	13.51	6.57	0.50
05/09/18 15:56:29	560	13.52	6.55	0.29
05/09/18 15:56:59	590	13.53	6.65	0.41
05/09/18 15:57:29	620	13.52	6.55	0.11
05/09/18 15:57:59	650	13.51	6.77	0.28
05/09/18 15:58:29	680	13.51	6.78	0.35
05/09/18 15:58:59	710	13.51	6.64	0.25
05/09/18 15:59:29	740	13.50	6.58	0.37
05/09/18 15:59:59	770	13.51	6.86	0.24
05/09/18 16:00:29	800	13.51	6.85	0.29
05/09/18 16:00:59	830	13.50	6.89	0.32
05/09/18 16:01:29	860	13.50	6.98	0.34
05/09/18 16:01:59	890	13.51	6.82	0.34
05/09/18 16:02:29	920	13.50	6.71	0.13
05/09/18 16:02:59	950	13.50	6.79	0.29
05/09/18 16:03:29	980	13.51	6.82	0.36
05/09/18 16:03:59	1010	13.53	6.63	0.19
05/09/18 16:04:29	1040	13.52	6.51	0.22
05/09/18 16:04:59	1070	13.51	6.46	0.28
05/09/18 16:05:29	1100	13.50	6.40	0.30
05/09/18 16:05:59	1130	13.49	6.01	0.34
05/09/18 16:06:29	1160	13.49	6.07	0.30
05/09/18 16:06:59	1190	13.49	6.14	0.23
05/09/18 16:07:29	1220	13.50	6.32	0.30
05/09/18 16:07:59	1250	13.50	6.41	0.39
05/09/18 16:08:29	1280	13.51	6.50	0.19
05/09/18 16:08:59	1310	13.50	6.48	0.46

RAW AVERAGE **13.51** **6.49** **0.31**

		O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
Bias	Serial Number:	inst-O2-0023	INST-NX-0064	INST-CO-0016
		(%)	(ppmvd)	(ppmvd)
	Initial Zero	0.03	0.15	0.21
	Final Zero	0.00	0.16	0.09
	Avg. Zero	0.01	0.16	0.15
	Initial UpScale	11.80	9.56	9.11
Final UpScale	11.79	9.62	9.10	
Avg. UpScale	11.80	9.59	9.11	

Upscale Cal Gas 12.02 9.30 9.10

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)	13.77	6.25	0.16
Concentration (ppm@ 15%O ₂)	N/A	5.17	0.13
Emission Rate (lb/hr)	N/A	36.03	0.56
Emission Rate (lb/MMBtu)	N/A	0.020	0.000

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
CPV VALLEY ENERGY CENTER

Fuel Data

Fuel Fd factor	9,234	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,033,261	Btu/SCF fuel
Turbine Fuel Flow	13,130	gal/hr

Weather Data

Barometric Pressure	29.57	in. Hg
Relative Humidity	33	%
Ambient Temperature	85	°F
Specific Humidity	0.008545	lb H ₂ O / lb air

Unit Data

Unit Load	180.0	megawatts
Stack Exhaust Flow (M19)	49,289,542	SCFH

Max Load, Run - 9

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
05/09/18 17:28:29	80	13.50	8.32	0.30
05/09/18 17:28:59	110	13.51	7.62	0.16
05/09/18 17:29:29	140	13.51	7.41	0.28
05/09/18 17:29:59	170	13.52	7.23	0.27
05/09/18 17:30:29	200	13.52	6.97	0.33
05/09/18 17:30:59	230	13.58	6.66	0.26
05/09/18 17:31:29	260	13.58	6.38	0.24
05/09/18 17:31:59	290	13.57	6.16	0.37
05/09/18 17:32:29	320	13.56	6.03	0.15
05/09/18 17:32:59	350	13.56	5.21	0.33
05/09/18 17:33:29	380	13.55	4.70	0.41
05/09/18 17:33:59	410	13.57	4.56	0.34
05/09/18 17:34:29	440	13.54	4.52	0.40
05/09/18 17:34:59	470	13.56	4.55	0.23
05/09/18 17:35:29	500	13.53	4.76	0.27
05/09/18 17:35:59	530	13.52	4.81	0.25
05/09/18 17:36:29	560	13.53	5.12	0.33
05/09/18 17:36:59	590	13.53	5.25	0.27
05/09/18 17:37:29	620	13.52	5.61	0.34
05/09/18 17:37:59	650	13.52	5.88	0.33
05/09/18 17:38:29	680	13.51	6.03	0.13
05/09/18 17:38:59	710	13.51	6.28	0.41
05/09/18 17:39:29	740	13.53	6.40	0.31
05/09/18 17:39:59	770	13.52	6.83	0.35
05/09/18 17:40:29	800	13.53	6.74	0.21
05/09/18 17:40:59	830	13.52	6.81	0.29
05/09/18 17:41:29	860	13.52	6.75	0.28
05/09/18 17:41:59	890	13.51	6.89	0.25
05/09/18 17:42:29	920	13.52	6.84	0.39
05/09/18 17:42:59	950	13.52	6.84	0.30
05/09/18 17:43:29	980	13.51	6.93	0.28
05/09/18 17:43:59	1010	13.52	6.99	0.13
05/09/18 17:44:29	1040	13.52	7.24	0.33
05/09/18 17:44:59	1070	13.53	7.14	0.19
05/09/18 17:45:29	1100	13.52	7.27	0.29
05/09/18 17:45:59	1130	13.52	6.98	0.22
05/09/18 17:46:29	1160	13.52	6.97	0.22
05/09/18 17:46:59	1190	13.51	6.98	0.30
05/09/18 17:47:29	1220	13.51	6.90	0.26
05/09/18 17:47:59	1250	13.51	6.82	0.25
05/09/18 17:48:29	1280	13.49	6.73	0.17
05/09/18 17:48:59	1310	13.44	6.80	0.34

RAW AVERAGE 13.53 6.38 0.28

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
Serial Number:	inst-O2-0023	INST-NX-0064	INST-CO-0016
Initial Zero	0.03	0.27	0.10
Final Zero	0.01	0.29	0.10
Avg. Zero	0.02	0.28	0.10
Bias			
Initial UpScale	11.78	9.72	9.07
Final UpScale	11.79	9.68	9.11
Avg. UpScale	11.79	9.70	9.09

Upscale Cal Gas 12.02 9.30 9.10

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)	13.80	6.02	0.18
Concentration (ppm@ 15%O ₂)	N/A	5.00	0.15
Emission Rate (lb/hr)	N/A	35.45	0.65
Emission Rate (lb/MMBtu)	N/A	0.020	0.000

APPENDIX C
CALIBRATION GAS CERTIFICATIONS



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0018276	Certification Date:	11/14/2017
Product ID Number:	124731	Expiration Date:	11/13/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0018276.20171101-0	Lot Number:	EB0018276.20171101
Customer PO. NO.:		Tracking Number:	040342692
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	49.7 PPM	±0.6 PPM	FTIR	11/07/2017, 11/14/2017
Air Balance				

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0085284	EB0085284.20161201	11/02/2020	GMIS	AIR	NO2	97 PPM	1.027	5605008

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/06/2017
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/14/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
Analyst

Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Assay Laboratory: Red Ball TGS
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0026154	Certification Date:	09/30/2016
Product ID Number:	125780	Expiration Date:	09/30/2019
Cylinder Pressure:	1900 PSIG	MFG Facility:	RBTGS-Shreveport-LA
COA #	EB0026154.20160901-0	Lot Number:	EB0026154.20160901
Customer PO. NO.:		Tracking Number:	083029619
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	18.41 PPM	±0.07 PPM	FTIR	09/30/2016
Nitric Oxide	18.1 PPM	±0.11 PPM	Chemiluminescence	09/09/2016, 09/17/2016, 09/29/2016
Total Oxides of Nitrogen	18.3 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC279029	091002	03/10/2020	NTRM	N2	CO	19.14 PPM	0.9927	091002
EB0006931	EB0006931.20150713g	10/22/2018	GMIS	N2	NO	14.95 PPM	1.095	121001
EB0011692	EB0011692.20160329g	06/11/2024	GMIS	N2	NO	276.5 PPM	0.476	2735

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	09/06/2016
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/12/2016

Red Ball Technical Gas Service
 PGVP Vendor ID # G12016
 Information and Ordering
 800-551-8150
 Fax (318-425-6309)



Fred Holt

Fred Holt
Analyst

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0098858	Certification Date:	09/19/2017
Product ID Number:	124737	Expiration Date:	09/18/2020
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0098858.20170825-0	Lot Number:	EB0098858.20170825
Customer PO. NO.:		Tracking Number:	095688549
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	9.1 PPM	±0.1 PPM	FTIR	09/08/2017
Nitric Oxide	9.2 PPM	±0.10 PPM	Chemiluminescence	09/12/2017, 09/19/2017
Total Oxides of Nitrogen	9.3 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC279029	091002	03/10/2020	NTRM	N2	CO	19.14 PPM	0.9927	091002
CC-349582	12100115CC-349582	07/22/2019	NTRM	N2	NO	95.2 PPM	1.05	12100115
ALM066143	ALM066143.20160913	05/24/2025	GMIS	N2	NO	31.77 PPM	1.05	12100115
CC238282	CC238282.2015012-0	12/20/2018	GMIS	N2	NO	9.36 PPM	1.004	2628a

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/08/2017
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	08/18/2017
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	09/01/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0027723	Certification Date:	01/26/2018
Product ID Number:	125564	Expiration Date:	01/25/2021
Cylinder Pressure:	1800 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0027723.20171229-0	Lot Number:	EB0027723.20171229
Customer PO. NO.:		Tracking Number:	048406516
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	5.07 PPM	±0.07 PPM	FTIR	01/03/2018
Nitric Oxide	5.09 PPM	±0.06 PPM	Chemiluminescence	01/18/2018, 01/26/2018
Total Oxides of Nitrogen	5.17 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0001986	EB0001986.20160718	01/19/2025	GMIS	N2	NO	90.61 PPM	1.054	12100115
EB0004877	EB0004877.20160721	07/05/2025	GMIS	N2	CO	18.78 PPM	1.005	091002
EB0027596	EB0027596.20151012g	12/20/2018	GMIS	N2	NO	5.802 PPM	1.01	2628a
EB0055450	EB0055450.20140403-0	12/21/2020	GMIS	N2	NO	32.02 PPM	1.058	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	12/26/2017
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	12/22/2017
NO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	12/29/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12017

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0032327	Certification Date:	10/09/2017
Product ID Number:	124605	Expiration Date:	10/07/2025
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0032327.20171005-0	Lot Number:	EB0032327.20171005
Customer PO. NO.:		Tracking Number:	056562288
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	18.7 %	±0.15 %	NDIR	10/09/2017
Oxygen	21.0 %	±0.11 %	MPA	10/09/2017
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0060740	EB0060740.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0064384	EB0064384.20170112	08/13/2025	GMIS	N2	CO2	19.6 %	0.761	101001
SG9916836	SG-9916836	06/06/2022	NTRM	N2	CO2	19.98 %	0.7	101001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	09/13/2017
CO2	NDIR	Thermo	410i	1162980025	09/22/2017

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder

Nate Fielder
Analyst

Assay Laboratory: Red Ball TGS
Version 02-1, Revised on 2017-09-07



Red Ball Technical Gas Service
 555 Craig Kennedy Way
 Shreveport, LA 71107
 800-551-8150
 PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0081248	Certification Date:	03/14/2018
Product ID Number:	124606	Expiration Date:	03/12/2026
Cylinder Pressure:	1900 PSIG	MFG Facility:	- Shreveport - LA
COA #	EB0081248.20180306-0	Lot Number:	EB0081248.20180306
Customer PO. NO.:		Tracking Number:	084092913
Customer:		Previous Certification Dates:	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	8.98 %	±0.08 %	NDIR	03/14/2018
Oxygen	12.02 %	±0.06 %	MPA	03/12/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.


Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0019964	EB0019964.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0032313	EB0032313.20170112	05/22/2025	GMIS	N2	O2	9.34 %	0.235	2658a
EB0045483	EB0045483.20170424	11/25/2025	GMIS	N2	CO2	9.53 %	0.724	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	02/23/2018
CO2	NDIR	Thermo	410i	1162980025	03/14/2018

SMART-CERT



This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

B. Theus

Brandon Theus
 Analytical Chemist
 Assay Laboratory: Red Ball TGS
 Version 02-1, Revised on 2017-09-07

CPV VALLEY LLC
May 9, 2018
Siemens, SCC6-5000F, Unit #1
AETB/QI and PGVP RATA Data Sheet
CPV VALLEY ENERGY CENTER

AirEmissionTestingData - Level 3

QILastName	QIFirstName	QIMiddleInitial	AETBName	AETBPhoneNumber	AETBEmail	ExamDate	ProviderName	ProviderEmail
Stockwell	Michael	D	Air Hygiene International Inc	888-461-8778	info@airhygiene.com	01/06/2017	Source Evaluation Society	qstiprogram@gmail.com

ProtocolGasData - Level 3

GasLevelCode	GasTypeCode	CylinderIdentifier	VendorIdentifier	ExpirationDate
HIGH	BALN,CO2,O2	EB0032327	G12017	1/7/2025
MID	BALN,CO2,O2	EB0081248	G12018	3/12/2026
HIGH	BALN,CO,NO,NOX	EB0026154	G12016	9/30/2019
MID	BALN,CO,NO,NOX	EB0098858	G12017	9/18/2020
LOW	BALN,CO,NO,NOX	EB0027723	G12018	1/25/2021

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the “hands of the test” on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the “hands of the test” on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene’s review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer’s instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3. A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO₂ to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO₂ in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS QUALITY ASSURANCE DATA

Date: May 8-9, 2018
Company: CPV VALLEY LLC
Location: Middletown, New York
Techs: MS/CM

Sample System Leak Check


Date	Sample System	Leak Rate (l/min)
May 8-9, 2018	1	0

Calibration Date: May 9, 2018
 Client: CPV VALLEY LLC

Location: CPV VALLEY ENERGY CENTER - Unit 1


NOx Span (ppm) = 18.30

THERMO 42i-HL (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
0.00	0.07	0.38	0.07	YES (%)
9.30	9.63	1.80	0.33	YES (%)
18.30	18.32	0.11	0.02	YES (%)
Linearity = 1.002				




CO Span (ppm) = 9.10

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
0.00	0.02	0.22	0.02	YES (%)
5.07	5.15	0.88	0.08	YES (%)
9.10	9.18	0.88	0.08	YES (%)
Linearity = 0.993				



O₂ Span (%) = 21.00

SERVOMEX 1440 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail ($\pm 2\%$, $\leq 0.5\%$)
0.00	-0.05	-0.24	0.05	YES (%)
12.02	12.05	0.14	0.03	YES (%)
21.00	21.06	0.29	0.06	YES (%)
Linearity = 0.995				



NOx Converter Efficiency

Date: May 9, 2018

Analyzer: INST-NX-0064

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO₂ to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO₂ concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas: NO₂ Concentration (C_v), ppmvd **49.70**

Converter Efficiency Calculations:

Analyzer Reading, NO Channel, ppmvd	5.20
Analyzer Reading, NOx Channel, ppmvd	53.04
Analyzer Reading, NO ₂ Channel (C _{Dir(NO2)}), ppmvd	47.84
Converter Efficiency, %	96.26

RM 7E, (02-27-14), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{47.84 \text{ ppmvd}}{49.70 \text{ ppmvd}} \times 100 = 96.26\%$$

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
05/09/18 06:30:53	2420	52.35	5.32
05/09/18 06:31:03	2430	52.44	5.30
05/09/18 06:31:13	2440	52.44	5.30
05/09/18 06:31:23	2450	52.44	5.27
05/09/18 06:31:33	2460	52.43	5.24
05/09/18 06:31:43	2470	52.43	5.24
05/09/18 06:31:53	2480	52.52	5.22
05/09/18 06:32:03	2490	52.61	5.16
05/09/18 06:32:13	2500	51.74	5.09
05/09/18 06:32:23	2510	50.69	5.15
05/09/18 06:32:33	2520	51.87	5.20
05/09/18 06:32:43	2530	53.03	5.20
05/09/18 06:32:53	2540	53.09	5.20
05/09/18 06:33:03	2550	53.11	5.19
05/09/18 06:33:13	2560	53.04	5.20

DRIFT AND BIAS CHECK			
Max Load, Run - 1	O₂	NOx	CO
Raw Average	13.56	6.67	0.41
Corrected Average	13.77	6.39	0.43
Initial Zero	0.00	0.16	0.05
Final Zero	0.00	0.23	-0.09
Avg. Zero	0.00	0.20	-0.02
Initial UpScale	11.89	9.47	5.00
Final UpScale	11.78	9.76	5.12
Avg. UpScale	11.84	9.62	5.06
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	5.15
Upscale Cal Gas	12.02	9.30	5.07
Initial Zero Bias	0.25%	0.49%	0.33%
Final Zero Bias	0.26%	0.87%	-1.21%
Zero Drift	0.00%	0.38%	1.54%
Initial Upscale Bias	-0.76%	-0.87%	-1.65%
Final Upscale Bias	-1.29%	0.71%	-0.33%
Upscale Drift	0.52%	1.58%	1.32%
Alternative Specification Abs Diff	Initial Zero	0.05	0.03
	Final Zero	0.05	0.11
	Initial Upscale	0.16	0.15
	Final Upscale	0.27	0.03
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 2	O₂	NOx	CO
Raw Average	13.54	6.68	0.38
Corrected Average	13.82	6.36	0.38
Initial Zero	0.00	0.23	-0.09
Final Zero	0.02	0.24	0.09
Avg. Zero	0.01	0.24	0.00
Initial UpScale	11.78	9.76	5.12
Final UpScale	11.78	9.57	5.16
Avg. UpScale	11.78	9.67	5.14
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	5.15
Upscale Cal Gas	12.02	9.30	5.07
Initial Zero Bias	0.26%	0.87%	-1.21%
Final Zero Bias	0.33%	0.93%	0.77%
Zero Drift	0.08%	0.05%	1.98%
Initial Upscale Bias	-1.29%	0.71%	-0.33%
Final Upscale Bias	-1.29%	-0.33%	0.11%
Upscale Drift	0.00%	1.04%	0.44%
Alternative Specification Abs Diff	Initial Zero	0.05	0.11
	Final Zero	0.07	0.07
	Initial Upscale	0.27	0.03
	Final Upscale	0.27	0.01
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 3	O₂	NOx	CO
Raw Average	13.54	6.48	0.35
Corrected Average	13.82	6.24	0.30
Initial Zero	0.02	0.24	0.09
Final Zero	0.02	0.21	0.00
Avg. Zero	0.02	0.23	0.04
Initial UpScale	11.78	9.57	5.16
Final UpScale	11.78	9.52	5.22
Avg. UpScale	11.78	9.55	5.19
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	5.15
Upscale Cal Gas	12.02	9.30	5.07
Initial Zero Bias	0.33%	0.93%	0.77%
Final Zero Bias	0.32%	0.77%	-0.23%
Zero Drift	0.01%	0.16%	1.00%
Initial Upscale Bias	-1.29%	-0.33%	0.11%
Final Upscale Bias	-1.29%	-0.60%	0.77%
Upscale Drift	0.00%	0.27%	0.66%
Alternative Specification Abs Diff	Initial Zero	0.07	0.17
	Final Zero	0.07	0.14
	Initial Upscale	0.27	0.06
	Final Upscale	0.27	0.11
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 4	O₂	NOx	CO
Raw Average	13.54	6.88	0.34
Corrected Average	13.82	6.65	0.28
Initial Zero	0.02	0.21	0.00
Final Zero	0.01	0.23	0.10
Avg. Zero	0.01	0.22	0.05
Initial UpScale	11.78	9.52	5.22
Final UpScale	11.78	9.54	5.19
Avg. UpScale	11.78	9.53	5.21
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	5.15
Upscale Cal Gas	12.02	9.30	5.07
Initial Zero Bias	0.32%	0.77%	-0.23%
Final Zero Bias	0.29%	0.87%	0.88%
Zero Drift	0.03%	0.11%	1.11%
Initial Upscale Bias	-1.29%	-0.60%	0.77%
Final Upscale Bias	-1.29%	-0.49%	0.44%
Upscale Drift	0.00%	0.11%	0.33%
Alternative Specification Abs Diff	Initial Zero	0.07	0.14
	Final Zero	0.06	0.16
	Initial Upscale	0.27	0.11
	Final Upscale	0.27	0.09
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 5	O₂	NOx	CO
Raw Average	13.53	6.37	0.32
Corrected Average	13.79	6.14	0.16
Initial Zero	0.01	0.23	0.10
Final Zero	0.03	0.15	0.21
Avg. Zero	0.02	0.19	0.16
Initial UpScale	11.78	9.54	9.20
Final UpScale	11.80	9.56	9.11
Avg. UpScale	11.79	9.55	9.16
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	9.18
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.29%	0.87%	0.88%
Final Zero Bias	0.38%	0.44%	2.09%
Zero Drift	0.09%	0.44%	1.21%
Initial Upscale Bias	-1.29%	-0.49%	0.22%
Final Upscale Bias	-1.19%	-0.38%	-0.77%
Upscale Drift	0.10%	0.11%	0.99%
Alternative Specification Abs Diff	Initial Zero	0.06	0.16
	Final Zero	0.08	0.08
	Initial Upscale	0.27	0.09
	Final Upscale	0.25	0.07
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 6	O₂	NOx	CO
Raw Average	13.51	6.49	0.31
Corrected Average	13.77	6.25	0.16
Initial Zero	0.03	0.15	0.21
Final Zero	0.00	0.16	0.09
Avg. Zero	0.01	0.16	0.15
Initial UpScale	11.80	9.56	9.11
Final UpScale	11.79	9.62	9.10
Avg. UpScale	11.80	9.59	9.11
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	9.18
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.38%	0.44%	2.09%
Final Zero Bias	0.23%	0.49%	0.77%
Zero Drift	0.15%	0.05%	1.32%
Initial Upscale Bias	-1.19%	-0.38%	-0.77%
Final Upscale Bias	-1.24%	-0.05%	-0.88%
Upscale Drift	0.05%	0.33%	0.11%
Alternative Specification Abs Diff	Initial Zero	0.08	0.08
	Final Zero	0.05	0.09
	Initial Upscale	0.25	0.07
	Final Upscale	0.26	0.01
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 7	O₂	NOx	CO
Raw Average	13.52	6.40	0.30
Corrected Average	13.78	6.14	0.25
Initial Zero	0.00	0.16	0.09
Final Zero	0.02	0.09	0.01
Avg. Zero	0.01	0.13	0.05
Initial UpScale	11.79	9.62	9.10
Final UpScale	11.79	9.64	9.18
Avg. UpScale	11.79	9.63	9.14
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	9.18
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.23%	0.49%	0.77%
Final Zero Bias	0.32%	0.11%	-0.11%
Zero Drift	0.09%	0.38%	0.88%
Initial Upscale Bias	-1.24%	-0.05%	-0.88%
Final Upscale Bias	-1.24%	0.05%	0.00%
Upscale Drift	0.00%	0.11%	0.88%
Alternative Specification Abs Diff	Initial Zero	0.05	0.07
	Final Zero	0.07	0.01
	Initial Upscale	0.26	0.01
	Final Upscale	0.26	0.01
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 8	O₂	NOx	CO
Raw Average	13.51	6.60	0.28
Corrected Average	13.79	6.28	0.23
Initial Zero	0.02	0.09	0.01
Final Zero	0.03	0.27	0.10
Avg. Zero	0.02	0.18	0.06
Initial UpScale	11.79	9.64	9.18
Final UpScale	11.78	9.72	9.07
Avg. UpScale	11.79	9.68	9.13
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	9.18
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.32%	0.11%	-0.11%
Final Zero Bias	0.37%	1.09%	0.88%
Zero Drift	0.05%	0.98%	0.99%
Initial Upscale Bias	-1.24%	0.05%	0.00%
Final Upscale Bias	-1.29%	0.49%	-1.21%
Upscale Drift	0.05%	0.44%	1.21%
Alternative Specification Abs Diff	Initial Zero	0.07	0.02
	Final Zero	0.08	0.20
	Initial Upscale	0.26	0.01
	Final Upscale	0.27	0.09
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 9	O₂	NOx	CO
Raw Average	13.53	6.38	0.28
Corrected Average	13.80	6.02	0.18
Initial Zero	0.03	0.27	0.10
Final Zero	0.01	0.29	0.10
Avg. Zero	0.02	0.28	0.10
Initial UpScale	11.78	9.72	9.07
Final UpScale	11.79	9.68	9.11
Avg. UpScale	11.79	9.70	9.09
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	9.18
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.37%	1.09%	0.88%
Final Zero Bias	0.30%	1.20%	0.88%
Zero Drift	0.07%	0.11%	0.00%
Initial Upscale Bias	-1.29%	0.49%	-1.21%
Final Upscale Bias	-1.24%	0.27%	-0.77%
Upscale Drift	0.05%	0.22%	0.44%
Alternative Specification Abs Diff	Initial Zero	0.08	0.08
	Final Zero	0.06	0.08
	Initial Upscale	0.27	0.11
	Final Upscale	0.26	0.07
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK			
Max Load, Run - 9	O₂	NOx	CO
Raw Average	13.53	6.38	0.28
Corrected Average	13.80	6.02	0.18
Initial Zero	0.03	0.27	0.10
Final Zero	0.01	0.29	0.10
Avg. Zero	0.02	0.28	0.10
Initial UpScale	11.78	9.72	9.07
Final UpScale	11.79	9.68	9.11
Avg. UpScale	11.79	9.70	9.09
Sys Resp (Zero)	-0.05	0.07	0.02
Sys Resp (Upscale)	12.05	9.63	9.18
Upscale Cal Gas	12.02	9.30	9.10
Initial Zero Bias	0.37%	1.09%	0.88%
Final Zero Bias	0.30%	1.20%	0.88%
Zero Drift	0.07%	0.11%	0.00%
Initial Upscale Bias	-1.29%	0.49%	-1.21%
Final Upscale Bias	-1.24%	0.27%	-0.77%
Upscale Drift	0.05%	0.22%	0.44%
Alternative Specification Abs Diff	Initial Zero	0.08	0.08
	Final Zero	0.06	0.08
	Initial Upscale	0.27	0.11
	Final Upscale	0.26	0.07
Calibration Span	21.00	18.30	9.10
3% of Cal. Span (drift)	0.63	0.55	0.27
5% of Cal. Span (bias)	1.05	0.92	0.46

DRIFT AND BIAS CHECK		
Strat Test Pre and Post QA/QC Check	O2	NOx
Initial Zero	0.06	0.50
Final Zero	0.01	-0.01
Avg. Zero	0.04	0.25
Initial UpScale	11.98	5.08
Final UpScale	12.01	5.17
Avg. UpScale	12.00	5.13
Sys Resp (Zero)	-0.05	0.10
Sys Resp (Upscale)	12.02	5.21
Upscale Cal Gas	12.02	5.17
Initial Zero Bias	0.50%	4.30%
Final Zero Bias	0.27%	-1.14%
Zero Drift	0.24%	5.44%
Initial Upscale Bias	-0.19%	-1.40%
Final Upscale Bias	-0.05%	-0.43%
Upscale Drift	0.14%	0.97%
Alternative Specification Abs Diff	Initial Zero	0.11
	Final Zero	0.06
	Initial Upscale	0.04
	Final Upscale	0.01
Calibration Span	21.00	9.30
3% of Range (drift)	0.63	0.28
5% of Range (bias)	1.05	0.47

Response Time (min)	0.7	2.8
Sys. Response (min)	2.8	

Date/Time mm/dd/yy hh:mm:ss	z	O2 %	s z	NOx PPM	s	INJECTIONS
6:32:14		13.38		7.75		
6:32:24		13.41		7.84		
6:32:34		11.92		7.92		
6:32:44		0.89		7.97		
6:32:54	x	0.10		7.37		
6:33:04		0.06		7.82		
6:33:14		0.05		5.24		
6:33:24		0.04		0.94		
6:33:34		0.03		3.81		
6:33:44		0.02		7.02		
6:33:54		0.02		7.39		
6:34:04		0.02		8.11		
6:34:14		0.02		8.14		
6:34:24		0.01		8.66		
6:34:34		0.01		5.43		
6:34:44		0.01		2.43		
6:34:54		0.00		1.88		
6:35:04		0.00	x	0.67		
6:35:14		0.00		0.62		
6:35:24		0.00		0.54		
6:35:34		0.00		0.46		
6:35:44		0.00		0.37	x	
6:35:54		0.00		0.34		
6:36:04		0.89		0.29		
6:36:14		10.56		0.30		
6:36:24		11.67	x	0.28		
6:36:34		11.92		0.27		
6:36:44		11.96		0.26		
6:36:54		11.96		0.26		
6:37:04		11.98		0.25		
6:37:14		11.97		0.25		
6:37:24		11.98		0.24		
6:37:34		11.99		0.24	x	
6:37:44		9.57		0.24		
6:37:54		0.51		0.23		
6:38:04		0.10		0.22		
6:38:14		0.07		0.22		
6:38:24		0.05		0.22		
6:38:34		0.03		0.22		
6:38:44		0.03		0.22		
6:38:54		0.02		0.21		
6:39:04		0.02		0.20		
6:39:14		0.01		0.21		
6:39:24		0.01		0.20		
6:39:34		0.01		1.18		
6:39:44		0.00		1.47		
6:39:54		0.01		2.79		
6:40:04		0.00		4.70		
6:40:14		0.00		4.81		



Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 General requirements for the competence of testing and calibration laboratories. This laboratory also meets the NELAP Institute Field Sampling and Measurement Organization Volume 1 (TNI FSMO V1 2007, Rev 0.1) requirements. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated 8 January 2009).



Presented this 20th day of July 2015



President & CEO

For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2017

For the tests to which this accreditation applies, please refer to the laboratory's Environmental Scope of Accreditation.



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited


AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036 - Standard Practice for Competence of Air Emission Testing Bodies.



Presented this 20th day of July 2015.



President & CEO
Certificate Number 3796.02
Valid to August 31, 2017

This accreditation program is not included under the A2LA ILAC Recognition Arrangement.

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

MICHAEL D. STOCKWELL

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR


GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 6TH DAY OF JANAUARY 2017 AND EFFECTIVE UNTIL JANAURY 5TH, 2022





Peter R. Westlin, QSTI/QSTO Review Board

Peter R. Westlin, QSTI/QSTO Review Board


Peter S. Pakalnis, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board


Theresa M. Lowe, QSTI/QSTO Review Board

Theresa M. Lowe, QSTI/QSTO Review Board



J. Wade Bice, QSTI/QSTO Review Board



Karen D. Kajiya-Mills, QSTI/QSTO Review Board



Bruce Randall QSTI/QSTO Review Board

CERTIFICATE

NO.

2010-503

APPENDIX E
FUEL ANALYSIS RECORDS

Client: CPV VALLEY LLC
Location: CPV VALLEY ENERGY CENTER
Date: May 9, 2018
Project #: sie-17-middletown.ny-start#1

Fuel Oil - Fuel Analysis

Characteristics of Fuel Gas		
Molecular Weight of oil =	15.243	lb/lb-mole
Btu per lb. of oil =	19,602.00	gross (HHV)
Btu per lb. of oil =	18,371.000	net (LHV)
Density of fuel oil ² =	52.7120	lb/cu. ft
Density of fuel oil ² =	7.0466	lb/gal
Specific Gravity =	0.8461	@ 68 deg F

Standardized to 68 deg F and 14.696 psia

Component	Wt%
carbon	86.21
oxygen	0.00
hydrogen	13.49
nitrogen	0.00
helium	0.00
sulfur	0.00
Total	99.70

Fuel Oil HHV Conv.	
HHV (Btu/lb)	19,602.00
HHV (Btu/SCF)	1,033,261

Fuel Oil LHV Conv.	
LHV (Btu/lb)	18,371.00
LHV (Btu/SCF)	968,373

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 9,234.02 (Based on EPA RM-19) at 68 deg F and 14.696 psia
--

F-Factor Calculation:

$$F\text{-Factor} = 1,000,000 * ((3.64 * \%H) + (1.53 * \%C) + (0.57 * \%S) + (0.14 * \%N) - (0.46 * \%O)) / GCV$$

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of fuel oil based on lab analysis or specific gravity multiplied by density of water at 68 deg F and 14.696 psia.

References:

¹ ASTM D 3588

² Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

³ Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

⁴ Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

⁵ GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-001	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 02:25 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,602
Net Heat of Combustion	18,371

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.79
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.27
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8486
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8381
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8275
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.21
Hydrogen	13.49
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-002	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 02:45 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,601
Net Heat of Combustion	18,369

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.82
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.25
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8487
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8381
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8275
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.20
Hydrogen	13.50
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-003	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 03:05 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,602
Net Heat of Combustion	18,375

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.82
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.26
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.26
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8488
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8382
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8276
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.25
Hydrogen	13.45
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.





Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-004	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 03:25 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,604
Net Heat of Combustion	18,372

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.82
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.27
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8488
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8383
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8275
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.20
Hydrogen	13.50
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-005	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 03:45 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,602
Net Heat of Combustion	18,375

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.84
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.28
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.26
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8489
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8383
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8277
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.25
Hydrogen	13.45
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



Certificate of Analysis



SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400

FAX: (281) 495-2410

CLIENT:	Siemens Power Generation, Inc.	REQUESTED BY:	Mr. Steve Turner
CLIENT PROJECT:	Valley Energy Center	PURCHASE ORDER NO:	4500780102
LABORATORY NO:	87519-006	REPORT DATE:	May 17, 2018
SAMPLE:	Sample "A" 04:05 2018-05-09		

Heat of Combustion of Liquid Hydrocarbon Fuel by Bomb Calorimeter, ASTM D 4809

	<u>Results, BTU/lb</u>
Gross Heat of Combustion	19,601
Net Heat of Combustion	18,374

<u>Parameter</u>	<u>Results</u>
Viscosity, Kinematic, at 60°F, cSt, ASTM D 445.d, cSt	3.83
Viscosity, Kinematic, at 70°F, cSt, ASTM D 445.d, cSt	3.25
Viscosity, Kinematic, at 100°F, cSt, ASTM D 445.d, cSt	2.26
Density by Digital Density Meter @ 15°C, Density, ASTM D 4052, g/cm ³	0.8490
Density by Digital Density Meter @ 30°C, Density, ASTM D 4052, g/cm ³	0.8383
Density by Digital Density Meter @ 45°C, Density, ASTM D 4052, g/cm ³	0.8277
Sulfur by X-Ray Fluorescence Spectroscopy, ASTM D 4294, wt. %	<0.010

Carbon, Hydrogen and Nitrogen in Petroleum Products, Instrumental, ASTM D 5291.a

	<u>Results, wt. %</u>
Carbon	86.25
Hydrogen	13.45
Nitrogen	<0.30
Oxygen	<0.30

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

Cert. No.: 0005085, 17025

Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.



APPENDIX F
STRATIFICATION TEST DATA

Source Information	
Company	CPV Valley LLC
Plant Name	CPV Valley Energy Center
Equipment	Siemens SCC6-5000F, CTG1 and CTG2
Location	Middletown, New York

Test Information	
Date	05/08/18
Project #	sie-17-middletown.ny-start#1
Unit Number	1
Load	multiple
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing)	Circular Stack
<input type="radio"/> Velocity Traverse (Flow and Flow RATA Test)	
<input type="radio"/> Stratification Traverse (Compliance Test) <input type="checkbox"/> RM 20	
<input checked="" type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input checked="" type="checkbox"/> Part 75	

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	CPV Valley LLC	Date	05/08/18
Plant Name	CPV Valley Energy Center	Project #	sie-17-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, CTG1 and CTG2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	239.00	in.
Distance to Near Wall of Stack	(L _{nw})	6.75	in.*
Diameter of Stack	(D)	232.25	in.
Area of Stack	(A _s)	294.20	ft ²



*assume 6.75 in. reference (must be measured and verified in field)

Distance from Disturbances to Port			
Distance Upstream	(A)	1200.00	in.
Diameters Upstream	(A _D)	5.17	diameters
Distance Downstream	(B)	1095.00	in.
Diameters Downstream	(B _D)	4.71	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of Traverse Points		Minimum Number of Traverse Points	
Down (B _D) Stream	Up (A _D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>= 2.00	8 or 12 ²	8 or 12 ²	Minimum Number of Traverse Points	
Upstream Spec		12	12	RATA Stratification	
Downstream Spec		24	16	Criteria	Points
Traverse Pts Required		24	16	Part75/60	12 RM1 pts
¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.					
² 8 for Circular Stacks 12 to 24 inches 12 for Circular Stacks over 24 inches					

Number of Traverse Points Used				
4	Ports by	3	Pts / port	Stratification Traverse Required (RATA)
12	Pts Used	12	Required	

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	10 2/8	17
2	14.6%	33 7/8	40 5/8
3	29.6%	68 6/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	CPV Valley LLC	Date	05/08/18
Plant Name	CPV Valley Energy Center	Project #	sie-17-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, CTG1 and CTG2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	232.25	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	294.20	ft ²	Run Start	6:46:44	Run End	8:01:44


Traverse Point	Time Per Point	Point Start Time	Point Stop Time (Reading)	O2	Percent Difference	NOx	Percent Difference	
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%	
D-3	6.00	6:46:44	6:52:44	13.68	0.02%	7.19	9.73%	5.9325069
D-2	6.00	6:52:44	6:58:44	13.67	0.09%	7.40	7.09%	5.8754848
D-1	6.00	6:58:44	7:04:44	13.68	0.02%	7.51	5.71%	6.0387275
C-3	6.00	7:04:44	7:10:44	13.61	0.53%	7.83	1.69%	6.1369806
C-2	6.00	7:10:44	7:16:44	13.60	0.60%	7.92	0.56%	6.337037
C-1	6.00	7:16:44	7:22:44	13.65	0.24%	7.83	1.69%	6.4010959
B-3	8.00	7:22:44	7:30:44	13.70	0.13%	8.52	6.97%	6.372
B-2	6.00	7:30:44	7:36:44	13.70	0.13%	8.47	6.34%	6.9816667
B-1	6.00	7:36:44	7:42:44	13.77	0.64%	8.67	8.85%	6.9406944
A-3	7.00	7:42:44	7:49:44	13.71	0.20%	8.03	0.82%	7.1743338
A-2	6.00	7:49:44	7:55:44	13.72	0.27%	8.26	3.70%	6.5892907
A-1	6.00	7:55:44	8:01:44	13.70	0.13%	7.95	0.19%	6.7874652
Average				13.68		7.97		6.5145833

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	CPV Valley LLC	Date	05/08/18
Plant Name	CPV Valley Energy Center	Project #	sie-17-middletown.ny-start#1
Equipment	Siemens SCC6-5000F, CTG1 and CTG2	# of Ports Available	4
Location	Middletown, New York	# of Ports Used	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	232.25	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	294.20	ft ²	Run Start	6:46:44	Run End	8:01:44

40 CFR 75 Criteria													
Stratification Results													
Maximum Percent Difference	9.73 % for NO _x		Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length							
Maximum Pollutant Conc. Diff.	0.78 ppm for NO _x												
Maximum Diluent Conc. Diff.	0.09 % for O ₂												
Stack Diameter	232.25 in.			%	in.	in.							
Stratification Conclusions													
			1	>16.95%	>39.37	>46.12							
Maximum % Diff.	Percent Diff. ≤10% Passed 6.5.6.3(a) Criteria		2										
Maximum Conc. Diff.	Conc. Diff. ≤ 0.3% Passed 6.5.6.3(b) Criteria		3										
Stack Diameter	D > 93.6 in.												
Passed Strat. Test Under 6.5.6.3(b) Criteria			<table border="0"> <tr> <td rowspan="3">Test Type</td> <td><input type="checkbox"/> Moisture, for MW</td> <td><input type="checkbox"/> Use 6.5.6.3(a) points?</td> </tr> <tr> <td><input type="checkbox"/> Moisture, for wet-to-dry</td> <td><input type="checkbox"/> 6.5.6(b)(2) alt. points could apply</td> </tr> <tr> <td><input checked="" type="checkbox"/> Gas</td> <td></td> </tr> </table>				Test Type	<input type="checkbox"/> Moisture, for MW	<input type="checkbox"/> Use 6.5.6.3(a) points?	<input type="checkbox"/> Moisture, for wet-to-dry	<input type="checkbox"/> 6.5.6(b)(2) alt. points could apply	<input checked="" type="checkbox"/> Gas	
Test Type	<input type="checkbox"/> Moisture, for MW	<input type="checkbox"/> Use 6.5.6.3(a) points?											
	<input type="checkbox"/> Moisture, for wet-to-dry	<input type="checkbox"/> 6.5.6(b)(2) alt. points could apply											
	<input checked="" type="checkbox"/> Gas												



**this page intentionally left blank
end of report**

ATTACHMENT 5

Opacity Monitoring Plan



Visible Emissions Observation

Valley Energy Center

Rev: 1

Rev Date: 10/26/2018

3102-VEC-PRO

1.0	PURPOSE.....	2
2.0	APPLICABILITY	2
3.0	REFERENCES.....	2
4.0	DEFINITIONS	2

ATTACHMENTS

2403.01-VEC-TOL Visible Emission Observations Log Sheet

Valley Energy Center

Rev: 1

Rev Date: 10/26/2018

3102-VEC-PRO

1.0 PURPOSE

To establish a procedure for the determination of visible emissions compliance for the Valley Energy Center.

2.0 APPLICABILITY

This procedure applies to the Valley Energy Center.

3.0 REFERENCES

1. The regulatory requirements pertaining to compliance with visible emission standards are contained in the facility State Air Permit 3-3356-00136/00001 Condition 61 and 62

4.0 DEFINITIONS

- 4.1 **Visible Emissions:** Particulate or gaseous matter that can be detected by the human eye. The radiant energy from an open flame is not considered a visible emission under this definition
- 4.2 **Opacity:** The degree to which an emission of air contaminants obstructs the transmission of light expressed as the percentage of light obstructed as measured by an optical instrument or trained observer.
- 4.3 **Method 9:** The EPA approved method for quantifying the opacity of emissions (determining a numerical value). This method will be utilized for all sources except for flares at the Valley Energy Center. The observer must be certified for performing this measurement.

5.0 REGULATORY REQUIREMENTS

- 5.1 Permit Condition 61: No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six-minute period per hour, not to exceed 27 percent, based upon the six-minute average in reference test Method 9 in Appendix A of 40 CFR 60.
- 5.2 Permit Condition 62: No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (six-minute

Valley Energy Center

Rev: 1

Rev Date: 10/26/2018

3102-VEC-PRO

average), except for one-six-minute period per hour of not more than 27 percent opacity. The Department reserves the right to perform or require the performance of a Method 9 opacity evaluation at any time during facility operation.

- 5.3 The permittee will conduct observations of visible emissions from the emission unit, process, etc. to which this condition applies at the monitoring frequency stated below while the process is in operation. The permittee will investigate, in a timely manner, any instance where there is causing to believe that visible emissions have the potential to exceed the opacity standard.
- 5.4 The permittee shall investigate the cause, make any necessary corrections, and verify that the excess visible emissions problem has been corrected. If visible emissions with the potential to exceed the standard continue, the permittee will conduct a Method 9 assessment within the next operating day of the sources associated with the potential noncompliance to determine the degree of opacity and will notify the NYSDEC if the method 9 test indicates that the opacity standard is not met.
- 5.5 Records of visible emissions observations (or any follow-up method 9 tests), investigations and corrective actions will be kept on-site. Should the Department determine that permittee's record keeping format is inadequate to demonstrate compliance with this condition, it shall provide written notice to the permittee stating the inadequacies, and permittee shall have 90 days to revise its prospective record-keeping format in a manner acceptable to the Department.

6.0 Procedure

6.1 Daily Visible Emissions Observations

Observe Unit 11 and 12 stacks for visible emissions least once each day during daylight hours when the unit operates on ***fuel oil***. Log each observation on attached Visible Emission Observations Log Sheet.

If visible emissions are observed, immediately contact the control room to take corrective actions to minimize visible emissions. Continue to observe the visible emissions for the next six minutes and note all deviations on the log sheet.

Valley Energy Center

Rev: 1

Rev Date: 10/26/2018

3102-VEC-PRO

If the visible emissions stop after the corrective actions, note the duration of the visible emissions and document the corrective actions in the Log Sheet.

If visible emissions continue for more than six minutes, contact the Plant Manager to dispatch a certified Method 9 observer to verify the visible emissions.

6.2 Non-Routine Observations

If visible emissions are observed at the time OTHER than the daily observation for more than six (6) minutes in a one (1) hour period. Immediately contact the control room to take corrective actions to minimize visible emissions and documents the observation event in the Log Sheet.

Contact the Plant Manager to dispatch a certified Method 9 observer to verify the visible emissions.

6.3 Method 9

The facility will schedule and ensure that a Method 9 Opacity observation is performed within the next operating day to verify the visible emissions. If the Method 9 observations indicate that the opacity standard has not been met. The Plant Manager or the EH&S Coordinator will notify the NYSDEC of this deviation.

Records of the Method 9 observation must be documented and filed with the Visible Emission Observations Log Sheet.



Visible Emissions Observation

Valley Energy Center

Rev: 1

Rev Date: 10/26/2018

3102-VEC-PRO

Revision History Log

Rev.	Date	Description	By Initials	Approved Initials
0	01/2018 (estimated)	Initial	DT	BS
1	10/26/2018	Updated to standard document format, issued appropriate procedure number and made minor edits and corrections.	BS	BS

**3102.02-VEC-TOL Rev.1
Valley Energy Center
Visible Emission Observations Log Sheet**

Date of Observation:	Start Time:	Stop Time:
Emission Unit Observe:	Operation Status:	Online Offline
Emission Unit Operation Condition:		
Weather Conditions:		
Did you observe any visible emissions on the emission unit?	Yes	No
*If visible emissions is observed, immediately contact the control room to take corrective actions to minimize visible emissions. Continue to observe the visible emissions for the next six minutes and note all deviation on the log sheet.		
Additional Comments:		
Observer Name (Print):		

Date of Observation:	Start Time:	Stop Time:
Emission Unit Observe:	Operation Status:	Online Offline
Emission Unit Operation Condition:		
Weather Conditions:		
Did you observe any visible emissions on the emission unit?	Yes	No
*If visible emissions is observed, immediately contact the control room to take corrective actions to minimize visible emissions. Continue to observe the visible emissions for the next six minutes and note all deviation on the log sheet.		
Additional Comments:		
Observer Name (Print):		

Date of Observation:	Start Time:	Stop Time:
Emission Unit Observe:	Operation Status:	Online Offline
Emission Unit Operation Condition:		
Weather Conditions:		
Did you observe any visible emissions on the emission unit?	Yes	No
*If visible emissions is observed, immediately contact the control room to take corrective actions to minimize visible emissions. Continue to observe the visible emissions for the next six minutes and note all deviation on the log sheet.		
Additional Comments:		
Observer Name (Print):		

Date of Observation:	Start Time:	Stop Time:
Emission Unit Observe:	Operation Status:	Online Offline
Emission Unit Operation Condition:		
Weather Conditions:		
Did you observe any visible emissions on the emission unit?	Yes	No
*If visible emissions is observed, immediately contact the control room to take corrective actions to minimize visible emissions. Continue to observe the visible emissions for the next six minutes and note all deviation on the log sheet.		
Additional Comments:		
Observer Name (Print):		

ATTACHMENT 6

Revised Title V Application

New York State Department of Environmental Conservation Air Permit Application



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Application ID											
-										/	

Application Type	
State Facility	* Title V

Section I - Certification

Certification	
I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons directly responsible for gathering the information required to complete this application, I believe the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.	
Responsible Official Donald Atwood	Title Asset Management Rep.
Signature	Date 08-24-2018
Professional Engineer Certification	
I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments as they pertain to the practice of engineering. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.	
Professional Engineer Peter T. Belmont	NYS License No. 0825409
Signature	Date 8-27-2018



Section II - Identification Information

Type of Permit Action Requested				
<input checked="" type="checkbox"/> New	<input type="checkbox"/> Renewal	<input type="checkbox"/> Significant Modification	<input type="checkbox"/> Administrative Amendment	<input type="checkbox"/> Minor Modification
Application for the construction of a new facility		Application involves the construction of new emission unit(s)		
Facility Information				
Name CPV Valley Energy Center				
Location Address 3330 Route 6				
* City / Town / Village Middletown, NY				Zip 10940
Owner/Firm Information				Business Taxpayer ID
Name CPV Valley LLC.				4 7 3 9 4 7 2 1 9
Street Address 8403 Colesville Road Suite 915				
City Silver Spring		State/Province MD	Country US	Zip 20910
Owner Classification: <input type="checkbox"/> Federal <input type="checkbox"/> State <input type="checkbox"/> Municipal <input checked="" type="checkbox"/> Corporation/Partnership <input type="checkbox"/> Individual				
Owner/Firm Contact Information				
Name Donald Atwood			Phone 781-848-2202	
E-mail Address Datwood@cpv.com			Fax	
Affiliation Asset Management Representative			Title Asset Management Rep.	
Street Address 50 Braintree Hill Office Park Suite 300				
City Braintree		State/Province MA	Country US	Zip 02184
Facility Contact Information				
Name Ben Stanley			Phone 845-649-8300	
E-mail Address b.stanley@dgc-ops.com			Fax	
Affiliation Operator			Title Plant Manager	
Street Address 3330 Route 6				
City Middletown		State/Province NY	Country US	Zip 10940

New York State Department of Environmental Conservation

Air Permit Application



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Project Description

Continuation Sheet(s)

CPV Valley, LLC owns and operates the CPV Valley Energy Center, a 680 megawatt (MW) natural gas-fired electric generating facility. The CPV Valley Energy Center will use ultra-low sulfur distillate oil for back-up for reliability purposes. The CPV facility will use "combined cycle" generation technology and will be comprised of two combined-cycle units, each consisting of a combustion turbine generator (CTG), a Heat Recovery Steam Generator (HRSG) with supplemental duct firing, and a steam turbine generator (STG).

Section III - Facility Information

Facility Classification

Hospital Residential Educational/Institutional Commercial Industrial Utility

Affected States (Title V Applications Only)

Vermont Massachusetts Rhode Island Pennsylvania Tribal Land: N/A
 New Hampshire Connecticut New Jersey Ohio Tribal Land: N/A

SIC Code(s)

4911

NAICS Code(s)

22112

Facility Description

Continuation Sheet(s)

The CPV Valley Energy Center consists of two dual fuel-fired Siemens F-class combustion turbine generators (CTGs), with a nominal heat input of 2,234 mm Btu/hr, each when operating on natural gas at base load, two 500 mmBtu/hr supplementary natural gas-fired duct burners, two heat recovery steam generators.

Compliance Statements (Title V Applications Only)

I certify that as of the date of this application the facility is in compliance with all applicable requirements. Yes No
 If one or more emission units at the facility are not in compliance with all applicable requirements at the time of signing this application (the 'NO' box must be checked), the noncomplying units must be identified in the "Compliance Plan" block on page 8 of this form along with the compliance plan information required. For all emission units at the facility that are operating in compliance with all applicable requirements, complete the following:

- This facility will continue to be operated and maintained in such a manner as to assure compliance for the duration of the permit, except those emission units referenced in the compliance plan portion of this application.
- For all emission units subject to any applicable requirements that will become effective during the term of the permit, this facility will meet such requirements on a timely basis.
- Compliance certification reports will be submitted at least once per year. Each report will certify compliance status with respect to each applicable requirement, and the method used to determine the status.

Facility Applicable Federal Requirements

Continuation Sheet(s)

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	82	F						
40	CFR	72	A						
40	CFR	60	A	3,7,8,11					
40	CFR	60	A	12,13,19					

Facility State Only Requirements

Continuation Sheet(s)

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	293							
6	NYCRR	202	1						
6	NYCRR	202	2						
6	NYCRR	621							

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section II - Identification Information

Project Description (continuation)

Auxiliary equipment includes a low nitrogen oxide (NOx) natural gas-fired auxiliary boiler, needed to keep the HRSGs warm during periods of turbine shutdown and to provide sealing steam during startups. The stacks for the facility are 275 feet tall. The project is located on an approximately 122-acre site in Wawayanda, Orange County, New York. The project activities are located on an approximately 21-acre area that is bounded to the east by State Route 17M/6; to the north by State Route 6 and to the south by Interstate 84.

New York State Department of Environmental Conservation
Air Permit Application Form



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section III - Facility Information

Facility Description (continuation)

(HRSGs) and a single steam turbine generator (STG). Supporting ancillary equipment includes a 48.1 mmBtu/hr natural gas fired auxiliary boiler, a 10.08 mmBtu/hr ULSD emergency generator, one dew point heater with two 4.48 mmBtu/hr fuel gas burners and a 1.96 mmBtu/hr ULSD fire water pump engine. The CTGs are fueled by natural gas. Ultra-low sulfur diesel may be used as backup fuel for up to 720 hours per year per turbine. The duct burners will fire natural gas exclusively. The CTGs utilize dry low-NOx (DLN) combustors for gas firing and water injection for control of nitrogen oxides (NOx) when firing ultra-low sulfur diesel. Selective catalytic reduction (SCRs) systems are used to further control NOx emissions. Oxidation catalysts and efficient combustion controls will be used to control emissions of carbon monoxide (CO) as well as volatile organic compounds (VOCs). Emissions of SO₂ and PM/PM-10 are minimized through the use of pipeline natural gas and ULSD as backup, as well as efficient combustion controls. Upon leaving the SCRs, turbine gases are directed to individual stacks at 275 feet above grade with a flue diameter of 19 feet. In addition, CTGs inlet air will be cooled using an evaporative cooler when ambient temperatures are high, to improve CTGs efficiency.

The auxiliary boiler employs low-NOx burners (LNB) and flue gas recirculation (FGR) to control emissions of NOx. The auxiliary boiler will operate as needed for any start up condition to keep the HRSG warm during periods of turbine shutdown and to provide sealing steam to the steam turbine in the case of warm and hot startups. Total boiler hours for the facility will be limited to 2,000 hours per year.

The dew point fuel gas heater employs two forced draft burners to reduce NOx emissions. The unit will heat the natural gas to optimum firing temperature. The dew point heaters is proposed to operate up to 8,760 hours per year.

The emergency diesel fire pump will provide on-site fire fighting capability independent of the utility grid. The emergency diesel generator will be operated only for testing and to maintain operational readiness or if needed for emergency operation. Each emergency engine will be allowed to operate for up to 500 hours per year.

A 1.3 megawatt or similar emergency mobile back up may be used only for testing and to maintain operational readiness or it needed for emergency operation.

The five space heaters are used inside the generation buildings for temperature regulation.

The 930,900 gallon fuel oil storage tank, 600 gallon emergency diesel generator storage tank, and 500 gallon emergency diesel fire pump storage tank are maintained at the facility.

Only the facility's combustion turbines, duct burners and auxiliary boiler are subject to NYSDEC NOx RACT provisions.

The dew point heater, the emergency diesel generator, the emergency diesel fire pump, the five space heaters, the mobile backup generator, the fuel oil storage tank, and the emergency diesel storage tanks are exempt activities pursuant to Part 201-3.2.

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section III - Facility Information

Facility Applicable Federal Requirements (continuation)									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	KKKK						
40	CFR	60	III						
40	CFR	60	Dc						
40	CFR	60	TTTT						
40	CFR	75	A						
40	CFR	75	B						
40	CFR	75	C						
40	CFR	75	D						
40	CFR	75	F						
40	CFR	75	G						
40	CFR	52	HH						
40	CFR	72	A	6	a	3			
40	CFR	72	A	9					
40	CFR	97	AAAAA						
40	CFR	97	BBBBB						
40	CFR	97	CCCCC						

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section III - Facility Information

Facility State Only Requirements (continuation)									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	200	3						
6	NYCRR	200	5						
6	NYCRR	200	6						
6	NYCRR	200	7						
6	NYCRR	201	1						
6	NYCRR	201	1	4					
6	NYCRR	201	1	11					
6	NYCRR	201	1	12					
6	NYCRR	201	1	13					
6	NYCRR	201	2						
6	NYCRR	201	3	1					
6	NYCRR	201	3	2					
6	NYCRR	201	3	3					
6	NYCRR	201	5						
6	NYCRR	201	6	1	a				
6	NYCRR	201	6	1	b				
6	NYCRR	201	6	2					
6	NYCRR	201	6	3					
6	NYCRR	201	6	4					
6	NYCRR	201	6	5					
6	NYCRR	201	6	6					
6	NYCRR	201	7						
6	NYCRR	202	1	1					
6	NYCRR	202	1	2					
6	NYCRR	202	1	3					
6	NYCRR	202	1	5					
6	NYCRR	207							
6	NYCRR	211	1						
6	NYCRR	211	2						
6	NYCRR	215							
6	NYCRR	225	1	2	h				

Continuation Sheet 1 of 2

New York State Department of Environmental Conservation

Air Permit Application



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Facility Compliance Certification										✕ Continuation Sheet(s)	
Rule Citation											
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause		
6	NYCRR	227	1	3	a						
✕ Applicable Federal Requirement					CAS Number		Contaminant Name				
☐ State Only Requirement			☐ Capping								
Monitoring Information											
✕ Work Practice Involving Specific Operations ☐ Ambient Air Monitoring ☐ Record Keeping/Maintenance Procedures											
Compliance Activity Description											
No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60. The opacity standards apply at all times except during periods of start up, shutdown, and malfunction; and all other applicable conditions cited in section 40CFR 60.11.											
Work Practice Type Code		Process Material				Reference Test Method					
		Code	Description			40 CFR 60, Method 9					
						Manufacturer's Name/Model Number					
Monitored Parameter		Description									
Code		Description									
01		Opacity									
Limit			Limit Units								
Upper	Lower	Code		Description							
20	0	136		Percent							
Averaging Method			Monitoring Frequency			Reporting Requirements					
Code	Description		Code	Description		Code	Description				
18	6-min average		14	As required		10	Upon Request				
Facility Emissions Summary										✕ Continuation Sheet(s)	
CAS Number		Contaminant Name				Potential to Emit (tons/yr)		Actual Emissions (pounds/yr)			
0NY075 - 00 - 5		PM-10				95.0					
0NY750 - 02 - 5		PM-2.5				95.0					
007446 - 09 - 5		Sulfur Dioxide				42.0					
0NY210 - 00 - 0		Oxides of Nitrogen				183.0					
000630 - 08 - 0		Carbon Monoxide				341.5					
007439 - 92 - 1		Lead (elemental)				0.02					
0NY998 - 00 - 0		Total Volatile Organic Compounds				64.0					
0NY100 - 00 - 0		Total Hazardous Air Pollutants				13.94					
0NY750 - 00 - 0		Carbon Dioxide Equivalents				2,164,438.0					
007664-93-9		Sulfuric Acid				13.0					
007664-41-7		Ammonia				104.8					

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section III - Facility Information

Facility Emissions Summary (continuation)				
CAS No.	Contaminant Name	PTE		Actual (lbs/yr)
		(lbs/yr)	Range	
106-99-0	1,3 Butadiene	6.50E+01	Y	
71-55-6	1, 1, 1-Trichloroethane	0.00E+00	Y	
56-49-5	3-Methylchloranthrene	4.49E-03	Y	
57-97-6	7, 12-Dimethylbenz(a)anthracene	4.40E-02	Y	
83-32-9	Acenaphthene	4.50E+01	Y	
208-96-8	Acenaphthylene	3.62E+00	Y	
75-07-0	Acetaldehyde	1.57E+03	Y	
107-02-8	Acrolein	2.50E+02	Y	
120-12-7	Anthracene	6.54E+00	Y	
07440-38-2	Arsenic	3.46E+01	Y	
56-55-3	Benz(a)anthracene	1.11E+01	Y	
71-43-2	Benzene	2.12E+03	Y	
50-32-8	Benzo(a)pyrene	2.24E+00	Y	
205-99-2	Benzo(b)fluoranthene	6.02E+00	Y	
191-24-2	Benzo(g, h, i)perylene	6.54E+00	Y	
207-08-9	Benzo(k)fluoranthene	6.02E+00	Y	
07740-41-7	Beryllium	9.90E-01	Y	
07740-43-9	Cadmium	1.78E+01	Y	
07740-47-3	Chromium	3.78E+01	Y	
218-01-9	Chrysene	7.82E+00	Y	
07740-48-4	Cobalt	2.30E-01	Y	
53-70-3	Dibenzo(a, h)anthracene	5.38E+00	Y	
106-46-7	Dichlorobenzene	3.30E+00	Y	
100-41-4	Ethylbenzene	1.25E+03	Y	
206-44-0	Fluoranthene	1.48E+01	Y	
7782-96-5	Fluorene	1.39E+01	Y	
50-00-0	Formaldehyde	5.02E+03	Y	
110-54-3	Hexane	4.94E+03	Y	
193-39-5	Indeno(1,2,3-cd)pyrene	7.34E+00	Y	
07439-92-1	Lead	4.46E+01	Y	

Continuation Sheet 1 of 2

New York State Department of Environmental Conservation Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section III - Facility Information

Facility Emissions Summary (continuation)				
CAS No.	Contaminant Name	PTE		Actual (lbs/yr)
		(lbs/yr)	Range	
07439-96-5	Manganese	2.44E+00	Y	
07439-97-6	Mercury	4.42E+00	Y	
133-02-7	Xylenes	2.50E+03	Y	
91-20-3	Naphthalene	1.57E+02	Y	
0770-02-0	Nickel	4.32E+01	Y	
130498-29-2	PAH	2.02E+02	Y	
85-01-8	Phenanthrene	5.00E+01	Y	
	POM	0.00E+00	Y	
75-56-9	Propylene Oxide	1.13E+03	Y	
129-00-0	Pyrene	1.70E+01	Y	
07782-49-2	Selenium	7.72E+01	Y	
108-88-3	Toluene	5.10E+03	Y	
56-23-5	Carbon Tetrachloride	7.08E+01	Y	
75-01-4	Vinyl Chloride	1.22E+02	Y	
79-01-06	Trichloroethylene	6.36E+01	Y	
127-18-4	Tetrachloroethylene (Perchloroethylene)	7.50E+01	Y	
7440-62-2	Vanadium	6.32E+00	Y	

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Description											<input type="checkbox"/> Continuation Sheet(s)	
Emission Unit	U	-	0	0	0	0	1					
<p>One Siemens SGT6-5000 F-Class combustion turbine which has a nominal rating of 1,998 mm Btu/hr at 51 °F (2,234 mmBtu/hr at -5°F) on natural gas and (2,145 mmBtu/hr at -5°F) on fuel oil (<0.0015% sulfur). The turbine is equipped with dry low-NOx combustors, steam injection, SCR and oxidation catalyst emission controls. This emission unit also contains a natural gas-fired duct burner rated at a nominal capacity of 500 mmBtu/hr.</p>												

Building Information					<input type="checkbox"/> Continuation Sheet(s)
Building ID	Building Name	Length (ft)	Width (ft)	Orientation	
GEN01	Generation Building	300	260	North	
ACC01	Air Cooled Condenser	296	327	North	
HRSG01	Heat Recovery Steam Generator - Inside Generation Building	160	105	North	

Emission Unit	Emission Unit Emissions Summary										<input checked="" type="checkbox"/> Continuation Sheet(s)	
U	-	0	0	0	0	1						
CAS Number	Contaminant Name											
ONY075-00 - 0	Particulates											
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)					(lbs/yr)					(lbs/yr)	
						94,200.0						
CAS Number	Contaminant Name											
ONY075 - 00 - 5	PM-10											
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)					(lbs/yr)					(lbs/yr)	
						94,200.0						
CAS Number	Contaminant Name											
ONY750 - 02 - 5	PM-2.5											
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)					(lbs/yr)					(lbs/yr)	
						94,200.0						
CAS Number	Contaminant Name											
ONY210 - 00 - 0	Oxides of Nitrogen											
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)					(lbs/yr)					(lbs/yr)	
						174,900.0						

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 1					
CAS No.		Contaminant Name			
000630 - 08 - 0		Carbon Monoxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		334,000.0			
CAS No.		Contaminant Name			
007446 - 09 - 5		Sulfur Dioxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		41,000.0			
CAS No.		Contaminant Name			
0NY998 - 00 - 0		Volatile Organic Compounds			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		62,800.0			
CAS No.		Contaminant Name			
0NY100 - 00 - 0		Total Hazardous Air Pollutants			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		13,770.0			
CAS No.		Contaminant Name			
0NY750 - 00 - 0		Carbon Dioxide Equivalents			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		2,164,438,000.0			
CAS No.		Contaminant Name			
007664-93-9		Sulfuric Acid			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		12,600.0			
CAS No.		Contaminant Name			
007664-41-7		Ammonia			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		104,800.0			

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 1					
CAS No.		Contaminant Name			
007439 - 92 - 1		Lead (elemental)			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		22.30			
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Point Information											<input type="checkbox"/> Continuation Sheet(s)
Emission Point		E	P	0	0	1					
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section						
					Length (in)	Width (in)					
496	275	140	228	195							
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal					
74.26	1,310,911	546.98048	4584.69287		178						
Emission Point											
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section						
					Length (in)	Width (in)					
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal					
Emission Point											
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section						
					Length (in)	Width (in)					
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal					

Emission Source/Control Information											<input checked="" type="checkbox"/> Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number				
ID	Type				Code	Description					
C	T	0	0	1	C		Siemens SGT6-5000 Class-F Turbine				
Design Capacity	Design Capacity Units			Waste Feed		Waste Type					
	Code	Description			Code	Description	Code	Description			
2234	25	mmBtu/hr									
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number				
ID	Type				Code	Description					
D	B	0	0	1	C		Forney Duct Burner				
Design Capacity	Design Capacity Units			Waste Feed		Waste Type					
	Code	Description			Code	Description	Code	Description			
500	25	mmBtu/hr									
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number				
ID	Type				Code	Description					
D	L	N	0	1	K	103	dry low NOx burner				
Design Capacity	Design Capacity Units			Waste Feed		Waste Type					
	Code	Description			Code	Description	Code	Description			

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Source/Control (continuation)										
Emission Unit		U - 0 0 0 0 0 1								
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.			
ID	Type				Code	Description				
STI01	K	08/2015	01/2018		028	steam or water injection				
Design Capacity	Design Capacity Units				Waste Feed		Waste Type			
	Code	Description			Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.			
ID	Type				Code	Description				
SCR01	K	08/2015	01/2018		033	selective catalytic reduction (SCR)	YARA SCR			
Design Capacity	Design Capacity Units				Waste Feed		Waste Type			
	Code	Description			Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.			
ID	Type				Code	Description				
OXY01	K	08/2015	01/2018		110	catalytic oxidation	SYNERGY			
Design Capacity	Design Capacity Units				Waste Feed		Waste Type			
	Code	Description			Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.			
ID	Type				Code	Description				
Design Capacity	Design Capacity Units				Waste Feed		Waste Type			
	Code	Description			Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.			
ID	Type				Code	Description				
Design Capacity	Design Capacity Units				Waste Feed		Waste Type			
	Code	Description			Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.			
ID	Type				Code	Description				
Design Capacity	Design Capacity Units				Waste Feed		Waste Type			
	Code	Description			Code	Description	Code	Description		

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6
Process Information											
Emission Unit											
U	-	0	0	0	0	0	1				
Process											
P	1	A									
Process Description											
<p>Process P1A represents natural gas firing in the Siemens SGT6-5000 Class-F combustion turbine, which has a nominal rating of 2,234 mmBtu/hr at -5°F (maximum heat input scenario). Dry low-NOx combustion technology, selective catalytic reduction (SCR) and oxidation catalyst will be used to minimize emissions of NOx, CO, and VOC. The quantity per hour throughput listed below represents the nominal firing rate (2,234 mm Btu/hr at -5°F) and the quantity per year throughput represents the turbine at the firing rate at the annual average ambient temperature of 51 °F (1,998 mmBtu/hr). Natural gas Higher Heating Value (HHV) is assumed to be 1,048 Btu/cubic foot.</p>											
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units							
2-01-002-01		Quantity/Hr	Quantity/Yr	Code	Description						
		2.13	1,690.51	0115	million cubic feet of natural gas						
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity		Operating Schedule		Building	Floor/Location						
		Hours/Day	Days/Year								
		24	365								
Emission Point Identifier(s)											
CT001	DLN01	SCR01	OXY01								
Emission Source/Control Identifier(s)											
Emission Unit											
U	-	0	0	0	0	0	1				
Process											
P	2	A									
Process Description											
<p>Process P2A represents combined natural gas firing in the Siemens SGT6-5000 Class-F combustion turbine, which has a nominal rating of 2,234 mmBtu/hr at -5°F (maximum heat input scenario) and natural gas firing with in the duct burner, which has a nominal rating of 500 mmBtu/hr. Dry low-NOx combustion technology, selective catalytic reduction (SCR) and oxidation catalyst will be used to minimize emissions of NOx, CO, and VOC. The quantity per hour throughput listed below represents the maximum firing rate of the turbine (2,234 mmBtu/hr at -5°F) plus the duct burner at rated capacity (500 mm Btu/hr) and the quantity per year throughput represents 8,760 hours of natural gas firing in the turbine at the annual average ambient temperature of 51 °F (1,998 mmBtu/hr) plus 2,628 hours of natural gas firing in the duct burner at rated capacity (500 mmBtu/hr). Natural gas Higher Heating Value (HHV) is assumed to be 1,048 Btu/cubic foot.</p>											
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units							
2-01-002-01		Quantity/Hr	Quantity/Yr	Code	Description						
		2.61	1,690.51	0115	million cubic feet of natural gas						
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity		Operating Schedule		Building	Floor/Location						
		Hours/Day	Days/Year								
		24	365								
Emission Point Identifier(s)											
CT001	DB001	DLN01	SCR01	OXY01							
Emission Source/Control Identifier(s)											

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Process Information (continuation)											
Emission Unit	U	-	0	0	0	0	1	Process	P	3	A
Description											
Process P3A represents fuel oil firing in the Class-F combustion turbine, which has a nominal rating of 2,145 mm Btu/hr at -5 F (maximum heat input scenario). Dry low-NOx combustion technology, steam or water injection, selective catalytic reduction (SCR) and oxidation catalyst will be used to minimize emissions of NOx, CO, and VOC. The quantity per hour throughput listed below represents the nominal firing rate (2,145 mm Btu/hr at -5 F) and the quantity per year fuel oil firing at the firing rate at -5 F ambient temperature. Fuel oil Higher Heating Value (HHV) is assumed to be 139,728 throughput represents 720 hours of Btu/gallon.											
Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units								
	Quantity/Hr	Quantity/Yr	Code	Description							
2-01-001-01	15.351	10,017	0607	1000 gallons burned							
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity			Operating Schedule		Building	Floor/Location					
			Hrs/Day	Days/Yr							
			24	30							
Emission Point Identifier(s)											
CT001	DLN01	STI01	SCR01	OXY01							
Emission Source/Control Identifier(s)											
Emission Unit	-							Process			
Description											
Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units								
	Quantity/Hr	Quantity/Yr	Code	Description							
<input type="checkbox"/> Confidential <input type="checkbox"/> Operating at Maximum Capacity			Operating Schedule		Building	Floor/Location					
			Hrs/Day	Days/Yr							
Emission Point Identifier(s)											
Emission Source/Control Identifier(s)											

New York State Department of Environmental Conservation
Air Permit Application



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Description											<input type="checkbox"/> Continuation Sheet(s)		
Emission Unit	U	-	0	0	0	0	2						
<p>One Siemens SGT6-5000 F-Class combustion turbine which has a nominal rating of 1,998 mm Btu/hr at 51 °F (2,234 mmBtu/hr at -5°F) on natural gas and (2,145 mmBtu/hr at -5°F) on fuel oil (<0.0015% sulfur). The turbine is equipped with dry low-NOx combustors, steam injection, SCR and oxidation catalyst emission controls. This emission unit also contains a natural gas-fired duct burner rated at a nominal capacity of 500 mmBtu/hr.</p>													

Building Information					<input type="checkbox"/> Continuation Sheet(s)	
Building ID	Building Name			Length (ft)	Width (ft)	Orientation
GEN02	Generation Building			300	260	North
ACC02	Air Cooled Condenser			296	327	North
HRSG02	Heat Recovery Steam Generator - Inside Generation Building			160	105	North

Emission Unit		Emission Unit Emissions Summary				<input checked="" type="checkbox"/> Continuation Sheet(s)
U	-	0	0	0	0	2
CAS Number		Contaminant Name				
ONY075-00 - 0		Particulates				
ERP (lbs/yr)	Potential to Emit		Actual Emissions			
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)		
		94,200.0				
CAS Number		Contaminant Name				
ONY075 - 00 - 5		PM-10				
ERP (lbs/yr)	Potential to Emit		Actual Emissions			
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)		
		94,200.0				
CAS Number		Contaminant Name				
ONY750 - 02 - 5		PM-2.5				
ERP (lbs/yr)	Potential to Emit		Actual Emissions			
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)		
		94,200.0				
CAS Number		Contaminant Name				
ONY210 - 00 - 0		Oxides of Nitrogen				
ERP (lbs/yr)	Potential to Emit		Actual Emissions			
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)		
		174,900.0				

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 2					
CAS No.		Contaminant Name			
000630 - 08 - 0		Carbon Monoxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		334,000.0			
CAS No.		Contaminant Name			
007446 - 09 - 5		Sulfur Dioxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		41,000.0			
CAS No.		Contaminant Name			
0NY998 - 00 - 0		Volatile Organic Compounds			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		62,800.0			
CAS No.		Contaminant Name			
0NY100 - 00 - 0		Total Hazardous Air Pollutants			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		13,770.0			
CAS No.		Contaminant Name			
0NY750 - 00 - 0		Carbon Dioxide Equivalents			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		2,164,438,000.0			
CAS No.		Contaminant Name			
007664-93-9		Sulfuric Acid			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		12,600.0			
CAS No.		Contaminant Name			
007664-41-7		Ammonia			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		104,800.0			

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 2					
CAS No.		Contaminant Name			
007439 - 92 - 1		Lead (elemental)			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		22.30			
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	

New York State Department of Environmental Conservation

Air Permit Application



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Point Information							<input type="checkbox"/> Continuation Sheet(s)
Emission Point	E	P	0	0	2		
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
496	275	140	228	195			
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
76.91	1,357,528	546.99053	4584.65455		305		
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control Information								<input checked="" type="checkbox"/> Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number	
ID	Type				Code	Description		
C	T	0	0	2	C		Siemens SGT6-5000 Class-F Turbine	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	
2234	25	mmBtu/hr						
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number	
ID	Type				Code	Description		
D	B	0	0	2	C		Forney Duct Burner	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	
500	25	mmBtu/hr						
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number	
ID	Type				Code	Description		
D	L	N	0	2	K	103 dry low NOx burner		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	

**New York State Department of Environmental Conservation
Air Permit Application Form**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Source/Control (continuation)									
Emission Unit		U - 0 0 0 0 0 2							
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
STI02	K	08/2015	01/2018		028	steam or water injection			
Design Capacity	Design Capacity Units				Waste Feed		Waste Type		
	Code	Description			Code	Description	Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
SCR02	K	08/2015	01/2018		033	selective catalytic reduction (SCR)	YARA SCR		
Design Capacity	Design Capacity Units				Waste Feed		Waste Type		
	Code	Description			Code	Description	Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
OXY02	K	08/2015	01/2018		110	catalytic oxidation	SYNERGY		
Design Capacity	Design Capacity Units				Waste Feed		Waste Type		
	Code	Description			Code	Description	Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units				Waste Feed		Waste Type		
	Code	Description			Code	Description	Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units				Waste Feed		Waste Type		
	Code	Description			Code	Description	Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units				Waste Feed		Waste Type		
	Code	Description			Code	Description	Code	Description	

New York State Department of Environmental Conservation

Air Permit Application



Department of
Environmental
Conservation

DEC ID																			
3	-	3	3	5	6	-	0	0	1	3	6								
Process Information																			
Emission Unit								U	-	0	0	0	0	2	Process		P	0	1
Process Description																			
<p>Process P01 represents natural gas firing in the Siemens SGT6-5000 Class-F combustion turbine, which has a nominal rating of 2,234 mmBtu/hr at -5°F (maximum heat input scenario). Dry low-NOx combustion technology, selective catalytic reduction (SCR) and oxidation catalyst will be used to minimize emissions of NOx, CO, and VOC. The quantity per hour throughput listed below represents the nominal firing rate (2,234 mm Btu/hr at -5°F) and the quantity per year throughput represents the turbine at the firing rate at the annual average ambient temperature of 51 °F (1,998 mmBtu/hr). Natural gas Higher Heating Value (HHV) is assumed to be 1,048 Btu/cubic foot.</p>																			
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units															
2-01-002-01		Quantity/Hr	Quantity/Yr	Code	Description														
		2.13	1,690.51	0115	million cubic feet of natural gas														
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity		Operating Schedule		Building	Floor/Location														
		Hours/Day	Days/Year																
		24	365																
Emission Point Identifier(s)																			
CT002	DLN02	SCR02	OXY02																
Emission Source/Control Identifier(s)																			
Emission Unit								U	-	0	0	0	0	2	Process		P	0	2
Process Description																			
<p>Process P02 represents combined natural gas firing in the Siemens SGT6-5000 Class-F combustion turbine, which has a nominal rating of 2,234 mmBtu/hr at -5°F (maximum heat input scenario) and natural gas firing with the duct burner, which has a nominal rating of 500 mmBtu/hr. Dry low-NOx combustion technology, selective catalytic reduction (SCR) and oxidation catalyst will be used to minimize emissions of NOx, CO, and VOC. The quantity per hour throughput listed below represents the maximum firing rate of the turbine (2,234 mmBtu/hr at -5°F) plus the duct burner at rated capacity (500 mm Btu/hr) and the quantity per year throughput represents 8,760 hours of natural gas firing in the turbine at the annual average ambient temperature of 51 °F (1,998 mmBtu/hr) plus 2,628 hours of natural gas firing in the duct burner at rated capacity (500 mmBtu/hr). Natural gas Higher Heating Value (HHV) is assumed to be 1,048 Btu/cubic foot.</p>																			
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units															
2-01-002-01		Quantity/Hr	Quantity/Yr	Code	Description														
		2.61	1,690.51	0115	million cubic feet of natural gas														
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity		Operating Schedule		Building	Floor/Location														
		Hours/Day	Days/Year																
		24	365																
Emission Point Identifier(s)																			
CT002	DB002	DLN02	SCR02	OXY02															
Emission Source/Control Identifier(s)																			

**New York State Department of Environmental Conservation
Air Permit Application Form**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Process Information (continuation)										
Emission Unit		U - 0 0 0 0 2					Process		P 0 3	
Description										
Process P03 represents fuel oil firing in the Siemens SGT6-5000 Class-F combustion turbine, which has a nominal rating of 2,145 mm Btu/hr at -5 F (maximum heat input scenario). Dry low-NOx combustion technology, steam or water injection, selective catalytic reduction (SCR) and oxidation catalyst will be used to minimize emissions of NOx, CO, and VOC. The quantity per hour throughput listed below represents the nominal firing rate (2,145 mm Btu/hr at -5 F) and the quantity per year fuel oil firing at the firing rate at -5 F ambient temperature. Fuel oil Higher Heating Value (HHV) is assumed to be 139,728 throughput represents 720 hours of Btu/gallon.										
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units						
2-01-001-01		Quantity/Hr	Quantity/Yr	Code	Description					
		15.351	10,017	0607	1000 gallons burned					
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity		Operating Schedule		Building		Floor/Location				
		Hrs/Day	Days/Yr							
		24	30							
Emission Point Identifier(s)										
CT002	DLN02	STI02	SCR02	OXY02						
Emission Source/Control Identifier(s)										
Emission Unit		-					Process			
Description										
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units						
		Quantity/Hr	Quantity/Yr	Code	Description					
<input type="checkbox"/> Confidential <input type="checkbox"/> Operating at Maximum Capacity		Operating Schedule		Building		Floor/Location				
		Hrs/Day	Days/Yr							
Emission Point Identifier(s)										
Emission Source/Control Identifier(s)										

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Description											<input type="checkbox"/> Continuation Sheet(s)	
Emission Unit	U	-	0	0	0	0	3					
<p>One auxiliary boiler with a nominal rating of 48.1 mmBtu/hr that will fire natural gas exclusively. The boiler hours will be limited to 2000 hours per year. The boiler will operate primarily to assist with startups and shutdowns of the turbine.</p>												

Building Information					<input type="checkbox"/> Continuation Sheet(s)
Building ID	Building Name		Length (ft)	Width (ft)	Orientation
GEN02	Auxiliary Boiler Located Inside Generation Building		300	260	North

Emission Unit	Emission Unit Emissions Summary										<input checked="" type="checkbox"/> Continuation Sheet(s)
U	-	0	0	0	0	3					
CAS Number		Contaminant Name									
0NY075 - 00 - 0		Particulates									
ERP (lbs/yr)	Potential to Emit					Actual Emissions					
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)			
					600.0						
CAS Number		Contaminant Name									
0NY075 - 00 - 5		PM-10									
ERP (lbs/yr)	Potential to Emit					Actual Emissions					
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)			
					600.0						
CAS Number		Contaminant Name									
0NY750 - 02 - 5		PM-2.5									
ERP (lbs/yr)	Potential to Emit					Actual Emissions					
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)			
					600.0						
CAS Number		Contaminant Name									
0NY210 - 00 - 0		Oxides of Nitrogen									
ERP (lbs/yr)	Potential to Emit					Actual Emissions					
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)			
					4,320.0						

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 3					
CAS No.		Contaminant Name			
000630 - 08 - 0		Carbon Monoxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		6,940.0			
CAS No.		Contaminant Name			
007446 - 09 - 5		Sulfur Dioxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		220.0			
CAS No.		Contaminant Name			
0NY998 - 00 - 0		Volatile Organic Compounds			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		360.0			
CAS No.		Contaminant Name			
007664-93-9		Sulfuric Acid			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		220.0			
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	

New York State Department of Environmental Conservation

Air Permit Application



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Point Information							<input type="checkbox"/> Continuation Sheet(s)
Emission Point	E	P	0	0	3		
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
496	275	140	228	301			
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
57.53	14,194	546.99053	4584.65455		305		
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control Information								<input type="checkbox"/> Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number	
ID	Type				Code	Description		
A U X 0 1	C	08/2015	01/2018			low NOx burner		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	
48.1	25	mmBtu/hr						
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number	
ID	Type				Code	Description		
L N B 0 1	K	08/2015	01/2018		102	low NOx burner		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number	
ID	Type				Code	Description		
F G R 0 1	K	08/2015	01/2018		026	flue gas recirculation		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	

New York State Department of Environmental Conservation
Air Permit Application



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6
Process Information											
Emission Unit								U - 0 0 0 0 0 3		Process	
								P		3 B	
Process Description											
<p>Process P3B represents natural gas firing in the auxiliary boiler, which has a nominal rating of 48.1 mmBtu/hr. Total natural gas usage will not exceed 2,000 full load boiler hours per year. Natural gas Higher Heating Value (HHV) is assumed to be 1,048 Btu/cubic foot.</p>											
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units							
		Quantity/Hr	Quantity/Yr	Code	Description						
1-02-006-02		0.07	93.73	0115	million cubic feet of natural gas						
<input type="checkbox"/> Confidential		Operating Schedule		Building		Floor/Location					
<input checked="" type="checkbox"/> Operating at Maximum Capacity		Hours/Day	Days/Year								
		24	365								
Emission Point Identifier(s)											
AUX01		LNB01		FGR01							
Emission Source/Control Identifier(s)											
Emission Unit		-								Process	
Process Description											
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units							
		Quantity/Hr	Quantity/Yr	Code	Description						
<input type="checkbox"/> Confidential		Operating Schedule		Building		Floor/Location					
<input type="checkbox"/> Operating at Maximum Capacity		Hours/Day	Days/Year								
Emission Point Identifier(s)											
Emission Source/Control Identifier(s)											

New York State Department of Environmental Conservation
Air Permit Application



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Description											<input type="checkbox"/> Continuation Sheet(s)		
Emission Unit	U	-	0	0	0	0	4						
Kohler Power System Model: 1000REOZDE Engine Manufacturer: Detroit Diesel/MTU Engine Model: 16V2000 G85 R163-8A37 Engine: type 4-Cycle, Turbocharged, Intercooled													

Building Information					<input type="checkbox"/> Continuation Sheet(s)
Building ID	Building Name		Length (ft)	Width (ft)	Orientation
DGB01	Generation Building		32	11	

Emission Unit	Emission Unit Emissions Summary										<input checked="" type="checkbox"/> Continuation Sheet(s)	
U	-	0	0	0	0	4						
CAS Number		Contaminant Name										
ONY075 - 00 - 0		Particulates										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			98.0									
CAS Number		Contaminant Name										
ONY075 - 00 - 5		PM-2.5										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			98.0									
CAS Number		Contaminant Name										
ONY750 - 02 - 5		PM-2.5										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			98.0									
CAS Number		Contaminant Name										
ONY210 - 00 - 0		Oxides of Nitrogen										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			6,660									

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 4					
CAS No.		Contaminant Name			
000630 - 08 - 0		Carbon Monoxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		984.0			
CAS No.		Contaminant Name			
007446 - 09 - 5		Sulfur Dioxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		9.7			
CAS No.		Contaminant Name			
0NY998 - 00 - 0		Volatile Organic Compounds			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		282.0			
CAS No.		Contaminant Name			
007664-93-9		Sulfuric Acid			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		0.2			
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Point Information							<input type="checkbox"/> Continuation Sheet(s)
Emission Point	E	P	0	0	4		
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
464	50	27	18	1,022			
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
104.3	7,840	547.12988	4584.6514	DGB01	262		
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control Information							<input type="checkbox"/> Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number
ID	Type				Code	Description	
E	G	0	1				16V2000 G85 R163-8A37
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
10.08	0104	mmBtu/hr					
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number
ID	Type				Code	Description	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number
ID	Type				Code	Description	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description

New York State Department of Environmental Conservation
Air Permit Application



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Description											<input type="checkbox"/> Continuation Sheet(s)		
Emission Unit	U	-	0	0	0	0	5						
Fire Pump Diesel Engine Cummins CFP9E-F20													

Building Information					<input checked="" type="checkbox"/> Continuation Sheet(s)
Building ID	Building Name		Length (ft)	Width (ft)	Orientation
FPB01	Fire Water Pump Building		30	12	

Emission Unit	Emission Unit Emissions Summary										<input type="checkbox"/> Continuation Sheet(s)	
U	-	0	0	0	0	5						
CAS Number		Contaminant Name										
ONY075 - 00 - 0		Particulates										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			36.0									
CAS Number		Contaminant Name										
ONY075 - 00 - 5		PM-10										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			36.0									
CAS Number		Contaminant Name										
ONY750 - 02 - 5		PM-2.5										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			36.0									
CAS Number		Contaminant Name										
ONY210 - 00 - 0		Oxides of Nitrogen										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)		(lbs/hr)		(lbs/yr)					
			684.0									

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 5					
CAS No.		Contaminant Name			
000630 - 08 - 0		Carbon Monoxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		440.0			
CAS No.		Contaminant Name			
007446 - 09 - 5		Sulfur Dioxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		150.2			
CAS No.		Contaminant Name			
0NY998 - 00 - 0		Volatile Organic Compounds			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		38.0			
CAS No.		Contaminant Name			
007664-93-9		Sulfuric Acid			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		0.030			
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Point Information							<input type="checkbox"/> Continuation Sheet(s)
Emission Point	E	P	0	0	5		
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
464	50	37	6	1,030	Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
136.2	1,813	546.81502	4584.66944	FPB01	161		
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control Information							<input type="checkbox"/> Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number
ID	Type				Code	Description	
F	P	0	1				CFP9E-F20
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
1.96	0104	mmBtu/hr					
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number
ID	Type				Code	Description	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number
ID	Type				Code	Description	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Description											<input type="checkbox"/> Continuation Sheet(s)		
Emission Unit	U	-	0	0	0	0	6						
One Dew Point Heater with Two Fuel Gas Burners: Model: Maxon OVENPAK® LE 45 Gas Burners – with SMARTLINK® DS Actuator													

Building Information					<input checked="" type="checkbox"/> Continuation Sheet(s)
Building ID	Building Name		Length (ft)	Width (ft)	Orientation
None	Located Outdoor				

Emission Unit	Emission Unit Emissions Summary										<input type="checkbox"/> Continuation Sheet(s)	
U	-	0	0	0	0	6						
CAS Number		Contaminant Name										
0NY075 - 00 - 0		Particulates										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)					
			666.0									
CAS Number		Contaminant Name										
0NY075 - 00 - 5		PM-10										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)					
			666.0									
CAS Number		Contaminant Name										
0NY750 - 02 - 5		PM-2.5										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)					
			666.0									
CAS Number		Contaminant Name										
0NY210 - 00 - 0		Oxides of Nitrogen										
ERP (lbs/yr)		Potential to Emit			Actual Emissions							
		(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)					
			3,190.0									

New York State Department of Environmental Conservation
Air Permit Application Form



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit		Emission Unit Emissions Summary (continuation)			
U - 0 0 0 0 6					
CAS No.		Contaminant Name			
000630 - 08 - 0		Carbon Monoxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		6,394.0			
CAS No.		Contaminant Name			
007446 - 09 - 5		Sulfur Dioxide			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		192.0			
CAS No.		Contaminant Name			
0NY998 - 00 - 0		Volatile Organic Compounds			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		438.0			
CAS No.		Contaminant Name			
007664-93-9		Sulfuric Acid			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
		17.6			
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	
CAS No.		Contaminant Name			
ERP (lbs/yr)	PTE Emissions		Actual Emissions		
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)	

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Point Information							<input type="checkbox"/> Continuation Sheet(s)
Emission Point	E	P	0	0	6		
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
464	125		24	850			
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
16.07	3,031	546.95885	4584.58	Outdoors	156		
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
Emission Point							
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control Information							<input type="checkbox"/> Continuation Sheet(s)				
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number				
ID	Type				Code	Description					
F	G	H	1		C	08/2015	01/2018		102	Low NOx Burner	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type					
	Code	Description			Code	Description	Code	Description			
9.0	0104	mmBtu/hr									
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number				
ID	Type				Code	Description					
										Low NOx Burner	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type					
	Code	Description			Code	Description	Code	Description			
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model Number				
ID	Type				Code	Description					
Design Capacity	Design Capacity Units			Waste Feed		Waste Type					
	Code	Description			Code	Description	Code	Description			

New York State Department of Environmental Conservation

Air Permit Application



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements							× Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00001				40	CFR	60	A	3					
U-00001				40	CFR	60	A	7					
U-00001				40	CFR	60	A	8					
U-00001				40	CFR	60	A	11					

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements							× Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00001				6	NYCRR	204	1	6,7					
U-00001				6	NYCRR	204	2						
U-00001				6	NYCRR	204	3						
U-00001				6	NYCRR	204	4						

Emission Unit Compliance Certification Continuation Sheet(s)

Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

Applicable Federal Requirement
 State Only Requirement
 Capping

Emission Unit	Emission Point	Process	Emission Source	CAS Number	Contaminant Name
U-00001	EP001	P1A,P2A		NY210-00-0	Oxides of nitrogen

Monitoring Information

Continuous Emission Monitoring
 Monitoring of a Process or Control Device Parameters as a Surrogate
 Intermittent Emission Testing
 Work Practice Involving Specific Operations
 Ambient Air Monitoring
 Record Keeping/Maintenance Procedures

Compliance Activity Description

2.0 ppmvd (corrected to 15% O₂) NO_x emission limit for the combustion turbine (with and without the duct burner) based upon the Higher Heating Value (HHV) of the fuel. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor NO_x stack emissions. The emission limits represents LAER.

Work Practice Type Code	Process Material		Reference Test Method		
	Code	Description			
			40 CFR Part 60, Appendix A, Method 7E		
Monitored Parameter			Manufacturer's Name/Model Number		
Code	Description				
23	Concentration				
Limit		Limit Units			
Upper	Lower	Code	Description		
2.0		275	parts per million by volume (dry, corrected to 15% O ₂)		
Averaging Method		Monitoring Frequency		Reporting Requirements	
Code	Description	Code	Description	Code	Description
47	3-hour block average	01	Continuous	07	Quarterly

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)										
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.	
U-00001				40	CFR	60	A	12						
U-00001				40	CFR	60	A	13						
U-00001				40	CFR	60	A	19						
U-00001				40	CFR	82	F							
U-00001				40	CFR	72	A	6						
U-00001				40	CFR	72	A	9						
U-00001				40	CFR	60	KKKK	4320	a,b					
U-00001				40	CFR	60	KKKK	4325						
U-00001				40	CFR	60	KKKK	4330	a	1,2				
U-00001				40	CFR	60	KKKK	4333	a,b	1,2				
U-00001				40	CFR	60	KKKK	4335	b	1,2,3				
U-00001				40	CFR	60	KKKK	4350						
U-00001				40	CFR	60	KKKK	4365	a					
U-00001				40	CFR	60	KKKK	4375	a					
U-00001				40	CFR	60	KKKK	4380	b					
U-00001				40	CFR	60	KKKK	4395						
U-00001				40	CFR	60	KKKK	4400						
U-00001				40	CFR	60	KKKK	4405						
U-00001				40	CFR	60	KKKK	4345	a,b,c,d,e					
U-00001				40	CFR	75	B	10						
U-00001				40	CFR	75	B	11	d					
U-00001				40	CFR	75	B	11	d	2				
U-00001				40	CFR	75	B	12	c					
U-00001				40	CFR	75	B	13	b					
U-00001				40	CFR	75	C							
U-00001				40	CFR	75	D							
U-00001				40	CFR	75	F	59						
U-00001				40	CFR	75	F	53	a,b,e,f					
U-00001				40	CFR	75	F	54						
U-00001				40	CFR	75	F	58	b	2,3				
U-00001				40	CFR	75	G							

Continuation Sheet 1 of 1

**New York State Department of Environmental Conservation
Air Permit Application Form**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements (continuation)										
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.	
U-00001				6	NYCRR	204	5							
U-00001				6	NYCRR	204	6							
U-00001				6	NYCRR	204	7							
U-00001				6	NYCRR	204	8							
U-00001				6	NYCRR	204	9							
U-00001				6	NYCRR	237	1	4	a					
U-00001				6	NYCRR	237	1	6,7						
U-00001				6	NYCRR	237	2							
U-00001				6	NYCRR	237	3							
U-00001				6	NYCRR	237	4	1						
U-00001				6	NYCRR	237	5	3	a					
U-00001				6	NYCRR	237	6							
U-00001				6	NYCRR	237	7							
U-00001				6	NYCRR	237	8							
U-00001				6	NYCRR	238	1	4,6,7						
U-00001				6	NYCRR	238	2							
U-00001				6	NYCRR	238	3							
U-00001				6	NYCRR	238	4	1						
U-00001				6	NYCRR	238	5	3						
U-00001				6	NYCRR	238	6							
U-00001				6	NYCRR	238	7							
U-00001				6	NYCRR	238	8							
U-00001				6	NYCRR	242	1	6,7						
U-00001				6	NYCRR	242	2,3,4,5							
U-00001				6	NYCRR	242	6,7,8,10							
U-00001				6	NYCRR	227	1	2	a	1				
U-00001				6	NYCRR	227	1	3						
U-00001				6	NYCRR	227	1	4	d					
U-00001				6	NYCRR	227	2	4	e	2				
U-00001				6	NYCRR	227	2	6						

New York State Department of Environmental Conservation

Air Permit Application



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements							✕ Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00002				40	CFR	60	A	3					
U-00002				40	CFR	60	A	7					
U-00002				40	CFR	60	A	8					
U-00002				40	CFR	60	A	11					

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements							✕ Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00002				6	NYCRR	204	1	6,7					
U-00002				6	NYCRR	204	2						
U-00002				6	NYCRR	204	3						
U-00002				6	NYCRR	204	4						

Emission Unit Compliance Certification Continuation Sheet(s)

Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

✕ Applicable Federal Requirement State Only Requirement Capping

Emission Unit	Emission Point	Process	Emission Source	CAS Number	Contaminant Name
U-00002	EP002	P01,P02		NY210-00-0	Oxides of nitrogen

Monitoring Information

Continuous Emission Monitoring Monitoring of a Process or Control Device Parameters as a Surrogate
 Intermittent Emission Testing Work Practice Involving Specific Operations
 Ambient Air Monitoring Record Keeping/Maintenance Procedures

Compliance Activity Description

2.0 ppmvd (corrected to 15% O₂) NO_x emission limit for the combustion turbine (with and without the duct burner) based upon the Higher Heating Value (HHV) of the fuel. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor NO_x stack emissions. The emission limits represents LAER.

Work Practice Type Code	Process Material		Reference Test Method		
	Code	Description			
			40 CFR Part 60, Appendix A, Method 7E		
Monitored Parameter			Manufacturer's Name/Model Number		
Code	Description				
23	Concentration				
Limit		Limit Units			
Upper	Lower	Code	Description		
2.0		275	parts per million by volume (dry, corrected to 15% O ₂)		
Averaging Method		Monitoring Frequency		Reporting Requirements	
Code	Description	Code	Description	Code	Description
47	3-hour block average	01	Continuous	07	Quarterly

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)										
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.	
U-00002				40	CFR	60	A	12						
U-00002				40	CFR	60	A	13						
U-00002				40	CFR	60	A	19						
U-00002				40	CFR	82	F							
U-00002				40	CFR	72	A	6	a	3				
U-00002				40	CFR	72	A	9						
U-00002				40	CFR	60	KKKK	4320	a,b					
U-00002				40	CFR	60	KKKK	4325						
U-00002				40	CFR	60	KKKK	4330	a	1,2				
U-00002				40	CFR	60	KKKK	4333	a,b	1,2				
U-00002				40	CFR	60	KKKK	4335	b	1,2,3				
U-00002				40	CFR	60	KKKK	4350						
U-00002				40	CFR	60	KKKK	4365	a					
U-00002				40	CFR	60	KKKK	4375	a					
U-00002				40	CFR	60	KKKK	4380	b					
U-00002				40	CFR	60	KKKK	4395						
U-00002				40	CFR	60	KKKK	4400						
U-00002				40	CFR	60	KKKK	4405						
U-00002				40	CFR	60	KKKK	4345	a,b,c,d,e					
U-00002				40	CFR	75	B	10						
U-00002				40	CFR	75	B	11	d					
U-00002				40	CFR	75	B	11	d	2				
U-00002				40	CFR	75	B	12	c					
U-00002				40	CFR	75	B	13	b					
U-00002				40	CFR	75	C							
U-00002				40	CFR	75	D							
U-00002				40	CFR	75	F	59						
U-00002				40	CFR	75	F	53	a,b,e,f					
U-00002				40	CFR	75	F	54						
U-00002				40	CFR	75	F	58	b	2,3				
U-00002				40	CFR	75	G							

Continuation Sheet 1 of 1

**New York State Department of Environmental Conservation
Air Permit Application Form**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements (continuation)										
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.	
U-00002				6	NYCRR	204	5							
U-00002				6	NYCRR	204	6							
U-00002				6	NYCRR	204	7							
U-00002				6	NYCRR	204	8							
U-00002				6	NYCRR	204	9							
U-00002				6	NYCRR	237	1	4	a					
U-00002				6	NYCRR	237	1	6,7						
U-00002				6	NYCRR	237	2							
U-00002				6	NYCRR	237	3							
U-00002				6	NYCRR	237	4	1						
U-00002				6	NYCRR	237	5	3	a					
U-00002				6	NYCRR	237	6							
U-00002				6	NYCRR	237	7							
U-00002				6	NYCRR	237	8							
U-00002				6	NYCRR	238	1	4,6,7						
U-00002				6	NYCRR	238	2							
U-00002				6	NYCRR	238	3							
U-00002				6	NYCRR	238	4	1						
U-00002				6	NYCRR	238	5	3						
U-00002				6	NYCRR	238	6							
U-00002				6	NYCRR	238	7							
U-00002				6	NYCRR	238	8							
U-00002				6	NYCRR	242	1	6,7						
U-00002				6	NYCRR	242	2,3,4,5							
U-00002				6	NYCRR	242	6,7,8,10							
U-00002				6	NYCRR	227	1	2	a	1				
U-00002				6	NYCRR	227	1	3						
U-00002				6	NYCRR	227	1	4	d					
U-00002				6	NYCRR	227	2	4	e	2				
U-00002				6	NYCRR	227	2	6						

New York State Department of Environmental Conservation Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00003				40	CFR	60	Dc	42c	d				
U-00003				40	CFR	60	Dc	43c	a	2			
U-00003				40	CFR	60	Dc	43c	c				

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements (continuation)										
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.	
U-00003				6	NYCRR	227	2	4	d					
U-00003				6	NYCRR	227	2	6						

New York State Department of Environmental Conservation Air Permit Application



Department of
Environmental
Conservation

DEC ID															
3	-	3	3	5	6	-	0	0	1	3	6				
Request for Emission Reduction Credits															
Emission Source										0	0	0	0	1	<input type="checkbox"/> Continuation Sheet(s)
Emission Reduction Description															
The facility purchased Emission Reductions Credits in the amount of 216.0 tons NOx and 75.0 tons VOC. Please see appendix 11 for additional information.															
Contaminant Emission Reduction Data															
Baseline Period ____/____/____ to ____/____/____						Reduction									
						Date		Method							
CAS Number		Contaminant Name				ERC (lbs/yr)									
						Netting		Offset							
ONY210 - 00 - 0		Oxides of Nitrogen						432,000.0							
ONY998 - 00 - 0		Volatile Organic Compounds						150,000.0							
Facility to Use Future Reduction															
Name CPV Valley Energy Center						Application ID									
						-					-				/
Location Address 3330 Route 6															
* City/ <input type="checkbox"/> Town / <input type="checkbox"/> Village Middletown						State NY			Zip 10940						
Use of Emission Reduction Credits															
Emission Source										<input type="checkbox"/> Continuation Sheet(s)					
Proposed Project Description															
Contaminant Emissions Increase Data															
CAS Number		Contaminant Name				Project Emission Potential (lbs/yr)									
Statement of Compliance															
All facilities under the ownership of this "owner/firm" are operating <u>in compliance</u> with all applicable requirements and state regulations including any compliance certification requirements under Section 114(a)(3) of the Clean Air Act Amendments of 1990, or are meeting the schedule of a consent order.															
Source of Emission Reduction Credit - Facility															
Name						Permit ID									
						-					-				/
Location Address															
<input type="checkbox"/> City/ <input type="checkbox"/> Town / <input type="checkbox"/> Village						State			Zip						
Emission Source		CAS Number		Contaminant Name				ERC (lbs/yr)							
								Netting		Offset					

New York State Department of Environmental Conservation Air Permit Application



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Supporting Documentation and Attachments	
Required Supporting Documentation	Date of Document
<input checked="" type="checkbox"/> List of Exempt Activities (attach form)	8/5/2018
<input checked="" type="checkbox"/> Plot Plan	5/5/2017
<input checked="" type="checkbox"/> Process Flow Diagram	7/16/2015
<input checked="" type="checkbox"/> Methods Used to Determine Compliance (attach form)	8/5/2018
<input checked="" type="checkbox"/> Emissions Calculations	Submitted 8/2017
Optional Supporting Documentation	Date of Document
<input checked="" type="checkbox"/> Air Quality Model	Attachment 11
<input type="checkbox"/> Confidentiality Justification	
<input type="checkbox"/> Ambient Air Quality Monitoring Plan or Reports	
<input checked="" type="checkbox"/> Stack Test Protocol	Submitted 8/9/2017
<input checked="" type="checkbox"/> Stack Test Report	USLD Test
<input checked="" type="checkbox"/> Continuous Emissions Monitoring Plan	
<input checked="" type="checkbox"/> Lowest Achievable Emission Rate (LAER) Demonstration	USLD Test
<input checked="" type="checkbox"/> Best Available Control Technology (BACT) Demonstration	USLD Test
<input type="checkbox"/> Reasonably Available Control Technology (RACT) Demonstration	
<input type="checkbox"/> Toxic Impact Assessment (TIA)	
<input type="checkbox"/> Environmental Rating Demonstration	
<input type="checkbox"/> Operational Flexibility Protocol/Description of Alternate Operating Scenarios	
<input checked="" type="checkbox"/> Title IV Permit Application	01/2018
<input type="checkbox"/> Emission Reduction Credit (ERC) Quantification (attach form)	
<input type="checkbox"/> Baseline Period Demonstration	
<input type="checkbox"/> Use of Emission Reduction Credits (attach form)	
<input type="checkbox"/> Analysis of Contemporaneous Emissions Increase/Decrease	
Other Supporting Documentation	Date of Document

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section III - Facility Information

Facility Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement			<input type="checkbox"/> Capping		CAS No.		Contaminant Name		
<input type="checkbox"/> State Only Requirement					007446-09-5		Sulfur Dioxide		
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input type="checkbox"/> Intermittent Emission Testing					<input checked="" type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
Facility Sulfur Dioxide emissions are subject to BACT and the fuel sulfur limit listed in 6 NYCRR 225-1.2 (g). The facility is proposing to limit the sulfur content no greater than 0.0015% sulfur by weight. The sulfur content of the fuel will be certified by the vendor and monitored by the facility.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	number 2 oil				ASTM D 2880-71			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	sulfur content								
Limit				Limit Units					
Upper		Lower		Code	Description				
0.0015				57	Percent by weight.				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum - not to be exceeded		11	per delivery		15	Annually		

Continuation Sheet 1 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00001	EP001	P3A	CT001	0NY210-00-0	Oxides of Nitrogen					
Monitoring Information										
<input checked="" type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 6.0 ppmvd (corrected to 15% O ₂) NO _x emission limit when firing on fuel oil from the combustion turbine based upon Higher Heating Value (HHV) of the fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor NO _x stack emissions. The emission limits represents LAER.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						40 CFR 60, Appendix A, Method 7E				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
6.0		275	parts per million by volume (dry, corrected to 15% O ₂)							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
47	3-Hour Block Average		01	Continuous		07	Quarterly			

Continuation Sheet 2 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00002	EP002	P03	CT002	0NY210-00-0	Oxides of Nitrogen					
Monitoring Information										
<input checked="" type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 6.0 ppmvd (corrected to 15% O ₂) NO _x emission limit when firing fuel oil from the combustion turbine based upon Higher Heating Value (HHV) of the fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor NO _x stack emissions. The emission limits represents LAER.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						40 CFR 60, Appendix A, Method 7E				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
6.0		275	parts per million by volume (dry, corrected to 15% O ₂)							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
47	3-Hour Block Average		01	Continuous		07	Quarterly			

Continuation Sheet 3 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00003	EP003	P3B	AUX01	0NY210-00-0	Oxides of Nitrogen				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
The facility will maintain 0.0450 lb/mmBtu NOx emission limit when firing natural gas from the auxiliary boiler based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup and shutdown. The facility will use vendor emission guarantees and/or stack testing to ensure compliance with the LAER emission limit, as required.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR 60, Appendix A, Method 7E			
		Parameter				Manufacturer Name/Model No.			
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.045		07	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence		

Continuation Sheet 4 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00001	EP001	P1A,P3A	CT001	0NY998-00-0	VOC					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.7 ppmvd (corrected to 15% O ₂) VOC emission limit from the combustion turbine based upon Higher Heating Value (HHV) of the natural gas (without duct burner) and fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. Stack testing will be used to demonstrate compliance with the LAER emission limit.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						40 CFR Part 60, Appendix A, Method 25A, Method 18				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.7		275	parts per million by volume (dry, corrected to 15% O ₂)							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 5 of 55

New York State Department of Environmental Conservation

Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00001	EP001	P2A	CT001	0NY998-00-0	VOC					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 1.8 ppmvd (corrected to 15% O ₂) VOC emission limit from the combustion turbine (with duct burner) based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. Stack testing will be used to demonstrate compliance with the LAER emission limit.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						40 CFR Part 60, Appendix A, Method 25A				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
1.8		275	parts per million by volume (dry, corrected to 15% O ₂)							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 6 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00002	EP002	P01,P03	CT002	0NY998-00-0	VOC					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.7 ppmvd (corrected to 15% O ₂) VOC emission limit from the combustion turbine based upon Higher Heating Value (HHV) of the natural gas (without duct burner) and fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. Stack testing will be used to demonstrate compliance with the LAER emission limit.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						40 CFR Part 60, Appendix A, Method 25A, Method 18				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.7		275	parts per million by volume (dry, corrected to 15% O ₂)							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 7 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00002	EP002	P02	CT002	0NY998-00-0	VOC					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 1.8 ppmvd (corrected to 15% O ₂) VOC emission limit from the combustion turbine (with duct burner) based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. Stack testing will be used to demonstrate compliance with the LAER emission limit.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						40 CFR Part 60, Appendix A, Method 25A, Method 18				
Parameter		Manufacturer Name/Model No.								
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
1.8		275	parts per million by volume (dry, corrected to 15% O ₂)							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 8 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00003	EP003	P3B	AUX01	0NY998-00-0	VOC					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
<p>The facility will maintain a 0.0038 lb/mmBtu VOC emission limit when firing on natural gas from the auxiliary boiler based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup and shutdown. The facility will use vendor emission guarantees and/or stack testing to ensure compliance with the LAER emission limit, as required</p>										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						40 CFR Part 60, Appendix A, Method 25A, Method 18				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.0038		7	pounds per million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 9 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001	EP001	P1A,P3A	CT001	000630-08-0	Carbon Monoxide				
Monitoring Information									
<input checked="" type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate						
<input type="checkbox"/> Intermittent Emission Testing			<input type="checkbox"/> Work Practice Involving Specific Operations						
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures						
Description									
<p>The facility will maintain a 2.0 ppmvd (corrected to 15% O₂) CO emission limit for the combustion turbine based upon the Higher Heating Value (HHV) of the the natural gas (without duct burner) and fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor CO stack emissions. The emission limit represents BACT.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR Part 60, Appendix A, Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0		275	parts per million by volume (dry, corrected to 15% O ₂)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
47	3-Hour Block Average		01	Continuous		07	Quarterly		

Continuation Sheet 10 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00002	EP002	P01,P03	CT002	000630-08-0	Carbon Monoxide				
Monitoring Information									
<input checked="" type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate						
<input type="checkbox"/> Intermittent Emission Testing			<input type="checkbox"/> Work Practice Involving Specific Operations						
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures						
Description									
<p>The facility will maintain a 2.0 ppmvd (corrected to 15% O₂) CO emission limit for the combustion turbine based upon the Higher Heating Value (HHV) of the the natural gas (without duct burner) and fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor CO stack emissions. The emission limit represents BACT.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR Part 60, Appendix A, Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0		275	parts per million by volume (dry, corrected to 15% O ₂)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
47	3-Hour Block Average		01	Continuous		07	Quarterly		

Continuation Sheet 11 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001	EP001	P2A	CT001	000630-08-0	Carbon Monoxide				
Monitoring Information									
<input checked="" type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate						
<input type="checkbox"/> Intermittent Emission Testing			<input type="checkbox"/> Work Practice Involving Specific Operations						
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures						
Description									
<p>The facility will maintain a 3.4 ppmvd (corrected to 15% O₂) CO emission limit for the combustion turbine (with duct burner) based upon the Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor CO stack emissions. The emission limit represents BACT.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR Part 60, Appendix A, Method 10			
		Parameter				Manufacturer Name/Model No.			
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
3.4		275	parts per million by volume (dry, corrected to 15% O ₂)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
47	3-Hour Block Average		01	Continuous		07	Quarterly		

Continuation Sheet 12 of 55

New York State Department of Environmental Conservation

Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00002	EP002	P02	CT002	000630-08-0	Carbon Monoxide				
Monitoring Information									
<input checked="" type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate						
<input type="checkbox"/> Intermittent Emission Testing			<input type="checkbox"/> Work Practice Involving Specific Operations						
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures						
Description									
<p>The facility will maintain a 3.4 ppmvd (corrected to 15% O₂) CO emission limit for the combustion turbine (with duct burner) based upon the Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor CO stack emissions. The emission limit represents BACT.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR Part 60, Appendix A, Method 10			
		Parameter				Manufacturer Name/Model No.			
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
3.4		275	parts per million by volume (dry, corrected to 15% O ₂)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
47	3-Hour Block Average		01	Continuous		07	Quarterly		

Continuation Sheet 13 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00003	EP003	P3B	AUX01	000630-08-0	Carbon Monoxide				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
The facility will maintain a 0.0721 lb/mmBtu CO emission limit when burning natural gas from the auxiliary boiler based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup and shutdown. The facility will use vendor emission guarantees and/or stack testing to ensure compliance with the BACT emission limit, as required.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR Part 60, Appendix A, Method 10			
		Parameter				Manufacturer Name/Model No.			
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0721		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence		

Continuation Sheet 14 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name				
U-00001	EP001	P1A,P2A	CT001	0NY075-00-0, 0NY075-00-5		PARTICULATES, PM-10				
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.0073 lb/mmBtu PM emission limit with and without duct burner from the combustion turbine based upon Higher Heating Value (HHV) of the natural gas. The emission limits applies at all load except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by stack testing.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						EPA RM 5, 201/201A or 202				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.0073		7	pounds per Million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 15 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name				
U-00002	EP002	P01,P02	CT002	0NY075-00-0, 0NY075-00-5		PARTICULATES, PM-10				
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.0073 lb/mmBtu PM emission limit with and without duct burner from the combustion turbine based upon Higher Heating Value (HHV) of the natural gas. The emission limits applies at all load except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by stack testing.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						EPA RM 5, 201/201A or 202				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.0073		7	pounds per Million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 16 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name				
U-00001	EP001	P3A	CT001	0NY075-00-0, 0NY075-00-5		Particulates, PM-10				
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.0368 lb/mmBtu PM emission limit when firing fuel oil from the combustion turbine based upon Higher Heating Value (HHV) of the fuel oil. The emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by stack testing.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						EPA RM 5, 201/201A or 202				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.0368		7	pounds per Million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 17 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00002	EP002	P03	CT002	0NY075-00-0, 0NY075-00-5	Particulates, PM-10					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.0368 lb/mmBtu PM emission limit when firing fuel oil from the combustion turbine based upon Higher Heating Value (HHV) of the fuel oil. The emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by stack testing.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						EPA RM 5, 201/201A or 202				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.0368		7	pounds per Million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 18 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00003	EP003	P3B	AUX01	0NY075-00-0, 0NY075-00-5	Particulates, PM-10					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.0063 lb/mmBtu PM emission limit when firing natural gas from the auxiliary boiler based on the Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup and shutdown. The facility will use vendor emission guarantees and/or stack testing to ensure compliance with the BACT emission limit, as required.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						EPA RM 5, 201A/201, and 202				
		Parameter				Manufacturer Name/Model No.				
Code	Description									
23	Concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.0063		7	pounds per Million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-Hour Average		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 19 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001	EP001	P1A,P2A	CT001	007446-09-5	Sulfur Dioxide				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0022 lb/mmBtu SO₂ emission limit from the combustion turbine (with and without duct burner) based on the Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by limiting sulfur content of the natural gas to 0.8 grains/100 SCF. The sulfur content of the natural gas will be verified through a certification or analysis provided by the fuels supplier and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	natural gas				ASTM 5504			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.8		13	grains per 100 dscf						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	as required		10	Upon Request		

Continuation Sheet 20 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00002	EP002	P01,P02	CT002	007446-09-5	Sulfur Dioxide				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0022 lb/mmBtu SO₂ emission limit from the combustion turbine (with and without duct burner) based on the Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by limiting sulfur content of the natural gas to 0.8 grains/100 SCF. The sulfur content of the natural gas will be verified through a certification or analysis provided by the fuels supplier and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	natural gas				ASTM 5504			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.8		13	grains per 100 dscf						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	as required		10	Upon Request		

Continuation Sheet 21 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001	EP001	P3A	CT001	007446-09-5	Sulfur Dioxide				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0015 lb/mmBtu SO₂ emission limit when firing fuel oil from the combustion turbine based on the Higher Heating Value (HHV) of the fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by maintaining compliance with the fuel oil sulfur limit of 0.0015%. The sulfur content of the fuel will be certified by the vendor and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 Oil				ASTM D 2880-71			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0015		57	percent by weight						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		11	Per Delivery		10	Upon Request		

Continuation Sheet 22 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00002	EP002	P03	CT002	007446-09-5	Sulfur Dioxide				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0015 lb/mmBtu SO₂ emission limit when firing fuel oil from the combustion turbine based on the Higher Heating Value (HHV) of the fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by maintaining compliance with the fuel oil sulfur limit of 0.0015%. The sulfur content of the fuel will be certified by the vendor and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 Oil				ASTM D 2880-71			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0015		57	percent by weight						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		11	Per Delivery		10	Upon Request		

Continuation Sheet 23 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00003	EP003	P3B	AUX01	007446-09-5	Sulfur Dioxide					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
The facility will maintain a 0.0022 lb/mm Btu SO ₂ emission limit from the auxiliary boiler based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup and shutdown. The facility will demonstrate compliance with the BACT emission limit by limiting the sulfur content of the natural gas to 0.8 grains/100 scf.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description				Reference Test Method				
						ASTM 5504				
Parameter		Manufacturer Name/Model No.								
Code	Description				Manufacturer Name/Model No.					
32	Sulfur Content									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.8		13	grains per 100 dscf							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
01	Maximum not to be exceeded		13	single occurrence		01	once / batch or monitoring occurrence			

Continuation Sheet 24 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001	EP001	P1A,P2A	CT001	007664-93-9	Sulfuric Acid				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0007 lb/mmBtu sulfuric acid mist emission limit from the combustion turbine (with and without duct burner) based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by limiting sulfur content of the natural gas to 0.8 grains/100 scf. The sulfur content of the natural gas will be verified through a certification or analysis provided by the fuels supplier and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	Natural Gas				ASTM 5504			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.8		13	grains per 100 dscf						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	as required		10	Upon Request		

Continuation Sheet 25 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00002	EP002	P01,P02	CT002	007664-93-9	Sulfuric Acid				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0007 lb/mmBtu sulfuric acid mist emission limit from the combustion turbine (with and without duct burner) based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by limiting sulfur content of the natural gas to 0.8 grains/100 scf. The sulfur content of the natural gas will be verified through a certification or analysis provided by the fuels supplier and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	Natural Gas				ASTM 5504			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.8		13	grains per 100 dscf						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	as required		10	Upon Request		

Continuation Sheet 26 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001	EP001	P3A	CT001	007664-93-9	Sulfuric Acid				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0005 lb/mm Btu sulfuric acid mist emission limit when firing fuel oil from the combustion turbine based upon Higher Heating Value (HHV) of the gas and fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by maintaining compliance with the fuel oil sulfur limit of 0.0015%. The sulfur content of the fuel will be certified by the vendor and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 Oil				ASTM D 2880-71			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0015		57	percent by weight						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		11	Per Delivery		10	Upon Request		

Continuation Sheet 27 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00002	EP002	P03	CT002	007664-93-9	Sulfuric Acid				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0005 lb/mm Btu sulfuric acid mist emission limit from the combustion turbine (with and without duct burner) based upon Higher Heating Value (HHV) of the gas and fuel oil. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will demonstrate compliance with the BACT emission limit by maintaining compliance with the fuel oil sulfur limit of 0.0015%. The sulfur content of the fuel will be certified by the vendor and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 Oil				ASTM D 2880-71			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0015		57	percent by weight						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		11	Per Delivery		10	Upon Request		

Continuation Sheet 28 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00003	EP003	P3B	AUX01	007664-93-9	Sulfuric Acid				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
<p>The facility will maintain a 0.0002 lb/mm Btu sulfuric acid mist emission limit from the auxiliary boiler based upon Higher Heating Value (HHV) of the natural gas. This emission limit applies at all loads except during startup and shutdown. The facility will demonstrate compliance with the BACT emission limit by limiting the sulfur content of the natural gas to 0.8 grains/100 scf. The sulfur content of the natural gas will be verified through a certification or analysis provided by the fuels supplier and monitored by the facility.</p>									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	Natural Gas				ASTM 5504			
Parameter		Manufacturer Name/Model No.							
Code	Description								
32	Sulfur Content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.8		13	grains per 100 dscf						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	as required		10	Upon Request		

Continuation Sheet 29 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	43	3	c				
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00003	EP003	P3B	AUX01						
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR 60, Method 9			
Parameter		Manufacturer Name/Model No.							
Code	Description								
01	Opacity								
Limit			Limit Units						
Upper	Lower	Code	Description						
20	0	136	Percent						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
18	6-min average		13	single occurrence		01	once / batch or monitoring occurrence		

Continuation Sheet 30 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	200	7						
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001	EP001	P1A,P2A,P3A	CT001	007664-41-7	Ammonia				
Monitoring Information									
<input checked="" type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate						
<input type="checkbox"/> Intermittent Emission Testing			<input type="checkbox"/> Work Practice Involving Specific Operations						
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures						
Description									
The facility will maintain a 5.0 ppmvd (corrected to 15% O2) limit applies during all fuels being fired and duct burner operations.. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor Ammonia stack emissions.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
	154	Ammonia				40 CFR 75 & 40 CFR 60 Appendices A/B/F			
Parameter		Manufacturer Name/Model No.							
Code	Description								
Limit			Limit Units						
Upper	Lower	Code	Description						
5.0		275	parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
47	3-hour block average		01	Continuous		07	Quarterly		

Continuation Sheet 31 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	200	7						
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00002	EP002	P01,P02,P03	CT002	007664-41-7	Ammonia				
Monitoring Information									
<input checked="" type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate						
<input type="checkbox"/> Intermittent Emission Testing			<input type="checkbox"/> Work Practice Involving Specific Operations						
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures						
Description									
The facility will maintain a 5.0 ppmvd (corrected to 15% O2) limit applies during all fuels being fired and duct burner operations. This emission limit applies at all loads except during startup, shutdown and fuel switching. The facility will use CEMS to monitor Ammonia stack emissions.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
	154	Ammonia				40 CFR 75 & 40 CFR 60 Appendices A/B/F			
Parameter		Manufacturer Name/Model No.							
Code	Description								
Limit			Limit Units						
Upper	Lower	Code	Description						
5.0		275	parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
47	3-hour block average		01	Continuous		07	Quarterly		

Continuation Sheet 32 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	200	7							
<input type="checkbox"/> Applicable Federal Requirement					<input checked="" type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
				007664-41-7	Ammonia					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate							
<input type="checkbox"/> Intermittent Emission Testing			<input checked="" type="checkbox"/> Work Practice Involving Specific Operations							
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures							
Description										
The facility will maintain records to verify concentration of ammonia stored on-site is less than 19%. The ammonia concentration will be certified by the vendor and monitored by the facility.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
04	154	Ammonia								
Parameter		Manufacturer Name/Model No.								
Code	Description									
Limit			Limit Units							
Upper	Lower	Code	Description							
19		21	percent by volume							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
01	Maximum not to be exceeded		11	Per Delivery		15	annually (calendar)			

Continuation Sheet 33 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001/U-00002	EP001/EP002	P1A,PO1	CT001/CT002						
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
The facility will have a heat rate of 7605 Btu/kW-hr (HHV) or less at ISO conditions without duct burner firing to achieve a design thermal efficiency.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						ASME PTC 46-1996			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
38	Heat Input								
Limit			Limit Units						
Upper	Lower	Code	Description						
7605			BTU per kilowatt-hour						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
60	maximum - not to exceed stated value		09	annually		14	semi-annually (calendar)		

Continuation Sheet 34 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	251	3	a					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00001/U-00002	EP001/EP002	P1A,P2A,P3A,P01,P02,P03	CT001/CT002	000124-38-9	Carbon Dioxide				
Monitoring Information									
<input checked="" type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate						
<input type="checkbox"/> Intermittent Emission Testing			<input type="checkbox"/> Work Practice Involving Specific Operations						
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures						
Description									
The facility are required to meet an emission rate of 925 pounds of CO2 per MW hour gross electrical output (output-based limit). These emission limits are measured on a 12-month rolling average basis, calculated by dividing the annual total of CO2 emissions over the relevant 12-month period by the annual total (gross) MW generated (output-based limit).									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
Parameter		Manufacturer Name/Model No.							
Code	Description								
Limit			Limit Units						
Upper	Lower	Code	Description						
925		8	pounds per megawatt hour						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
17	annual maximum rolled monthly		01	continuous		13	quarterly (calendar)		

Continuation Sheet 35 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00004	EP004	P04		0NY998-00-0	VOC				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
LAER is 0.0331 lb/mmBtu. Will be achieved using good combustion controls. Emission testing to be performed upon request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Method 25A			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0331		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 36 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00004	EP004	P04		0NY210-00-0	Oxides of Nitrogen				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
LAER is 4.77 grams per brake horsepower-hour. Will be achieved using good combustion controls. Emission testing to be performed upon request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						Method 7E			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
4.77		319	grams per brake horsepower-hour						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 37 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00004	EP004	P04		0NY075-00-0	PARTICULATES					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
BACT is 0.03 g/hp-hr. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						Method 201/201A and 202				
Parameter		Manufacturer Name/Model No.								
Code	Description									
23	concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.03		319	grams per brake horsepower-hour							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-hour average		14	as required		01	once / batch or monitoring occurrence			

Continuation Sheet 38 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00004	EP004	P04		0NY075-00-5	PM-10					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
BACT is 0.03 g/hp-hr. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						Method 201/201A and 202				
Parameter		Manufacturer Name/Model No.								
Code	Description									
23	concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.03		319	grams per brake horsepower-hour							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-hour average		14	as required		01	once / batch or monitoring occurrence			

Continuation Sheet 39 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00004	EP004	P04		007446-09-5	SULFUR DIOXIDE				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.0014 lb/mmBtu. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						EPA approved methods			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0014		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 40 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00004	EP004	P04		007664-93-9	SULFURIC ACID				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.0003 lb/mmBtu. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						EPA approved methods			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.00003		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 41 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00004	EP004	P04		000630-08-0	CARBON MONOXIDE				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.45 g/hp-hr. Will be achieved using good combustion controls. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.45		319	grams per brake horsepower-hour						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 42 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00005	EP005	P05		0NY210-00-0	Oxides of Nitrogen				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
LAER is 0.857 pounds per million Btus. Will be achieved using good combustion controls. Emission testing to be performed upon request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						Method 7E			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.857		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 43 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00005	EP005	P05		0NY998-00-0	VOC					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
LAER is 0.3612 lb/mmBtu. Will be achieved using good combustion controls. Emission testing to be performed upon request of the Department.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description				Method 25A				
Parameter		Manufacturer Name/Model No.								
Code	Description									
23	concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.3612		7	pounds per million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-hour average		14	as required		01	once / batch or monitoring occurrence			

Continuation Sheet 44 of 55

New York State Department of Environmental Conservation

Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00005	EP005	P05		000630-08-0	CARBON MONOXIDE				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.75 lbs/mmBtus. Will be achieved using good combustion controls. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.75		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 45 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00005	EP005	P05		0NY075-00-0, 0NY075-00-5	PARTICULATES, PM-10				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.043 lb/mmBtus. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						Method 201/201A and 202			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.043		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 46 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00005	EP005	P05		007446-09-5	SULFUR DIOXIDE				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.0014 lb/mmBtu. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						EPA approved methods			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0014		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 47 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00005	EP005	P05		007664-93-9	SULFURIC ACID				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.0003 lb/mmBtu. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						EPA approved methods			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.00003		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 48 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00006	EP006	P06		0NY210-00-0	Oxides of Nitrogen					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
LAER is 0.058 pounds per million Btus for each individual gas heater. Will be achieved using forced draft low NOx Burner. Emission testing to be performed upon request of the Department.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						Method 7E				
Parameter		Manufacturer Name/Model No.								
Code	Description									
23	concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.058		7	pounds per million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-hour average		14	as required		01	once / batch or monitoring occurrence			

Continuation Sheet 49 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	5	4						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00006	EP006	P06		0NY998-00-0	VOC					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
LAER is 0.011 lb/mmBtu. Will be achieved using good combustion controls. Emission testing to be performed upon request of the Department.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description				Reference Test Method				
						Method 25A				
Parameter		Manufacturer Name/Model No.								
Code	Description				Manufacturer Name/Model No.					
23	concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.011		7	pounds per million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-hour average		14	as required		01	once / batch or monitoring occurrence			

Continuation Sheet 50 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)										
Rule Citation										
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause	
6	NYCRR	231	7	6						
<input checked="" type="checkbox"/> Applicable Federal Requirement					<input type="checkbox"/> State Only Requirement			<input type="checkbox"/> Capping		
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name					
U-00006	EP006	P06		007664-93-9	SULFURIC ACID					
Monitoring Information										
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate					
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations					
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures					
Description										
BACT is 0.0002 lb/mmBtu. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.										
Work Practice		Process Material				Reference Test Method				
Type	Code	Description								
						EPA approved methods				
Parameter		Manufacturer Name/Model No.								
Code	Description									
23	concentration									
Limit			Limit Units							
Upper	Lower	Code	Description							
0.0002		7	pounds per million Btus							
Averaging Method			Monitoring Frequency			Reporting Requirements				
Code	Description		Code	Description		Code	Description			
08	1-hour average		14	as required		01	once / batch or monitoring occurrence			

Continuation Sheet 51 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00006	EP006	P06		000630-08-0	CARBON MONOXIDE				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.084 lbs/mmBtus.. Will be achieved using good combustion controls. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.084		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 52 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



Department of
Environmental
Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping	
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00006	EP006	P06		0NY075-00-0, 0NY075-00-5	PARTICULATES, PM-10				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.0076 lb/mmBtus.. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						Method 201/201A and 202			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0076		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

Continuation Sheet 53 of 55

New York State Department of Environmental Conservation
Air Permit Application Form



DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					
<input checked="" type="checkbox"/> Applicable Federal Requirement <input type="checkbox"/> State Only Requirement						<input type="checkbox"/> Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name				
U-00006	EP006	P06		007446-09-5	SULFUR DIOXIDE				
Monitoring Information									
<input type="checkbox"/> Continuous Emission Monitoring					<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate				
<input checked="" type="checkbox"/> Intermittent Emission Testing					<input type="checkbox"/> Work Practice Involving Specific Operations				
<input type="checkbox"/> Ambient Air Monitoring					<input type="checkbox"/> Record Keeping/Maintenance Procedures				
Description									
BACT is 0.0022 lb/mmBtu. Will be achieved using low sulfur fuel. Emission testing to be performed at the request of the Department.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						EPA approved methods			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.0022		7	pounds per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	as required		01	once / batch or monitoring occurrence		

New York State Department of Environmental Conservation
Air Permit Application Form



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)																																																	
Rule Citation																																																	
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause																																								
6	NYCRR	201	7																																														
<input checked="" type="checkbox"/> Applicable Federal Requirement						<input type="checkbox"/> State Only Requirement		<input type="checkbox"/> Capping																																									
Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name																																												
				0NY075-02-5	PM 2.5																																												
Monitoring Information																																																	
<input type="checkbox"/> Continuous Emission Monitoring			<input type="checkbox"/> Monitoring of Process or Control Device Parameters as a Surrogate																																														
<input type="checkbox"/> Intermittent Emission Testing			<input checked="" type="checkbox"/> Work Practice Involving Specific Operations																																														
<input type="checkbox"/> Ambient Air Monitoring			<input type="checkbox"/> Record Keeping/Maintenance Procedures																																														
Description																																																	
<p>Monthly facility-wide emissions of PM-2.5 will be calculated as the sum of monthly PM-2.5 emissions from individual emission units or source groups. Emissions will be calculated based on heat input (or, equivalently, from fuel use) and emission factors as described below. Annual facility-wide emissions will then be determined at the end of each month on a rolling 12-month basis in order to demonstrate compliance with the 95 ton per year cap.</p> <table border="1"> <thead> <tr> <th>Unit Op Load</th><th>Fuel</th><th>Grp</th><th>Emission Factor</th></tr> </thead> <tbody> <tr> <td>CT only > 80%</td><td>Gas</td><td>1</td><td>0.0056</td></tr> <tr> <td>CT only < 80%</td><td>Gas</td><td>2</td><td>0.0073</td></tr> <tr> <td>CT + DB > 80%</td><td>Gas</td><td>3</td><td>0.0064</td></tr> <tr> <td>CT only > 85%</td><td>Oil</td><td>4</td><td>0.0247</td></tr> <tr> <td>CT only < 85%</td><td>Oil</td><td>5</td><td>0.0368</td></tr> <tr> <td>Aux Boiler All</td><td>Gas</td><td>6</td><td>0.0063</td></tr> <tr> <td>Gas Heater All</td><td>Gas</td><td>7</td><td>0.0076</td></tr> <tr> <td>EDG All</td><td>Oil</td><td>8</td><td>0.0091</td></tr> <tr> <td>EFP All</td><td>Oil</td><td>9</td><td>0.0429</td></tr> </tbody> </table> <p>In cases where fuel use (gallons of oil or SCF of gas) for a source group is monitored directly rather than heat input, the equivalent heat input will be determined by multiplying the monthly fuel usage for the source group by the corresponding fuel heating value (mmBtu/gallon or mmBtu/scf), using the higher heating. In cases where fuel use (gallons of oil or standard cubic feet of gas) for a source group is monitored directly rather than heat input, the equivalent heat input will be determined by multiplying the monthly fuel usage for the source group by the corresponding fuel heating value (mmBtu/gallon or mmBtu/scf), using the higher heating value basis for fuel.</p>										Unit Op Load	Fuel	Grp	Emission Factor	CT only > 80%	Gas	1	0.0056	CT only < 80%	Gas	2	0.0073	CT + DB > 80%	Gas	3	0.0064	CT only > 85%	Oil	4	0.0247	CT only < 85%	Oil	5	0.0368	Aux Boiler All	Gas	6	0.0063	Gas Heater All	Gas	7	0.0076	EDG All	Oil	8	0.0091	EFP All	Oil	9	0.0429
Unit Op Load	Fuel	Grp	Emission Factor																																														
CT only > 80%	Gas	1	0.0056																																														
CT only < 80%	Gas	2	0.0073																																														
CT + DB > 80%	Gas	3	0.0064																																														
CT only > 85%	Oil	4	0.0247																																														
CT only < 85%	Oil	5	0.0368																																														
Aux Boiler All	Gas	6	0.0063																																														
Gas Heater All	Gas	7	0.0076																																														
EDG All	Oil	8	0.0091																																														
EFP All	Oil	9	0.0429																																														
Work Practice		Process Material				Reference Test Method																																											
Type	Code	Description																																															
04	318	Fuel																																															
Parameter		Manufacturer Name/Model No.																																															
Code	Description																																																
38	Heat Input																																																
Limit			Limit Units																																														
Upper	Lower	Code	Description																																														
95		38	tons per year																																														
Averaging Method			Monitoring Frequency			Reporting Requirements																																											
Code	Description		Code	Description		Code	Description																																										
17	annual maximum rolled monthly		01	CONTINUOUS		15	ANNUALLY (CALENDAR)																																										

Continuation Sheet 55 of 55

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6
Process Information											
Emission Unit								U - 0 0 0 0 4		Process	
								P		0 4	
Process Description											
Process P04 represents the emergency generator firing on diesel fuel.											
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units							
		Quantity/Hr	Quantity/Yr	Code	Description						
2-01-002-01		110.4	36,300	0045	gallons						
<input type="checkbox"/> Confidential		Operating Schedule		Building		Floor/Location					
<input checked="" type="checkbox"/> Operating at Maximum Capacity		Hours/Day	Days/Year								
		500 Hours									
Emission Point Identifier(s)											
EG01											
Emission Source/Control Identifier(s)											
Process Information											
Emission Unit								-		Process	
Process Description											
Source Classification Code (SCC)		Total Throughput		Throughput Quantity Units							
		Quantity/Hr	Quantity/Yr	Code	Description						
<input type="checkbox"/> Confidential		Operating Schedule		Building		Floor/Location					
<input type="checkbox"/> Operating at Maximum Capacity		Hours/Day	Days/Year								
Emission Point Identifier(s)											
Emission Source/Control Identifier(s)											

New York State Department of Environmental Conservation
Air Permit Application



Department of Environmental Conservation

DEC ID																		
3	-	3	3	5	6	-	0	0	1	3	6							
Process Information											Continuation Sheet(s)							
Emission Unit						U	-	0	0	0	0	6	Process		P	0	6	
Process Description																		
Process P06 represents one dew point heater with two fuel gas burners operating on natural gas.																		
Source Classification Code (SCC)			Total Throughput				Throughput Quantity Units											
			Quantity/Hr		Quantity/Yr		Code	Description										
2-01-002-01			5.02		78,489.6		0104	million Btu heat input										
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity			Operating Schedule				Building		Floor/Location									
			Hours/Day		Days/Year													
			24		365													
Emission Point Identifier(s)																		
FGH1																		
Emission Source/Control Identifier(s)																		
Emission Unit						-						Process						
Process Description																		
Source Classification Code (SCC)			Total Throughput				Throughput Quantity Units											
			Quantity/Hr		Quantity/Yr		Code	Description										
<input type="checkbox"/> Confidential <input type="checkbox"/> Operating at Maximum Capacity			Operating Schedule				Building		Floor/Location									
			Hours/Day		Days/Year													
Emission Point Identifier(s)																		
Emission Source/Control Identifier(s)																		

**New York State Department of Environmental Conservation
Air Permit Application**



**Department of
Environmental
Conservation**

DEC ID																							
3	-	3	3	5	6	-	0	0	1	3	6												
Process Information											× Continuation Sheet(s)												
Emission Unit							U	-	0	0	0	0	6	Process		P	0	6					
Process Description																							
Process P06 represents one 9.0 mmBtu/hr dew point heater with two fuel gas burners operating on natural gas.																							
Source Classification Code (SCC)			Total Throughput				Throughput Quantity Units																
			Quantity/Hr		Quantity/Yr		Code		Description														
2-01-002-01			5.02		78,489.6		0104		million Btu heat input														
<input type="checkbox"/> Confidential <input checked="" type="checkbox"/> Operating at Maximum Capacity			Operating Schedule				Building		Floor/Location														
			Hours/Day		Days/Year																		
			24		365																		
Emission Point Identifier(s)																							
FGH1																							
Emission Source/Control Identifier(s)																							
Emission Unit							-												Process				
Process Description																							
Source Classification Code (SCC)			Total Throughput				Throughput Quantity Units																
			Quantity/Hr		Quantity/Yr		Code		Description														
<input type="checkbox"/> Confidential <input type="checkbox"/> Operating at Maximum Capacity			Operating Schedule				Building		Floor/Location														
			Hours/Day		Days/Year																		
Emission Point Identifier(s)																							
Emission Source/Control Identifier(s)																							

New York State Department of Environmental Conservation
Air Permit Application



Department of Environmental Conservation

DEC ID											
3	-	3	3	5	6	-	0	0	1	3	6

Section IV - Emission Unit Information

Emission Unit Description											<input type="checkbox"/> Continuation Sheet(s)		
Emission Unit	U	-	0	0	0	0	7						
Five EngA Space Heaters Model: DGP-500													

Building Information					<input type="checkbox"/> Continuation Sheet(s)	
Building ID	Building Name			Length (ft)	Width (ft)	Orientation
GEN01	Generation Building			300	260	North
GEN02	Generation Building			300	260	North

Emission Unit	Emission Unit Emissions Summary										<input type="checkbox"/> Continuation Sheet(s)	
U	-	0	0	0	0	7						
CAS Number		Contaminant Name										
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)				
CAS Number		Contaminant Name										
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)				
CAS Number		Contaminant Name										
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)				
CAS Number		Contaminant Name										
ERP (lbs/yr)	Potential to Emit					Actual Emissions						
	(lbs/hr)		(lbs/yr)			(lbs/hr)		(lbs/yr)				